

E.P.A. PROTOCOL METHODS 28 AND 5H  
CERTIFICATION TESTING

PERFORMED FOR

MARK'S CUSTOM STOVES  
MODEL K-400 FREESTANDING



## TABLE OF CONTENTS

	Page
Introduction	1
Summary of Results	3
Discussion of Results	15
Wood Heater Information	16
Procedures / Sampling	28
Calibrations	53
Example Calculations	87
Raw Test Data	107

# NORTHWEST TESTING LABORATORIES, INC.

CONSTRUCTION INSPECTION  
MATERIALS INSPECTION  
CHEMICAL ANALYSIS  
PHYSICAL TESTING

5405 N. Lagoon Avenue  
P.O. Box 17126  
Portland, Oregon 97217-0126  
Phone: (503) 289-1778

NON-DESTRUCTIVE TESTING  
WELDING CERTIFICATION  
SOIL TESTING  
ASSAYING

May 17, 1989

Mark's Custom Stoves  
13736 South Locan  
Selma, CA 93662

Attention: Mr. Mark Freeman

In accordance with E.P.A. test protocol as specified in Methods 28 and 5H for the certification and auditing of wood heaters, seven certification tests were performed on the model K-400 Freestanding manufactured by Marks Custom Stoves.

All testing was conducted at Northwest Testing Laboratories, Inc. located at 5405 N. Lagoon Ave. Portland, Oregon. The laboratory is approximately 40 feet above sea level. Test team personnel included Michael Cave, Environmental Supervisor; Fred Thomas, Chemist; David Windsor, Assistant Environmental Supervisor; Tony Palmer, E.P.A. Operations; and Howard Kitt, E.P.A. Technician.

The wood heater was received on April 3, 1989 for E.P.A. certification testing and installed immediately into a safety test cell for the fifty hour catalyst aging. Aging was performed between April 3, 1989 and April 7, 1989. The wood heater was then installed into the certification test cell on April 8, 1989. Testing began on April 10, 1989 and continued through April 18, 1989.

The model K-400 Freestanding is a catalytic wood heater and is equipped with two identical primary combustion air inlets located below the firebox opening. The woodstove also includes secondary air inlets which are four holes drilled above the door. The unit is designed with a front loading double door with neo-ceram glass and a top flue exhaust. The firebox is brick lined with a calculated volume of 3.55 cubic feet.

One abnormality was encountered during test run No. 1 in which a thermocouple on the skin of the wood heater fell out. The thermocouple was re-attached with cement and testing continued with no other problems.

Mark's Custom Stoves

May 17, 1989

Page 2

The weighted average was calculated using six test runs, Nos. 2 through 7, with a result of 2.88 g/hr. Test run No. 1 was not included in the calculation of the weighted average since the emission rate was excessive. Thus the manufacturer reduced the primary combustion air inlet to 2 inches which eliminated test run No. 1 from the weighted average. Excluding test run No. 1, burn rates were achieved between 0.88 to 4.73 kg/hr with emission rates ranging from 0.90 to 8.99 g/hr. The model K-400 Freestanding manufactured by Marks Custom Woodstoves meets the Wood Heater Emission Limits, Phase II criterion for catalytic wood heaters.

The organization of this application is as follows: Introduction, Summary of Results, Discussion of Results, Wood Heater Information, Procedure and Sampling Approach, Calibrations, Example Calculations, and Raw Test Data. If there are any questions regarding this application for certification please contact either Michael Cave or David Windsor at Northwest Testing Laboratories, Inc.

Respectfully,  
NORTHWEST TESTING LABORATORIES, INC.

*Michael Cave*

Michael Cave,  
Environmental Supervisor

SUMMARY OF RESULTS

SUMMARY OF EMISSION RESULTS

Lab Name: NORTHWEST TESTING LABS, INC.  
 Stv Manu: MARKS CUSTOM STOVES  
 Model No: K-400 FS  
 Date : MAY 15, 1989

Run Number	Dry Burn Rate (kg/hr)	Method 5H Particulate Matter Emission Rate (g/hr)
2	2.57	4.76
3	0.98	1.56
4	0.88	0.90
5	2.34	7.87
6	1.39	1.78
7	4.73	8.99

Weighted Emission Rate = 2.88 g/hr  
 (Excludes Test Run No. 1)

Re-tested #1 Test Run

TEST FACILITY CONDITIONS

Lab Name: NORTHWEST TESTING LABS, INC.  
 Stv Manu: MARKS CUSTOM STOVES

Model No: K-300 FS  
 Date : MAY 15, 1989

Run Number	Room Temperature Before (F)	Room Temperature After (F)	Barometric Pressure Before (in. Hg)	Barometric Pressure After (in. Hg)	Relative Humidity Before (%)	Relative Humidity After (%)	Air Velocity Before (ft/min)	Air Velocity After (ft/min)
1	75	78	29.93	29.98	39	44	<5	<5
2	71	77	30.11	30.10	53	49	<5	<5
3	70	76	29.98	29.87	46	43	<5	<5
4	71	76	29.84	29.82	51	49	<5	<5
5	74	79	29.91	29.93	48	46	<5	<5
6	68	73	29.94	29.95	47	42	<5	<5
7	81	84	29.99	29.94	62	42	<5	<5

SUMMARY OF HEATER OPERATION

Lab Name: NORTHWEST TESTING LABS, INC.  
 Stv Manu: MARKS CUSTOM STOVES

Model No: K-400 FS  
 Date : MAY 15, 1989

Test No.	Average Dry Burn Rate (kg/hr)	Average Catalyst Temperature		Average Surface Temperature (F)	Delta T Surface* (F)	Initial Draft (in. H2O)	Prim. Air Setting (in.)	Run Time (min.)	Average Draft (in. H2O)
		Inlet (F)	Outlet (F)						
1	6.81	1358	N/A	938	14	0.0	OPEN	74	-----
2	2.57	1098	N/A	624	-147	0.0	7/8	200	-0.070
3	0.98	854	N/A	423	-143	0.0	1/8	580	-0.033
4	0.88	818	N/A	417	-123	0.0	3/16	610	-0.034
5	2.34	577	N/A	589	- 87	0.0	1/2	220	-0.065
6	1.39	900	N/A	505	-115	0.0	5/16	375	-0.052
7	4.73	1252	N/A	773	- 63	0.0	2	110	-0.090

\*Difference between average surface temperature at beginning of test and average temperature at end of test.



SUMMARY OF STACK GAS MEASUREMENTS AND SAMPLING DATA (SH)

Lab Name: NORTHWEST TESTING LABS, INC Model No: K-400 FS  
 Stv Manu: MARKS CUSTOM STOVES Date : MAY 15, 1989

Run Number	Length of Test Run (minutes)	Average Stack Gas Measurements			Sampling Data		
		CO % vol	CO2 % vol	Volumetric Flow Rate (dscf/hr)	Temperature (F)	Total Sample Volume (dscf)	Particulate Catch (g)
<del>1</del>	<del>74</del>	<del>0.96</del>	<del>16.13</del>	<del>1363.88</del>	<del>596</del>	<del>6.504</del>	<del>0.1539</del>
2	200	0.18	12.79	667.47	293	23.047	0.1628
3	580	0.23	12.08	267.59	162	45.449	0.2600
4	610	0.14	11.98	243.64	147	54.001	0.1956
5	220	1.19	14.21	517.61	238	25.796	0.3897
6	375	0.26	12.86	357.28	274	36.960	0.1827
7	110	0.63	15.05	1028.27	449	17.982	0.1553

SUMMARY OF FUEL MEASUREMENTS


Lab Name: NORTHWEST TESTING LABS, INC.  
 Stv Manu: MARKS CUSTOM STOVES

Model No: K-400 F5  
 Date : MAY 15, 1989

Run Number	Pretest Fuel		Coal Bed Weight (lb)	Test Fuel		Fuel Loading		Piece Length (in)	No. of	
	Weight (lb)	Moisture Dry Basis (%)		Weight (lb)	Moisture Dry Basis (%)	Density (lbs/ft <sup>3</sup> )	Moisture Content Dry (%)		2x4's	4x4's
1	24.9	19.35	4.6	23.0	7.0	24.41	20.0	0	4	
2	26.4	19.65	4.6	23.1	7.0	22.35	20.0	0	4	
3	25.5	19.46	5.2	25.6	7.0	23.07	20.0	0	4	
4	25.0	20.08	5.4	24.5	7.0	24.80	20.0	0	5	
5	23.2	21.76	4.6	22.7	7.0	20.29	21.0	0	4	
6	25.6	19.41	4.9	23.4	7.0	22.62	19.0	0	5	
7	35.6	20.30	4.7	23.4	7.0	22.43	20.0	0	5	

NO PHOTO DOCUMENTATION AVAILABLE

TEST FUEL LOAD RUN NO. 1





TEST FUEL LOAD RUN NO. 2




NO TEST FUEL PHOTO DOCUMENTATION AVAILABLE



TEST FUEL LOAD RUN NO. 3



TEST FUEL LOAD RUN NO. 4





TEST FUEL LOAD RUN NO. 5



TEST FUEL LOAD RUN NO. 6





TEST FUEL LOAD RUN NO. 7

DISCUSSION OF RESULTS

## DISCUSSION OF RESULTS

### Discussion of Run Included in Weighted Average

Six of the seven certification tests performed on Mark's Custom Stoves K-400 Freestanding Wood Heater were used to calculate the weighted average. A design change was made to the combustion air inlet, limiting the opening to 2.0 inches. Thus test run No. 1 is eliminated from the weighted average, since the resulting burn rate is no longer achievable.

### Discussion of Specific Problems

There were no specific test run problems with quality checks, train components, or aborted test runs. One equipment problem occurred during test run No. 1 in which a thermocouple fell off the wood heater during certification testing. The thermocouple was re-adhered to the unit and no other problems were experienced.

### Discussion of Special Test Considerations

There were no special test considerations. All burn rates were achieved with a flue damper and there were no special pre-test procedures used.

WOOD HEATER INFORMATION

## WOOD HEATER DESCRIPTION

Heater Type: Catalytic

Manufacturer: Mark's Custom Stoves

Appliance I.D.: Model K-400 Freestanding

Distinguishing Features: Freestanding, firebrick lined firebox, double door on firebox opening, without thermal transfer blower or grate.

### Air Introduction and Controls:

The inlet of primary air includes two opening locations. Two identical oval holes are cut below the doors and are adjustable slide controls. The two controls are to be operated in unison and measure  $7/8$ " high by 2" at their widest opening.


The inlet of secondary air includes four  $5/16$ " holes drilled over the firebox door opening. The inner two holes are located  $2-7/8$ ", on center, from by-pass control and the outer two holes are  $2-7/8$ ", on center, from inner holes. No adjustments can be made to these air inlets.

## WOOD HEATER OPERATING INSTRUCTIONS

Written instructions for testing were provided in a letter by Mark's Custom Stoves and are enclosed on the following page. Adjustments were made during certification testing to combustion air inlet settings and during 5 minute test fuel loading period. Alterations were made in the air inlet settings to achieve burn rates in the appropriate categories. In the past the laboratory has found it to be beneficial for catalytic wood heaters to have the door and by-pass closed as soon as the test fuel is loaded and to adjust the combustion air inlet to the desired setting at the end of the five minuted test fuel loading period. All operating procedures performed during certification testing have been documented in this application.

SPECIAL WOOD HEATER INSTALLATION INSTRUCTIONS

There were no special wood heater installation instructions.



WOOD HEATER<sub>20</sub> INSTALLATION



WOOD HEATER AND CATALYST AGING DOCUMENTATION

The fifty hour catalyst aging was performed and documented on the Mark's Custom Stoves Model K-400 Freestanding and is included on the following pages entitled Wood Heater & Catalyst Aging Documentation.

WOOD HEATER & CATALYST AGING DOCUMENTATION

Manufacturer: marks Custom Stoves  
 Model: K400 FS  
 Technician: m. case

Date: 4/3/89  
 I.D. No.: 184  
 Burn Rate: med/high

Type: NON-CAT  CAT  PELLET

Setting: 7/8" to 1" draft setting  
 Catalyst Info.: SN#: \_\_\_\_\_ Length in.: \_\_\_\_\_  
 Grid, #/in2: \_\_\_\_\_ Coating: \_\_\_\_\_  
 Manufacturer: \_\_\_\_\_

Pellet Info.: Feed Cycle: ON N/A sec. OFF N/A sec.  
 Type of pellet fuel: N/A

Fuel Info.: Type: Douglas Fir  
 Fuel Moisture: 22.3 % Fuel Weight: 52.8 lbs. Load No.: 1  
 Fuel Moisture: 20.0 % Fuel Weight: 51.4 lbs. Load No.: 1  
 Fuel Moisture: 21.0 % Fuel Weight: 3.0 lbs. Load No.: 1

DATE	TIME	TEMP °F	FUEL	COMMENTS
4/3/89	11:00	60	*1	Initial - 20 lbs
	12:00	1151	↓	
	13:00	1313		
	14:00	1000		
	15:00	1153		ADDED - 6 lbs
	16:00	1100		
	17:00	1210		
	18:00	959		
4/4/89	06:00	65		*1
	07:00	1332	↓	
	08:00	1400		
	09:00	1211		
	10:00	1000		
	11:00	948		ADDED - 9.9 lbs
	12:00	1334		
	13:00	1212		
	14:00	1014		
	15:00	988		
	16:00	899		
	15:00	653	↓	
4/5/89	06:00	67	*2	Initial - 22.5 lbs
	07:00	1098	↓	
	08:00	1270		
	09:00	1142		
	10:00	1021		
	11:00	1061		Added - 19.1 lbs
	12:00	1374		
	13:00	1233		
	14:00	1145		
	15:00	1099		
	16:00	1004		
	17:00	920		
	18:00	801	↓	

Signature: Michael Case  
 Date: 4/5/89

30 ms

12 ms

7 ms

11 ms

WOOD HEATER & CATALYST AGING DOCUMENTATION

Manufacturer: marks Custom Stoves  
 Model: K400FS  
 Technician: M. Cave

Date: 4/6/89  
 I.D. No.: 184  
 Burn Rate: CAT 3

Type: NON-CAT  CAT  PELLET

Setting: 7/8" - 1" draft setting  
 Catalyst Info.: SN#: \_\_\_\_\_ Length in.: \_\_\_\_\_  
 Grid, #/in2: \_\_\_\_\_ Coating: \_\_\_\_\_  
 Manufacturer: \_\_\_\_\_

Pellet Info.: Feed Cycle: ON N/A sec. OFF N/A sec.  
 Type of pellet fuel: N/A

Fuel Info.: Type: \_\_\_\_\_  
 Fuel Moisture: 19.5 % Fuel Weight: 47.7 lbs. Load No.: 1  
 Fuel Moisture: 20.0 % Fuel Weight: 50.9 lbs. Load No.: 2  
 Fuel Moisture: \_\_\_\_\_ % Fuel Weight: \_\_\_\_\_ lbs. Load No.: \_\_\_\_\_

DATE	TIME	TEMP °F	FUEL	COMMENTS
4/6/89	07:00	64	*1	25.4 lbs initial
	08:00	1053		
	09:00	1197		
	10:00	1030		
	11:00	952		Added 22.7 lbs
	12:00	1212		
	13:00	1167		
	14:00	1089		
	15:00	1018		
	16:00	930		
	17:00	873	↓	10 hrs
4/7/89	06:00	67	*2	25.9 lbs initial
	07:00	1103		
	08:00	1285		
	09:00	1121		
	10:00	1067		
	11:00	994		Added 25.0 lbs
	12:00	1311		
	13:00	1194		
	14:00	1070		
	15:00	1011		
	16:00	967		
	17:00	871	↓	


Signature: M. Cave  
 Date: 4/7/89

WOOD HEATER DIMENSIONS AND USEABLE FIREBOX VOLUME

# Useable Firebox Volume Calculation

Marks Custom Stoves Model K-400 Freestanding

V<sub>1</sub>



$$L_1 = 24.0''$$


$$L_2 = 20.5''$$

$$H = 15.5$$

$$W = 1.75''$$

$$V_1 = (15.5)(.5)(1.75)(20.5 + 24.0) \\ = 603.5 \text{ cu. in.}$$

V<sub>2</sub>




$$L = 24.0''$$

$$W = 14.5''$$

$$H = 15.5''$$

$$V_2 = (24.0)(14.5)(15.5) \\ = 5394.0 \text{ cu. in.}$$

V<sub>3</sub>



$$L_1 = 24.0''$$

$$L_2 = 17.0''$$

$$W = 3.25''$$


$$H = 15.5''$$

$$V_3 = (15.5)(.5)(3.25)(17.0 + 24.0) \\ = 1032.7 \text{ cu. in.}$$

Handwritten calculations:  

$$\begin{array}{r} 17.0 \\ 1.25 \\ \hline 16.75 \\ 1.25 \\ \hline 15.5 \end{array}$$

V4



L = 16.0"

W = 14.0"

H = 4.0"

$$V_4 = (16.0)(14.0)(4.0)$$

$$= 896.0 \text{ cu. in.}$$

Calculation of Useable Firebox Volume:

$$V_T = V_1 + V_2 + V_3 - V_4$$

$$= 603.5 + 5394.0 + 1032.7 - 896.0$$

$$= 6134.2 \text{ cu. in.}$$


$$= \underline{3.55 \text{ cu. ft.}}$$

Ideal Test Fuel Weight = 24.8 lbs.


Test Fuel Weight Range = 22.3 to 27.3 lbs.

Test Fuel Length = 20.0 in.


Drawing of Firebox  
Males Custom Blows Middle K-100 Free-standing



Top View



Front View



Side View

PROCEDURES / SAMPLING




## METHODS USED

### PM Sampling Approach: E.P.A. Method 5H

Particulate matter is withdrawn proportionally from the wood heater exhaust and is collected on two glass fiber filters separated by impingers immersed in an ice bath. The first filter is maintained at 248 degrees F. The second filter and the impinger system are cooled such that the exiting temperature of the gas is maintained at 68 degrees F or less.

Sampling apparatus is identical to configurations shown in E.P.A. Method 5H-1 and 5H-2 and meets all specifications outlined in Method 5H, section 2. The probe nozzle/sample probe used for the particulate sampling train is one piece, all pyrex glass, 6 inches in length with a 90 degree bend at one end, and having an internal diameter of 0.62 inches. The bend is pointed in to the stack gas flow at the centroid of the stack and extends 2 inches below the horizontal plane of the probe.



The probe is connected directly to the sampling train just before the first filter. The probe is always at stack temperature and leads directly into the 248 degrees F oven containing the first filter.

Both filter holders are glass with a glass frit filter support and measure 5 inches (125 mm) in diameter. All sampling train components are glass with ground glass ball and socket connections. The differential pressure gauge used for orifice differential pressure readings is a Magnehelic Gauge manufactured by Dwyer Instruments, Inc. with a range of 0 to 0.25 inches of H<sub>2</sub>O. Orifice Delta H settings are generated using an equation which insures particulate sampling flow rates are proportional to the stack flow rate, (See Example Calculations). A Fortin mercurial barometer is used for atmospheric pressure measurements.

## PM Sampling Approach: E.P.A. Method 5H (cont.)

The stack flow rate measurement system consists of a 1/4 inch stainless steel probe bent at 90 degrees and pointing into the gas flow. It is located near the center of the stack at 8' above the platform scale. The probe leads to two impingers immersed in an ice bath, the first impinger is used for condensation, the second contains drierite to further remove moisture. The gas sample then passes through a glass fiber filter (Gelman A/E 61631) and stainless steel filter support, to the inert sampling pump, a sampling manifold, rotameter, and finally to the gas analyzer. CO<sub>2</sub>, CO, and O<sub>2</sub> are measured from this manifold.

The proportional flow rate system is identical to that described in Method 5H, section 2.3. The injection loop is 3/8-inch stainless steel, having an overall diameter of 3-1/2 inches, and 19 (1/8 inch) holes on the top side of the loop. An identical loop with slightly larger holes is used as the tracer sample probe. Between the injection loop and tracer sample probe a static mixer comprised of three slightly twisted plates are suspended by wire to insure complete mixing of the 100% SO<sub>2</sub> tracer gas with the stack gas. These plates in no way impede flow and do insure homogeneous mixing. The conditioning system is as described in Method 5H, section 2.3.3 a tube furnace combustor maintained @ 1350 degrees F precedes two impingers immersed in an ice bath, a glass fiber filter (Gelman A/E 61631) and stainless steel support, inert sampling pump, flowmeter and SO<sub>2</sub> analyzer. All lines are stainless steel, glass or teflon and a quartz tube is used in the combustor.

### Efficiency Procedure

Northwest Testing Laboratories, Inc. opts to use the default efficiency values as provided in the E.P.A. test protocol.

### Description of Pretest


Crumpled newspaper was loaded with kindling, averaging 4.3 lbs. in weight, and a fire was ignited in the Marks Custom Stoves model K-400 freestanding woodstove. The pretest fuel charge consisted of 2x4's cut to 7.0" lengths and had approximately the same weight as the test fuel charge. In test run no. 7 an additional pretest fuel load was used and during the lower burn rate test runs there was an occasional coalbed raking to achieve uniform charcoalization. Both air inlet supply controls were set at 100% open to maintain combustion of the pretest fuel load. The air inlet supply controls are adjusted to achieve the desired burn rate and the unit was operated at the desired burn rate for a minimum of 60 minutes before the start of the test runs.

Description of Pretest: E.P.A. Method 5H (cont.)

The coalbed raking adjustments were made up to 15 minutes prior to the start of the test run and were recorded. At the end of the preburn period the platform scale was zeroed, and the test run started. The kindling and pretest fuel consumed to leave a fuel weight between 20 and 25 percent of the weight of the test fuel charge.

DESCRIPTION OF ALLOWABLE ALTERNATIVES

No variation throughout testing performed for K-400 Freestanding Wood Heater manufactured by Mark's Custom Stoves



Facility and Wood Heater

FACILITY AND WOOD HEATER LIST

<u>Item from Figure</u>	<u>Description</u>
Flue Pipe :	It is a 6" or 8" diameter by 24" lengths, 24 gauge steel single wall pipe painted black. Sealing compound is Grant Wilson's Furnace and Retort Cement.
Insulated Flue Pipe :	It is a 6" diameter by one 36" length and one 24" length, double wall insulated stainless steel pipe. Manufactured by Jackes Evans Subsidiary G.S.W., Inc. U.L. Listed 98H3. OR It is a 8" diameter by two 36" lengths, double wall insulated stainless steel pipe. Manufactured by Security Chimneys Ltd. U.L. Listed 377X.
Liquid Seal:	The oil pan is an U-shaped trough in the form of a square which measure 14-1/8" in length by 14-1/8" in width by 5-1/4" in depth on the outside. The trough, which holds the oil, measures 3" in depth by 2" in width. The collar, which is put into the oil, is a single wall square box measuring 12" x 12" x 3" in depth with a 6" or 8" diameter, 24 guage single wall flue pipe located in the center of the box. All materials are constructed out of 24 guage steel. The oil is L-45 Polydimethylsiloxane with viscosity of 350 cSt manufactured by Union Carbide Silicones.
Supports :	Three rubber coated cords connected to the top of the insulated flue pipe with lengths 54-1/2", 56", and 28". The two longest lengths are connected to the wall and the third to a brace from the ceiling. The cords are evenly spaced around the circumference of the pipe, with a turn buckle centrally located on each cord to take up the stack.

FACILITY AND WOOD HEATER LIST cont.

<u>Item from Figure</u>	<u>Description</u>
Platform Scale :	It is a digital dormant scale manufactured by ElectroScale Corporation, Model 3030 with a StreeterAmet, Quantomatic 9000 digital weight indicator. Range is 0 to 1000 lbs. Capacity is 1000 lbs. Resolution is 0.1 lbs. Accuracy is $\pm 0.05$ lbs.
Fuel Storage Area :	The humidifying room's dimensions are 75" in length by 48" in width by 93-1/2" in height and is lined with Celotex Thermal Sheathing. Joints in the sheathing are sealed with sprayed foam insulation and duct tape. There is one 11" x 11" ventilation hole and one 80" x 35" door which seals closed. The room is equipped with an Edison humidifier with an outlet capacity of 8 gallons per 24 hours.
Moisture Meter :	It is an electrical resistance type moisture meter, Model G-30 manufactured by the Delmhorst Instrument Company and equipped with the 26-E electrode fitted with insulated pins. Range is 6 to 30%. Resolution is 0.25% from 6 to 15% and 0.5% from 15 to 30%. Accuracy is within $\pm 0.5\%$ from 6 to 12%, within $\pm 1.0\%$ from 12 to 20%, and within 2.0% from 20 to 30%. A calibration check is made at 12% and 22% using calibration moisture standards. Pins are driven into the wood with a sliding hammer on a shaft to desired depth. Then the moisture content is read on the meter scale.

FACILITY AND WOOD HEATER LIST cont.


<u>Item from Figure</u>	<u>Description</u>
Surface and Catalyst Temperature Monitors :	Surface temperature monitors are, in all cases, 24 guage Type K (chromel-alumel) thermocouple wire. The ends of the wire are twisted together and cemented to the stove on the top, sides, rear, and bottom. Catalyst and primary temperatures are measured using 12" long and 1/8" diameter stainless steel Type K probes. Holes are drilled into the desired locations, the probe is inserted through the hole to the appropriate point and furnace cement is used to seal the hole. Thermocouples are used with a digital indicator calibrated for Type K thermocouples. Range is 0 to 2280 degrees F. Resolution is 1.0 degree F. Accuracy is $\pm 0.5$ degrees F.
Draft Guage:	It is an adjustable level, inclined 1" manometer manufactured by Dwyer Instruments, Inc. Range is -0.10 to 1.0 inches in H2O. Resolution is 0.005 inches in H2O. Accuracy is $\pm 0.002$ inches in H2O.
Anemometer :	It is a swing vane anemometer manufactured by Dwyer Instruments, Inc. and the model no. is 480 Vaneometer. Range is 0 to 400 ft/min. Resolution is 10 ft/min from 0 to 50 ft/min, 5 ft/min from 50 to 200 ft/min, and 50 ft/min from 200 to 400 ft/min. Accuracy is $\pm 5\%$ of full scale from 0 to 100 ft/min and $\pm 10\%$ from 100 ft/min to top of scale.
Humidity Guage :	It is a mason type, hygrometer manufactured by Taylor, part no. 59-377. Range is 30 to 120 degrees F. Resolution is 1.0 degree F. Accuracy is $\pm 0.5$ degrees F.



FACILITY AND WOOD HEATER LIST cont.

<u>Item from</u> <u>Figure</u>	<u>Description</u>
Barometer :	It is a Fortin type mercurial barometer manufactured by the Sargent-Welch Scientific Company. Range is 21.70 to 32.70 inches. Resolution is 0.01 inches. Accuracy is $\pm$ 0.005 inches.
Wet Bulb :	It is a 3/16" diameter x 25-1/2" in length stainless steel Type K temperature probe with an 1/8" diameter copper tubing running along the top of the probe. A gauze sponge is wrapped around the end of the tubing and probe. The gauze tip is moistened and placed into the stack at 8' above the top of the platform scale. The gauze tip is kept moist, throughout the test, by introducing water through the copper tubing.

SAMPLING TRAIN (5H)



SAMPLING TRAIN 5H

<u>Item from Figure</u>	<u>Description</u>
Probe :	The probe nozzle/sample probe is one piece, all pyrex glass, 6" in length with a 90 degree bend at one end, and having an internal diameter of 0.62". Refractory fiber packing seals the probe in the port and the probe is always at stack temperature.
Front Filter Holder :	The filter holder is a four piece, all glass, 4" filter support assembly. The first outer part has a 28/15 outer joint bent perpendicular to the flow path. Next in line is a neoprene gasket used to hold the filter paper and prevent leakage around filter. The third piece is a porosity B fritted disc measuring 4-1/2" in diameter. And the last part is seated for the fritted disc and has a 28/15 inner joint
Front Filter :	The filter is a 125 mm diameter, glass fiber paper manufactured by Reeve Angel. The effective surface area is approximately 122.66 sq. cm.
Back Filter Holder :	Same as Front Filter Holder.
Back Filter :	Same as Front Filter.
Thermometer :	There are two thermometers which are 24 gauge Type K thermocouple wire with the same range, resolution, and accuracy as the surface temperature monitors. The first wire is located in the heated zone of the train, it is wrapped around the arm of the filter holder. The second wire is located on the arm of the third impinger and is held on by duct tape.
Desiccant :	It is a grade H, type IV, indicating, 6-16 mesh silica gel. The amount used is approximately 200 grams.

SAMPLING TRAIN 5H cont.

<u>Item from Figure</u>	<u>Description</u>
Dry Gas Meter:	It is a standard T 11C Rockwell Dry Gas meter with test index. Capacity is 1000.0 cu. ft. range is 0 to 1000.0 cu. ft. Resolution is 0.001 cu. ft. and is certified as 100% accurate $\pm$ 1.0% of total flow.
Orifice :	The differential pressure gauge used for orifice differential readings is a Magnehelic Gauge manufactured by Dwyer Instruments, Inc. with a range of 0 to 0.25 inches of H <sub>2</sub> O. Readout resolution is 0.0025 inches of H <sub>2</sub> O. Accuracy is $\pm$ 0.001 inches of H <sub>2</sub> O. Orifice delta H settings are generated using an equation which insures particulate sampling flow rates are proportional to the stack flow rate (See Example Calculations).

# GLASS MICROFIBER FILTERS



## Unique Material

Glass microfibers are unique among fibrous materials used for laboratory filter media. They differ from naturally occurring cellulose fibers in that they are circular in cross section and are made extremely fine.

## Superior Performance

The glass microfibers are used in a modified paper making process to produce filter media with filtration characteristics markedly superior to cellulose-based filter papers. In terms of loading capacity, Reeve Angel brand glass microfiber filters far outperform filter papers; increased loading does not cause a proportional decrease in flow rate, and pressure increase with loading is nearly undetectable for most of the effective life of the filter. They are capable of much better retention efficiencies yet have higher flow rates than the fastest filter papers.

## High Purity

Since Reeve Angel brand glass microfiber filters are 100% borosilicate glass they have the purity characteristic of this material inasmuch as great care is taken to avoid contamination during manufacture. The composition of borosilicate glass is typically\*:

Constituent	%	Constituent	%
SiO <sub>2</sub>	57.9	K <sub>2</sub> O	2.9
B <sub>2</sub> O <sub>3</sub>	10.7	CaO	2.6
FeO <sub>3</sub>	5.9	MgO	0.4
Al <sub>2</sub> O <sub>3</sub>	10.1	BaO	5.0
Na <sub>2</sub> O		ZnO	3.9
F	0.6		

\*Surface extractables. Determined by dispersing pre-washed filter material in 200 ml distilled water and filtering through an acid-washed funnel and diluting to 250 ml.

### Binder Free

No binders of any kind are present in Reeve Angel brand glass microfiber filters. Although binders facilitate the manufacturing process, they adversely affect filter performance. For example, binders may make the filter hydrophobic. Organic binders introduce adsorptive characteristics and thus can influence the concentration of low molecular solution compounds in the filtrate. It is important that the final filter be "binder free".

### Excellent Chemical Resistance

Since the only constituent of Reeve Angel brand glass microfiber filters is borosilicate glass, they have excellent chemical resistance except to hydrofluoric acid and strong alkalis. The material is little affected by organic solvents; wet strength actually increases in non-polar solvents. These filters can thus be used in chemical environments where other filter materials cannot. The fibers do not swell in either organic solvents or in water.

### Non-Hygroscopic, Yet Highly Absorbent

Glass microfibers are non-hygroscopic; Reeve Angel brand glass microfiber filters will maintain constant weight over a wide range of ambient humidity. At the same time the filter material will absorb relatively large amounts (three to five times the amount of paper filter material) of liquid. This is because of the fine capillary structure between the fibers. The individual fibers themselves do not absorb the liquid.

### Biologically Inert

Reeve Angel brand glass microfiber filters are unaffected by and will not denature biological fluids. They will not absorb soluble proteins or other macromolecules even at low molecular concentrations. They can, of course, be easily sterilized by standard techniques.

### High Use-Temperature Range

Borosilicate glass softens at about 700°C. Glass microfiber filters should not, however, be used above about 500°C, since above that temperature the stability of the inter-fiber bonds is affected. Of course, 500°C is far above the temperature-use limit of other filter materials. High use-temperature makes Reeve Angel brand glass microfiber filters useful for, e.g., filtration of hot gases. It also permits them to be used in gravimetric analyses where ignition of the precipitate is involved.

It is useful to note that Reeve Angel brand glass microfiber filters can be used as well at extremely low temperatures without embrittlement.

### Typical Applications

Highly versatile because of the nature of the material used and the absence of binders, Reeve Angel brand glass microfiber filters are used in a wide variety of applications. A few of these uses are:

- |                               |                          |
|-------------------------------|--------------------------|
| Liquid Scintillation Counting | Water Pollution Analyses |
| Air Pollution Analyses        | Cell Harvesting          |
| Radioimmunoassay              | Wastewater Analyses      |

### Non-Filtration Uses

Reeve Angel brand glass microfiber filter sheets and circles have been used in paper chromatography and paper electrophoresis with great success. They have been used as matrices of impregnation with, e.g., silicic acid, and to bond various functionalities for specialized chromatography. In both chromatography and electrophoresis these materials are ideal for conditions where paper cannot be used, such as at high temperatures or acidity.

### Typical Characteristics

Characteristic	Grade 900-AF*	Grade 934-AH	Grade 984-H
Particle Retention <sup>(1)</sup>	n/a	98 + %	100%
DOP Penetration (0.3 μm smoke)	0.03%	0.022%	0.001%
Ash, %	0	0	0
Thickness, mm	0.304	0.304	0.304
Tensile Strength, dry, g/in. wd.	900 +	700 +	1000
Wet Strength, g/in. wd.	n/a	150 +	150 +
Air-flow Resistance, mm H <sub>2</sub> O <sup>(2)</sup>	39	75	220
Color	White	White	White
Surface	Smooth	Smooth	Smooth

\* Used for gas filtration.  
 (1) Precipitated calcium oxide.  
 (2) 934-AH, 984-H @ 85 liters/min; 900-AF @ 32 liters/min.

REEVE ANGEL 934AH

(BOROSILICATE TYPE)

GLASS FIBER COMPOSITION

<u>CHEMICAL COMPONENT</u>	<u>%</u>
SiO <sub>2</sub>	57.9
B <sub>2</sub> O <sub>3</sub>	10.7
R <sub>2</sub> O <sub>3</sub>	5.9 (Mainly Al <sub>2</sub> O <sub>3</sub> , Trace Fe <sub>2</sub> O <sub>3</sub> )
Na <sub>2</sub> O	10.1
K <sub>2</sub> O	2.9
CaO	2.6
MgO	0.4
BaO	5.0
ZnO	3.9
F	0.6

SOFTENING POINT - 1254° F (678° C)

SOLUBILITY - 1 Hour At Boil

0.1 N. NaOH - 6.4%

1.0 N. H<sub>2</sub>SO<sub>4</sub> - 2.34%

SPECTRAL ANALYSISReeve Angel Grade 934-AHNon-metals (water extractable)Micrograms/8 1/2" x 11" Filter

sulfate	(SO <sub>4</sub> <sup>-</sup> )	700
nitrate	(NO <sub>3</sub> <sup>-</sup> )	4.4
ammonium	(NH <sub>4</sub> <sup>+</sup> )	115
fluoride	(F <sup>-</sup> )	20
chloride	(Cl <sup>-</sup> )	50

Benzene Soluble Organics


2940

Metals (Nitric acid extractable)

cadmium		4.0
beryllium		0.1
iron		>2000
lead		96
chromium		60
copper		7.5
tin		<0.2
antimony		27
manganese		30
nickel		20
bismuth		<.1
molybdenum		<.5
vanadium		20
titanium		50
zinc		85
cobalt		2
barium		20



CO, CO2, and O2 EQUIPMENT



## O2, CO, AND CO2 FLOW MEASUREMENT EQUIPMENT

<u>Item from Figure</u>	<u>Description</u>
CO, CO2 Calibration Gas :	Concentrations: .5% CO, 3.0% CO, Balance Air; 1% CO, 7.0% CO2, Balance Air or N2; 1.5% CO, 12.0% CO2, Balance N2; 6.5% CO, 17.0% CO2 Balance N2. All gas mixtures are traceable to NBS standards per E.P.A. Protocol #1. Size of cylinder for each gas mixture is 150.
CO, CO2 Flow Regulator :	It is a two stage brass regulator manufactured by Smiths Welding Equipment, Model H713. It has a maximum inlet pressure of 3000 psi and ranges of 0 to 4000 psi on gauge 1 and 0 to 150 psi on gauge 2.
O2 Calibration Gas :	Concentrations: 7% oxygen in balance nitrogen; 14% oxygen in nitrogen; and 21% oxygen in nitrogen. The gas is contained in 200 size cylinders.
O2 Flow Regulator :	It is a two stage brass with stainless steel diaphragm regulator manufactured by Airco, Model 806-9621. It has a maximum inlet pressure of 3000 psi and ranges of 0 to 4000 psi on gauge 1 and 0 to 60 psi on gauge 2.
Point of Injection :	The calibration gas can enter the system in two locations. It can enter at the two-way valve #3 which then goes directly to the analyzers, or it can enter the sample line right before the sample condenser, so it flows through the whole system. The limiting restriction of the flow would be from the flowmeters.

O<sub>2</sub>, CO, AND CO<sub>2</sub> FLOW MEASUREMENT EQUIPMENT cont.

<u>Item from Figure</u>	<u>Description</u>
Condenser :	The condenser consists of two glass impingers, one modified and one standard, which are connected with a U-adapter. The standard impinger is filled with approximately 100 ml of water and the modified impinger is filled with approximately 200 grams of Drierite indicating desiccant. Both impingers are placed in an ice bath (about 32 degrees F). Moisture is removed two ways; by maintaining the temperature below the dew point of water and by the desiccant. The efficiency indicators are the change in color, from blue to pink, and the accumulation of water in the first impinger. To clean the standard impinger, water is drained and the impinger is rinsed with water and acetone. To clean the modified impinger, when the Drierite is spent it is discarded and the impinger rinsed with water and acetone.
Filter :	An in-line type, stainless steel 47 mm, filter holder with type A/E 47 mm, glass fiber filter manufactured by Gelman Sciences, Inc. The filter holder contains filter, support screen, perforated support disc of stainless steel, Teflon compression ring, and O-ring seal of Viton. It is tightened using a threaded collar assembly. The glass fiber filter is changed after each run and the stainless steel parts are rinsed with acetone. Also a filter is changed if it becomes necessary during a test run.
Primary Rotameter :	It is a direct reading precision flowmeter manufactured by Dwyer Instruments, Inc., Model RMA-SSV. The range is from 2 to 20 scfh air and is constructed of polycarbonate plastic. The accuracy is $\pm 4\%$ of the full scale. The control is a precision metering valve, made of stainless steel.
Manifold :	It is a 7" section of 1/4" diameter stainless steel tubing with three stainless steel branch tee ports which lead to the secondary flowmeters.


O2, CO, AND CO2 FLOW MEASUREMENT EQUIPMENT cont.

<u>Item from Figure</u>	<u>Description</u>
Exhaust :	The exhaust flow meter is a plastic direct reading model with a range from 0 to 4.5 scfh air.
CO Analyzer:	The Horiba Model PIR-2000 General Purpose Infrared Gas Analyzer is a precision gas analyzer based on non-dispersive infrared ray absorption for continuously determining the concentration of a given component in a gaseous stream. Zero gas is introduced into the instrument and the front panel zero control is adjusted until the meter indicates zero. Next, span gas is introduced into the instrument and the span control is adjusted to indicate the concentration of the span gas. The procedure of zero/span is repeated to insure reproducibility and then sample gas is introduced into the analyzer and the concentration is read on the digital display.
CO Range :	The measuring range is from 100 ppm to 100% of full scale concentrations. Resolution is 0.005%. The response speed is set at 1.2 sec. Linearity is determined by a multi-point calibration using different concentrations of CO after each test series. The results are always linear.
CO Flow Indicator :	It is a direct reading precision flowmeter manufactured by Dwyer Instruments, Inc., Model RMA-SSV. The range is from 0.5 to 5.0 scfh air and is constructed of polycarbonate plastic. A flow rate of 1.5 scfh air is maintained. The accuracy is $\pm 4\%$ of full scale. It is located in the gas sample line right before the CO2 analyzer.
CO2 Analyzer:	Same as CO Analyzer, except unit is equipped with an analog readout.
CO2 Range :	Same as CO Range.

O2, CO, AND CO2 FLOW MEASUREMENT EQUIPMENT cont.

<u>Item from Figure</u>	<u>Description</u>
CO2 Flow Indicator :	Same as CO Flow Indicator.
O2 Analyzer :	The Horiba Model PMA-200 is a high precision oxygen analyzer based on the magnetic dumb-bell sphere method for continuously measuring the oxygen concentration change in the sample gas. Zero gas is introduced into the instrument and the front panel zero control is adjusted until the meter indicates zero. Next, introduce span gas into the instrument and adjust the span control until the meter indicates the concentration of the span gas. Repeat. Lastly, sample gas is introduced into the analyzer and measurement commences.
O2 Range :	There are two measuring ranges, from 0 to 10% and from 0 to 25%. Resolution is 0.5. The response speed is within 20 sec. Linearity is determined by a multi-point calibration using different concentrations of O2 after each test series. The results are always linear. Accuracy is $\pm 1\%$ of full scale. The unit is equipped with an analog readout.
O2 Flow Indicator :	It is a direct reading precision flowmeter manufactured by Dwyer Instruments, Inc., Model RMA-SSV. The range is from 1 to 10 scfh air and is constructed of polycarbonate plastic. A flow rate of 1.0 scfh air is maintained. The accuracy is $\pm 4\%$ of full scale. It is located in the sample gas line right before the O2 analyzer.

SO2 EQUIPMENT



## TRACER GAS EQUIPMENT

<u>Item from Figure</u>	<u>Description</u>
Injection Probe	: The injection loop is 3/8" stainless steel tubing, having an overall diameter of 3-1/2", and nineteen 1/8" holes on the top side of the loop. The loop is inserted into the pipe from the inside at 10 ft. above the top of the platform scale.
Rotameter	: The Matheson Series 601 rotameter is made of borosilicate glass, have plain tapered ends, and integral rib guides to center the floats. The tube contains two floats, one glass and one stainless steel. The range is 4 to 262 scc/min and is controlled by a high accuracy valve. The tube is accurate to $\pm 5\%$ of full scale.
Control Valve	: It is a Matheson, Series 4170 high accuracy needle valve. Constructed of stainless steel and has a range from 0 to 400 scc/min.
Injection Gas	: Pure SO <sub>2</sub> is used for the tracer gas and is contained in a 300 size cylinder. The regulator is a two-stage, high purity, stainless steel, Model 3500 Series manufactured by Matheson. The delivery pressure gauge has a range from 0 to 100 psig and the cylinder pressure gauge range is from 0 to 3000 psig.
Calibration Gas	: Concentrations are 100 ppm of SO <sub>2</sub> , 250 ppm of SO <sub>2</sub> , 500 ppm of SO <sub>2</sub> , and 2000 ppm of SO <sub>2</sub> in which all concentrations are in nitrogen. They are all in 150A size cylinders and are NBS traceable per E.P.A. protocol #1. SO <sub>2</sub> calibration gas can be injected into the sample line before the combustor or it can be injected directly through the flow meter to the analyzer. The injection is controlled by a 3-way stainless steel ball valve.

TRACER GAS EQUIPMENT cont.

<u>Item from Figure</u>	<u>Description</u>
Sample Probe:	It is an identical loop to the injection probe with slightly larger holes. It is inserted into the double insulated flue pipe, from the inside, at eight flue pipe diameters from the injection probe. Between the injection probe and the sample probe is a static mixer comprised of three slightly twisted metal plates and are suspended by wire to insure complete mixing.
Combustor :	The combustor is a tube furnace manufactured by Thermolyne Corporation Model No. F21100. The range is 400 to 1800 degrees F for continuous use and 1800 to 2000 degrees F for intermittent use. Resolution is 25 degrees F. The control tolerance is $\pm 20$ degrees F. Overall dimensions are 16" in width x 14-5/8" in height x 12" in depth. The tube is made of quartz, it is 20-1/2" in length and 1.0" diameter. The 1.0" diameter section is 16" in length and has a capacity of 12.6 cu. in.
Filter Assembly :	An in-line type, stainless steel 47 mm, filter holder with type A/E 47 mm, glass fiber filter both manufactured by Gelman Sciences, Inc. The filter holder contains filter, support screen, perforated support disc of stainless steel, Teflon compression ring, and O-ring seal of Viton. It is tightened with a threaded collar assembly. The glass fiber filter is replaced after each test run or when the filter becomes clogged.
Sample Condenser :	The sample condenser consists of two glass modified high velocity, 28/15 ball on the inlet and outlet, impingers. The impingers are connected with a U-adaptor and placed into an ice bath. The moisture is removed because the impingers are kept at a temperature (about 32 degrees F) below the dew point of water.



TRACER GAS EQUIPMENT cont.

<u>Item from Figure</u>	<u>Description</u>
Sample Condenser cont.	: Since the flow rate through the impingers is slow and the impingers are always kept in the ice bath, this method proves to be efficient. To clean, all glassware is rinsed with acetone and water to remove any particules which collected.
SO2 Analyzer:	The Horiba Model PIR-2000 General Purpose Infrared Gas Analyzer is a precision gas analyzer based on non-dispersive infrared ray absorption for continuously determining the concentration of a given component in a gaseous stream. Zero gas is introduced into the instrument and the front panel zero control is adjusted until the meter indicates zero. Next, introduce span gas into the instrument and adjust the span control until the meter indicates the concentration of the span gas. Repeat. Lastly, sample gas is introduced into the analyzer and measurement commences.
Instrument Range	: The measuring range is from 100 ppm to 100% of full scale concentrations. Resolution is 0.5%. The response speed is set at 1.2 sec. Linearity is determined by a multi-point calibration using different concentrations of SO2 after each test series. The results are always linear. The type of readout is an analog meter. The accuracy of the unit is $\pm$ 0.5%.
Flow Indicator	: It is a direct reading precision flowmeter manufactured by Dwyer Instruments, Inc., Model RMA-SSV. The range is from 0.5 to 5.0 scfh air and is constructed of polycarbonate plastic. A flow rate of 2.0 scfh air is maintained. The accuracy is $\pm$ 4% of full scale. It is located in the SO2 sample line right before the SO2 analyzer.

CALIBRATIONS

## METHOD 28 EQUIPMENT CALIBRATION

### Platform Scale

The platform scale is serviced and calibrated at least annually by a qualified service representative and is audited before each certification test. With the wood heater in place at least five N.B.S. traceable calibration weights are used to span the operational range of the scale to 0.1 lbs. or 1 percent of the expected test fuel charge weight.

Scale Model: Platform Shreeter Amet Electro scale Balance Quantomatic 9000 Indicator Test Facility NW Testing Labs, Inc.

Calibration Performed By O. Windoor Date 4/10/89 to 4/18/89

Wood Heater Model K-400 freestanding Weight of Test Fuel 24.8 lbs.  
 Marks Custom Stoves

Time	Test Run Number	Platform Temperature	Class F Calibration Weight (A)	Initial Scale Reading or Tare (B)	Final Scale Reading (C)	Measured Calibration Weight (D = C - B)	Difference (D minus A)
09:30	1	60	15.0	0.0	15.0	15.0	0.0
08:00	2	61	15.0	0.0	15.0	15.0	0.0
09:00	3	65	15.0	0.0	15.0	15.0	0.0
09:00	4	66	15.0	0.0	15.0	15.0	0.0
09:50	5	67	15.0	0.0	15.0	15.0	0.0
10:00	6	62	15.0	0.0	15.0	15.0	0.0
11:00	7	64	15.0	0.0	15.0	15.0	0.0

Single Point Scale Calibration Check

Instrument to be Calibrated Platform Scale Test Facility NW Testing Labs, Inc.  
 Model Number Electro Scale Calibration Performed by D. Windsor  
Model B030 Date of Calibration 4-21-89

Method of Measurement	Reference Value (A)	Measured Value (B)	Difference (A minus B)	Acceptable Tolerance
Dual Load Cell	50.0	50.0	0.0	0.1
	35.0	35.0	0.0	0.1
	25.0	25.0	0.0	0.1
	10.0	10.0	0.0	0.1
	5.0	5.0	0.0	0.1
	1.0	1.6	0.0	0.1

Semiannual Calibration Sheet

Instrument to be Calibrated Platform Scale Test Facility NW Testing Labs, Inc  
 Model Number Electroscale Corp. Calibration Performed by D Windsor  
Model 3030 Date of Calibration 4-7-89

Method of Measurement	Reference Value (A)	Measured Value (B)	Difference (A minus B)	Acceptable Tolerance
Dual Load cell	50.0	50.0	0.0	0.1
	35.0	35.0	0.0	0.1
	25.0	25.0	0.0	0.1
	10.0	10.0	0.0	0.1
	5.0	5.0	0.0	0.1
	1.0	1.0	0.0	0.1

Semiannual Calibration Sheet

## METHOD 28 EQUIPMENT CALIBRATION

### Barometer

The Fortin-type mercurial barometer used for measuring atmospheric pressure was standardized and calibrated upon initial installation as described in ASTM D-3631. The secondary standard used was the barometric pressure as measured by the U.S. Weather Bureau at Portland International Airport. Appropriate altitude and temperature corrections were applied. Subsequent comparison with U.S. Weather Bureau barometric pressure readings showed consistent reproduceability. Periodic checks are made with the U.S. Weather Bureau to insure accuracy of atmospheric pressure readings.

### Draft Gauge

The draft gauge is always zeroed prior to a certification test and requires no calibration since a liquid manometer is used. Periodic cleaning and replacement of liquid in the manometer insures accurate measurement of the draft.

### Anemometer

It is physically inspected and cleaned before each certification test. No calibration is needed as stated in advertisement enclosed.

### Moisture Meter

The moisture meter is calibrated before and after each certification series with a calibrated moisture block supplied by Delmhorst Instrument Company. On the following page it explains how the calibration is performed (N.T.L. uses the MCS - Pin Type Electrode).

### Relative Humidity Gauge

Relative humidity is determined using a hygrometer, Mason type. Wet bulb and dry bulb temperatures are read directly and the relative humidity is determined from the tables supplied. Thermometers are calibrated mercury-in-glass with a range of 30 to 120 degrees F. Periodic verification of wet bulb/dry bulb readings are made by comparison with a sling psychrometer.

HOW TO USE  
A MOISTURE CONTENT STANDARD

The "MCS" contains two "standards", to check the calibration of Delmhorst Moisture Detectors.

PROCEDURE

1. Adjust the Moisture Detector, according to instructions.
2. Using a pin-type electrode, touch the center (common) lug and one of the side lugs of the "MCS" with the pins of the electrode, FIG A, turn the meter on and take a reading; the meter should read the same value as indicated on the "standard".
3. If a prod-type electrode is used, FIG B, contact between electrode and MCS is made by inserting the prod in the clips, with the tip held in the center clip and the lower metal band held in either of the outer two clips.




FIGURE A  
MCS - PIN TYPE




FIGURE B  
MCS - PROBE TYPE





# Dwyer

## No. 480 Vaneometer™

Swing Vane Anemometer. Use this sensitive new Dwyer unit to measure low air velocities — at low cost.\*

The Dwyer 480 Vaneometer™ Swing Vane Anemometer is a durable low-priced instrument specifically designed to simplify the measurement of low air velocities from 25 to 400 feet per minute. OSHA, EPA and other safety ventilation requirements for spray booths and at fume, smoke and dust exhaust hoods can now be quickly checked, even by untrained personnel. Its small size and light weight — only four ounces make it ideal to carry from one work station to another. A versatile steel mounting bracket for continuous monitoring is also included. The Vaneometer Swing Vane Anemometer is accurate to  $\pm 5\%$  of full scale to 100 FPM and  $\pm 10\%$  from 100 FPM to top of scale. It has a spirit level to insure accurate readings and the large scales are easy to read and visible from both sides. The housing is molded from tough ABS plastic and easy to clean with soap and water. The polyester vane can be cleaned with lacquer thinner. A spare vane is provided.

Use a Vaneometer to measure velocity of air flow into laboratory fume hoods and at paint spray booths to determine when to change filters. Or wherever needed to meet OSHA standards of ventilation for smoke, dust or fume removal.



The Vaneometer's large scales are easy to read. Both sides have factory calibrated scales. Recessed spirit level at top helps insure accurate readings.

\*U.S. Patent No. 4,154,101

## METHOD 28 EQUIPMENT CALIBRATION

### Temperature Monitors

The temperature monitor meter is sent semi-annually to Grant Edgel Company for calibration and thermocouple wires are semi-annually calibrated to within 1 percent of expected temperature with a mercury-in-glass thermometer.

TEMPERATURE MONITOR CALIBRATION SHEET

TEMPERATURE MONITOR TYPE Chromel-Alumel K TEST FACILITY NW Testing Labs  
 REFERENCE TEMPERATURE MONITOR TYPE Mercurv in DATE January 6, 1989  
 READOUT DEVICE Omega Engineering Glass Thermometer CALIBRATION PERFORMED BY D Windsor  
 AMBIENT TEMPERATURE 70 BAROMETRIC PRESSURE 30.00

Reference Point Source	Temperature of Reference Point	Observed Temperature Temperature Monitor	Difference in Percent of Absolute Temperature
Amb #1	32°F	30°F	0.4%
" "	211°F	208°F	0.4%
Top #2	32°F	31°F	0.2%
" #2	210°F	210°F	0%
Bottom #3	32°F	31°F	0.2%
" #3	209°F	209°F	0%
Rear #4	212°F	210°F	0.3%
" #4	32°F	31°F	0.2%
Right Side #5	32°F	31°F	0.2%
" " #5	212°F	212°F	0%
Left Side #6	212°F	212°F	0%
" " #6	32°F	32°F	0%
Primary #7	32°F	33°F	0.2%
" U #7	212°F	213°F	0.1%
Secondary #8	212°F	212°F	0%
" U #8	34°F	35°F	0.2%
Flue db #9	32°F	31°F	0.2%
" " #9	212°F	211°F	0.1%
Flue Wb #10	212°F	212°F	0%
" " #10	32°F	32°F	0%
Oven #13	32°F	30°F	0.4%
" #13	212°F	210°F	0.3%
Impinger #14	32°F	32°F	0%
" #14	212°F	210°F	0.3%

Thermocouple #9 (Secondary) was not calibrated since it is not used.

Thermocouples #11 (Inlet), #12 (outlet), #15 (Tracer) were not calibrated because they are inaccessible.

## METHOD 5H EQUIPMENT CALIBRATION

### Thermometers

Calibrated the same as Temperature Monitors in Method 28 Equipment Calibration.

### Barometer

See Barometer in Method 28 Equipment Calibration.

### Analytical Balance

The analytical balance is calibrated quarterly by Quality Control Services and the last date of calibration was September 1987. The unit also contains a self-calibration check and audit when turned on. A further calibration can be performed by the balance, by engaging the calibration phase.

## METHOD 5H EQUIPMENT CALIBRATION

### SO2 Injection Rotameter

The SO<sub>2</sub> injection rotameter calibration is performed each certification series. During calibration pure SO<sub>2</sub> is metered through the injection flowmeter at different rates. A constant head pressure of 20 psig is maintained and the injection is measured and verified to be at 0.12 in. of H<sub>2</sub>O. A 100-ml soap film flowmeter and stopwatch are used to measure actual flowrates at different settings of the fine metering valve. The linear calibration curve generated gives calibrated flowrates at any setting using the stainless steel float.

Date: 4-20-89

Technician: T. Palmer

SO<sub>2</sub> INJECTION RATE CALIBRATION SHEET

SO <sub>2</sub> Injection Rate mm/min.	t Min.	Volume Measured ml	SO <sub>2</sub> Tank Inj. Tank psi	Calculations
50	2.11	99	20	$\frac{99}{2.11} = 46.92 = .099 \text{ ft}^3/\text{hr}$
50	2.11			$\frac{99}{2.11} = 46.92 = .099 \text{ ft}^3/\text{hr}$
55	1.77			$\frac{99}{1.77} = 55.93 = .119 \text{ ft}^3/\text{hr}$
55	1.77			$\frac{99}{1.77} = 55.93 = .119 \text{ ft}^3/\text{hr}$
60	1.49			$\frac{99}{1.49} = 66.44 = .141 \text{ ft}^3/\text{hr}$
60	1.49			$\frac{99}{1.49} = 66.44 = .141 \text{ ft}^3/\text{hr}$
65	1.29			$\frac{99}{1.29} = 76.74 = .163 \text{ ft}^3/\text{hr}$
65	1.29			$\frac{99}{1.29} = 76.74 = .163 \text{ ft}^3/\text{hr}$
70	1.15			$\frac{99}{1.15} = 86.09 = .182 \text{ ft}^3/\text{hr}$
70	1.15			$\frac{99}{1.15} = 86.09 = .182 \text{ ft}^3/\text{hr}$

Date: 4-20-89

Signature: T. Palmer

Date: 4-7-89  
 Technician: T. Palmer

30.27

SO<sub>2</sub> INJECTION RATE CALIBRATION SHEET

SO <sub>2</sub> Injection Rate mm/min.	t Min.	Volume Measured ml	SO <sub>2</sub> Tank Inj. Tank psi	Calculations
50	1.89	99	20	$\frac{99}{1.89} = 52.38 = .111 \text{ ft}^3/\text{min}$
50	1.89	( )	( )	$\frac{99}{1.89} = 52.38 = .111 \text{ ft}^3/\text{min}$
55	1.67	( )	( )	$\frac{44}{1.67} = 26.35 = .126 \text{ ft}^3/\text{min}$
55	1.67	( )	( )	$\frac{99}{1.67} = 59.28 = .126 \text{ ft}^3/\text{min}$
60	1.45	( )	( )	$\frac{99}{1.45} = 68.28 = .145 \text{ ft}^3/\text{min}$
60	1.45	( )	( )	$\frac{99}{1.45} = 68.28 = .145 \text{ ft}^3/\text{min}$
65	1.24	( )	( )	$\frac{99}{1.24} = 79.84 = .169 \text{ ft}^3/\text{min}$
65	1.24	( )	( )	$\frac{99}{1.24} = 79.84 = .169 \text{ ft}^3/\text{min}$
70	1.17	( )	( )	$\frac{99}{1.17} = 84.62 = .179 \text{ ft}^3/\text{min}$
70	1.17	( )	( )	$\frac{99}{1.17} = 84.62 = .179 \text{ ft}^3/\text{min}$

Date: 4-7-89  
 Signature: T. Palmer

## METHOD 5H EQUIPMENT CALIBRATION

### Dry Gas Meter

The dry gas meter is calibrated annually with the wet test meter as described in Method 5, Section 5.3.1 and the last date calibrated was January of 1987. The dry gas meter is also calibrated before and after each certification series using the dry gas meter as a calibration standard found in Method 5, Section 7, for alternative calibration standards. The dry gas volume is corrected to standard conditions using the equation found in Example Calculations. Leak checks are done before and after each certification test and results can be found on pages 1 and 7, respectively, of the raw data. To perform a leak check first plug the inlet to the filter, open the flow adjustment completely and adjust to a vacuum of 5 in. Hg, and measure the leakage rate for 1 minute and record. A leakage rate of less than 0.02 cfm at 5 in. Hg is acceptable.



## WET TEST METER CALIBRATION

Date 1-10-89

Meter Reading - one revolution of index

Room Temperature =  $62.6^{\circ}\text{F} = 17^{\circ}\text{C}$

Meter Temperature =  $62.0^{\circ}\text{F} = 16.7^{\circ}\text{C}$

Bottle Temperature =  $62.6^{\circ}\text{F} = 17^{\circ}\text{C}$

$\Delta P_m = 2.9 \text{ in. H}_2\text{O} = (2.9)(0.0737 \text{ in. Hg/in. H}_2\text{O}) = 0.214 \text{ in. Hg}$

$\Delta P_B = 2.9 \text{ in. H}_2\text{O}$

Weight of water =  $\left(\frac{2910.6 + 2912.5}{2}\right)^{-85.0} = (2911.6 - 85.0) = 2826.6 \text{ gm} = 6.2314 \text{ lbs.}$   
@  $62.6^{\circ}\text{F}$

Correction for buoyancy =  $(6.2314)(0.00106) = 0.0066$

Correction for density of water @  $62.6^{\circ}\text{F} (17^{\circ}\text{C})$

F-11 to density @  $39.2^{\circ}\text{F}$  =  $(6.2314) \left(\frac{1.00000}{0.99879} - 1\right) = 0.0075$

Correction for temperature difference =  $(6.2314) \left(\frac{460 + 62.0}{460 + 62.6} - 1\right) = -0.0072$

Correction for pressure difference =  $(6.2314) \left(\frac{29.92 + 0.214 - 0.572}{29.92 + 0.214 - 0.561} - 1\right) = -0.0023$

Bottle-vapor pressure  $\text{H}_2\text{O}$  @  $17^{\circ}\text{C} = 14.530 \text{ mm Hg} = 0.572 \text{ in. Hg}$

Meter-vapor pressure  $\text{H}_2\text{O}$  @  $16.7^{\circ}\text{C} = 14.257 \text{ mm Hg} = 0.561 \text{ in. Hg}$

Corresponding weight of  $\text{H}_2\text{O}$  @ max. density =  $(6.2314 + 0.0066 + 0.0075 - 0.0072 - 0.0023)$

= ~~6.2380~~ 6.2360

equivalent volume,  $\text{ft}^3$  =  $6.2360 / 62.4262 = 0.0999$

one revolution of index = 0.0999 cu. ft.

Test Numbers \_\_\_\_\_ Date 4-19-89 Wood Heater \_\_\_\_\_  
 Barometric Pressure,  $P_b = 29.87$  in. Hg Dry Gas Meter Number # Pretest Y .973

Rotameter or Orifice Manometer Setting, ( $\Delta H$ ), in. $H_2O$	Gas Volume		Wet Reference Test Meter ( $V_w$ ), ft <sup>3</sup>	Temperature			Time ( $\theta$ ), min	Vacuum Setting, in. Hg	$Y_i$	$Y_i = \frac{V_w P_b (t_d + 460)}{V_d (P_b + \frac{\Delta H}{13.6}) (t_w + 460)}$	
	Wet Reference Test Meter ( $V_w$ ), ft <sup>3</sup>	Dry Gas Meter ( $V_d$ ), ft <sup>3</sup>		Wet Reference Test Meter ( $t_w$ ), °F	Dry Gas Meter						Average <sup>a</sup> ( $t_d$ ), °F
					Inlet ( $t_{di}$ ), °F	Outlet ( $t_{do}$ ), °F					
.01	3.055	3.148	75	83.5	71.5	78	30.00	0	.976	$\frac{3.055(29.87)(538)}{3.148(29.87 + \frac{10}{13.6})(538)}$	
.03	4.724	4.912	75	89.5	68.5	79	30.00	0	.969	$\frac{4.724(29.87)(538)}{4.912(29.87 + \frac{10}{13.6})(538)}$	
.05	5.974	6.271	76	93.5	68	81	30.00	0	.961	$\frac{5.974(29.87)(541)}{6.271(29.87 + \frac{10}{13.6})(541)}$	
									$Y = .969$		

<sup>a</sup> If there is only one thermometer on the dry gas meter, record the temperature under  $t_d$

$V_w$  = Gas volume passing through the reference test meter, ft<sup>3</sup>

$V_d$  = Gas volume passing through the dry gas meter, ft<sup>3</sup>

$t_w$  = Temperature of the gas in the reference test meter, °F

$t_{di}$  = Temperature of the inlet gas of the dry gas meter, °F

$t_{do}$  = Temperature of the outlet gas of the dry gas meter, °F

$t_d$  = Average temperature of the gas in the dry gas meter, obtained by the average of  $t_{di}$  and  $t_{do}$ , °F

$\Delta H$  = Pressure differential across orifice or dry gas meter, in  $H_2O$

$Y_i$  = Ratio of accuracy of reference test meter to dry gas meter for each run

$Y$  = Average ratio of accuracy of reference test meter to dry gas meter for all three runs;

tolerance = pretest  $Y \pm 0.05Y$

$P_b$  = Barometric pressure, in. Hg

$\theta$  = Time of calibration run, min

### Post-Test Dry Gas Meter Calibration Data Form (English Units)

Date: 4-19-89

Technician: T. Palmer

DRY GAS METER CALIBRATION

Barometric Pressure 29.87 in Hg  
(Initial)

H = .01 in H<sub>2</sub>O

Barometric Pressure 29.87 in Hg  
(Finish)

Elapse Time t = 30.00

Avg. Barometric Pressure 29.87 in Hg

Particulate Train Meter

Calibration Meter <sup>Wet</sup> ~~#26563~~

ft<sup>3</sup><sub>f</sub> 648.0

ft<sup>3</sup><sub>f</sub> 99.10

ft<sup>3</sup><sub>f</sub> 651.148

ft<sup>3</sup><sub>f</sub> 102.155

ft<sup>3</sup> 3.148

ft<sup>3</sup> 3.055

T in<sub>i</sub> 80

T in<sub>i</sub> 74

T in<sub>f</sub> 87

T in<sub>f</sub> 75

T in avg. 83.5

T avg. 74.5

T out<sub>i</sub> 74

Inches H<sub>2</sub>O = .25"

T out<sub>f</sub> 69

T out avg. 71.5

T avg. 77.5

CALCULATIONS:

Date: 4-19-89

Signature: T. Palmer  
69

Date: 4-19-89

Technician: T. Palmer

DRY GAS METER CALIBRATION

Barometric Pressure 29.87 in Hg  
(Initial)

H = 103 in H<sub>2</sub>O

Barometric Pressure 29.87 in Hg  
(Finish)

Elapse Time t = 30.00

Avg. Barometric Pressure 29.87 in Hg

Particulate Train Meter

Calibration Meter #26563 <sup>Wet</sup>

ft<sup>3</sup><sub>f</sub> 651.148

ft<sup>3</sup><sub>f</sub> 2.155

ft<sup>3</sup><sub>f</sub> 656.060

ft<sup>3</sup><sub>f</sub> 6.979

ft<sup>3</sup> 4.912

ft<sup>3</sup> 4.724

T in<sub>i</sub> 87

T in<sub>i</sub> 75

T in<sub>f</sub> 92

T in<sub>f</sub> 75

T in avg. 89.5

T avg. 75

T out<sub>i</sub> 69

T out<sub>f</sub> 68

Inches H<sub>2</sub>O = .25"

T out avg. 68.5

T avg. 79

CALCULATIONS:

Date: 4-19-89

Signature: T. Palmer

Date: 4-19-89

Technician: T. Palmer

DRY GAS METER CALIBRATION

Barometric Pressure 29.87 in Hg  
(Initial)

H = .05 in H<sub>2</sub>O

Barometric Pressure 29.87 in Hg  
(Finish)

Elapse Time t = 30.00

Avg. Barometric Pressure 29.87 in Hg

Particulate Train Meter

Calibration Meter #26563 <sup>Wc<sub>f</sub></sup>

ft<sup>3</sup><sub>f</sub> 652.060

ft<sup>3</sup><sub>f</sub> 6.879

ft<sup>3</sup><sub>f</sub> 662.331

ft<sup>3</sup><sub>f</sub> 12.853

ft<sup>3</sup> 6.271

ft<sup>3</sup> 5.974

T in<sub>i</sub> 92

T in<sub>i</sub> 75

T in<sub>f</sub> 95

T in<sub>f</sub> 76

T in avg. 93.5

T avg. 75.5

T out<sub>i</sub> 68

T out<sub>f</sub> 68

T out avg. 68

T avg. 81

Inches H<sub>2</sub>O = .25"

CALCULATIONS:

Date: 4-19-89

Signature: T. Palmer  
70a

Test Numbers \_\_\_\_\_ Date 4-4-89 Wood Heater \_\_\_\_\_  
 Barometric Pressure,  $P_b = 30.22$  In. Hg Dry Gas Meter Number #1 Pretest Y .970

Rotameter or Orifice Manometer Setting, (AH), In. H <sub>2</sub> O	Gas Volume		Temperature				Time (θ), min.	Vacuum Setting, In. Hg	$Y_i = \frac{V_w P_b (t_d + 460)}{V_d (P_b + \frac{AH}{13.6}) (t_w + 460)}$
	Reference Test Meter (V <sub>w</sub> ), ft <sup>3</sup>	Dry Gas Meter (V <sub>d</sub> ), ft <sup>3</sup>	Reference Test Meter (t <sub>w</sub> ), °F	Dry Gas Meter		Average <sup>a</sup> (t <sub>d</sub> ), °F			
				Inlet (t <sub>d1</sub> ), °F	Outlet (t <sub>d2</sub> ), °F				
.01	2.818	2.901	62	70	63	67	30.00	0	$\frac{2.818(30.22)}{(2.901)(30.22 + \frac{.01}{13.6})} (527)$
.03	4.598	4.775	63	76	59.5	68	30.00	0	$\frac{4.598(30.22)}{(4.775)(30.22 + \frac{.03}{13.6})} (527)$
.05	5.845	6.122	63	79.5	57.5	69	30.00	0	$\frac{5.845(30.22)}{(6.122)(30.22 + \frac{.05}{13.6})} (527)$
									$Y = .973$

<sup>a</sup> If there is only one thermometer on the dry gas meter, record the temperature under t<sub>d</sub>

V<sub>w</sub> = Gas volume passing through the reference test meter, ft<sup>3</sup>

V<sub>d</sub> = Gas volume passing through the dry gas meter, ft<sup>3</sup>

t<sub>w</sub> = Temperature of the gas in the reference test meter, °F

t<sub>d1</sub> = Temperature of the inlet gas of the dry gas meter, °F

t<sub>d2</sub> = Temperature of the outlet gas of the dry gas meter, °F

t<sub>d</sub> = Average temperature of the gas in the dry gas meter, obtained by the average of t<sub>d1</sub> and t<sub>d2</sub>, °F

AH = Pressure differential across orifice or dry gas meter, In H<sub>2</sub>O

Y<sub>i</sub> = Ratio of accuracy of reference test meter to dry gas meter for each run

Y = Average ratio of accuracy of reference test meter to dry gas meter for all three runs;

tolerance = pretest Y ± 0.05Y

P<sub>b</sub> = Barometric pressure, In. Hg

θ = Time of calibration run, min

Post-Test Dry Gas Meter Calibration Data Form (English Units)

Date: 4-4-89

Technician: J. Palmer

DRY GAS METER CALIBRATION

Barometric Pressure 30.22 in Hg  
(Initial)

H = .01 in H<sub>2</sub>O

Barometric Pressure 30.82 in Hg  
(Finish)

Elapse Time t = 30.0

Avg. Barometric Pressure 30.72 in Hg

Particulate Train Meter

Calibration Meter #26563

ft<sup>3</sup><sub>f</sub> 395.80

ft<sup>3</sup><sub>f</sub> 83.777

ft<sup>3</sup><sub>f</sub> 398.701

ft<sup>3</sup><sub>f</sub> 86.595

ft<sup>3</sup> 2.901

ft<sup>3</sup> 2.818

T in<sub>i</sub> 66

T in<sub>i</sub> 62

T in<sub>f</sub> 74

T in<sub>f</sub> 62

T in avg. 70

T avg. 62

T out<sub>i</sub> 65

T out<sub>f</sub> 61

In H<sub>2</sub>O .25"

T out avg. 63

T avg. 66.5

CALCULATIONS:

Date: 4-4-89

Signature: J. Palmer

Date: 4-4-89  
Technician: T. Palmer

DRY GAS METER CALIBRATION

Barometric Pressure 30.22 in Hg  
(Initial)

H = .03 in H<sub>2</sub>O

Barometric Pressure 30.22 in Hg  
(Finish)

Elapse Time t = 30.00

Avg. Barometric Pressure 30.22 in Hg

Particulate Train Meter

Calibration Meter #26563

ft<sup>3</sup><sub>f</sub> 398.701

ft<sup>3</sup><sub>f</sub> 86.595

ft<sup>3</sup><sub>f</sub> 403.476

ft<sup>3</sup><sub>f</sub> 91.193

ft<sup>3</sup> 4.775

ft<sup>3</sup> 4.598

T in<sub>i</sub> 74

T in<sub>i</sub> 63

T in<sub>f</sub> 78

T in<sub>f</sub> 63

T in avg. 76

T avg. 63

T out<sub>i</sub> 61

T out<sub>f</sub> 58

T out avg. 59.5

T avg. 68

In H<sub>2</sub>O .25"

CALCULATIONS:

Date: 4-4-89

Signature: T. Palmer  
73



Date: 4-4-89

Technician: J. Palmer

DRY GAS METER CALIBRATION

Barometric Pressure 30.22 in Hg  
(Initial)

H = .05 in H<sub>2</sub>O

Barometric Pressure 30.22 in Hg  
(Finish)

Elapse Time t = 30.0

Avg. Barometric Pressure 30.22 in Hg

Particulate Train Meter

Calibration Meter #26563

ft<sup>3</sup><sub>f</sub> 403.476

ft<sup>3</sup><sub>f</sub> 91.193

ft<sup>3</sup><sub>f</sub> 409.598

ft<sup>3</sup><sub>f</sub> 97.038

ft<sup>3</sup> 6.122

ft<sup>3</sup> 5.845

T in<sub>i</sub> 78

T in<sub>i</sub> 63

T in<sub>f</sub> 81

T in<sub>f</sub> 63

T in avg. 79.5

T avg. 63

T out<sub>i</sub> 58

T out<sub>f</sub> 57

T out avg. 57.5

T avg. 68.5

In H<sub>2</sub>O .25"

CALCULATIONS:

Date: 4-4-89

Signature: J. Palmer

\*\*\*\*\*  
THIS PROGRAM CALCULATES THE AVERAGE Km AND DELTA H@  
BY DAVID A. WINDSOR  
\*\*\*\*\*

RAFT SETTING	Gm	Km
0.010	0.104	1.325
0.030	0.161	1.187
0.050	0.204	1.169

\*\*\*\*\*

THE AVERAGE Km IS 1.22682  
DELTA H@ IS .6112599

Date: 4-19-89  
 Technician: T. P. [Signature]

Case. 29.87

H @ CALIBRATION SHEET

H In H2O	V <sub>13</sub> ft	V <sub>F3</sub> ft	Ø Min.	T <sub>1</sub> °F			T <sub>2</sub> °F			Qm ccm	Km
				I	E	A	I	E	A		
.01	648.0	651.148	30.0	80	87	87.5	74	69	71.5		
.03	651.148	656.060	30.0	87	92	89.5	69	68	68.5		
.05	656.060	662.331	30.0	92	95	93.5	68	68	68		

H @ = .61

Date: 4-19-89  
 Signature: [Signature]

\*\*\*\*\*  
THIS PROGRAM CALCULATES THE AVERAGE Km AND DELTA H@  
BY DAVID A. WINDSOR  
\*\*\*\*\*

AFT SETTING	Gm	Km
*****	*****	*****
0.010	0.096	1.248
0.030	0.157	1.175
0.050	0.200	1.163
*****	*****	*****

E AVERAGE Km IS 1.19375  
E DELTA H@ IS .6455966

Date: 4-4-89  
 Technician: T. Palmer

H @ CALIBRATION SHEET

H In H2O	V <sub>13</sub> ft	V <sub>23</sub> ft	Ø Min.	T <sub>1</sub> °F			T <sub>2</sub> °F			Qm ccm	K <sub>m</sub>
				I	E	A	I	E	A		
.01	395.80	398.701	30.0	66	74	70	65	61	63		
.03	398.701	403.476	30.0	74	78	76	61	58	57.5		
.05	403.476	409.598	30.0	78	81	79.5	58	57	57.5		

H @ = \_\_\_\_\_  
 \_\_\_\_\_

Date: 4-4-89  
 Signature: T. Palmer

## METHOD 5H EQUIPMENT CALIBRATION

### O2, CO, CO2, SO2 Error Check

The analyzer calibration error check is conducted prior to each certification test. After the flow rate measurement system and the tracer gas measurement system have been prepared for use, introduce zero gases and then the mid-level calibration gases for each analyzer. Set the analyzers' output responses to the appropriate levels. Then introduce the low-level and high-level calibration gases, one at a time, for each analyzer. Record the analyzer responses.

Date: 4-21-89  
 Technician: Malcolm

Barometric Pressure<sub>i</sub> 29.80 in Hg  
 Barometric Pressure<sub>f</sub> 29.80 in Hg  
 Barometric Pressure Avg. 29.80 in Hg

MULTI-POINT AUDIT

	CO <sub>2</sub>	CO	SO <sub>2</sub>
Gas/Concentration	14.98%	5.01%	512.5 ppm
Zero	0.0	0.0	0.0
Actual	59.9	5.01	34.2
Desired	59.9	5.01	34.2
% Diff.	0.0%	0.0%	0.0%

Gas/Concentration	12.1%	1.38%	271 ppm
Zero	0.0	0.0	0.0
Actual	49.9	1.41	18.2
Desired	48.4	1.38	18.1
% Diff.	3.1%	2.17%	0.29%

Gas/Concentration	2.89%	.397%	108 ppm
Zero	0.0	0.0	0.0
Actual	12.1	.360	7.3
Desired	11.6	.397	7.2
% Diff.	4.3%	9.3%	1.3%

Gas/Concentration	14.98	5.01%	512.5 ppm
Zero	0.0	0.0	0.0
Actual	59.9	5.01	34.2
Desired	59.9	5.01	34.2
% Diff.	0.0%	0.0%	34.2

CALCULATIONS:

Date: 4-21-89 80 Signature: [Signature]

Date: 4-7-89  
 Technician: T. Walker

Barometric Pressure; 30.27 in Hg  
 Barometric Pressure; 30.27 in Hg  
 Barometric Pressure Avg. 30.17 in Hg

MULTI-POINT AUDIT

	CO <sub>2</sub>	CO	SO <sub>2</sub>
Gas/Concentration	14.98%	5.01%	572.5 ppm
Zero	0.0	0.0	0.0
Actual	59.9	5.01	34.2
Desired	59.9	5.01	34.2
% Diff.	0.0%	0.0%	0.0%

Gas/Concentration	12.1%	1.39%	271 ppm
Zero	0.0	0.0	0.0
Actual	49.9	1.41	18.7
Desired	48.4	1.39	18.1
% Diff.	3.1%	2.17%	1.1%

Gas/Concentration	2.89%	1.397%	108 ppm
Zero	0.0	0.0	0.0
Actual	12.1	1.360	7.7
Desired	11.4	1.397	7.2
% Diff.	4.7%	9.3%	1.3%

Gas/Concentration	14.98%	5.01%	572.5 ppm
Zero	0.0	0.0	0.0
Actual	59.9	5.01	34.2
Desired	59.9	5.01	34.2
% Diff.	0.0%	0.0%	0.0%

CALCULATIONS:

Date: 4-7-89

81 Signature: T. Walker





**Industrial Gases**

Division of The BOC Group, Inc.

2009 Bellaire Avenue  
Royal Oak  
Michigan 48067  
Telephone: 313-399-8020

ANALYTICAL REPORT

TO: Vancouver Welding Supply  
800 Harney Street  
Vancouver, WA 98660

LAST ANALYSIS DATE: 8/24/87  
EXPIRATION DATE: 2/24/88  
REFERENCE NUMBER: 805722  
PURCHASE ORDER #: 1065/MEL

MATERIAL SUBMITTED - NOMINAL VALUE: 5% CO + 15.5% CO2 in N2

TEST CYLINDER NUMBER: CC-4145

METHOD OF ANALYSIS: Gas Chromatograph

INST. CALIB. DATE:  
First: 8/17/87  
Second: 8/24/87

NBS SRM's USED: (CRM 2642) 1675b

**\*\*DATA\*\***

<u>FIRST ANALYSIS DATE</u>	<u>SRM NO.</u>	<u>SRM CONC.</u>	<u>TEST CYL. CONCENTRATION</u>
8/17/87	2642(CRM)	7.71% (CO)	5.00%
	1675b	14.00% (CO2)	15.16%

<u>SECOND ANALYSIS DATE</u>	<u>SRM NO.</u>	<u>SRM CONC.</u>	<u>TEST CYL. CONCENTRATION</u>
8/24/87	2642(CRM)	7.71% (CO)	5.01%
	1675b	14.00% (CO2)	15.21%

**\*\*CYLINDER INVESTIGATION\*\***

<u>CYLINDER NO.</u>	<u>COMPONENT</u>	<u>MEAN CONCENTRATION</u>
CC-4145	Carbon Monoxide	5.00%
	Carbon Dioxide	15.19%
	Nitrogen	Balance

**\*\*TRACEABLE TO NBS PER EPA PROTOCOL 2 JUNE 15, 1978\*\***

*Michael E. Kelley*  
PRINCIPAL GAS ANALYST  
Michael E. Kelley

"This report states accurately the results of the investigation made upon the materials submitted to the analytical laboratory. Every effort has been made to determine objectively, the information requested, HOWEVER, in connection with its rendering of this report AIRCO shall have no liability in excess of its established charge for the service. Any use of this report or the information contained herein shall be at the sole risk of the user."

Union Landing & River Roads  
P.O. Drawer No. 272  
Riverton  
New Jersey 08077  
Telephone: Marketing; 609-829-7878  
Prod. & Admin.; 609-829-7914  
International; 609-829-7917

**ANALYTICAL REPORT**

To: Vancouver Welding Supply  
800 Harney Street  
Vancouver, WA 98660

Date Reported: 08-15-88  
Test Number: 84344

Material Submitted: 21%Oxygen/Nitrogen

Specification Number:

Method of Analysis: Percent Oxygen Analyzer

Result of Investigation: Cylinder No. CC-383

<u>Component</u>	<u>Specification</u>	<u>Concentration</u>
Oxygen	21%	21.8 %
Nitrogen	Balance	Balance

By

*Duan J...*  
Authorized Signature



**Industrial Gases**  
Division of Airco, Inc.

660 North Balowin Park Blvd.  
P.O. Box 1290  
City of Industry  
California 91749  
Telephone: (818) 369-2871

**ANALYTICAL REPORT**

To: Vancouver Welding Supply  
800 Harney St.  
Vancouver, WA 98660

Date Reported: 4-27-87

Reference: 309860  
467-11846


Material Submitted: One size #152 cylinder containing 500 ppm Sulfur Dioxide, balance Air

Information Requested: Certification of Analysis

Method of Analysis: UV Photometric Analyzer

Result of Investigation:

Component	Cylinder	Specification	Concentration
SO2	DC3669	500 ppm	513 ppm
Balance Air (synthetic)			

By   
PRINCIPAL GAS ANALYST

"This report states accurately the results of the investigation made upon the materials submitted to the Analytical Laboratory. Every effort has been made to determine objectively, the information requested; HOWEVER, in connection with its rendering of this report, AIRCO shall have no liability in excess of its established charge for the service. Any use of this report or the information contained herein shall be at the sole risk of the user."

## METHOD 5H EQUIPMENT CLAIBRATION

### O2, CO, CO2, SO2 Response Check

The analyzer response check is performed on a semi-annual basis. Zero gas is introduced at the calibration gas valve into the flow rate measurement system and the tracer gas measurement system until all readings are stable. Then, quickly switch to introduce the mid-level calibration gas at the calibration valve until a stable value is obtained. Record the response time and repeat the procedure three times.

ANALYZER RESPONSE CHECK

Test Facility: N.W. Testing Labs, Inc. Date: 3-7-89

Technician: T. Palmer Barometric Pressure: 28.83

Analyzer	Timings (sec.)			Response Time Specification	Stability
	1	2	3		
S02	19.1	17.4	15.0	2.0 min	Came to Stability & Remained
CO2	14.9	12.9	12.9	↓	
CO	14.6	11.8	12.4		
O2	28.5	27.4	27.1		

EXAMPLE CALCULATIONS

## DRY BURN RATE, (BR)

### Equation Used

$$BR = \left[ \frac{60W_{wd}}{\Theta} \right] \left[ \frac{100 - \%M_w}{100} \right]$$

### Nomenclature

BR = Dry wood burn rate, kg/hr (lb/hr)

$W_{wd}$  = Total mass of wood burned (wet basis) during the test run, kg (lb)

$\Theta$  = Total time of test run, minutes

$\% M_w$  = Average moisture in test fuel charge, wet basis, percent

NOTE: To convert from dry basis to wet basis:

(100) (percent dry reading) ÷ (100 + percent dry reading) =  
percent moisture wet basis

### Sample Calculation

$$BR = \left( \frac{60 \text{ min/hr (6.62 kg)}}{120 \text{ minutes}} \right) \left( \frac{100 \% - 18.6 \%}{100 \%} \right)$$

BR = 2.69 kg/hr (dry basis)

VOLUME OF GAS SAMPLE CORRECTED TO DRY STANDARD CONDITIONS

$$\left( V_{m(std)} \right)$$

Equation Used

$$V_{m(std)} = K_1 V_m Y \left( \frac{P_{bar} + \left( \frac{\Delta H}{13.6} \right)}{T_m} \right)$$

Nomenclature

$V_{m(std)}$  = Volume of gas sample measured by the dry gas meter, corrected to standard conditions, dscm<sup>3</sup> (dscf)

$K_1$  = 0.3858 °K/mm Hg for metric units  
 = 17.64 °R/in. Hg for English units

$V_m$  = Volume of gas sample as measured by the dry gas meter, dm<sup>3</sup> (dcf)

$Y$  = Dry gas meter calibration factor

$P_{bar}$  = Barometric pressure at the sampling site, mm Hg (in. Hg)

$\Delta H$  = Average pressure differential across the orifice meter (if used), mm H<sub>2</sub>O (in. H<sub>2</sub>O)

$T_m$  = Absolute average dry gas meter temperature, °K (°R)

Sample Calculation

$$V_{m(std)} = (17.64^{\circ R/in. Hg}) \times (61.588 \text{ dcf}) \times (1.003) \times$$

$$\left( 29.23 \text{ in. Hg} + \frac{2.31 \text{ in. H}_2\text{O}}{13.6 \left( \frac{\text{in. H}_2\text{O}}{\text{in. Hg}} \right)} \right)$$

$$542^{\circ R}$$

$$V_{m(std)} = 59.11 \text{ dscf}$$



TOTAL AMOUNT OF PARTICULATE MATTER COLLECTED (5G-2 and 5H)

$(m_n)$

Equation Used

$$m_n = F_1 + F_2 + R + I_{ex} + I_w - \left( \frac{m_a V_{aw}}{V_a} \right) - \left( \frac{m_{dcm} V_{dcmw}}{V_{dcm}} \right) - \left( \frac{m_w V_{iw}}{V_w} \right)$$

Nomenclature

- $m_n$  = Total amount of particulate matter collected, mg
- $F_1$  = Particulate matter collected on front filter, mg
- $F_2$  = Particulate matter collected on second filter, mg
- $R$  = Residue from evaporated probe and filter holder rinses, mg
- $I_{ex}$  = Weight of residue from evaporated impinger water extract, mg
- $I_w$  = Weight of residue from evaporated impinger water, mg
- $m_a$  = Mass of residue of acetone solvent blank after evaporation, mg
- $V_{aw}$  = Volume of acetone used in probe and filter holder rinses, ml
- $V_a$  = Volume of acetone blank, ml
- $m_{dcm}$  = Mass of residue in dichloromethane solvent blank after evaporation, mg
- $V_{dcmw}$  = Volume of dichloromethane used in impinger rinses and impinger extractions, ml
- $V_{dcm}$  = Volume of dichloromethane blank, ml
- $m_w$  = Mass of residue in water blank after evaporation, mg
- $V_{iw}$  = Volume of water placed in train impingers, ml
- $V_w$  = Volume of water blank, ml

Sample Calculation

$$m_n = 75.1 \text{ mg} + 13.2 \text{ mg} + 56.4 \text{ mg} + 35 \text{ mg} + 23 \text{ mg}$$

$$- \left( \frac{(0.2 \text{ mg})(250 \text{ ml})}{(50 \text{ ml})} \right) - \left( \frac{(0.1)(100 \text{ ml})}{(75 \text{ ml})} \right)$$

$$- \left( \frac{(0.1 \text{ mg})(200 \text{ ml})}{(200 \text{ ml})} \right)$$

$$m_n = 201.47 \text{ mg}$$

## PARTICULATE CONCENTRATION ( $C_s$ )

### Equation Used

$$C_s = (0.001 \text{ g/mg}) \times (m_n/V_{m(\text{std})})$$

### Nomenclature

$C_s$  = Concentration of particulate matter in stack gas or dilution tunnel, dry basis, corrected to standard conditions  $\text{g/dsm}^3$  ( $\text{g/dscf}$ )

$m_n$  = Total amount of particulate matter collected in the sampling train, mg

$V_{m(\text{std})}$  = Volume of gas sample measured corrected to dry standard conditions,  $\text{dsm}^3$  ( $\text{dscf}$ )

### Sample Calculation

$$C_s = (0.001 \text{ g/mg}) \times \frac{52.4 \text{ mg}}{12.23 \text{ dscf}}$$

$$C_s = 0.00428 \text{ g/dscf}$$

TOTAL DRY MOLES OF STACK EXHAUST GAS ( $N_T$ )  
METHOD 5H CARBON BALANCE

Equation Used

$$N_T = \frac{42.5}{(Y_{CO_2} + Y_{CO} + Y_{HC})}$$

Nomenclature

$N_T$  = Total dry moles of exhaust gas per kg of dry wood burned, g-moles/kg  
(lb-moles/1000 lb)

42.5 = gram moles of carbon per kilogram of dry fuel (lb/lb)

$Y_{CO}$  = Measured mole fraction of CO (dry), average g/g-mole, (lb/lb-mole)

$Y_{CO_2}$  = Measured mole fraction of CO<sub>2</sub> (dry) average g/g-mole, (lb/lb-mole)

$Y_{HC}$  = Assumed mole fraction of HC (dry), average g/g-mole, (lb/lb-mole)

= 0.0088 for catalytic wood heaters

= 0.0132 for non catalytic wood heaters

= 0.0080 for pellet-fired wood heaters.

Sample Calculation

$$N_T = \frac{42.5 \text{ g-atoms of carbon/kg}}{(0.1128) + (0.0126) + (0.0132) \text{ (g-carbon/mole stack gas)}}$$

$N_T = 306.64$  moles of stack gas/kg

## TOTAL STACK GAS FLOW RATE ( $Q_{sd}$ )

### METHOD 5H CARBON BALANCE

#### Equation Used

$$Q_{sd} = K_4 N_T BR$$

#### Nomenclature

$Q_{sd}$  = Total stack gas flow rate corrected to dry standard conditions,  
dsm<sup>3</sup>/hr (dscf/hr)

$K_4$  = 0.02406 dsm<sup>3</sup>/g-mole for metric units  
= 384.8 dscf/lb-mole for English units

$N_T$  = Total dry moles of exhaust gas per kg of dry wood burned, g-moles/kg  
(lb-moles/1000 lbs)

BR = Dry burn rate, kg/hr (lb/hr)

#### Sample Calculation

$$Q_{sd} = 0.02406 \frac{\text{dsm}^3}{\text{g-mole}} \times 306.64 \frac{\text{g-mole}}{\text{kg}} \times 4.65 \frac{\text{kg}}{\text{hr}}$$

$$Q_{sd} = 34.307 \frac{\text{dsm}^3}{\text{hr}}$$

## ORIFICE PRESSURE DIFFERENTIAL, ( H@)

### Equation Used

$$\Delta H@ = \frac{0.0317 \Delta H}{P_b (T_o + 460)} \left[ \frac{(T_w + 460) \theta}{V_w} \right]^2$$

### Nomenclature

$\Delta H$  = Orifice manometer setting, in.  $H_2O$ .

$P_b$  = Barometric pressure, in. Hg.

$T_o$  = Volume meter inlet temperature, °F.

$T_w$  = Wet test meter temperature, °F.

$\theta$  = Time, min.

$V_w$  = Wet test meter gas volume,  $ft^3$ .

### Sample Calculation

$$H@ = \frac{(0.0317)(0.10 \text{ in. } H_2O)}{(30.11 \text{ in. Hg})(71^\circ F + 460)} \left[ \frac{(68^\circ F + 460)(15 \text{ min})}{(3.053 \text{ cu. ft.})} \right]^2$$

$$= (1.98 \times 10^{-7})(2594.2)^2$$

$$= 1.334$$

## ANALYZER ERROR CHECKS

### Equation Used

$$AE (\%) = \frac{\Delta C}{\text{span}} \times 100$$

### Nomenclature

AE = Analyzer error in measuring low level and high level calibration gases; expressed as percent relative to the instrument range, (%)

span = The upper limit of the instrument range, ppmv or (%)

C = The absolute difference between analyzer response and known calibration gas concentrations, ppmv or (%)

### Sample Calculation

CO<sub>2</sub> Analyzer Range (span): 0 - 25% vol

Low level calibration gas concentration: 6.25% vol

Analyzer response to low level calibration gas: 6.42% vol

High Level calibration gas concentration: 22.10% vol

Analyzer response to high level calibration gas: -22.62% vol

$$\text{Low level AE} = \frac{6.42 - 6.25\% \text{ vol}}{25.00\% \text{ vol}} \times 100 = 0.68\%$$

$$\text{High level AE} = \frac{22.62 - 22.10\% \text{ vol}}{25.00\% \text{ vol}} \times 100 = 2.08\%$$

PERCENT OF PROPORTIONAL SAMPLING RATE (PR)

Equation Used

$$PR = \left( \frac{\theta \sum_{i=1}^n S_i V_{mi(std)}}{10 \sum_{i=1}^n (S_i V_{mi(std)})} \right) \times 100$$

Nomenclature

PR = Percent of proportional sampling rate (%).

$\theta$  = Total sampling time, min.

$S_i$  = Concentration measured at the He analyzer for the " $i^{th}$ " 10-minute interval, ppm.

$V_{mi(std)}$  = Volume of gas sample measured by the dry gas meter during the  $i^{th}$  10-minute interval,  $dm^3$  (dscf).

Sample Data

<u>i</u>	<u>(min.)</u>	<u>(ppm)</u>	<u><math>V_{mi(std)}</math></u>	<u>PR<sub>i</sub></u> <u>(%)</u>
1	0	2400	1.9439	100
2	10	2750	1.6085	97.3
3	20	2650	1.7228	100.3
4	30	2650	1.6881	98.7
5	40	2550	1.8090	101.4

Sample Calculation

When  $i = 1$ :

$$PR = \left[ \frac{10 \text{ min. (2400 ppm) (1.9439 dscf)}}{10 \text{ min. (2400 ppm) (1.9439 dscf)}} \right] \times 100 = 100\%$$

When  $i = 2$ :

$$PR = \left[ \frac{20 \text{ min. (2750 ppm) (1.6085 dscf)}}{10 \text{ min. [(2400 ppm) (1.9439 dscf) + 2750 ppm (1.6085 dscf)]} \right] \times 100 = 97.3\%$$



When  $i = 3$ :

$$PR = \left[ \frac{30 (2650) (1.7228)}{10 (2400) (1.9439) + (2750) (1.6085) + (2650) (1.7228)} \right] \times 100$$

= 100.3%

When  $i = 4$ :

$$PR = \left[ \frac{40 (2650) (1.6881)}{10 \left[ (2400) (1.9439) + 2750 (1.6085) + (2650) (1.7228) \right] + (2650) (1.6881)} \right] \times 100$$

= 98.7%

When  $i = 5$ :

$$PR = \left[ \frac{50 (2550) (1.8090)}{10 \left[ (2400) (1.9439) + 2750 (1.6085) + 2550 (1.7228) \right] + (2550) (1.6881) + (2550) (1.8090)} \right] \times 100$$

= 101.4%

## ANALYZER DRIFT CHECKS

### Equation Used

$$\text{Drift} = \frac{\Delta R}{\text{span}} \times 100$$

### Nomenclature

Drift = the change in analyzer response to calibration gas over the duration of the test run relative to the instrument range, (%)

$\Delta R$  = the difference between the analyzer response at the end of the test run and the known calibration gas value, ppmv or (%)

span = the upper limit of the instrument range, ppmv or (%)

### Sample Calculation

CO<sub>2</sub> Analyzer Range: 0 - 25% vol

Calibration Gas: 0.00, 12.50% vol

Post-test Run Instrument Response: 0.32, 11.95% vol

$$\text{Zero Drift} = [(0.32 - 0.00\% \text{ vol}) / 25\% \text{ vol}] \times 100$$

$$= 1.28\%$$

$$\text{Midlevel Drift} = [(12.50 - 11.95\% \text{ vol}) / 25\% \text{ vol}] \times 100$$

$$= 2.2\%$$

## PARTICULATE EMISSION RATE, (E)

### Equation Used

$$E = C_s Q_{sd}$$

### Nomenclature

E = Particulate emission rate, g/hr

$C_s$  = Concentration of particulate matter in stack gas or dilution tunnel gas, dry basis corrected to standard conditions, g/dscm<sup>3</sup>, (g/dscf)

$Q_{sd}$  = Total gas flow rate, dry basis corrected to standard conditions, dsm<sup>3</sup>/hr (dscf/hr)

### Sample Calculation

$$E = (0.1770 \text{ g/dscf}) (19.77 \text{ dscf/hr})$$

$$E = 3.50 \text{ g/hr}$$

## CORRECTION TO DRY GAS METER

### Equation Used

$$\text{Correction to meter readings} = [(A - B)/B] \times 100$$

### Nomenclature

A = Small water-sealed rotating-drum meter reading, where  
A = Final reading - Initial reading.

B = Dry gas meter reading, where B = Final reading - Initial  
reading.

### Sample Calculation

$$\begin{aligned} A &= 4.713 - 1.660 \\ &= 3.053 \text{ cu. ft.} \end{aligned}$$

$$\begin{aligned} B &= 717.755 - 714.600 \\ &= 3.155 \text{ cu. ft.} \end{aligned}$$

$$\begin{aligned} \text{Correction to meter readings} &= [(3.053 - 3.155)/3.155] \times 100 \\ &= -3.23\%. \end{aligned}$$

## WEIGHTED EMISSION RATE, ( $E_w$ )

### Equation Used

$$E_w = \frac{\sum_{i=1}^n (K_i E_i)}{\sum_{i=1}^n K_i}$$

### Nomenclature

$E_w$  = Weighted average emission rate, g/hr

$E_i$  = Emission rate for test run, i, adjusted to Method 5H equivalent, g/hr

$K_i$  = Test run weighting factor =  $P_{i+1} - P_{i-1}$

n = Total number of test runs

$P_i$  = Probability for burn rate during test run, i

### Sample Calculation

$$E_w = \frac{(5.00 \text{ g/hr}) (0.300) + (4.70 \text{ g/hr}) (0.259) + (5.30 \text{ g/hr}) (0.422) + (3.80 \text{ g/hr}) (0.532) + (5.10 \text{ g/hr}) (0.278)}{(0.300) + (0.259) + (0.422) + (0.532) + (0.278)}$$

$$E_w = \frac{8.40 \text{ g/hr}}{1.791}$$

$$E_w = 4.69 \text{ g/hr}$$

## CALCULATION OF OXYGEN VALUE, (% by volume)

### Equation Used

$$\text{Oxygen (O}_2\text{)} = 20.9 - ((1.06 \times \text{CO}_2) + (0.61 \times \text{CO}))$$

### Nomenclature

Oxygen (O<sub>2</sub>) = The percentage of oxygen by volume in the flue gas.

CO<sub>2</sub> = The percentage of carbon dioxide by volume in the flue gas.

CO = The percentage of carbon monoxide by volume in the flue gas.

20.9 = Percent of oxygen by volume in ambient air.

### Sample Calculation

$$\begin{aligned} \text{Oxygen (O}_2\text{)} &= 20.9 - ((1.06 \times 10.30\% \text{ by volume}) + (0.61 \times 0.65\% \\ &\quad \text{by volume})) \\ &= 9.59\% \text{ by volume.} \end{aligned}$$

PARTICULATE SAMPLING RATE FOR ISOKINETIC/PROPORTIONAL FLOW

EQUATION USED

$$\frac{\Delta H}{Set} = \frac{H\phi D_n^4 Q_{ti} P_{ti}^2}{3.86E-06 A_s P_s C't T_{ti}^2}$$

NOMENCLATURE

- C't = Downstream tracer concentration, ppm  
 Tm = Average meter temperature R  
 Ps = Stack pressure, in. Hg =  $\left( P_b + \frac{\text{draft}}{13.6} \right)$   
 Tti = Tracer gas injection temperature, R  
 Pti = Tracer gas injection pressure, in. Hg =  $\left( P_b + \frac{\text{in. H}_2\text{O}}{13.6} \right)$   
 Qti = Tracer gas injection rate, ft<sup>3</sup>/hr.  
 ΔHφ = Orifice calibration factor, in H<sub>2</sub>O  
 Dn = Diameter of nozzle, inches  
 As = Stack area, ft<sup>2</sup>  
 Pb = Barometric pressure, in. Hg

SAMPLE CALCULATION

$$\begin{aligned} \Delta H &= \frac{(1.55)(.62)^4 (533.5)(.15)^2 \left( 29.99 + \frac{.12}{13.6} \right)^2}{(3.86E-06)(.1963) \left( 29.99 + \frac{.10}{13.6} \right)^2 (645) (531)} \\ &= \frac{(1.55)(.148)(533.5)(.0225)(899.93)}{(3.86E-06)(.0385)(299.997)(415025)(281951)} \\ &= \frac{2474.1376}{523382.63} \\ &= 4.7272E-03 \text{ in H}_2\text{O.} \end{aligned}$$

FUEL FACTOR  
Fo

Equation Used

$$F_o = \left( \frac{20.9 - \%O_2}{\%CO_2} \right)$$

Nomenclature

%O<sub>2</sub> = Percent O<sub>2</sub> by volume (dry basis).

%CO<sub>2</sub> = Percent CO<sub>2</sub> by volume (dry basis).

20.9 = Percent O<sub>2</sub> by volume in ambient air.

NOTE : If CO is measurable, O<sub>2</sub> and CO<sub>2</sub> are adjusted using the following equations.

$$\%CO_2(\text{adj}) = \%CO_2 + \%CO$$

$$\%O_2(\text{adj}) = \%O_2 - 0.5 \%CO$$

%CO = Percent CO by volume (dry basis).

Sample Calculation

$$\%CO_2(\text{adj}) = 11.25 + .15$$

$$= 11.40$$

$$\%O_2(\text{adj}) = 9.0 - (0.5)(.15)$$

$$= 8.925$$

$$F_o = \left( \frac{20.9 - 8.925}{11.4} \right)$$
$$= 1.05.$$



## DRY GAS VOLUME CORRECTED TO STANDARD CONDITIONS

### Equation Used

$$V_{m \text{ std}} = 17.65 V_m \left( \frac{P_{\text{bar}} + \frac{\Delta H}{13.6}}{T_m} \right)$$

### Nomenclature

- $V_{m \text{ std}}$  = Volume of gas sample measured by the dry gas meter to standard conditions, dscf.
- $V_m$  = Volume of gas sample as measured by the dry gas meter, dcf.
- $T_m$  = Absolute average dry gas meter temperature, R.
- $P_{\text{bar}}$  = Barometric pressure at the sampling site, in. Hg.
- $\Delta H$  = Average pressure differential across the orifice meter, in H<sub>2</sub>O.

### Sample Calculation

$$\begin{aligned} V_{m \text{ std}} &= (17.65)(23.0 \text{ dcf}) \left( \frac{30.29 \text{ in. Hg} + \frac{0.03 \text{ in H}_2\text{O}}{13.6}}{526 \text{ R}} \right) \\ &= (405.95)(0.0576) \\ &= 23.379 \text{ dscf.} \end{aligned}$$

SOLVENT BLANKS FOR SAMPLE EXTRACTION

Deionized Water

0.0019 gm/200 ml

Dichloromethane

0.0009 gm/150 ml

Acetone

0.0018 gm/200 ml

RAW TEST DATA

SAMPLE EXTRACTION DATA

Stove Mfg.: Marks Custom Stoves Test: 1  
 Stove Model: K-400 FS Test Cycle: High  
 Date: 4-6-89 Stove I.D. No.: 184  
 Technician: D. Windsor

V<sub>v</sub>

CONDENSED WATER VOLUME, GMS

	Modified Temp. 100 ml H <sub>2</sub> O	Standard Imp 100 ml Hz	Modified Imp. Dry	Modified Imp. 200 Gms Silica Gel
Gross Weight	586.9	607.4	487.3	749.6
Initial Weight	564.0	606.3	487.3	748.3
Net Weight	22.9	1.1	0.0	1.3

TOTAL 25.3 GMS

W <sup>18188</sup> PARTICULATE CATCH, GMS <sup>.7627</sup> 4-10 13:30

	OVEN FILTER(S)			TRAIN FILTER(S)	
Gross Weight	.8189			.7580	
Initial Weight	.7631			.7582	
Net Weight	0.0558			0.000	

TOTAL 0.0558 GMS

#8	Front Catch Probe	Rear Catch Impingers	DCM	H <sub>2</sub> O
Beaker, ml	90	150	150	250
Gross, Weight	99.3802	100.0442	102.6929	100.1972
Initial Weight	99.3425	100.0092	102.6722	100.1870
Net Weight	0.0377	0.0350	0.0207	0.0102
Evaporation	0.0008	0.0014	0.0009	0.0024
Residue Weight	0.0369	0.0336	0.0198	0.0078

TOTAL 0.0981 GMS

0.0705

0.0276

Total Particulate = 0.1539 gm  
 = 153.9 mg



METHOD 5H FLOW RATE (STACK) CALCULATIONS

(Put general info in col B, data info in col H.)

Lab name: NORTHWEST TESTING LABS, INC.      Yhc 1=cat,2=ncat :      1  
 Stv manu: MARKS CUSTOM STOVES      Wc (if supplied) :  
 Model no: K-400 FREESTANDING      Burn rate (kg/hr):      6.81  
 Tst Date: APRIL 10, 1989      Run Number :      1

run time (min)	O2 (%)	CO2 (%)	CO (%) (1.-1.12)	Fo	Stack Gas Flow Rate		
					(dscfh)	(dscfm)	(dsm3/hr)
0	3.20	16.60	0.11	1.06	1363.88	22.73	38.66
10	0.20	18.40	2.03	1.06			
20	0.10	18.40	2.32	1.06			
30	0.10	18.50	2.45	1.05			
40	0.60	18.30	1.53	1.06			
50	3.30	16.50	0.20	1.06			
60	6.80	13.30	0.01	1.06			
70	7.40	12.80	0.01	1.05			
74	7.60	12.50	0.02	1.06			

Method 5H Proportionality Rate and Sample Volume Calculation  
 (put general info in col. C; Pb,Y,& unit info in col. G)

```

=====
Lab name: NORTHWEST TESTING LAB., INC.          Units 1=metric,
Stv manu: MARKS CUSTOM STOVES                  2=English:    2.0
Model no: K-400 FREESTANDING                    Y, DGM:      0.971
Tst date: APRIL 10, 1989                       Pb (mm,in. Hg): 30.0
Run no  : 1.0
    
```

NOTE: Input raw data below, use F9 for CALC.

run time (min)	tracer conc (ppm,%)	DGM rdg (m3,ft3)	DGM temp (C,F)	DGM dH (mm H20) (in.H20)	dDGM vol std (m3,ft3)	PR (%)	Sample vol std (m3,ft3)
0	157.5	435.646	72	0.011			
10	195.0	436.650	75	0.007	0.968	107.3	6.215
20	172.5	437.430	77	0.009	0.748	102.6	
30	195.0	438.300	77	0.007	0.831	100.9	
40	165.0	439.030	78	0.010	0.697	95.7	
50	165.0	439.950	80	0.010	0.877	101.8	
60	150.0	440.860	79	0.012	0.865	100.4	
70	157.5	441.780	80	0.011	0.876	92.4	
74	157.5	442.150	80	0.011	0.352	97.4	

NORTHWEST TESTING LABORATORIES  
Woodstove Emission Testing

PAGE 1 - STOVE INFORMATION AND PRE-TEST DATA

Stove Manufacturer: Marks Custom Stoves  
Stove Model: K-300 F5  
Stove I.D. Number: 184  
Run Number: 1  
Date: 4-10-89  
Expected Burn Rate: High

STOVE  
Weight: 502.1 lb.  
Platform Scale Audit?: yes -ok  
Primary Air Control Setting: 100% open  
Blower: On OFF Auto. N/A ✓  
Flue Pipe Gauge: 24  
Flue Pipe Diameter in.: 8 in.  
Pictures: Yes ✓ No \_\_\_\_\_  
Operating Instructions: \_\_\_\_\_  
Stove Manual Verbal Other ✓  
Stack Cleaned: Yes ✓ No \_\_\_\_\_

CATALYST Yes ✓ No \_\_\_\_\_  
Catalyst Brand: Applied Ceramics  
Catalyst I.D.: Firecat 2 1/2 x 7 1/2 x 3 1 lb cell  
Catalyst Age: 50+ hrs.  
Catalyst Provided: Marks Custom Stoves

AMBIENT  
Dry Bulb Reading 77 °F  
Wet Bulb Reading 61 °F  
Relative Humidity 39 %  
Baro. 29.93 in Hg.  
% Moisture 1.3 % Volume

CONTINUOUS ANALYZERS  
Audited by: D. Windsor  
Leak Tested by: P. Winder

PARTICULATE TRAIN  
Probe Length & Type 6" Pyrex  
Nozzle Size 0.62 in.  
# 0.65  
# Magnelic Range, 0-1 in H2O  
Leakage Rate: 0.009 Ft.3/min.

TRACER GAS  
Gas Used: SO2  
Rotameter No.: 601  
Rotameter Rdg.: 60 mm  
Ball Read: Stainless Steel  
CC/Min.: 70.62  
Ft.3/hr. 0.15  
(cc/min. ÷ 472 = Ft3/hr.)  
Injection System Rate  
Checked: Yes: ✓ No: \_\_\_\_\_

SIGNED BY: David Windsor  
DATE: April 10, 1989



PAGE 2 - FUEL DATA

Stove Manufacturer: Marks Custom Stoves Run Number: 1  
 Stove Model: K-400 FS Expected Burn Rate: High  
 Stove I.D. Number: 184 Calculated Charge Wt.: 24.8  
 Technician: D. Windsor Coal Bed Wt. Lbs.: 4.6  
 HHV Sample: Yes  No   
 (Saw Dust Catch & Block)

I. Fuel Moisture Content, % (Dry Basis):

1.	<u>19.2</u>	<u>19.2</u>	<u>19.2</u>	11.	<u>19.8</u>	<u>19.2</u>	<u>19.2</u>	21.	
2.	<u>19.2</u>	<u>19.2</u>	<u>19.2</u>	12.	<u>19.2</u>	<u>19.2</u>	<u>19.8</u>	22.	
3.	<u>19.2</u>	<u>19.2</u>	<u>19.2</u>	13.	<u>19.2</u>	<u>19.2</u>	<u>19.2</u>	23.	
4.	<u>19.2</u>	<u>19.2</u>	<u>19.2</u>	14.				24.	
5.	<u>19.2</u>	<u>19.2</u>	<u>19.2</u>	15.				25.	
6.	<u>19.2</u>	<u>19.2</u>	<u>19.2</u>	16.				26.	
7.	<u>19.8</u>	<u>19.2</u>	<u>19.2</u>	17.				27.	<u>24.8</u> <u>23.7</u> <u>24.3</u>
8.	<u>19.2</u>	<u>19.2</u>	<u>19.2</u>	18.				28.	<u>24.8</u> <u>24.8</u> <u>24.3</u>
9.	<u>19.2</u>	<u>19.2</u>	<u>19.2</u>	19.				29.	<u>24.3</u> <u>24.3</u> <u>24.8</u>
10.	<u>19.2</u>	<u>19.2</u>	<u>19.2</u>	20.				30.	<u>23.7</u> <u>24.8</u> <u>24.3</u>

II. Test Fuel:

1. No. of 2 x 4's: 0 5. Species: DF  
 2. No. of 4 x 4's: 4 6. Moisture Content, % Ave. (Dry Basis): 24.41  
 3. Total No. of Fuel Pieces: # 27-30 7. Length, In.: 20.0  
 4. Weight, Lbs.: 23.0

III. Pre-Burn Fuel:

1. No. of 2 x 4's: 13 5. Species: DF  
 2. No. of 4 x 4's: 0 6. Moisture Content, % Ave. (Dry Basis): 19.35  
 3. Total No. of Fuel Pieces: # 1-13 7. Length, In.: 21 ÷ 3 = 7.0  
 4. Weight, Lbs.: 24.9

IV. Kindling Fuel:

1. No. of 2 x 4's: 0 5. Species: DF  
 2. No. of 4 x 4's: 1 6. Moisture Content, % Ave. (Dry Basis): 19.0  
 3. Total No. of Fuel Pieces: 1 7. Length, In.: 20.0  
 4. Weight, Lbs.: 4.2

Date: 4-13-89

Attention: Mike Cave

Subject: Analysis on one (1) wood fuel sample received 4-10-89.

Item: Wood Fuel

Reference: MARK'S Custom Stoves  
MODEL K-400 FS  
184-1  
high cycle

REPORT:

Analysis:

Moisture, %, as received .....	<u>12.1</u>
Moisture, %, dry basis .....	<u>13.8</u>
Density, g/cm <sup>3</sup> , dry basis .....	<u>0.48</u>
Higher Heat of Combustion, BTU/lb., dry basis .....	<u>8397.6</u>

J.M.Toll

Report Number: 321591

Charges: \$ 70<sup>-</sup>

**WOOD/FUEL**  
(ON NTL STOVE DISK)

PAGE 3 - STOVE OPERATION LOG

Stove Mfg.: Marks Custom Stoves Date: 4-10-89  
Stove Model: K-400 FS Technician: O. Windsor  
Stove I.D. Number: 184  
Run Number: 1

24 Hr. Time

OPERATION

09:43 Ignited 4.2 lbs kindling, Door ajar, By-pass open,  
Drafts 100% open  
09:50 Added 24.9 lbs Preburn, Door ajar, By-pass open  
Drafts 100%  
09:55 Door closed, By-pass closed, Draft 100% open  
10:00 started Preburn Readings  
10:42 Stoked and Added 3.8 lbs Preburn  
10:57 Stoked and Added 6.2 lbs Preburn

Stove Mfg.: Marks Custom Stoves Run Number: 1  
 Stove Model: K-400 FS Date: 4-10-89  
 Stove I.D. No.: 184 Air Control Setting: 100% open

Data Set No.	Elapsed Time 24/Hr.	TEMPERATURES										Fuel Wt/lb	Prim. Temp. (7)	Cat. Temp. (8)	Cat. Temp. (16)
		Amb. (1)	Stove Surfaces			IS(6)	Fuel Wt/lb	Prim. Temp. (7)	Cat. Temp. (8)	Cat. Temp. (16)					
			T(2)	B(3)	R(4)						RS(5)				
1	10:00	62	128	286	354	408	21.6	622	1238	N/A					
2	10:05	63	176	340	417	524	19.1	764	1353						
3	10:10	65	227	395	480	609	16.7	810	1386						
4	10:15	66	162	459	544	667	14.1	966	1405						
5	10:20	67	175	525	604	740	11.7	1140	1333						
6	10:25	68	180	602	667	803	9.6	1057	1281						
7	10:30	70	193	655	712	855	8.0	1148	1424						
8	10:35	70		695	781	887	6.7	1162	1361						
9	10:40	70		723	869	901	5.6	1169	1385						
10	10:45	72		776	875	893	7.8	1042	1274						
11	10:50	74		787	951	933	5.9	1243	1404						
12	10:55	74		824	983	957	4.6	1265	1394						
13	11:00	77		850	937	961	8.6	1177	1261						
14	11:05	74		788	899	899	6.8	1179	1322						
15	11:10	78		789	915	926	5.4	1176	1398						
				Test	Fuel	Added	at 4.6 lbs,								

Range

4.6 to 5.8 lb

< 3.5 lbs added  
at 5.0 lbs

< Add 6.2 lb  
preburn

SIGNED: David Winters DATE: April 10, 1989

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 5 - STOVE TEST DATA

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400 FS  
 Stove I.D. No.: 184  
 Run No.: 1  
 Date: 4-10-89

Date Set No.	24 hr. Time	Test Fuel Wt. Lb.	Amb. (1)	TEMPERATURES					Primary Comb. (7)	Catl. or Secondary Comb. (8)	Catl. or Secondary Comb. (16)	Flue		Dry Gas		Oven Temp. °F (13)	Imp. Temp. °F (14)	Tracer Temp. °F (15)
				Stove Surfaces	R(4)	RS(5)	LS(6)	db (9)				wb (10)	In (11)	Out (12)				
1	0	23.0	75	795	915	922	1140	1407			633	165	70	73	248	32	71	
2	10	18.8	76	669	767	739	803	1329			588	168	75	74	246	32	72	
3	20	15.4	79	642	793	720	925	1435			681	174	80	73	248	32	73	
4	30	11.2	77	748	986	852	1369	1436			604	169	83	71	241	32	74	
5	40	7.5	78	840	1042	951	1325	1468			617	174	85	70	248	32	75	
6	50	4.5	78	987	1037	972	1246	1375			596	165	89	70	244	32	76	
7	60	2.4	80	999	985	977	1274	1273			557	151	88	69	230	32	76	
8	70	0.5	78	965	948	973	1210	1227			540	156	90	69	232	32	77	
9	74		78	953	943	971	1178	1276			546	154	91	69	229	32	77	
		avg	78	844	935	877	1163	1358			596		83	71			75	

SIGNED BY: David A. Wurdson

DATE: April 10, 1989

DT = 14.0  
 Avg SKIn = 938°F

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 6 - PARTICULATE TRAIN OPERATION

Date: 4-10-89  
Expected Burn Rate: High  
Oven Temp. Setting: 548°F  
Tracer Rota, mm: 60  
Tracer Pressure in H<sub>2</sub>O: 0.12

Stove Mfg.: Marks Custom Stoves  
Stove Model: K-400 FS  
Stove I.D. No.: 184  
Run No.: 1

Proportional:

Data Point	24 hr. Time	Elap. Time Δt	SO <sub>2</sub>		CO <sub>2</sub> Scale	CO %	O <sub>2</sub> %	Orifice ΔH In H <sub>2</sub> O	Dry Gas Meter ft <sup>3</sup>	Vacuum in Hg	Stove Static Pressure In H <sub>2</sub> O	Comments
			Scale	ppm								
1	11:13	0	10.5	157.5	66.5	1.1	3.2	0.011	435.646	2.5		
2	11:23	10	13	195	73.5	2.03	0.18	0.007	436.65	2.5		
3	11:33	20	11.5	172.5	73.5	2.32	0.07	0.009	437.43	2.5		
4	11:43	30	13	195	74	2.45	0.10	0.007	438.30	2.5		
5	11:53	40	11	165	73	1.53	1.62	0.010	439.03	2.5		
6	12:03	50	11	165	66	0.20	3.29	0.010	439.95	2.5		
7	12:13	60	10	150	53	0.01	6.85	0.012	440.86	2.5		
8	12:23	70	10.5	157.5	51	0.01	7.38	0.011	441.78	2.5		
9	12:27	74	10.5	157.5	50	0.02	7.64	0.011	442.150	2.5		
10												
11												
12					64.5	0.96		0.010	6.504			
13			Avg		16.13							
14												
15												
16												
17												
18												
19												
20												
21												
22												
23												
24												
25												

SIGNED: David Windsor DATE: April 10, 1989

NORTHWEST TESTING LABORATORIES, INC.  
 Woodstove Emission Testing

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400 FS  
 Stove I.D. No.: 184  
 Run No.: 1  
 Date: 4-10-89

	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:	<del>Pre - Test</del>			
ZERO GAS:	0.0	0.00	N/A	0.0
AUDIT GAS:	59.9	5.01		34.2
DESIRED:	59.9	5.01		34.2
PERCENT DIFFERENCE:	0.0%	0.0%		0.0%
TIME (24 HOUR):	10:17	10:17	↓	10:17

SIGNED: David Wunders  
 DATE: April 10, 1989

NORTHWEST TESTING LABORATORIES  
Woodstove Emmission Testing

PAGE 7 - POST TEST DATA

Stove Mfg.: Marks Custom Stoves Run No.: 1  
 Stove Model: K-400 F5 Date: 4-10-89  
 Stove I.D. No.: 184 Time: 12145

Analyzer Audit

	Scale Readings		
	CO <sub>2</sub>	O <sub>2</sub>	CO
Zero Gas	<u>0.0</u>	<u>N/A</u>	<u>0.00</u>
Audit Gas	<u>60.0</u>	<u>↓</u>	<u>5.03</u>
Desired	<u>59.9</u>	<u>↓</u>	<u>5.01</u>
% Difference	<u>0.2%</u>	<u>↓</u>	<u>0.4%</u>
% Drift Check:			
Zero Drift	<u>0.0%</u>		<u>0.0%</u>
Mid Level Drift	<u>0.1%</u>		<u>0.2%</u>
Leak Test Results	<u>passed</u>		<u>passed</u>

Particulate Train  
 Leakage Rate: 0.007 ft<sup>3</sup>/min.  
 Extra Filters Used: N/A

Ambient

Tdb 79 °F  
 Twb 64 °F  
 Pbaro 29.98 in Hg. 29.955  
 Moisture 1.5 % By Volume 1.4  
 Relative Humidity, % 44

SIGNED: David Windsor DATED: April 10, 1989



SAMPLE EXTRACTION DATA

Stove Mfg.: Marks Custom Stoves Test: 2  
 Stove Model: K-400 FS Test Cycle: High  
 Date: 4-10-89 Stove I.D. No.: 184  
 Technician: D. Windsor

V<sub>v</sub>

CONDENSED WATER VOLUME, GMS

	Modified Temp. 100 ml H <sub>2</sub> O	Standard Imp 100 ml Hz	Modified Imp. Dry	Modified Imp. 200 Gms Silica Gel
Gross Weight	620.9	610.0	487.1	711.6
Initial Weight	563.2	607.8	487.1	704.8
Net Weight	57.7	2.2	0.0	6.8

TOTAL 66.7 GMS

W

PARTICULATE CATCH, GMS

	OVEN FILTER(S)				TRAIN FILTER(S)		TOTAL
Gross Weight	.7934				.7718		
Initial Weight	.7612				.7666		
Net Weight	0.0322				0.0052		

TOTAL 0.0374 GMS

	Front Catch Probe	-Rear Catch Impingers	DCM	H <sub>2</sub> O	TOTAL
	Beaker, ml	45ml	145ml	150ml	
Gross, Weight	94.1006	97.0210	98.7689	95.2346	
Initial Weight	94.0797	96.9716	98.7338	95.2096	
Net Weight	0.0209	0.0494	0.0351	0.0250	
Evaporation	0.0004	0.0013	0.0009	0.0024	
Residue Weight	0.0205	0.0481	0.0342	0.0226	TOTAL

TOTAL 0.1254 GMS

0.0686

0.0568

Particulate Total = 0.1628 gm

162.8 mg



METHOD 5H FLOW RATE (STACK) CALCULATIONS

(Put general info in col B, data info in col H.)

Lab name: NORTHWEST TESTING LABS, INC.      Yhc 1=cat,2=ncat :      1  
 Stv manu: MARKS CUSTOM STOVES              Wc (if supplied) :  
 Model no: K-400 FREESTANDING              Burn rate (kg/hr):      2.57  
 Tst Date: APRIL 11, 1989                  Run Number              :      2

run time (min).					Stack Gas Flow Rate		
	O2 (%)	CO2 (%)	CO (%)	Fo (1.-1.12)	(dscfh)	(dscfm)	(dsm3/hr)
0	5.00	15.00	0.05	1.06	667.47	11.12	18.92
10	4.40	15.50	0.13	1.06			
20	8.90	11.30	0.13	1.06			
30	10.60	9.60	0.10	1.07			
40	12.10	8.30	0.05	1.06			
50	10.90	9.40	0.08	1.06			
60	5.40	14.30	0.60	1.06			
70	1.40	17.40	1.84	1.06			
80	1.90	17.80	0.26	1.06			
90	3.10	16.80	0.15	1.05			
100	4.70	15.30	0.04	1.06			
110	6.80	13.30	0.04	1.06			
120	5.30	14.80	0.02	1.05			
130	6.40	13.60	0.04	1.06			
140	7.40	12.80	0.05	1.05			
150	6.20	13.90	0.06	1.06			
160	7.90	12.30	0.08	1.05			
170	10.40	9.90	0.02	1.06			
180	10.70	9.60	0.03	1.06			
190	11.70	8.60	0.03	1.07			
200	10.80	9.50	0.03	1.06			

Method 5H Proportionality Rate and Sample Volume Calculation  
 (put general info in col. C; Pb,Y,& unit info in col. G)

```

=====
Lab name: NORTHWEST TESTING LAB., INC.           Units 1=metric,
Stv manu: MARKS CUSTOM STOVES                   2=English:    2.0
Model no: K-400 FREESTANDING                     Y, DGM:      0.971
Tst date: APRIL 11, 1989                         Pb (mm,in. Hg): 30.1
Run no : 2.0
    
```

NOTE: Input raw data below, use F9 for CALC.

```

=====
run      tracer      DGM      DGM      DGM dH      dDGM      PR      Sample
time     conc          rdg      temp    (mm H2O)  vol std   (%)     vol std
(min)    (ppm,%) (m3,ft3) (C,F) (in.H2O) (m3,ft3)
-----
0        255.0  442.221  70      0.013
10       255.0  443.350  74      0.013  1.098  108.9  22.167
20       240.0  444.460  77      0.014  1.072  106.3
30       247.0  445.590  78      0.013  1.085  101.3
40       240.0  446.690  79      0.014  1.054  101.3
50       232.0  447.800  78      0.015  1.062  99.1
60       225.0  448.940  77      0.016  1.093  98.6
70       247.5  450.100  76      0.014  1.114  97.5
80       240.0  451.245  76      0.014  1.102  106.0
90       232.5  452.390  76      0.015  1.102  102.8
100      217.5  453.525  76      0.017  1.092  98.7
110      225.0  454.700  76      0.016  1.130  95.6
120      217.5  455.870  76      0.017  1.126  98.5
130      210.0  457.050  76      0.019  1.135  96.0
140      217.0  458.340  76      0.017  1.241  101.3
150      225.0  459.520  76      0.016  1.135  95.8
160      225.0  460.660  76      0.016  1.097  95.9
170      232.0  461.810  76      0.015  1.106  96.8
180      232.0  462.960  77      0.015  1.106  99.8
190      232.0  464.110  77      0.015  1.104  99.6
200      232.0  465.268  77      0.015  1.112  100.3
    
```

NORTHWEST TESTING LABORATORIES  
Woodstove Emission Testing

Stove Manufacturer: Marks Custom Stoves  
 Stove Model: K-400FS  
 Stove I.D. Number: 184  
 Run Number: 2  
 Date: 4-11-89  
 Expected Burn Rate: Med. High

STOVE

Weight: 502.1 lb.  
 Platform Scale Audit?: OK  
 Primary Air Control Setting: 7 1/2 Open  
 Blower: On Off Auto. N/A  
 Flue Pipe Gauge: 24  
 Flue Pipe Diameter in.: 8 in.  
 Pictures: Yes X No     
 Operating Instructions: Written  
 Stove Manual: Verbal Other X  
 Stack Cleaned: Yes X No   

CATALYST

Yes X No     
 Catalyst Brand: Applied Ceramics  
 Catalyst I.D.: Firecat, 1 1/2 x 7 1/2 x 3, 16 cell  
 Catalyst Age: 50+ hrs  
 Catalyst Provided: Marks Custom Stoves

AMBIENT

Dry Bulb Reading 72 °F  
 Wet Bulb Reading 61 °F  
 Relative Humidity 53 %  
 Baro. 30.11 in Hg.

% Moisture 1.4 % Volume   

CONTINUOUS ANALYZERS

Audited by: T. Padman  
 Leak Tested by: T. Padman

PARTICULATE TRAIN

Probe Length & Type 6" Pyrex  
 Nozzle Size .62 in.  
 II Q .65  
 II Magnehelic Range, 0-1 in H<sub>2</sub>O  
 Leakage Rate: .001 Ft. 3/min.

TRACER GAS

Gas Used: SO2  
 Rotameter No.: 601  
 Rotameter Rdg.: 60  
 Ball Read: 55  
 CC/Min.: 70.62  
 ft. 3/hr. .15  
 (cc/min. ÷ 472 = ft. 3/hr.)  
 Injection System Rate  
 Checked: Yes: X No:   

SIGNED BY:

[Signature]

DATE: 4-11-89

PAGE 2 - FUEL DATA

Stove Manufacturer: Marks Custom Stoves Run Number: 2  
 Stove Model: K-400 FS  
 Stove I.D. Number: 184  
 Technician: T. Paterson  
 Expected Burn Rate: Med. High  
 Calculated Charge Wt.: 24.8  
 Coal Bed Wt. Lbs.: 4.6  
 HHV Sample: Yes  No   
 (Saw Dust Catch & Block)

I. Fuel Moisture Content, % (Dry Basis):

1.	19.2	19.2	19.2	11.	19.2	19.2	19.2	21.	
2.	14.2	19.2	14.2	12.	19.2	19.2	19.2	22.	
3.	19.8	19.8	19.8	13.	19.2	19.2	19.2	23.	
4.	19.8	19.8	19.8	14.	19.2	19.2		24.	
5.	19.8	19.2	19.8	15.				25.	
6.	19.8	19.8	20.3	16.				26.	
7.	21	19.8	21	17.				27.	21.5 22.0 23.1
8.	19.8	21	21	18.				28.	21.5 23.1 23.1
9.	22	19.2	19.2	19.				29.	21.5 22.6 19.8
10.	19.2	19.2	19.2	20.				30.	22.6 23.1 24.3

II. Test Fuel:

1. No. of 2 x 4's: 0  
 2. No. of 4 x 4's: 4  
 3. Total No. of Fuel Pieces: #27 → #30  
 4. Weight, Lbs.: 23.1  
 5. Species: D.F.  
 6. Moisture Content, % Ave. (Dry Basis): 22.35  
 7. Length, In.: 20"

III. Pre-Burn Fuel:

1. No. of 2 x 4's: 14  
 2. No. of 4 x 4's: 0  
 3. Total No. of Fuel Pieces: #1 → 146  
 4. Weight, Lbs.: 26.4  
 5. Species: D.F.  
 6. Moisture Content, % Ave. (Dry Basis): 19.65  
 7. Length, In.: 21" ÷ 3 = 7"

IV. Kindling Fuel:

1. No. of 2 x 4's: 0  
 2. No. of 4 x 4's: 1  
 3. Total No. of Fuel Pieces: 1  
 4. Weight, Lbs.: 4.4  
 5. Species: D.F.  
 6. Moisture Content, % Ave. (Dry Basis): 20%  
 7. Length, In.: 20"

Date: 4-20-89

Attention: Mike Cave

Subject: Analysis on one (1) wood fuel sample received 4-11-89.

Item: Wood Fuel

Reference: Mark's Custom Stoves

Model K-4000 FS

1842

REPORT:

Analysis:

Moisture, %, as received .....	<u>20.3</u>
Moisture, %, dry basis .....	<u>25.5</u>
Density, g/cm <sup>3</sup> , dry basis .....	<u>0.55</u>
Higher Heat of Combustion, BTU/lb., dry basis .....	<u>8,028</u>

gmm2

Report Number: 321591

**WOOD/FUEL**  
(ON NTL STOVE DISK)

charges: \$70-

PAGE 3 - STOVE OPERATION LOG

Stove Mfg.: Marks Custom Stoves Date: 4-11-89  
Stove Model: K-400 FS Technician: D. Windsor  
Stove I.D. Number: 184  
Run Number: 2

24 Hr. Time

OPERATION

08:37 Ignited 4.4 lbs kindling Door ajar, By-pass open,  
Drafts 100% open  
08:45 Added #1 Pre-Burn 26.4 lbs, Shut Dampers,  
Set Air at 7/8" open on both sides  
08:50 Started Pre-Burn Readings  
09:32 Stoked Fire  
09:52 Stoked Fire  
10:05 Added 23.1 lbs Test Fuel, Drafts 100% open  
By-pass open  
10:10 closed Door and By-pass; Drafts set at 7/8"



Stove Mfg.: Mark's Custom Stoves Run Number: 2  
 Stove Model: K-400 FS Date: 4-11-89  
 Stove I.D. No.: 184 Air Control Setting: 7/8" open on both sides

Data Set No.	Elapsed Time 24/Hr.	TEMPERATURES										Fuel Wt/lb	Prim. Temp. (7)	Cat. Temp. (8)	Cat. Temp. (16)
		Amb. (1)		Stove Surfaces			LS(6)		Cat. Temp. (16)						
		T(2)	B(3)	R(4)	RS(5)	LS(6)	LS(6)								
1	08:50	63	141	39J	280	447	21.2	527	1155						
2	08:55	63	17J	395	307	472	21.5	560	1188						
3	09:00	63	214	40J	371	570	19.2	624	1187						
4	09:05	64	222	39J	452	530	17.2	647	1227						
5	09:10	66	324	40J	494	542	15.7	658	1244						
6	09:15	67	370	425	539	568	14.7	712	1218						
7	09:20	68	40J	457	611	598	12.9	758	1210						
8	09:25	68	421	473	670	616	11.7	781	1200						
9	09:30	69	432	498	699	639	10.8	781	1225						
10	09:35	69	453	562	700	671	9.1	822	1141						
11	09:40	69	488	58J	71J	701	8.4	895	1164						
12	09:45	68	538	608	730	724	7.6	884	1142						
13	09:50	70	575	616	740	717	7.1	866	1106						
14	09:55	71	608	648	728	716	5.7	876	1130						
15	10:00	72	631	645	722	709	5.1	876	1190						
			Added less fuel					4.6							

4.6 → 5.8

← STOKED

← STOKED

SIGNED: [Signature] DATE: 4-11-89

+ 271 = 1.9  
- 412 = 1.25

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-409 FS  
 Stove I.D. No.: 189  
 Run No.: 2  
 Date: 4-11-89

Data Set No.	24 hr. Time	Test Fuel Wt. lb.	TEMPERATURES								Catal. or Secondary Comb. (8)	Catal. or Secondary Comb. (16)	Flue		Dry Gas		Oven Temp °F (13)	Imp. Temp. °F (14)	Tracer Temp. °F (15)
			Amb. (1)	Stove Surfaces			727.8		Primry Comb. (7)	db (9)			wb (10)	In (11)	Out (12)				
ΔT	I(2)	B(3)	R(4)	RS(5)	TS(6)	(7)	(9)	(10)			(11)	(12)				(13)	(14)	(15)	
1	10:05	27.1	937	641	643	713	709	871	1170	1170	147	69	71	247	52	70			
2	10:15	20.9	816	657	558	564	600	617	1158	1158	153	75	72	246	52	71			
3	10:25	19.6	779	647	488	520	527	570	1142	1142	150	81	72	225	52	71			
4	10:35	18.6	713	611	455	470	492	530	1062	1062	146	84	71	224	52	74			
5	10:45	17.7	667	572	437	463	477	581	985	985	145	87	70	217	52	75			
6	10:55	16.8	624	536	422	455	477	550	1059	1059	145	85	70	241	52	75			
7	11:05	15.2	634	494	427	473	532	714	1192	1192	164	80	72	241	32	71			
8	11:15	13.0	827	467	477	514	642	918	1203	1203	162	80	72	248	32	71			
9	11:25	11.0	926	456	525	619	733	924	1233	1233	162	80	72	248	32	72			
10	11:35	9.2	949	457	561	667	757	895	1215	1215	161	80	71	248	32	72			
11	11:45	7.6	954	460	588	696	828	1315	1206	1206	158	81	70	248	32	72			
12	11:55	6.4	877	453	596	688	812	908	1145	1145	155	81	70	248	32	72			
13	12:05	5.2	862	451	588	690	775	941	1117	1117	155	81	70	248	32	73			
14	12:15	4.1	886	469	581	700	735	881	1125	1125	153	82	70	248	32	73			
15	12:25	3.3	793	500	594	692	706	848	1075	1075	147	81	70	248	52	73			
16	12:35	2.3	793	563	581	673	705	878	1112	1112	145	81	70	248	52	73			
17	12:45	1.5	779	582	598	669	687	806	1099	1099	147	82	70	248	52	73			
18	12:55	1.1	717	588	592	644	658	797	1010	1010	141	82	70	248	32	74			
19	13:05	1.7	677	573	568	621	636	845	969	969	134	82	70	248	52	75			
20	13:15	1.4	648	555	535	609	612	808	920	920	132	85	71	247	52	76			

SIGNED BY: [Signature] DATE: 4-11-89

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 5 - STOVE TEST DATA

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400 FS  
 Stove I.D. No.: 184  
 Run No.: 2  
 Date: 4-11-89

Data Set No.	24 hr. Time	Test Fuel Wt. Lb.	TEMPERATURES					Primary Comb. (7)	Catl. or Secondary Comb. (8)	Catl. or Secondary Comb. (16)	Flue		Dry Gas		Oven Temp. °F	Imp. Temp. °F	Tracer Temp. °F
			Amb. (1)	Stove Surfaces	db	wb	In				Out						
$\Delta T$	F(2)	B(3)	R(4)	RS(5)	IS(6)												
21	13:25	.0	77	624	575	605	597	901			237	127	82	72	246	55	74
		avg	74	784	536	608	652	1098			293		81	71			73

SIGNED BY:

DATE:

$\Delta T = -146.6^\circ F$   
 Avg skin =  $624.4^\circ F$

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 6 - PARTICULATE TRAIN OPERATION

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400 FS  
 Stove I.D. No.: 184  
 Run No.: 2

Date: 4-11-89  
 Expected Burn Rate: Med. High  
 Oven Temp. Setting: 2480F  
 Tracer Rota, mm: 60  
 Tracer Pressure in H<sub>2</sub>O: 1.12

PC = 3


Data Point	24 hr. Time	Elap. Time Δ t	SO2		CO2 Scale	CO %	O2 %	Orifice Δ H In H2O	Dry Gas Meter ft <sup>3</sup>	Vacuum in Hg	Stove Static Pressure In H2O	Comments
			Scale	ppm								
1	10:05	0	17.5	255	60	.05	4.97	.013	442.221	2.5	.075	
2	10:15	10	17	255	62	.17	4.79	.013	447.135	2.5	.080	
3	10:25	20	16	240	45	.13	8.9	.014	444.416	2.5	.075	
4	10:35	30	16.5	247	38.5	.10	10.64	.013	445.579	2.5	.075	
5	10:45	40	16	240	33	.08	12.12	.014	446.67	2.5	.070	
6	10:55	50	15.5	232	37.5	.08	10.91	.015	447.80	2.5	.070	
7	11:05	60	15	225	57	.60	5.43	.016	448.94	2.5	.075	
8	11:15	70	16.5	247.5	69.5	1.84	1.36	.014	450.10	2.5	.080	
9	11:25	80	16	240	71	0.26	1.93	.014	451.245	2.5	.080	
10	11:35	90	15.5	232.5	67	.15	3.05	.015	452.39	2.5	.075	
11	11:45	100	14.5	217.5	61	.04	4.71	.017	453.525	2.5	.075	
12	11:55	110	15	225	53	.04	6.83	.016	454.70	2.5	.070	
13	12:05	120	14.5	217.5	59	.02	5.25	.017	455.87	2.5	.070	
14	12:15	130	14	210	54.5	.04	6.43	.019	457.05	2.5	.070	
15	12:25	140	14.5	217	51	.05	7.35	.017	458.34	2.5	.070	
16	12:35	150	15	225	55.5	.06	6.16	.016	459.52	2.5	.065	
17	12:45	160	15	225	49	.08	7.87	.016	460.66	2.5	.065	
18	12:55	170	15.5	232	49.5	.02	10.42	.015	461.81	2.5	.065	
19	13:05	180	15.5	232	38.5	.05	10.68	.015	462.96	2.5	.060	
20	13:15	190	15.5	232	34.5	.05	11.74	.015	464.11	2.5	.060	
21	13:25	200	15.5	232	38	.07	10.81	.015	465.265	2.5	.055	
22	13:35	210			51.14	0.18		0.015	23.047		0.070	
23	13:45	220			12.79							
24	13:55	230										
25	14:05	246										

SIGNED: [Signature] DATE: 4-11-89

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

Stove Mfg.: Marks Custom Stoves  
 Stove Model: 1C-400 FS  
 Stove I.D. No.: 184  
 Run No.: 2  
 Date: 4-11-89

	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:		PRE-Test Calibration		
ZERO GAS:	0.0	0.0	NA	0.0
AUDIT GAS:	59.9	5.01	}	34.2
DESIRED:	59.9	5.01		34.2
PERCENT DIFFERENCE:	0.0%	0.0%		0.0%
TIME (24 HOUR):	09:30	09:30		09:30

SIGNED:   
 DATE: 4-11-89

NORTHWEST TESTING LABORATORIES, INC.  
 Woodstove Emission Testing

Stove Mfg.: Marks Custom Stoves  
 Stove Model: k-400 FS  
 Stove I.D. No.: 184  
 Run No.: 2  
 Date: 4-11-89

	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:				
	120 min			
ZERO GAS:	0.0	0.00	N/A	.5
AUDIT GAS:	60.0	5.02		35.5
DESIRED:	59.9	5.01		34.2
PERCENT DIFFERENCE:	0.2%	0.2%		2.9%
TIME (24 HOUR):	12:10	12:10	↓	12:10

SIGNED: David Wurdson

DATE: April 11, 1989

NORTHWEST TESTING LABORATORIES  
Woodstove Emission Testing

PAGE 7 - POST TEST DATA

Stove Mfg.: Marks Custom Stoves Run No.: 2  
 Stove Model: K-400FS Date: 4-11-89  
 Stove I.D. No.: 184 Time: 13:46

Analyzer Audit

	CO2	O2	CO	SO2
Zero Gas	<u>0.0</u>	<u>N/A</u>	<u>0.0</u>	<u>0.5</u>
Audit Gas	<u>59.9</u>		<u>5.01</u>	<u>35.0</u>
Desired	<u>59.9</u>		<u>5.01</u>	<u>34.2</u>
% Difference	<u>0.0%</u>		<u>0.0%</u>	<u>5.8%</u>
% Drift Check:			<u>0.0%</u>	<u>0.5%</u>
Zero Drift	<u>0.0%</u>		<u>0.0%</u>	<u>0.8%</u>
Mid Level Drift	<u>0.0%</u>		<u>0.0%</u>	
Leak Test Results	<u>OK</u>			

Particulate Train  
 Leakage Rate: 1001 ft<sup>3</sup>/min.  
 Extra Filters Used: N/A

Ambient

Tdb 77 °F 30.105  
 Twb 64 °F  
 Pbaro 30.10 in Hg. 1.45  
 Moisture 1.45 % By Volume  
 Relative Humidity, % 49

SIGNED: [Signature] DATED: 4-11-89

SAMPLE EXTRACTION DATA

Stove Mfg.: Marks Custom Stoves

Test: 3

Stove Model: K-400 FS

Test Cycle: Low

Date: 4-11-89

Stove I.D. No.: 184

Technician: D Windsor

Vv

CONDENSED WATER VOLUME, GMS

	Modified Temp. 100 ml H2O	Standard Imp 100 ml Hz	Modified Imp. Dry	Modified Imp. 200 Gms Silica Gel
Gross Weight	675.9	609.5	488.0	719.6
Initial Weight	563.3	607.0	486.8	711.9
Net Weight	112.6	2.5	1.2	7.7

TOTAL 124.0 GMS

W

.8012

PARTICULATE CATCH, GMS .7588

4-13-89 08:04

	OVEN FILTER(S)			TRAIN FILTER(S)	
Gross Weight	.7960			.7585	
Initial Weight	.7602			.7545	
Net Weight	0.0358			0.0040	

TOTAL

TOTAL 0.0398 GMS

	Front Catch Probe	Rear Catch Impingers	DCM	H2O
	Beaker, ml	75	160	150
Gross, Weight	102.6355	104.7922	95.4052	101.3562
Initial Weight	102.5950	104.7458	95.3330	101.2889
Net Weight	0.0405	0.0464	0.0722	0.0673
Evaporation	0.0007	0.0014	0.0009	0.0032
Residue Weight	0.0398	0.0450	0.0713	0.0641

TOTAL

TOTAL 0.2202 GMS

0.0848

0.1354

Total Particulate = 0.2600 gm

= 260.0 mg





METHOD 5H FLOW RATE (STACK) CALCULATIONS

(Put general info in col B; data info in col H.)

Lab name: NORTHWEST TESTING LABS, INC.  
 Stv manu: MARKS CUSTOM STOVES  
 Model no: K-400 FREESTANDING  
 Tst Date: APRIL 12, 1989

Yhc 1=cat,2=ncat : 1  
 Wc (if supplied) :  
 Burn rate (kg/hr): 0.98  
 Run Number : 3

run time (min)	Stack Gas Flow Rate						
	O2 (%)	CO2 (%)	CO (%)	Fo (1.-1.12)	(dscfh)	(dscfm)	(dsm3/hr)
0	4.50	14.90	1.06	1.06	267.59	4.46	7.58
10	10.40	9.90	0.02	1.06			
20	9.20	11.00	0.02	1.06			
30	7.90	12.30	0.01	1.06			
40	9.60	10.60	0.01	1.07			
50	9.80	10.50	0.01	1.06			
60	9.40	10.90	0.01	1.05			
70	8.80	11.40	0.01	1.06			
80	9.00	11.30	0.02	1.05			
90	9.80	10.50	0.02	1.06			
100	9.90	10.40	0.02	1.06			
110	10.40	9.90	0.02	1.06			
120	10.20	10.10	0.02	1.06			
130	9.20	11.00	0.02	1.06			
140	7.80	12.40	0.02	1.06			
150	6.40	13.60	0.02	1.07			
160	5.90	14.10	0.02	1.06			
170	6.40	13.60	0.02	1.07			
180	9.10	11.10	0.02	1.06			
190	8.40	11.80	0.02	1.06			
200	7.00	13.10	0.02	1.06			
210	5.90	13.90	0.45	1.06			
220	3.90	15.00	1.75	1.07			
230	4.10	14.90	1.65	1.06			
240	3.10	15.30	2.60	1.07			
250	4.00	15.10	1.45	1.06			
260	4.60	14.60	1.25	1.07			
270	4.50	14.60	1.40	1.07			
280	4.60	14.90	0.90	1.06			
290	6.30	13.80	0.08	1.05			
300	6.70	13.40	0.02	1.06			
310	6.40	13.60	0.02	1.07			
320	6.30	13.82	0.02	1.06			
330	6.70	13.40	0.03	1.06			
340	6.40	13.60	0.03	1.06			
350	7.20	12.90	0.02	1.06			
360	6.80	13.30	0.02	1.06			
370	7.00	13.10	0.02	1.06			
380	7.80	12.40	0.02	1.06			
390	8.30	11.90	0.02	1.06			
400	8.80	11.40	0.02	1.06			
410	9.90	10.40	0.02	1.06			
420	10.60	9.80	0.02	1.05			
430	10.40	9.90	0.02	1.06			
440	10.40	9.90	0.02	1.06			
450	9.90	10.40	0.02	1.06			
460	9.80	10.50	0.02	1.06			

470	9.60	10.60	0.02	1.06
480	9.10	11.10	0.02	1.06
490	8.60	11.60	0.02	1.06
500	9.10	11.10	0.02	1.06
510	8.60	11.60	0.02	1.06
520	9.10	11.10	0.02	1.06
530	9.60	10.60	0.02	1.06
540	9.40	10.90	0.02	1.05
550	9.50	10.80	0.02	1.05
560	8.80	11.40	0.02	1.06
570	9.10	11.10	0.02	1.06
580	9.40	10.90	0.02	1.05

Method 5H Proportionality Rate and Sample Volume Calculation  
 (put general info in col. C; Pb,Y,& unit info in col. G)

```

=====
Lab name: NORTHWEST TESTING LAB., INC.          Units 1=metric,
Stv manu: MARKS CUSTOM STOVES                 2=English:    2.0
Model no: K-400 FREESTANDING                  Y, DGM:      0.971
Tst date: APRIL 12, 1989                     FL (mm, in. Hg): 29.9
Run no  :      3.0
    
```

NOTE: Input raw data below, use F9 for CALC.

run time (min)	tracer conc (ppm,%)	DGM rdg (m3,ft3)	DGM temp (C,F)	DGM dH (mm H2O) (in.H2O)	dDGM vol std (m3,ft3)	PR (%)	Sample vol std (m3,ft3)
0	592.5	465.375	73	0.004			
10	390.0	466.060	76	0.009	0.659	108.8	43.311
20	427.5	466.960	79	0.007	0.861	93.5	
30	382.5	467.770	78	0.009	0.770	91.8	
40	390.0	468.690	77	0.009	0.877	93.4	
50	390.0	469.640	76	0.009	0.907	98.6	
60	420.0	470.600	75	0.008	0.918	99.8	
70	420.0	471.540	74	0.008	0.901	105.4	
80	427.0	472.470	73	0.007	0.893	104.5	
90	427.0	473.270	74	0.007	0.769	91.6	
100	427.0	474.080	74	0.007	0.778	92.5	
110	442.0	474.880	74	0.007	0.768	91.4	
120	457.0	475.660	75	0.006	0.749	92.2	
130	427.0	476.410	75	0.007	0.719	91.5	
140	412.0	477.220	76	0.008	0.776	92.4	
150	412.0	478.150	76	0.008	0.889	102.1	
160	397.0	479.080	76	0.009	0.889	102.1	
170	382.0	480.030	77	0.009	0.908	100.5	
180	405.0	480.970	78	0.008	0.897	95.5	
190	427.0	481.830	78	0.007	0.819	92.5	
200	435.0	482.640	78	0.007	0.772	91.8	
210	435.0	483.440	79	0.007	0.762	92.4	
220	412.0	484.230	79	0.008	0.751	91.1	
230	412.0	485.080	79	0.008	0.808	92.8	
240	405.0	485.930	80	0.008	0.808	92.8	
250	397.0	486.800	80	0.009	0.826	93.2	
260	427.0	487.680	81	0.007	0.835	92.4	
270	442.0	488.490	81	0.007	0.767	91.3	
280	472.0	489.270	81	0.006	0.739	91.0	
290	495.0	490.000	81	0.005	0.692	91.0	
300	487.0	490.700	81	0.006	0.663	91.5	
310	502.0	491.410	81	0.005	0.673	91.3	
320	495.0	492.110	81	0.005	0.663	92.8	
330	510.0	492.830	81	0.005	0.682	94.1	
340	510.0	493.530	81	0.005	0.663	94.3	
350	495.0	494.230	81	0.005	0.663	94.3	
360	487.0	494.940	80	0.006	0.673	92.8	
370	487.0	495.670	80	0.006	0.693	94.0	
380	495.0	496.390	80	0.005	0.683	92.8	
390	517.0	497.150	80	0.005	0.721	99.5	
400	517.0	497.950	80	0.005	0.759	109.4	
410	547.0	498.750	80	0.004	0.759	109.4	
420	562.0	499.510	79	0.004	0.721	110.0	

430	570.0	500.240	79	0.004	0.694	108.7
440	570.0	500.960	79	0.004	0.685	108.8
450	592.0	501.680	78	0.004	0.685	108.8
460	577.0	502.380	78	0.004	0.667	110.0
470	592.0	503.090	78	0.004	0.676	108.8
480	600.0	503.790	78	0.004	0.667	110.0
490	592.0	504.480	78	0.004	0.657	109.9
500	600.0	505.180	77	0.004	0.667	110.0
510	615.0	505.860	78	0.004	0.649	108.5
520	607.0	506.530	77	0.004	0.638	109.4
530	600.0	507.210	78	0.004	0.649	109.8
540	600.0	507.930	77	0.004	0.686	114.7
550	592.0	508.660	77	0.004	0.697	116.5
560	585.0	509.380	76	0.004	0.687	113.4
570	592.0	510.100	76	0.004	0.689	112.3
580	615.0	510.824	76	0.004	0.692	114.2

NORTHWEST TESTING LABORATORIES  
Woodstove Emission Testing

PAGE 1 - STOVE INFORMATION AND PRE-TEST DATA

Stove Manufacturer: Marks Custom Stoves  
Stove Model: K-400 FS  
Stove I.D. Number: 184  
Run Number: 3  
Date: 4-12-89  
Expected Burn Rate: Low

STOVE

Weight: 502.1 lb.  
Platform Scale Audit?: yes - ok  
Primary Air Control Setting: 1/2"  
Blower: On Off Auto. N/A   
Flue Pipe Gauge: 24  
Flue Pipe Diameter In.: 8 In.  
Pictures: Yes  No   
Operating Instructions: Written Letter  
Stove Manual Verbal Other   
Stack Cleaned: Yes  No

CATALYST Yes  No

Catalyst Brand: Applied Ceramics  
Catalyst I.D.: Firecat, 2 1/2 x 7 1/2 x 3, 16 cells  
Catalyst Age: 50+ hrs  
Catalyst provided: Marks Custom Stoves

AMBIENT

Dry Bulb Reading 72 °F  
Wet Bulb Reading 59 °F  
Relative Humidity 46 %  
Baro. 29.98 in Hg.

% Moisture 1.3 % Volume     

CONTINUOUS ANALYZERS

Audited by: D. Windsor  
Leak Tested by: D Windsor

PARTICULATE TRAIN

Probe Length & Type 6" Pyrex  
Nozzle Size 0.62 In.  
# 0.65  
# Magnehelic Range, 0 in H<sub>2</sub>O  
Leakage Rate: 0.000 Ft.<sup>3</sup>/min.

TRACER GAS

Gas Used: SO<sub>2</sub>  
Rotameter No.: 601  
Rotameter Rdg.: 60 mm  
Ball Read: Stainless Steel  
CC/Min.: 70.62  
ft.<sup>3</sup>/hr. 0.15  
(cc/min. ÷ 472 = Ft.<sup>3</sup>/hr.)  
Injection System Rate  
Checked: Yes:  No:

SIGNED BY: David Windsor

DATE: April 12, 1989



Date: 4-20-89

Attention: Mike Cave

Subject: Analysis on one (1) wood fuel sample received 4-12-89.

Item: Wood Fuel

Reference: Mark's Custom Stoves  
Model: K-400 F.S.  
184-3  
Low cycle

REPORT:

Analysis:

Moisture, %, as received .....	<u>21.5</u>
Moisture, %, dry basis .....	<u>27.3</u>
Density, g/cm <sup>3</sup> , dry basis .....	<u>0.47</u>
Higher Heat of Combustion, BTU/lb., dry basis .....	<u>8,304</u>

JMT

Report Number: 321591

**WOOD/FUEL**  
(ON NTL STOVE DISK)

charges: \$70<sup>-</sup>



PAGE 3 - STOVE OPERATION LOG

Stove Mfg.: Marks Custom Stoves Date: 4-12-89  
Stove Model: K-400 FS Technician: D. Windsor  
Stove I.D. Number: 184  
Run Number: 3

24 Hr. Time

OPERATION

08:53 Ignited 4.8 lbs of kindling, Door ajar,  
By-pass open, Drafts 100% open  
09:03 Added 25.5 lbs of Preburn, Door ajar,  
By-pass open, Drafts 100% open  
09:08 Door and By-pass closed  
09:30 set Drafts at 1/8" open  
09:35 Started Preburn Readings  
10:03 Stoked the Fire  
10:35 Test Fuel added, By-pass open, Drafts 100% open  
10:39 Door and By-pass closed  
10:40 Drafts set at 1/8"

Stove Mfg.: Marks Custom Stoves Run Number: 3  
 Stove Model: K-400 FS Date: 4-12-89  
 Stove I.D. No.: 184 Air Control Setting: 1/8"

Data Set No.	Elapsed Time 24/Hr.	TEMPERATURES							Fuel Wt/lb	Prim. Temp. (7)	Cat. Temp. (8)	Cat. Temp. (16)
		Amb. (1)	T(2)	B(3)	R(4)	RS(5)	LS(6)					
1	9:35	69	932	448	563	599	666	10.7	751	1044	N/A	
2	9:40	68	911	473	542	589	618	10.1	707	1036		
3	9:45	68	857	481	523	586	584	9.6	685	1039		
4	9:50	69	816	481	508	589	560	9.0	670	1018		
5	9:55	69	778	480	497	591	539	8.7	646	1019		
6	10:00	70	742	471	489	593	523	8.4	630	1012		
7	10:05	71	693	461	488	616	506	7.6	604	779		
8	10:10	70	718	464	478	581	502	7.0	619	870		
9	10:15	70	737	468	464	559	495	6.5	609	901		
10	10:20	70	737	469	454	544	489	6.2	602	948		
11	10:25	70	731	464	449	534	487	5.9	602	963		
12	10:30	70	732	459	444	528	485	5.6	595	962		
				Test	Fuel	Added	At 5.2					

Range  
5.1 to 6.4

← Stoked

SIGNED: David Windsor DATE: April 12, 1987

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

Stove Mfg.: Marks Custom Stoves  
Stove Model: K-400 FS  
Stove I.D. No.: 184  
Run No.: 3  
Date: 4-12-89

PAGE 5 - STOVE TEST DATA

7454 = 1.25  
7567 = 1.0

Data Set No.	ΔT	24 hr. Time	Test Fuel Wt. Lb.	TEMPERATURES							Catl. or Secondary Comb. (8)	Catl. or Secondary Comb. (16)	Flue		Dry Gas		Oven Temp. °F (13)	Imp. Temp. °F (14)	Tracer Temp. °F (15)
				Amb. (1)	Stove Surfaces			528.0 Surfaces					Primary Comb. (7)	db (9)	wb (10)	In (11)			
				T(2)	B(3)	R(4)	RS(5)	LS(6)											
1	0	10:35	25.6	70	730	457	443	527	483	593	956	179	127	72	74	247	32		
2	10	10:45	23.9	71	640	456	409	459	461	468	924	233	143	77	75	248	33		
3	20	10:55	23.2	70	575	473	351	405	399	416	908	181	136	83	75	248	32		
4	30	11:05	22.5	70	565	452	328	395	375	420	928	182	138	80	75	248	32		
5	40	11:15	21.9	71	552	438	318	406	362	415	868	171	134	78	76	248	32		
6	50	11:25	21.4	71	536	422	310	405	352	406	857	170	131	77	74	248	32		
7	60	11:35	20.8	72	532	409	304	391	345	404	897	167	131	77	72	248	32		
8	70	11:45	20.2	71	541	397	306	385	346	414	926	170	135	78	69	248	32		
9	80	11:55	19.6	72	550	384	307	385	347	414	931	168	134	78	68	247	32		
10	90	12:05	19.1	72	552	376	306	383	347	414	917	167	133	79	68	247	32		
11	100	12:15	18.6	71	550	365	305	378	348	417	906	166	131	79	68	248	32		
12	110	12:25	18.1	71	543	357	304	378	349	414	887	164	129	80	68	248	32		
13	120	12:35	17.6	72	539	352	302	380	348	421	902	166	127	80	69	248	32		
14	130	12:45	17.0	72	542	347	302	387	345	423	921	167	131	81	69	248	32		
15	140	12:55	16.4	72	560	341	302	389	347	432	977	173	134	81	70	248	32		
16	150	13:05	15.7	72	576	335	308	398	356	445	1026	180	137	82	70	248	32		
17	160	13:15	15.0	72	629	330	317	412	370	463	1046	182	137	82	70	248	32		
18	170	13:25	14.1	73	657	330	327	433	393	517	1015	187	138	83	71	240	32		
19	180	13:35	13.5	74	616	342	327	426	402	494	905	175	130	83	72	240	32		
20	190	13:45	13.1	73	587	349	332	420	397	480	895	169	128	83	72	239	32		

SIGNED BY: [Signature] DATE: 4-12-89  
3517 1593 1459

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 5 - STOVE TEST DATA

Stove Mfg.: Marks Custom Stoves  
 Stove Model: C-400 FS  
 Stove I.D. No.: 184  
 Run No.: 3  
 Date: 4-12-89

Date Set No.	ΔT	24 hr. Time	Test Fuel Wt. lb.	TEMPERATURES										Catl. or Secondary Comb. (8)	Catl. or Secondary Comb. (16)	Flue db (9)	Wb (10)	Dry Gas In (11)	Dry Gas Out (12)	Oven Temp °F (13)	Imp. Temp. °F (14)	Tracer Temp. °F (15)
				Amb. (1)	T(2)	B(3)	R(4)	RS(5)	LS(6)	Primary Comb. (7)												
21	200	13:55	12.6	74	583	355	355	355	423	386	475	927		172	129	83	75	259	579	77		
22	210	14:05	12.0	74	585	358	340	388	429	388	486	969		172	130	84	75	240	577	77		
23	220	14:15	11.3	74	633	356	356	404	446	404	577	977		176	135	84	74	214	544	77		
24	230	14:25	10.5	74	644	363	377	422	469	422	584	984		181	137	84	74	242	543	78		
25	240	14:35	9.6	75	652	365	373	432	495	432	547	964		182	138	86	74	244	548	79		
26	250	14:45	8.9	76	671	365	400	527	537	441	537	964		185	138	86	74	244	532	79		
27	260	14:55	8.1	76	682	370	395	516	576	453	580	958		182	134	86	75	247	535	79		
28	270	15:05	7.5	76	674	381	398	520	582	459	582	950		180	132	85	76	246	538	79		
29	280	15:15	6.9	75	661	390	398	522	582	464	594	947		174	128	85	76	245	535	79		
30	290	15:25	6.5	76	646	397	397	522	577	464	594	904		170	122	85	77	246	535	79		
31	300	15:35	6.1	77	612	403	395	514	574	486	577	860		163	119	84	77	241	532	78		
32	310	15:45	5.8	77	599	408	396	519	578	483	578	863		163	119	84	77	240	531	79		
33	320	15:55	5.4	77	585	408	396	523	576	446	570	849		161	117	84	77	226	528	78		
34	330	16:05	5.1	78	576	410	386	516	576	442	567	844		159	117	84	77	225	525	78		
35	340	16:15	4.8	78	570	411	394	510	570	418	560	849		160	117	84	77	227	525	78		
36	350	16:25	4.4	78	565	411	388	507	565	416	563	857		160	117	84	77	227	527	78		
37	360	16:35	4.0	77	561	410	385	484	567	440	567	857		161	118	84	76	227	527	77		
38	370	16:45	3.7	77	563	404	382	478	566	442	566	869		161	118	84	76	227	527	77		
39	380	16:55	3.4	77	564	401	378	475	566	445	570	862		160	115	83	76	228	528	77		
40	390	17:05	3.1	77	555	396	372	471	564	442	564	834		157	112	83	76	222	525	77		

SIGNED BY: [Signature] DATE: 4-12-89  
 1823 12131 7764 7671 9856 8251 11186 18087  
 3379 1684 1512 1560

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 5 - STOVE TEST DATA

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400 FS  
 Stove I.D. No.: 184  
 Run No.: 3  
 Date: 4-12-89

Data Set No.	24 hr. Time	Test Fuel Wt. Lb.	Amb. (1)	TEMPERATURES						Primary Comb. (7)	Catl. or Secondary Comb. (8)	Catl. or Secondary Comb. (16)	Flue		Dry Gas		Oven Temp. °F (13)	Imp. Temp. °F (14)	Tracer Temp. °F (15)
				(2)	B(3)	R(4)	RS(5)	IS(6)	db (9)				wb (10)	In (11)	Out (12)				
41	17:15	2.7	76	538	586	570	467	438	556	796		152	107	83	76	228	36	77	
42	17:25	2.7	77	523	579	564	460	432	551	760		147	104	83	76	228	37	76	
43	17:35	2.6	77	502	569	564	447	422	537	751		143	100	82	75	229	39	76	
44	17:45	2.4	76	484	560	559	434	417	534	710		141	100	82	75	225	41	76	
45	17:55	2.3	77	473	549	558	427	412	529	704		140	100	82	75	226	44	75	
46	18:05	2.1	77	467	539	556	421	410	526	703		138	100	81	74	227	45	75	
47	18:15	2.0	77	464	532	554	419	406	521	705		138	100	82	74	224	46	75	
48	18:25	1.9	77	467	525	553	420	402	520	704		139	100	81	74	223	47	75	
49	18:35	1.7	77	464	519	556	423	397	514	713		138	100	82	73	226	47	75	
50	18:45	1.5	77	470	512	561	427	393	511	728		141	102	82	73	225	51	75	
51	18:55	1.4	78	475	506	565	428	391	507	724		140	102	82	72	224	54	75	
52	19:05	1.2	77	474	499	567	424	386	502	720		141	102	83	72	224	54	75	
53	19:15	1.0	78	471	491	568	418	388	505	714		141	100	82	72	226	56	75	
54	19:25	.9	78	466	485	566	414	390	501	709		141	99	82	72	226	57	75	
55	19:35	.7	77	461	482	570	410	389	500	699		137	98	81	72	225	58	74	
56	19:45	.5	77	457	477	574	405	384	490	693		137	98	81	72	225	59	74	
57	19:55	.2	77	463	476	581	405	381	494	740		133	102	80	72	224	61	74	
58	19:05	.2	77	469	474	572	408	380	475	749		140	104	80	71	224	61	72	
59	19:15	1.0	76	469	472	598	409	379	492	731		138	100	80	71	223	63	72	
		avg	75	555	365	359	432	404	505	854		162		82	73			75	

SIGNED BY: [Signature] DATE: 4-12-89

DT = -142.6°F  
 Avg Skim = 423°F

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 6 - PARTICULATE TRAIN OPERATION

Date: 4-12-89  
Expected Burn Rate: Low  
Oven Temp. Setting: 248°F  
Tracer Rota, nm: 60  
Tracer Pressure in H<sub>2</sub>O: 0.12

Stove Mfg.: Marks Custom Stoves  
Stove Model: K-400 FS  
Stove I.D. No.: 184  
Run No.: 3

Proportional: 5

Data Point	24 hr. Time	Elap. Time Δt	SO <sub>2</sub>		CO <sub>2</sub> Scale	CO %	O <sub>2</sub> %	Drifrice ΔH In H <sub>2</sub> O	Dry Gas Meter ft <sup>3</sup>	Vacuum in Hg	Stove Static Pressure In H <sub>2</sub> O	Comments
			Scale	ppm								
1	10:35	0	39.5	592.5	59.5	1.06	4.49	0.004	465.375	2.5	0.045	
2	10:45	10	26	390	39.5	0.02	10.42	0.009	466.06	2.5	0.050	
3	10:55	20	28.5	427.5	44	0.02	9.22	0.007	466.96	2.5	0.050	
4	11:05	30	25.5	382.5	49	0.01	7.91	0.009	467.77	2.5	0.045	
5	11:15	40	26	390	42.5	0.01	7.63	0.009	468.69	2.5	0.045	
6	11:25	50	26	390	42	0.01	7.76	0.009	469.64	2.5	0.045	
7	11:35	60	28	420	43.5	0.01	7.17	0.008	470.60	2.5	0.045	
8	11:45	70	28	420	45.5	0.01	8.84	0.008	471.54	2.5	0.045	
9	11:55	80	28.5	427	45	0.02	8.96	0.007	472.47	2.5	0.045	
10	12:05	90	28.5	427	42	0.02	9.76	0.007	473.27	2.5	0.040	
11	12:15	100	28.5	427	41.5	0.02	9.89	0.007	474.08	2.5	0.040	
12	12:25	110	29.5	442	39.5	0.02	10.42	0.007	474.88	2.5	0.040	
13	12:35	120	30.5	457	40.5	0.02	10.16	0.006	475.66	2.5	0.040	
14	12:45	130	28.5	427	44	0.02	9.23	0.007	476.41	2.5	0.045	
15	12:55	140	27.5	412	49.5	0.02	7.77	0.008	477.22	2.5	0.045	
16	13:05	150	27.5	412	54.5	0.02	6.45	0.008	478.15	2.5	0.045	
17	13:15	160	26.5	397	56.5	0.02	5.92	0.009	479.08	2.5	0.045	
18	13:25	170	25.5	382	54.5	0.02	6.45	0.009	480.03	2.5	0.045	
19	13:35	180	27	405	44.5	0.02	9.1	0.008	480.97	2.5	0.040	
20	13:45	190	28.5	427	47	0.02	8.43	0.007	481.83	2.5	0.040	
21	13:55	200	29	435	52.5	0.02	6.98	0.007	482.64	2.5	0.035	
22	14:05	210	29	435	55.5	0.02	5.92	0.007	483.44	2.5	0.040	
23	14:15	220	27.5	412	60	1.75	3.93	0.008	484.23	2.5	0.040	
24	14:25	230	27.5	412	59.5	1.65	4.13	0.008	485.08	2.5	0.040	
25	14:35	240	27	405	61	2.6	3.15	0.008	485.93	2.5	0.040	

SIGNED: [Signature] DATE: 4-12-89 1.07

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 6 - PARTICULATE TRAIN OPERATION

Stove Mfg.: Mark's Cast Iron Stoves  
Stove Model: K-400 FS  
Stove I.D. No.: 184  
Run No.: 5

Date: 4-12-87  
Expected Burn Rate: 1000  
Oven Temp. Setting: 2480F  
Tracer Rota, mm: 60  
Tracer Pressure in H<sub>2</sub>O: 1.12

Data Point	24 hr. Time	Elap. Time Δt	SO <sub>2</sub>		CO <sub>2</sub> Scale	CO %	O <sub>2</sub> %	Orifice ΔH In H <sub>2</sub> O	Dry Gas Meter ft <sup>3</sup>	Vacuum in Hg	Stove Static Pressure In H <sub>2</sub> O	Comments
			Scale	ppm								
1	14:45	250	86.5	197	60.5	1.45	9.98	1.009	486.80	1.5	0.40	
2	14:55	260	88.5	427	58.5	1.25	4.64	1.007	487.68	1.5	0.40	
3	15:05	270	89.5	442	58.5	1.40	4.54	1.007	488.69	1.5	0.40	
4	15:15	280	91.5	472	59.5	.90	4.58	1.006	489.27	1.5	0.35	
5	15:25	290	93	495	55	1.08	6.28	1.005	490.00	1.5	0.30	
6	15:35	300	92.5	487	53.5	1.02	6.71	1.006	490.70	1.5	0.30	
7	15:45	310	93.5	502	54.5	1.02	6.45	1.005	491.41	1.5	0.30	
8	15:55	320	93	495	55	1.02	6.81	1.005	492.11	1.5	0.30	
9	16:05	330	94	570	53.5	1.03	6.7	1.005	492.83	1.5	0.30	
10	16:15	340	94	570	54.5	1.03	6.44	1.005	493.53	1.5	0.30	
11	16:25	350	93	495	57.5	1.02	7.24	1.005	494.23	1.5	0.30	
12	16:35	360	92.5	487	53	1.02	6.24	1.006	494.94	1.5	0.30	
13	16:45	370	92.5	487	52.5	1.02	6.98	1.006	495.67	1.5	0.30	
14	16:55	380	93	495	49.5	1.02	7.77	1.005	496.39	1.5	0.25	
15	17:05	390	94.5	577	47.5	1.02	8.3	1.005	497.15	1.5	0.25	
16	17:15	400	94.5	577	45.5	1.02	8.83	1.005	497.95	1.5	0.25	
17	17:25	410	96.5	547	41.5	1.02	9.89	1.004	498.75	1.5	0.25	
18	17:35	420	97.5	532	39	1.02	10.55	1.004	499.57	1.5	0.25	
19	17:45	430	98	570	39.5	1.02	10.42	1.004	500.24	1.5	0.20	
20	17:55	440	98	570	39.5	1.02	10.12	1.004	500.96	1.5	0.20	
21	18:05	450	99.5	592	41.5	1.02	9.89	1.004	501.68	1.5	0.20	
22	18:15	460	98.5	577	42	1.02	9.76	1.004	502.38	1.5	0.20	
23	18:25	470	99.5	592	42.5	1.02	9.63	1.004	503.09	1.5	0.20	
24	18:35	480	90	600	44.5	1.02	9.10	1.004	503.79	1.5	0.20	
25	18:45	490	99.5	592	46.5	1.02	8.57	1.004	504.48	1.5	0.20	

SIGNED: [Signature] DATE: 4-12-87

1.705

1239

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 6 - PARTICULATE TRAIN OPERATION

Stove Mfg.: Marks Cast Iron Stove Date: 4-12-89  
 Stove Model: K-400 FS Expected Burn Rate: 4000  
 Stove I.D. No.: 184 Oven Temp. Setting: 2480F  
 Run No.: 3 Tracer Rota, mm: 60  
 Tracer Pressure in H<sub>2</sub>O: 1.2

Data Point	24 hr. Time	Elap. Time Δt	SO2		CO2 Scale	CO %	O2 %	Orifice ΔH In H2O	Dry Gas Meter ft 3	Vacuum in Hg	Stove Static Pressure In H2O	Comments
			Scale	ppm								
1	18:55	500	40	620	44.5	.02	9.10	.004	505.18	5.5	.020	
2	19:05	570	41	615	46.5	.02	8.57	.004	505.86	5.5	.020	
3	19:15	520	40.5	607	44.5	.02	9.10	.004	506.55	5.5	.020	
4	19:25	530	40	600	42.5	.02	9.63	.004	506.21	5.5	.020	
5	19:35	540	40	600	43.5	.02	9.36	.004	507.93	5.5	.020	
6	19:45	550	39	572	43	.02	9.49	.004	508.66	5.5	.020	
7	19:55	560	38.5	585	45.5	.02	8.83	.004	509.58	5.5	.020	
8	20:05	570	39	590	44.5	.02	9.10	.004	510.10	5.5	.020	
9	20:15	580	41	615	41.5	.02	9.36	.004	510.82	5.5	.020	
10					39.8							
11												
12												
13			avg		48.3	0.23		0.006	45.449		-0.033	
14			0		12.08							
15												
16												
17												
18												
19												
20												
21												
22												
23												
24												
25												

SIGNED: [Signature] DATE: 4-12-89



NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K - 400 FS  
 Stove I.D. No.: 184  
 Run No.: 3  
 Date: 4-12-89


	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:	<u>Pre-Test</u>			
ZERO GAS:	0.0	0.00	N/A	0.0
AUDIT GAS:	59.9	5.01		34.2
DESIRED:	59.9	5.01		34.2
PERCENT DIFFERENCE:	0.0%	0.0%		0.0%
TIME (24 HOUR):	09115	09115	↓	09115

SIGNED: David Windsor  
 DATE: April 12, 1989

NORTHWEST TESTING LABORATORIES, INC.  
 Woodstove Emission Testing

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400 FS  
 Stove I.D. No.: 184  
 Run No.: 3  
 Date: 4-12-89


	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:		120' w/ w <sub>1</sub>		
ZERO GAS:	0.0	0.0	N/A	0.5
AUDIT GAS:	60.1	5.03	}	34.8
DESIRED:	59.9	5.01		34.2
PERCENT DIFFERENCE:	0.33%	0.4%	✓	3.2%
TIME (24 HOUR):	12:35	12:35		12:35

SIGNED:   
 DATE: 4-12-89

NORTHWEST TESTING LABORATORIES, INC.  
 Woodstove Emission Testing

Stove Mfg.: Mark's Custom Stoves  
 Stove Model: K-400FS  
 Stove I.D. No.: 184  
 Run No.: 3  
 Date: 4-12-89


	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:		240	min.	
ZERO GAS:	0.0	0.0	NA	0.5
AUDIT GAS:	60.1	5.03	}	34.8
DESIRED:	59.9	5.01		34.2
PERCENT DIFFERENCE:	0.33%	0.42%	↓	3.2%
TIME (24 HOUR):	14:35	14:35		14:35

SIGNED:   
 DATE: 4-12-89

NORTHWEST TESTING LABORATORIES, INC.  
 Woodstove Emission Testing

Stove Mfg.: Mark's Custom Stoves  
 Stove Model: K-400 FS  
 Stove I.D. No.: 184  
 Run No.: 7  
 Date: 4-12-89


	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:		360 min		
ZERO GAS:	0.0	0.0	NA	0.5
AUDIT GAS:	60.1	5.03	}	34.8
DESIRED:	59.9	5.01		34.2
PERCENT DIFFERENCE:	0.33%	0.4%		3.2%
TIME (24 HOUR):	16:35	16:35		16:35

SIGNED:   
 DATE: 4-12-89

NORTHWEST TESTING LABORATORIES, INC.  
 Woodstove Emission Testing

Stove Mfg.: Mark-Craft Stoves  
 Stove Model: K-400 FS  
 Stove I.D. No.: 184  
 Run No.: 3  
 Date: 4-12-89

	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:		480mic		
ZERO GAS:	0.0	0.0	N/A	0.5
AUDIT GAS:	60.1	5.03	}	34.8
DESIRED:	59.9	5.01		34.2
PERCENT DIFFERENCE:	0.33%	0.4%	↓	3.2%
TIME (24 HOUR):	18:35	18:35		18:35

SIGNED:   
 DATE: 4-12-89

NORTHWEST TESTING LABORATORIES  
Woodstove Emission Testing

PAGE 7 - POST TEST DATA

Stove Mfg.: Marks Custom Stoves Run No.: 3  
 Stove Model: K-400 FS Date: 4-12-87  
 Stove I.D. No.: 184 Time: 20:30

Analyzer Audit

particulate Train  
 Leakage Rate: .001 ft<sup>3</sup>/min.  
 Extra Filters Used: NA

	Scale Readings		
	O <sub>2</sub>	CO	SO <sub>2</sub>
Zero Gas	<u>NA</u>	<u>0.0</u>	<u>0.5</u>
Audit Gas	<u>60.1</u>	<u>5.03</u>	<u>54.8</u>
Desired	<u>57.9</u>	<u>5.01</u>	<u>34.2</u>
% Difference	<u>0.35%</u>	<u>0.4%</u>	<u>3.8%</u>
% Drift Check:			
Zero Drift	<u>0.0%</u>	<u>0.0%</u>	<u>0.5%</u>
Mid Level Drift	<u>0.2%</u>	<u>0.2%</u>	<u>0.6%</u>
Leak Test Results	<u>OK</u>		

Ambient  
 Tdb 78 °F  
 Twb 63 °F  
 Pbaro 29.87 in Hg.  
 Moisture 1.4 % By Volume  
 Relative Humidity, % 43

SIGNED: [Signature] DATED: 4-12-87

SAMPLE EXTRACTION DATA

Stove Mfg.: Marks Custom Stoves Test: 4  
 Stove Model: K-400 FS Test Cycle: Medium Low  
 Date: 4-13-89 Stove I.D. No.: 184  
 Technician: D. Windsor

Vv

CONDENSED WATER VOLUME, GMS

	Modified Temp. 100 ml H2O	Standard Imp 100 ml Hz	Modified Imp. Dry	Modified Imp. 200 Gms Silica Gel
Gross Weight	683.8	610.2	487.1	728.0
Initial Weight	563.9	607.9	487.0	719.1
Net Weight	119.9	2.3	0.1	8.9

TOTAL 131.2 GMS

W

PARTICULATE CATCH, GMS

	OVEN FILTER(S)				TRAIN FILTER(S)		TOTAL
Gross Weight	.7945				.7602		
Initial Weight	.7634				.7583		
Net Weight	0.0311				0.0019		

TOTAL 0.0330 GMS

Beaker #3

	Front Catch Probe	Rear Catch Impingers	DCM	H2O	TOTAL
	Beaker, ml	75 ml	160	150	
Gross, Weight	99.4839	92.4401	97.0400	98.3263	
Initial Weight	99.4555	92.3884	96.9969	98.2808	
Net Weight	0.0284	0.0517	0.0431	0.0455	
Evaporation	0.0007	0.0014	0.0009	0.0031	
Residue Weight	0.0277	0.0503	0.0422	0.0424	

TOTAL 0.1626 GMS

0.0780

0.0846

Total Particulate = 0.1956 gm  
 = 195.6 mg





METHOD 5H FLOW RATE (STACK) CALCULATIONS

(Put general info in col B, data info in col H.)

Lab name: NORTHWEST TESTING LABS, INC.  
 Stv manu: MARKS CUSTOM STOVES  
 Model no: K-400 FREESTANDING  
 Tst Date: APRIL 13, 1989

Yhc 1=cat,2=ncat : 1  
 Wc (if supplied) :  
 Burn rate (kg/hr): 0.88  
 Run Number : 4

run time (min)	O2 (%)	CO2 (%)	CO (%)	Fo (1.-1.12)	Stack Gas Flow Rate		
					(dscfh)	(dscfm)	(dsm3/hr)
0	6.60	13.50	0.01	1.06	243.64	4.06	6.91
10	12.70	7.80	0.01	1.05			
20	13.10	7.40	0.01	1.05			
30	9.90	10.40	0.01	1.06			
40	9.10	11.10	0.01	1.06			
50	12.40	8.00	0.01	1.06			
60	11.40	9.00	0.01	1.05			
70	11.00	9.40	0.01	1.05			
80	8.40	11.80	0.01	1.06			
90	7.50	12.60	0.01	1.06			
100	6.30	13.80	0.01	1.06			
110	8.20	12.00	0.01	1.06			
120	7.90	12.30	0.01	1.06			
130	7.40	12.80	0.01	1.05			
140	6.60	13.50	0.01	1.06			
150	6.80	13.30	0.02	1.06			
160	6.30	13.80	0.02	1.06			
170	5.70	14.40	0.02	1.05			
180	5.10	14.90	0.02	1.06			
190	5.00	15.00	0.02	1.06			
200	4.30	15.60	0.02	1.06			
210	3.00	16.80	0.20	1.06			
220	0.80	17.10	3.15	1.07			
230	1.80	17.40	1.15	1.06			
240	1.80	17.50	0.91	1.06			
250	2.10	17.30	0.87	1.06			
260	2.20	17.40	0.47	1.06			
270	2.10	17.00	1.20	1.07			
280	5.00	15.00	0.02	1.06			
290	6.50	13.60	0.01	1.06			
300	6.60	13.50	0.01	1.06			
310	6.30	13.80	0.01	1.06			
320	7.10	13.00	0.01	1.06			
330	7.10	13.00	0.01	1.06			
340	6.80	13.30	0.02	1.06			
350	6.70	13.40	0.01	1.06			
360	7.10	13.00	0.01	1.06			
370	7.40	12.80	0.02	1.05			
380	7.20	12.90	0.01	1.06			
390	7.40	12.80	0.02	1.05			
400	7.90	12.30	0.01	1.06			
410	9.20	11.00	0.01	1.06			
420	9.50	10.80	0.02	1.05			
430	9.50	10.80	0.01	1.06			
440	9.90	10.40	0.02	1.06			
450	10.30	10.00	0.02	1.06			
460	10.20	10.10	0.01	1.06			

470	10.30	10.00	0.01	1.06
480	10.30	10.00	0.01	1.06
490	11.10	9.30	0.01	1.05
500	10.80	9.50	0.01	1.06
510	10.80	9.50	0.01	1.06
520	10.80	9.50	0.02	1.06
530	11.00	9.40	0.01	1.05
540	11.40	9.00	0.01	1.05
550	11.40	9.00	0.01	1.05
560	11.90	8.50	0.01	1.06
570	11.00	9.40	0.01	1.05
580	11.90	8.50	0.01	1.06
590	12.10	8.30	0.01	1.06
600	12.70	7.80	0.01	1.05
610	12.90	7.50	0.01	1.07

Method 5H Proportionality Rate and Sample Volume Calculation  
 (put general info in col. C; Pb,Y,& unit info in col. G)

```

=====
Lab name: NORTHWEST TESTING LAB., INC.      Units 1=metric,
Stv manu: MARKS CUSTOM STOVES              2=Englsh:    2.0
Model no: K-400 FREESTANDING                Y, DGM:    0.971
Tst date: APRIL 13, 1969                   Pb (mm,in. Hg): 29.8
Run no : 4.0
    
```

NOTE: Input raw data below, use F9 for CALC.

```

-----
run   tracer   DGM   DGM   DGM   dDGM   PR   Sample
time  conc      rdg   temp  dH     vol std  (%)  vol std
(min) (ppm,%) (m3,ft3) (C,F) (in.H2O) (m3,ft3)
    0   465.0  510.959   77   0.006
   10   412.0  511.830   80   0.008   0.829   98.2   51.453
   20   435.0  512.830   81   0.007   0.946   99.4
   30   487.0  513.710   80   0.006   0.831   92.2
   40   450.0  514.560   79   0.007   0.804   99.8
   50   450.0  515.500   78   0.007   0.891  102.2
   60   502.0  516.440   78   0.005   0.893  102.4
   70   495.0  517.270   77   0.005   0.788  100.9
   80   502.0  518.100   77   0.005   0.790   99.6
   90   480.0  518.950   77   0.006   0.809  103.5
  100   465.0  519.810   77   0.006   0.818  100.1
  110   412.0  520.680   77   0.008   0.780   92.5
  120   450.0  521.540   76   0.007   0.866   90.9
  130   450.0  522.410   76   0.007   0.829   95.1
  140   480.0  523.280   76   0.006   0.829   95.1
  150   450.0  524.150   76   0.007   0.829  101.5
  160   442.0  525.010   76   0.007   0.820   94.0
  170   442.0  525.880   76   0.007   0.829   93.4
  180   420.0  526.770   77   0.008   0.848   95.6
  190   442.0  527.660   77   0.007   0.847   90.7
  200   457.0  528.540   79   0.006   0.837   94.3
  210   427.0  529.430   79   0.007   0.844   98.3
  220   427.0  530.320   80   0.007   0.844   91.8
  230   427.0  531.210   80   0.007   0.842   91.7
  240   435.0  532.100   80   0.008   0.842   91.7
  250   435.0  532.980   80   0.007   0.833   92.3
  260   435.0  533.850   79   0.007   0.823   91.3
  270   405.0  534.720   79   0.008   0.825   91.4
  280   420.0  535.640   79   0.008   0.872   90.0
  290   435.0  536.530   79   0.007   0.844   90.3
  300   435.0  537.420   78   0.007   0.844   93.5
  310   450.0  538.300   79   0.007   0.836   92.7
  320   450.0  539.190   78   0.007   0.844   96.8
  330   465.0  540.080   78   0.006   0.845   97.0
  340   465.0  540.970   77   0.006   0.845  100.2
  350   465.0  541.850   77   0.006   0.837   99.2
  360   472.5  542.760   76   0.006   0.866  102.6
  370   465.0  543.640   76   0.006   0.839  101.0
  380   465.0  544.520   76   0.006   0.839   99.4
  390   472.5  545.410   75   0.006   0.848  100.6
  400   465.0  546.290   75   0.006   0.840  101.2
  410   450.0  547.180   74   0.007   0.850  100.7
  420   465.0  548.070   75   0.006   0.852   97.7
    
```

430	480.0	548.960	74	0.006	0.850	100.7
440	480.0	549.850	73	0.006	0.852	104.2
450	495.0	550.740	73	0.005	0.853	104.4
460	495.0	551.630	73	0.005	0.853	107.6
470	510.0	552.520	73	0.005	0.853	107.6
480	510.0	553.410	72	0.005	0.853	110.9
490	510.0	554.290	72	0.005	0.845	109.9
500	525.0	555.190	72	0.005	0.864	112.4
510	525.0	556.080	71	0.005	0.855	114.4
520	510.0	556.970	71	0.005	0.856	114.6
530	510.0	557.860	71	0.005	0.856	111.3
540	495.0	558.750	73	0.005	0.856	111.3
550	495.0	559.630	74	0.005	0.844	106.4
560	495.0	560.520	75	0.005	0.852	107.4
570	487.5	561.400	76	0.005	0.840	106.0
580	480.0	562.320	75	0.005	0.877	109.0
590	480.0	563.180	74	0.005	0.821	100.5
600	480.0	564.060	74	0.005	0.842	103.0
610	495.0	564.960	74	0.005	0.861	105.4

**NORTHWEST TESTING LABORATORIES**  
Woodstove Emission Testing

PAGE 1 - STOVE INFORMATION AND PRE-TEST DATA

Stove Manufacturer: Marks Custom Stoves  
 Stove Model: K-400 ES  
 Stove I.D. Number: 4-189  
 Run Number: 4  
 Date: 4-13-89  
 Expected Burn Rate: Med. Low

STOVE

Weight: 502.1 lb.  
 Platform Scale Audit?: OK  
 Primary Air Control Setting: 3/16" open <sup>Boiler Sides</sup>  
 Blower: On Off Auto. N/A   
 Flue Pipe Gauge: 24 in.  
 Flue Pipe Diameter in.: 8 in.  
 Pictures: Yes  No   
 Operating Instructions: Verbal  Other  <sup>written</sup>  
 Stove Manual Yes  No   
 Stack Cleaned: Yes  No

CATALYST

Yes  No   
 Catalyst Brand: Applied Ceramics  
 Catalyst I.D.: Firecat 2 1/2 x 7 1/2 x 3, 16 cell  
 Catalyst Age: 50+ yrs.  
 Catalyst Provided: Marks Custom Stoves

AMBIENT

Dry Bulb Reading 74 °F  
 Wet Bulb Reading 62 °F  
 Relative Humidity 51 %  
 Baro. 29.84 in Hg.  
 Moisture 1.4 % Volume

CONTINUOUS ANALYZERS

Audited by: T. Palmer  
 Leak Tested by: T. Palmer

PARTICULATE TRAIN

Probe Length & Type 6" Pyrex  
 Nozzle Size .62 in.  
 ID .65  
 Magnehelic Range, 0-1 in H<sub>2</sub>O  
 Leakage Rate: 0.012 Ft.<sup>3</sup>/min.

TRACER GAS

Gas Used: SO<sub>2</sub>  
 Rotameter No.: 601  
 Rotameter Rdg.: 60  
 Ball Read: 55  
 CC/Min.: 70.62  
 Ft.<sup>3</sup>/hr. 115  
 (cc/min. ÷ 472 = ft<sup>3</sup>/hr.)  
 Injection System Rate  
 Checked: Yes  No

SIGNED BY:

DATE:

T. Palmer  
4-13-89



Date: 4-20-89

Attention: Mike Cave

Subject: Analysis on one (1) wood fuel sample received 4-13-89.

Item: Wood Fuel

Reference: Mark's Custom Stoves  
Model: K-400 F.S.  
184-4  
Medium Low

REPORT:

Analysis:

Moisture, %, as received .....	<u>18.5</u>
Moisture, %, dry basis .....	<u>22.7</u>
Density, g/cm <sup>3</sup> , dry basis .....	<u>0.49</u>
Higher Heat of Combustion, BTU/lb., dry basis .....	<u>9579</u>

JMT / RWH

Report Number: 321591

**WOOD/FUEL**  
(ON NTL STOVE DISK)

0800 charges \$170

PAGE 3 - STOVE OPERATION LOG

Stove Mfg.: Marks Cast Iron Stove Date: 4-13-89  
Stove Model: K-400 FS Technician: T. Palmer  
Stove I.D. Number: 184  
Run Number: 4

24 Hr. Time

OPERATION

08:45 Lit 4.1 lbs of Kindling, Door ajar  
Air controls 100% open  
08:50 Shut Door  
8:55 Added #1 Pine-Burner 25.0 lbs  
09:00 Shut Damper  
09:15 Set Air Controls at 3/16" open  
09:20 Started Pine-Burner Readings  
09:37 Stoked Fire  
09:52 Stoked Fire  
10:17 Stoked Fire  
11:10 Added Test Fuel 24.5 lbs  
Air + By-Pass 100% open  
11:02 Shut Door  
11:03 Closed By-Pass + set air 3/16" open



Stove Mfg.: Mark's Custom Stoves Run Number: 4  
 Stove Model: K-400FS Date: 4-13-89  
 Stove I.D. No.: 184 Air Control Setting: 3/16" open

4.9 → 6.1  
 ← STOKED  
 ← STOKED  
 ← STOKED

Data Set No.	Elapsed Time 24/Hr.	TEMPERATURES										Fuel Wt/lb	Prim. Temp. (7)	Cat. Temp. (8)	Cat. Temp. (16)
		Amb. (1)	Stove Surfaces					IS(6)							
			T(2)	B(3)	R(4)	RS(5)	IS(6)								
1	09:20	68	870	348	472	588	522	15.8	629	1105					
2	09:25	69	814	373	468	578	505	15.2	608	1084					
3	09:30	70	771	384	462	572	483	14.8	557	1034					
4	09:35	69	719	382	453	591	466	14.4	543	1021					
5	09:40	70	687	371	462	593	451	13.6	581	884					
6	09:45	70	707	370	455	562	449	13.1	560	934					
7	09:50	70	714	374	449	540	446	12.6	566	1039					
8	09:55	70	713	380	440	520	446	12.2	551	1022					
9	10:00	71	684	382	494	544	496	10.8	634	830					
10	10:05	71	670	392	481	500	471	10.1	627	899					
11	10:10	71	687	396	473	507	485	9.7	608	938					
12	10:15	71	675	391	470	505	487	9.7	612	983					
13	10:20	72	679	384	483	546	528	8.2	661	829					
14	10:25	71	676	391	480	545	572	7.7	622	874					
15	10:30	71	710	400	473	544	679	7.3	633	911					
16	10:35	72	725	406	467	537	492	6.9	609	919					
17	10:40	72	734	406	462	531	491	6.5	607	936					
18	10:45	71	730	406	460	524	490	6.2	610	1002					
19	10:50	72	711	402	455	574	485	6.0	582	963					
20	10:55	72	676	399	447	500	475	5.9	577	943					
21	11:00	72	654	399	440	490	466	5.8	572	925					
22	11:05	71	632	401	433	482	458	5.6	568	907					
							Test Fuel Added at	5.4 lbs.							

SIGNED: D. S. Ferguson DATE: 4-13-89

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400 FS  
 Stove I.D. No.: 184  
 Run No.: 4  
 Date: 4-13-89

BT = 479 °F  
 ET = °F  
 -T = °F

Data Set No.	ΔT	24 hr. Time	Test Fuel Wt., lb.	TEMPERATURES				Primary Comb. (7)	Catl. or Secondary Comb. (8)	Catl. or Secondary Comb. (16)	Flue		Dry Gas		Oven Temp °F (13)	Imp. Temp. °F (14)	Tracer Temp. °F (15)	
				Amb. (1)	'Stove Surfaces' (2) (3) (4) (5) (6)	478, 8 (7) (8) (9)	db (9)				wb (10)	In (11)	Out (12)					
1	0	11:10	24.5	71	627	401	431	479	456	565	909	137	119	76	78	248	32	76
2	10	11:20	23.7	72	573	415	365	404	388	405	816	155	131	81	78	248	35	77
3	20	11:30	23.4	72	491	421	327	358	346	376	687	133	124	83	78	246	34	77
4	30	11:40	23.1	72	449	407	304	332	325	361	699	132	127	80	79	247	35	74
5	40	11:50	22.7	72	433	394	292	322	315	365	716	129	128	79	79	248	35	75
6	50	12:00	22.3	73	424	386	283	319	308	358	683	128	125	79	77	247	36	75
7	60	12:10	21.9	72	405	378	275	302	291	354	629	126	122	79	76	248	36	75
8	70	12:20	21.6	73	401	370	268	307	298	352	672	126	122	79	75	248	37	75
9	80	12:30	21.2	73	417	365	266	304	297	352	746	130	128	79	74	248	37	75
10	90	12:40	20.7	74	446	360	270	308	300	376	813	139	133	80	75	248	37	75
11	100	12:50	20.0	74	479	358	279	321	306	394	892	146	133	80	73	239	39	73
12	110	13:00	19.4	75	488	361	272	346	318	393	838	149	133	80	73	240	39	73
13	120	13:10	18.8	74	498	364	303	367	324	408	834	147	132	80	72	240	34	72
14	130	13:20	18.2	75	515	366	310	373	330	416	872	149	136	80	72	240	34	73
15	140	13:30	17.7	75	528	369	316	378	334	418	872	150	137	80	71	249	35	73
16	150	13:40	17.1	76	574	369	322	381	339	425	892	149	135	80	71	238	35	73
17	160	13:50	16.5	76	615	363	326	384	346	427	927	155	138	81	70	236	35	75
18	170	14:00	15.9	75	630	361	329	394	353	449	925	158	139	81	70	230	37	76
19	180	14:10	15.2	75	632	358	327	416	360	460	941	160	140	83	70	225	34	77
20	190	14:20	14.6	76	639	356	324	417	369	486	959	162	141	83	71	224	36	78
1475 10264 7522 6241 7242 6713 8159 16523																		

SIGNED BY: [Signature] DATE: 4/13/89  
 2858 1603 1480

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 5 - STOVE TEST DATA

Stove Mfg.: Manf's Custom Stoves  
 Stove Model: 12-400FS  
 Stove I.D. No.: 184  
 Run No.: 4-13-89  
 Date: 4-13-89

Data Set No.	AT	24 hr. Time	Test Fuel Wt. Lb.	TEMPERATURES										Flue		Dry Gas		Oven Temp °F (13)	Imp. Temp. °F (14)	Tracer Temp. °F (15)
				Amb. (1)	Stove Surfaces				Primary Comb. (7)	Catl. or Secondary Comb. (8)	Catl. or Secondary Comb. (16)	db (9)	wb (10)	In (11)	Out (12)					
					T(2)	B(3)	R(4)	RS(5)								LS(6)				
21	200	14:30	15.9	76	642	353	347	442	576	468	1017	166	158	85	72	224	36	79		
22	210	14:40	13.0	77	674	353	353	450	393	509	1040	173	143	85	72	222	36	79		
23	220	14:50	11.9	78	740	362	376	502	419	542	921	174	149	86	73	227	36	78		
24	230	15:00	11.7	79	734	376	387	512	430	548	963	172	146	85	75	230	38	77		
25	240	15:10	10.2	78	718	395	395	518	444	570	963	171	144	84	75	239	40	77		
26	250	15:20	9.4	79	713	400	397	518	454	585	980	170	137	84	75	244	41	77		
27	260	15:30	8.7	80	719	410	400	525	463	591	961	167	138	83	75	244	43	76		
28	270	15:40	8.1	79	725	418	404	529	479	631	969	169	138	83	75	242	44	76		
29	280	15:50	7.5	78	723	430	408	525	493	620	961	167	133	83	74	239	44	77		
30	290	16:00	7.2	78	671	435	405	513	489	611	914	160	125	84	73	239	44	77		
31	300	16:10	6.6	80	630	437	396	503	478	589	881	156	124	82	74	246	32	76		
32	310	16:20	6.5	79	611	436	391	500	469	575	863	154	123	82	75	242	32	76		
33	320	16:30	6.2	79	590	442	384	496	458	562	824	150	119	81	74	242	32	75		
34	330	16:40	5.9	78	578	443	378	488	451	557	817	150	116	81	74	245	32	74		
35	340	16:50	5.6	79	572	441	374	482	445	550	834	150	119	81	73	244	33	74		
36	350	17:00	5.3	79	571	439	372	480	443	548	847	149	118	80	73	244	34	73		
37	360	17:10	4.9	79	573	437	371	472	440	546	854	150	119	80	72	247	36	73		
38	370	17:20	4.6	79	569	437	370	464	438	545	844	150	116	79	72	246	35	73		
39	380	17:30	4.4	79	567	435	370	460	435	545	846	149	116	79	72	247	37	72		
40	390	17:40	4.1	78	566	429	370	457	433	543	859	149	116	79	71	246	38	72		
				1571	12886	8304	11418	9736	8934	11235	18158	3196	1616	1449			1511			

SIGNED BY: Michael C... DATE: 4/13/89

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 5 - STOVE TEST DATA

Stove Mfg.: Marks Custom Stoves  
Stove Model: K-400 FS  
Stove I.D. No.: 184  
Run No.: 4  
Date: 4/13/69

Data Set No.	ΔT	24 hr. Time	Test Fuel Wt. Lb.	TEMPERATURES						Primary Comb. (7)	Catl. or Secondary Comb. (8)	Catl. or Secondary Comb. (16)	Flue		Dry Gas		Oven Temp °F (13)	Imp. Temp. °F (14)	Tracer Temp. °F (15)
				Amb. (1)	T(2)	B(3)	Stove Surfaces (4)	RS(5)	LS(6)				db (9)	wb (10)	In (11)	Out (12)			
41	400	17:50	3.8	79	563	422	370	453	431	541	854	149	115	79	70	239	40	72	
42	410	18:00	3.6	78	538	420	367	404	435	550	804	146	115	79	70	242	40	71	
43	420	18:10	3.4	78	518	423	363	435	430	540	777	144	111	79	70	240	40	72	
44	430	18:20	3.3	79	505	425	358	425	424	533	763	142	109	78	70	241	40	71	
45	440	19:10	3.1	79	494	421	353	418	417	524	747	141	108	77	69	241	32	71	
46	450	19:40	2.9	78	489	419	349	410	410	515	744	140	107	77	69	240	32	71	
47	460	18:50	2.7	78	481	412	346	404	402	503	740	139	107	77	69	242	33	69	
48	470	19:00	2.5	78	477	409	344	396	395	498	744	139	109	77	68	240	34	70	
49	480	19:10	2.3	78	474	406	344	393	392	497	743	139	110	76	68	240	35	70	
50	490	19:20	2.2	78	470	400	344	388	388	489	730	139	110	75	68	240	35	69	
51	500	19:30	2.0	79	464	394	347	388	386	492	721	138	109	75	68	240	35	68	
52	510	19:40	1.8	79	461	386	350	387	388	499	722	137	104	75	67	239	36	69	
53	520	19:50	1.6	78	459	379	353	384	387	497	728	137	104	75	67	240	37	68	
54	530	20:00	1.5	79	456	367	362	384	383	489	737	138	105	75	67	239	39	68	
55	540	20:10	1.3	77	452	353	367	383	376	479	735	138	105	81	64	239	40	72	
56	550	20:20	1.1	78	445	341	372	381	369	473	726	138	105	85	62	235	40	75	
57	560	20:30	.9	77	435	327	371	380	361	459	716	138	104	88	61	240	40	72	
58	570	20:40	.7	77	428	317	374	382	356	451	716	140	106	89	62	241	41	71	
59	580	20:50	.5	76	425	303	386	399	353	445	716	138	107	83	66	241	41	71	
60	590	21:00	.3	76	423	292	388	399	349	438	701	136	103	79	69	240	32	69	

SIGNED BY: unmarked DATE: 4/13/69 1559 7456 7616 8035 7832 9912 14864 2796 1578 1211 101X

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 5 - STOVE TEST DATA

Stove Mfg.: Mark's Custom Stoves  
 Stove Model: K-400F3  
 Stove I.D. No.: 184  
 Run No.: 4  
 Date: 4/13/87

Data Set No.	24 hr. Time	Test Fuel Wt. lb.	TEMPERATURES										Flue db (9)	Flue wb (10)	Dry Gas		Oven Temp °F (13)	Imp. Temp. °F (14)	Tracer Temp. °F (15)
			Amb. (1)	T(2)	B(3)	R(4)	RS(5)	LS(6)	Primary Comb. (7)	CatL. or Secondary Comb. (8)	CatL. or Secondary Comb. (16)	In (11)			Out (12)				
61	21:10	.1	76	417	279	382	391	343	429	684	684	134	102	77	70	241	32	68	
62	21:20	0	76	411	271	381	379	334	423	684	684	132	103	79	69	240	33	71	
			152	828	580	763	770	679	852	1368	1368			156	138	481	65	139	
			4757	33434	24992	21859	25883	24158	30158	50713	50713			4983	4421			4555	
			77	539	387	353	417	390	486	818	818	147		80	71			73	

SIGNED BY: Franklin Gure DATE: 4/13/87

DT = -123.2 °F  
 Avg skin = 417.2 °F

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 6 - PARTICULATE TRAIN OPERATION

Stove Mfg.: Marks Custom Stoves Date: 4-13-89  
 Stove Model: K-400ES Expected Burn Rate: Med. Low  
 Stove I.D. No.: 184 Oven Temp. Setting: 248°F  
 Run No.: 4 Tracer Rota, mm: 60  
 Tracer Pressure in H<sub>2</sub>O: 112

Proportional rate = 5

Data Point	24 hr. Time	Elap. Time Δt	SO <sub>2</sub>		CO <sub>2</sub> Scale	CO %	O <sub>2</sub> %	Orifice ΔH <sub>v</sub> In H <sub>2</sub> O	Dry Gas Meter ft <sup>3</sup>	Vacuum in Hg	Stove Static Pressure In H <sub>2</sub> O	Comments
			Scale	ppm								
1	11:10	0	31	465	54	0.01	6.58	0.006	510.959	2.5	0.030	
2	11:20	10	27.5	412	31	0.01	12.68	0.008	571.83	2.5	0.040	
3	11:30	20	29	435	29.5	0.01	13.08	0.007	572.83	2.5	0.035	
4	11:40	30	32.5	487	41.5	0.01	9.9	0.006	573.71	2.5	0.035	
5	11:50	40	30	450	44.5	0.01	9.1	0.007	574.56	2.5	0.030	
6	12:00	50	30	450	32	0.01	12.41	0.007	575.50	2.5	0.030	
7	12:10	60	33.5	502	36	0.01	11.35	0.005	576.44	2.5	0.030	
8	12:20	70	33	495	37.5	0.01	10.96	0.005	577.27	2.5	0.030	
9	12:30	80	33.5	502	47	0.01	8.44	0.005	578.10	2.5	0.030	
10	12:40	90	32	480	52.5	0.01	7.57	0.006	578.95	2.5	0.035	
11	12:50	100	31	465	55	0.01	6.32	0.006	519.81	2.5	0.040	
12	13:00	110	27.5	412	48	0.01	8.17	0.008	520.63	2.5	0.040	
13	13:10	120	30	450	49	0.01	7.91	0.007	521.54	2.5	0.035	
14	13:20	130	30	450	51	0.01	7.38	0.007	522.41	2.5	0.040	
15	13:30	140	32	480	54	0.01	6.58	0.006	523.28	2.5	0.040	
16	13:40	150	30	450	53	0.02	6.84	0.007	524.15	2.5	0.040	
17	13:50	160	29.5	442	55	0.02	6.31	0.007	525.01	2.5	0.040	
18	14:00	170	29.5	412	57.5	0.02	5.65	0.007	525.88	2.5	0.040	
19	14:10	180	28	420	59.5	0.02	5.12	0.008	526.77	2.5	0.040	
20	14:20	190	29.5	442	60	0.02	4.99	0.007	527.66	2.5	0.040	
21	14:30	200	30.5	457	62.5	0.02	4.33	0.006	528.57	2.5	0.040	
22	14:40	210	28.5	427	67	0.02	3.82	0.007	529.47	2.5	0.045	
23	14:50	220	28.5	427	68.5	0.02	0.83	0.007	530.32	2.5	0.045	
24	15:00	230	28.5	427	69.5	0.02	1.78	0.007	531.21	2.5	0.040	
25	15:10	240	29	435	70	0.02	1.79	0.008	532.10	2.5	0.040	

SIGNED: Michael Carr 11:30A 12:53 DATE: April 13, 1989 .93

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 6 - PARTICULATE TRAIN OPERATION

Stove Mfg.: Marks Custom Stove  
Stove Model: K-400 FS  
Stove I.D. No.: 184  
Run No.: 4

Date: 4/13/89  
Expected Burn Rate: med/Low  
Oven Temp. Setting: 248  
Tracer Rota, mm: 60  
Tracer Pressure in H<sub>2</sub>O: 0.12

Data Point	24 hr. time	Elap. Time Δt	SO <sub>2</sub> / ppm		CO <sub>2</sub> Scale	CO %	O <sub>2</sub> %	Orifice ΔH In H <sub>2</sub> O	Dry Gas Meter ft <sup>3</sup>	Vacuum in Hg	Stove Static Pressure In H <sub>2</sub> O	Comments
			Scale	ppm								
26 A	15:20	250	29	435	69	.87	2.08	.007	532.98	.5	.045	
27 X	15:30	260	29	435	69.5	.47	2.20	.007	533.85	.5	.040	
28 Z	15:40	270	27	405	68	1.20	2.15	.008	534.72	.5	.045	
29 A	15:50	280	28	420	60	.02	4.98	.008	535.64	.5	.040	
30 B	16:00	290	29	435	54.5	.01	6.45	.007	536.53	.5	.035	
31 C	16:10	300	29	435	54	.01	6.58	.007	537.42	.5	.035	
32 D	16:20	310	30	450	55	.01	6.32	.007	538.30	.5	.035	
33 E	16:30	320	30	450	52	.01	7.11	.007	539.19	.5	.030	
34 F	16:40	330	31	465	52	.01	7.11	.006	540.08	.5	.030	
35 G	16:50	340	31	465	53	.02	6.84	.006	540.97	.5	.030	
36 H	17:00	350	31	465	53.5	.01	6.72	.006	541.85	.5	.030	
37 I	17:10	360	31.5	472.5	52	.01	7.11	.006	542.76	.5	.030	
38 J	17:20	370	31	465	51	.02	7.37	.006	543.64	.5	.030	
39 K	17:30	380	31	465	51.5	.01	7.25	.006	544.52	.5	.030	
40 L	17:40	390	31.5	472.5	51	.02	7.37	.006	545.41	.5	.030	
41 M	17:50	400	31	465	49	.01	7.90	.006	546.29	.5	.030	
42 N	18:00	410	30	450	44	.01	9.20	.007	547.18	.5	.030	
43 O	18:10	420	31	465	43	.02	9.49	.006	548.07	.5	.030	
44 P	18:20	430	32	480	43	.01	9.50	.006	548.96	.5	.030	
45 Q	18:30	440	32	480	41.5	.02	9.89	.006	549.85	.5	.030	
46 R	18:40	450	33	495	40	.02	10.29	.005	550.74	.5	.030	
47 S	18:50	460	33	495	40.5	.01	10.16	.005	551.63	.5	.030	
48 T	19:00	470	34	510	40	.01	10.29	.005	552.52	.5	.030	
49 U	19:10	480	34	510	40	.01	10.29	.005	553.41	.5	.030	
50 V	19:20	490	34	510	37	.01	11.08	.005	554.29	.5	.030	

.815

2.83 165.13 .156

1264

11595

1

1

1

1

1

SIGNED: *Muehlbauer*

DATE: 4/13/89

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 6 - PARTICULATE TRAIN OPERATION

Stove Mfg.: Marks Custom Stove  
 Stove Model: K-400FS  
 Stove I.D. No.: 184  
 Run No.: 4  
 Date: 4/13/89  
 Expected Burn Rate: M.A./L.H.  
 Oven Temp. Setting: 24T  
 Tracer Rota, mm: 60  
 Tracer Pressure in H<sub>2</sub>O: 112

Data Point	24 hr. Time	Elap. Time Δt	SO <sub>2</sub>		CO <sub>2</sub> Scale	CO %	O <sub>2</sub> %	Orifice ΔH In H <sub>2</sub> O	Dry Gas Meter ft <sup>3</sup>	Vacuum in Hg	Stove Static Pressure In H <sub>2</sub> O	Comments
			Scale	ppm								
1	19:30	500	35	525	38	.01	10.82	.005	555.19	.5	.030	
2	19:40	510	35	525	38	.01	10.82	.005	556.08	.5	.030	
3	19:50	520	34	510	38	.02	10.82	.005	556.97	.5	.030	
4	20:00	530	34	510	37.5	.01	10.95	.005	557.86	.5	.030	
5	20:10	540	33	495	36	.01	11.35	.005	558.75	.5	.030	
6	20:20	550	33	495	36	.01	11.35	.005	559.63	.5	.030	
7	20:30	560	33	495	34	.01	11.88	.005	560.52	.5	.030	
8	20:40	570	32.5	487.5	37.5	.01	10.96	.005	561.40	.5	.030	
9	20:50	580	32	480	34	.01	11.88	.005	562.29	.5	.030	
10	21:00	590	32	480	33	.01	12.15	.005	563.18	.5	.030	
11	21:10	600	32	480	31	.01	12.68	.005	564.06	.5	.030	
12	21:20	610	32	495	30	.01	12.94	.005	564.960	.5	.030	
13	21:30	620										
14	21:40	630										
15												
16				5977.5	423	.13	138.6	.06			.36	
17												
18				28870.5	2970	8.64	503.42	.383			2.105	
19												
20				465.75	47.903	.1393	8.1916	.00617	54.001		.03395	
21				11.98								
22												
23												
24												
25												


SIGNED: Michael Cur DATE: 4/13/89



NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400FS  
 Stove I.D. No.: 184  
 Run No.: 4  
 Date: 4-13-89

	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:		PRE-Test Calibration		
ZERO GAS:	0.0	0.0	N/A	0.0
AUDIT GAS:	59.9	5.01	}	34.2
DESIRED:	59.9	5.01		34.2
PERCENT DIFFERENCE:	0.0%	0.0%		↓
TIME (24 HOUR):	09:30	09:30		09:30

SIGNED:   
 DATE: 4-13-89

NORTHWEST TESTING LABORATORIES, INC.  
 Woodstove Emission Testing

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400 FS  
 Stove I.D. No.: 184  
 Run No.: 4  
 Date: 4/13/89

	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:	120 minute	audit	—————→	
ZERO GAS:	0.0	0.0	<del>X</del>	0.4
AUDIT GAS:	59.8	5.03		34.0
DESIRED:	59.9	5.01		34.2
PERCENT DIFFERENCE:	0.2%	0.4%		1.8%
TIME (24 HOUR):	13:20	—————→		

SIGNED: Michael Cam  
 DATE: 4/13/89

NORTHWEST TESTING LABORATORIES, INC.  
 Woodstove Emission Testing




Stove Mfg.: Mark's Custom Stoves  
 Stove Model: K-400 FS  
 Stove I.D. No.: 184  
 Run No.: 4  
 Date: 4/13/89

	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:	240 minute			
ZERO GAS:	0.0	0.0		0.2
AUDIT GAS:	59.9	5.00		34.2
DESIRED:	59.9	5.01		34.2
PERCENT DIFFERENCE:	0.07	0.2%		1.27.
TIME (24 HOUR):	15:20			

SIGNED: Michael Cerr  
 DATE: 4/13/89

NORTHWEST TESTING LABORATORIES, INC.  
 Woodstove Emission Testing



Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400FS  
 Stove I.D. No.: 184  
 Run No.: 4  
 Date: 4/13/89

	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:	360 minute audit 			
ZERO GAS:	0.0	0.0		0.2
AUDIT GAS:	59.9	5.00		34.2
DESIRED:	59.9	5.01		34.2
PERCENT DIFFERENCE:	0.09.	0.27.		0.62
TIME (24 HOUR):	17:20 			

SIGNED: Michael Calk  
 DATE: 4/13/89

NORTHWEST TESTING LABORATORIES, INC.  
 Woodstove Emission Testing

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400 FS  
 Stove I.D. No.: 184  
 Run No.: 4  
 Date: 4/13/89

	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:	480 minute audit 			
ZERO GAS:	0.0	0.0	<del>X</del>	0.3
AUDIT GAS:	60.0	5.01		34.3
DESIRED:	59.9	5.01		34.2
PERCENT DIFFERENCE:	0.2%	0.0%		1.5%
TIME (24 HOUR):	19:00 			

SIGNED: Michael Cava

DATE: 4/13/89

NORTHWEST TESTING LABORATORIES  
Woodstove Emission Testing

PAGE 7 - POST TEST DATA

Stove Mfg.: Mark's Custom Stoves  
Stove Model: K-420 FS  
Stove I.D. No.: 184

Run No.: 4  
Date: 4/13/89  
Time: 21:35

Analyzer Audit

CO<sub>2</sub> 0.0  
Audit Gas 60.1  
Desired 59.9  
% Difference 0.37

% Drift Check:

Zero Drift 0.0%  
Mid Level Drift 0.2%  
Leak Test Results Pass

Ambient

Tdb 77 °F  
Twb 64 °F  
Pbaro 29.82 in Hg. 29.83  
Moisture 1.5 % By Volume  
Relative Humidity, % 49%

Scale Readings

	O <sub>2</sub>	CO	SO <sub>2</sub>
Zero Gas	<del>0.0</del>	<del>0.0</del>	<del>0.2</del>
Audit Gas	<del>60.1</del>	<del>5.62</del>	<del>34.4</del>
Desired	<del>59.9</del>	<del>5.01</del>	<del>34.2</del>
% Difference	<del>0.37</del>	<del>0.27</del>	<del>0.67</del>
Zero Drift	<del>0.0%</del>	<del>0.0%</del>	<del>0.2%</del>
Mid Level Drift	<del>0.2%</del>	<del>0.1%</del>	<del>0.2%</del>
Leak Test Results	<del>Pass</del>	<del>Pass</del>	<del>Pass</del>

Particulate Train

Leakage Rate: 0.008 ft<sup>3</sup>/min.

Extra Filters Used: N/A

SIGNED: Michael Cwik

DATED: 4/13/89

SAMPLE EXTRACTION DATA

Stove Mfg.: marks Custom Stoves

Test: 5

Stove Model: K-400FS

Test Cycle: med/High

Date: 4/14/89

Stove I.D. No.: 184

Technician: M Case

V<sub>v</sub>

CONDENSED WATER VOLUME, GMS

	Modified Temp. 100 ml H <sub>2</sub> O	Standard Imp 100 ml Hz	Modified Imp. Dry	Modified Imp. 200 Gms Silica Gel
Gross Weight	641.3	612.5	487.1	733.3
Initial Weight	563.6	607.6	487.0	728.0
Net Weight	77.7	4.9	0.1	5.3

TOTAL 88.0 GMS

W

PARTICULATE CATCH, GMS

	OVEN FILTER(S)				TRAIN FILTER(S)			
Gross Weight	8.347				7.842			
Initial Weight	7.594				7.586			
Net Weight	0.0753				0.0256			

TOTAL 0.1009 GMS

	Front Catch Probe	Rear Catch Impingers	DCM	H <sub>2</sub> O
Beaker, ml	70ml	175ml	150ml	200ml + 100
Gross, Weight	102.4607	100.5800	102.3051	101.3905
Initial Weight	102.4167	100.4681	102.2099	101.3468
Net Weight	0.0440	0.1119	0.0952	0.0437
Evaporation	0.0006	0.0016	0.0009	0.0029
Residue Weight	0.0434	0.1103	0.0943	0.0408

TOTAL 0.2888 GMS

0.1537

0.1351

Total Particulate = 0.3897 gm  
= 389.7 mg





METHOD 5H FLOW RATE (STACK) CALCULATIONS

(Put general info in col B, data info in col H.)

Lab name: NORTHWEST TESTING LABS, INC.      Yhc 1=cat,2=ncat :      1  
 Stv manu: MARKS CUSTOM STOVES              Wc (if supplied) :  
 Model no: K-400 FREESTANDING              Burn rate (kg/hr):      2.34  
 Tst Date: APRIL 14, 1989                  Run Number              :      5

run time (min)	O2 (%)	CO2 (%)	CO (%) (1.-1.12)	Fo	Stack Gas Flow Rate		
					(dscfh)	(dscfm)	(dsm3/hr)
0	5.60	14.40	0.08	1.06	517.61	8.63	14.67
10	8.10	12.00	0.05	1.06			
20	10.40	9.90	0.03	1.06			
30	10.70	9.60	0.02	1.06			
40	10.30	10.00	0.03	1.06			
50	2.10	17.30	0.90	1.06			
60	0.30	17.60	3.10	1.07			
70	0.10	17.30	4.85	1.05			
80	0.10	17.10	5.60	1.04			
90	0.50	17.60	2.75	1.07			
100	0.50	17.80	2.60	1.06			
110	0.60	17.90	2.25	1.06			
120	1.10	17.10	2.65	1.07			
130	2.10	16.60	1.95	1.07			
140	3.60	16.10	0.40	1.06			
150	6.00	14.00	0.02	1.06			
160	6.70	13.40	0.02	1.06			
170	7.60	12.50	0.01	1.06			
180	8.20	12.00	0.01	1.06			
190	8.20	12.00	0.01	1.06			
200	7.90	12.30	0.01	1.06			
210	8.70	11.50	0.02	1.06			
220	9.20	11.00	0.01	1.06			

Method 5H Proportionality Rate and Sample Volume Calculation  
 (put general info in col. C; Pb,Y,& unit info in col. G)

```

=====
Lab name: NORTHWEST TESTING LAB., INC.          Units 1=metric,
Stv manu: MARKS CUSTOM STOVES                  2=English:    2.0
Model no: K-400 FREESTANDING                    Y, DGM:      0.971
Tst date: APRIL 14, 1989                       Pb (mm,in. Hg): 29.9
Run no  :      5.0
    
```

NOTE: Input raw data below, use F9 for CALC.

run time (min)	tracer conc (ppm,%)	DGM rdg (m3,ft3)	DGM temp (C,F)	DGM dH (mm H2O) (in.H2O)	dDGM vol std (m3,ft3)	PR (%)	Sample vol std (m3,ft3)
0	330.0	564.961	66	0.013			
10	345.0	566.080	68	0.011	1.090	110.3	23.849
20	300.0	567.070	68	0.015	0.961	101.6	
30	292.0	568.210	69	0.016	1.107	101.7	
40	285.0	569.350	70	0.017	1.104	98.8	
50	292.0	570.520	70	0.016	1.131	98.8	
60	277.0	571.660	69	0.018	1.102	98.7	
70	262.0	572.910	70	0.020	1.211	102.8	
80	247.0	574.170	70	0.023	1.218	97.8	
90	240.0	575.550	70	0.024	1.334	101.0	
100	255.0	577.000	70	0.021	1.402	103.1	
110	270.0	578.300	69	0.019	1.257	98.3	
120	255.0	579.560	70	0.021	1.221	101.0	
130	277.0	580.850	71	0.018	1.247	97.5	
140	285.0	582.040	71	0.017	1.149	97.5	
150	285.0	583.150	73	0.017	1.071	93.6	
160	330.0	584.270	72	0.012	1.077	94.1	
170	315.0	585.300	73	0.014	0.992	100.4	
180	315.0	586.400	74	0.013	1.058	102.1	
190	315.0	587.500	75	0.013	1.056	101.9	
200	315.0	588.520	75	0.014	0.977	94.3	
210	285.0	589.650	75	0.017	1.082	104.5	

NORTHWEST TESTING LABORATORIES  
Woodstove Emission Testing

PAGE 1 - STOVE INFORMATION AND PRE-TEST DATA

Stove Manufacturer: Marks Custom Stoves  
Stove Model: K-400 FS  
Stove I.D. Number: 184  
Run Number: 5  
Date: 4-14-89  
Expected Burn Rate: Med. High

STOVE

Weight: 50.1 lb.  
Platform Scale Audit?: OK  
Primary Air Control Setting: 1/2" open sides  
Blower: On OFF Auto. N/A  
Flue Pipe Gauge: 24  
Flue Pipe Diameter in.: 8 in.  
Pictures: Yes X No      
Operating Instructions: written  
Stove Manual Verbal     Other X  
Stack Cleaned: Yes X No    

CATALYST Yes X No    

Catalyst Brand: Applied Ceramics  
Catalyst I.D.: Firecat 2 1/2 x 7 1/2 x 3, 16 cell  
Catalyst Age: 50+ hrs.  
Catalyst Provided: Marks Custom Stoves

AMBIENT

Dry Bulb Reading 75 °F  
Wet Bulb Reading 62 °F  
Relative Humidity 48 %  
Baro. 29.91 in Hg.

% Moisture 1.4 % Volume    

CONTINUOUS ANALYZERS

Audited by: T. Palmer  
Leak Tested by: T. Palmer

PARTICULATE TRAIN

Probe Length & Type 6" Pyrex  
Nozzle Size 1/62 in.  
Inlet 65  
Magnehelic Range, 0-1 in H<sub>2</sub>O  
Leakage Rate: .001 Ft. <sup>3</sup>/min.

TRACER GAS

Gas Used: SO<sub>2</sub>  
Rotameter No.: 601  
Rotameter Rdg.: 60  
Ball Read: 55  
CC/Min.: 70.62  
Ft. <sup>3</sup>/hr. 115  
(cc/min. ÷ 472 = ft. <sup>3</sup>/hr.)  
Injection System Rate  
Checked: Yes: X No:    

SIGNED BY: [Signature]

DATE: 4-14-89

Date: 4-21-89

Attention: Mike Cave

Subject: Analysis on one (1) wood fuel sample received 4-14-89.

Item: Wood Fuel

Reference: Mark's Custom Stoves  
Model: K-400 F.S.  
184-5  
Medium High

REPORT:

Analysis:

Moisture, %, as received .....	<u>15.4</u>
Moisture, %, dry basis .....	<u>18.2</u>
Density, g/cm <sup>3</sup> , dry basis .....	<u>0.51</u>
Higher Heat of Combustion, BTU/lb., dry basis .....	<u>8745</u>

JMT / RWH

Report Number: 321591

**WOOD/FUEL**  
(ON NTL STOVE DISK)

0800 charges \$170

PAGE 3 - STOVE OPERATION LOG

Stove Mfg.: Marks Custom Stoves Date: 4-14-89  
Stove Model: K-400 FS Technician: J. Palmer  
Stove I.D. Number: 124  
Run Number: 5

24 Hr. Time

OPERATION

09:50 Lit 4.0 lbs of Kindling, Door-Ajdar  
Air controls 100% open, By-Pass open  
09:55 Shut Door  
10:00 Added #1 Pre-Burn  
10:02 Shut By-Pass  
10:05 Set Air controls at 1/2" open  
10:10 Started Pre-Burn Readings  
10:42 Stoked Fire  
10:57 Stoked Fire  
11:15 Added 22.7 lbs of Test Fuel  
By-Pass open, Air controls 100% open  
11:16 + 10 sec Shut Door + By-Pass  
11:20 Set Air controls at 1/2" open

+ 271 = 1.9  
- 412 = 1.25

Stove Mfg.: Marks Custom Stoves Run Number: 5  
 Stove Model: K-400FS Date: 4-14-89  
 Stove I.D. No.: 184 Air Control Setting: Med. High

4.5 ↓  
5.7

← STOKEN  
← STOKEN

Data Set No.	Elapsed Time	TEMPERATURES										Fuel Wt/lb	Prim. Temp. (7)	Cat. Temp. (8)	Cat. Temp. (16)
		Amb. (1)	Stove Surfaces					LS(6)	Fuel Wt/lb						
			T(2)	B(3)	R(4)	RS(5)	LS(6)								
1	10:10	69	527	166	379	435	477	19.5	520	1204					
2	10:15	68	579	214	415	502	431	17.9	587	1150					
3	10:20	69	621	246	474	585	459	16.5	614	1025					
4	10:25	69	654	275	527	715	497	14.9	688	1007					
5	10:30	70	671	286	532	717	508	13.5	727	994					
6	10:35	70	726	312	528	678	525	12.1	686	1028					
7	10:40	71	756	344	550	670	556	10.9	755	1029					
8	10:45	71	795	385	572	658	579	8.9	707	1027					
9	10:50	72	828	416	557	628	567	8.1	703	1069					
10	10:55	72	831	438	542	615	570	7.5	720	1067					
11	11:00	73	842	469	590	650	607	6.0	760	1053					
12	11:05	74	850	482	586	654	610	5.4	762	1110					
13	11:10	73	854	470	577	639	615	5.0	757	1101					
	11:15			Add col test for c.1 →					4.6						

SIGNED: [Signature] DATE: 4-14-89

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 5 - STOVE TEST DATA

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400FS  
 Stove I.D. No.: 184  
 Run No.: 5  
 Date: 4-14-89

Data Set No.	24 hr. Time	Test Fuel Wt. Lb.	Amb. (1)	TEMPERATURES						Primary Comb. (7)	Catl. or Secondary Comb. (8)	Catl. or Secondary Comb. (16)	Flue		Dry Gas		Oven Temp °F (13)	Imp. Temp. °F (14)	Tracer Temp. °F (15)
				T(2)	B(3)	R(4)	RS(5)	LS(6)	db (9)				wb (10)	In (11)	Out (12)				
1	0	11:15	74	841	493	573	631	617	748	1080		240	140	64	68	241	72	65	
2	10	11:25	73	789	575	492	499	576	459	1053		270	150	67	68	245	72	66	
3	20	11:35	74	681	575	448	449	468	458	942		271	145	69	67	231	72	66	
4	30	11:45	74	615	498	421	441	441	452	885		220	142	71	67	234	72	67	
5	40	11:55	73	577	477	404	447	427	472	918		217	141	73	67	240	72	67	
6	50	12:05	75	621	458	408	478	479	480	1167		217	154	73	67	245	72	66	
7	60	12:15	74	799	444	437	503	467	577	1124		264	160	72	66	247	72	66	
8	70	12:25	74	828	474	504	673	499	560	1156		269	161	73	66	246	72	66	
9	80	12:35	76	802	426	592	787	528	621	1151		282	161	73	66	238	72	66	
10	90	12:45	76	817	420	641	796	570	672	1130		273	158	74	66	233	72	66	
11	100	12:55	77	878	449	662	728	603	720	1113		265	156	74	66	230	72	67	
12	110	1:05	77	895	427	662	709	611	726	1101		260	154	73	65	230	72	66	
13	120	1:15	77	913	474	655	714	622	739	1085		258	151	75	65	227	72	68	
14	130	1:25	78	875	446	623	686	639	752	1099		251	146	78	64	219	72	71	
15	140	1:35	78	877	463	625	690	704	908	1081		276	138	78	65	241	72	71	
16	150	1:45	78	785	471	621	680	693	873	1008		237	129	80	65	240	72	72	
17	160	1:55	79	730	477	601	656	668	879	952		231	124	78	66	213	72	71	
18	170	1:05	78	690	481	589	631	647	782	930		220	122	71	67	211	72	71	
19	180	1:15	78	668	481	572	611	624	753	890		214	122	80	67	241	72	73	
20	190	1:25	78	637	489	557	593	607	730	871		210	117	81	68	241	72	74	

SIGNED BY: [Signature] DATE: 4-17-89  
 1521 1522 1523 1524 1525 1526 1527 1528 1529 1530 1531 1532 1533 1534 1535 1536 1537 1538 1539 1540 1541 1542 1543 1544 1545 1546 1547 1548 1549 1550 1551 1552 1553 1554 1555 1556 1557 1558 1559 1560 1561 1562 1563 1564 1565 1566 1567 1568 1569 1570 1571 1572 1573 1574 1575 1576 1577 1578 1579 1580 1581 1582 1583 1584 1585 1586 1587 1588 1589 1590 1591 1592 1593 1594 1595 1596 1597 1598 1599 1600

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 5 - STOVE TEST DATA

Stove Mfg.: Marks Custom Stoves  
 Stove Model: 17-400ES  
 Stove I.D. No.: 184  
 Run No.: 5  
 Date: 4-14-89

Data Set No.	ΔT	24 hr. Time	Test Fuel Wt. Lb.	TEMPERATURES										Oven Temp. °F (13)	Imp. Temp. °F (14)	Tracer Temp. °F (15)				
				Amb. (1)	Stove Surfaces			Primary Comb. (7)			Catl. or Secondary Comb. (8)		Catl. or Secondary Comb. (16)				Flue		Dry Gas	
				F(2)	B(3)	R(4)	RS(5)	LS(6)												
21	200	14:35	0.6	78	618	496	541	582	593	221	862	862	204	115	80	69	248	31	72	
22	210	14:41	0.3	78	616	486	532	568	581	241	853	853	200	111	79	70	247	86	72	
23	220	14:55	0.1	79	592	480	517	549	583	242	822	822	199	114	79	71	248	36	71	
				235	1820	1420	1504	1600	1761	2224	2510	2510			234	210				215
			Avg	76	743	467	552	613	572	669	577	238		75	67					69

SIGNED BY: [Signature] DATE: 4-14-89  
 ΔT = -87.2 °F  
 Avg Skin = 589.4 °F



NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 6 - PARTICULATE TRAIN OPERATION

Date: 4-14-89  
Expected Burn Rate: Med. High  
Oven Temp. Setting: 2480F  
Tracer Rota, mm: 60  
Tracer Pressure in H<sub>2</sub>O: 112

Stove Mfg.: Marks Custom Stoves  
Stove Model: K-400ES  
Stove I.D. No.: 184  
Run No.: 5

Data Point	24 hr. Time	Elap. Time Δt	SO2		CO2 Scale	CO %	O2 %	Orifice ΔH In H2O	Dry Gas Meter ft 3	Vacuum in Hg	Stove Static Pressure In H2O	Comments
			Scale	ppm								
1	11:15	0	22	530	57.5	1.08	5.61	0.03	564.761	2.5	.065	
2	11:25	10	23	545	48	1.05	8.15	0.11	566.08	2.5	.070	
3	11:35	20	20	300	39.5	1.03	10.41	0.15	567.07	2.5	.065	
4	11:45	30	19.5	292	38.5	1.02	10.69	0.16	568.21	2.5	.065	
5	11:55	40	19	285	40	1.01	10.28	0.17	569.35	2.5	.070	
6	12:05	50	17.5	272	69	1.90	2.07	0.16	570.52	2.5	.075	
7	12:15	60	18.5	277	70.5	3.10	.33	0.18	571.66	2.5	.075	
8	12:25	70	17.5	262	69	4.85	0.0	0.20	572.91	2.5	.075	
9	12:35	80	16.5	247	68.5	5.60	0.0	0.27	574.17	2.5	.070	
10	12:45	90	16	240	70.5	2.75	.54	0.24	575.55	2.5	.070	
11	12:55	100	17	255	71	2.6	.58	0.21	577.00	2.5	.070	
12	13:05	110	18	270	71.5	2.25	.58	0.19	578.70	2.5	.070	
13	13:15	120	17	255	68.5	2.65	1.17	0.21	579.56	2.5	.065	
14	13:25	130	18.5	277	66.5	1.95	2.09	0.18	580.80	2.5	.060	
15	13:35	140	19	285	64.5	1.40	3.56	0.17	582.04	2.5	.050	
16	13:45	150	19	285	56	1.08	6.05	0.17	583.15	2.5	.050	
17	13:55	160	22	330	55.5	1.02	6.71	0.12	584.27	2.5	.050	
18	14:05	170	21	315	50	1.01	7.64	0.14	585.30	2.5	.050	
19	14:15	180	21	315	48	1.01	8.17	0.13	586.40	2.5	.050	
20	14:25	190	21	315	48	1.01	8.17	0.13	587.50	2.5	.050	
21	14:35	200	21	315	49	1.01	7.90	0.14	588.52	2.5	.050	
22	14:45	210	19	285	46	1.02	8.69	0.19	589.65	2.5	.050	
23	14:55	220	19	285	44	1.01	9.23	0.16	590.757	2.5	.050	
24			66.4	66.4	44.5	37.37	43.25				490	
25			Avg		130.75	1.19	5.98	0.17	25.796		-0.065	

SIGNED: [Signature] DATE: 4-17-89

NORTHWEST TESTING LABORATORIES, INC.  
 Woodstove Emission Testing

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400 FS  
 Stove I.D. No.: 184  
 Run No.: 5  
 Date: 4-14-89

	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:		PRE-Test Calibration		
ZERO GAS:	0.0	0.0	N/A	0.0
AUDIT GAS:	59.9	5.01	}	34.2
DESIRED:	59.9	5.01		34.2
PERCENT DIFFERENCE:	0.0%	0.0%		↓
TIME (24 HOUR):	10:30	10:30		10:30

SIGNED: J. Palmer  
 DATE: 4-14-89

NORTHWEST TESTING LABORATORIES  
Woodstove Emission Testing

PAGE 7 - POST TEST DATA

Stove Mfg.: Marks Custom Stoves Run No.: 5  
 Stove Model: K-100 FS Date: 4/14/89  
 Stove I.D. No.: 184 Time: 15:16

Analyzer Audit

	CO <sub>2</sub>	O <sub>2</sub>	CO	SO <sub>2</sub>
Zero Gas	<u>0.0</u>	<del>_____</del>	<u>0.0</u>	<u>0.2</u>
Audit Gas	<u>59.9</u>	<del>_____</del>	<u>5.00</u>	<u>34.4</u>
Desired	<u>59.9</u>	<del>_____</del>	<u>5.01</u>	<u>34.2</u>
% Difference	<u>0.0%</u>	<del>_____</del>	<u>0.2%</u>	<u>0.6%</u>
% Drift Check:				
Zero Drift	<u>0.0%</u>	<del>_____</del>	<u>0.0%</u>	<u>0.2%</u>
Mid Level Drift	<u>0.0%</u>	<del>_____</del>	<u>0.1%</u>	<u>0.2%</u>
Leak Test Results	<u>PASS</u>	_____		

Particulate Train  
 Leakage Rate: 0.00% ft<sup>3</sup>/min.  
 Extra Filters Used: N/A

Ambient

Tdb 78 °F  
 Twb 64 °F  
 Pbaro 29.93 in Hg. 29.92  
 Moisture 1.6 % By Volume  
 Relative Humidity, % 46

SIGNED: Michael Caine DATED: 4/14/89

SAMPLE EXTRACTION DATA

Stove Mfg.: Marks Custom Stoves Test: 6  
 Stove Model: K-400FS Test Cycle: Med. High  
 Date: 4-17-89 Stove I.D. No.: 184  
 Technician: T. Palmar

Vv

CONDENSED WATER VOLUME, GMS

	Modified Temp. 100 ml H2O	Standard Imp 100 ml Hz	Modified Imp. Dry	Modified Imp. 200 Gms Silica Gel
Gross Weight	678.3	610.8	464.5	738.8
Initial Weight	586.5	606.0	463.8	737.1
Net Weight	91.8	4.8	0.7	5.7

TOTAL 103.0 GMS

W .7916 PARTICULATE CATCH, GMS .7664 4/18 0800

	OVEN FILTER(S)				TRAIN FILTER(S)			
Gross Weight	.7864				.7645			
Initial Weight	.7569				.7605			
Net Weight	0.0295				0.0040			

TOTAL 0.0335GMS

# 8

	Front Catch Probe	Rear Catch Impingers	DCM	H2O
Beaker, ml	75	150	150	200 + 115
Gross, Weight	99.3704	100.0591	102.7165	100.2239
Initial Weight	99.3437	100.0104	102.6723	100.1883
Net Weight	0.0267	0.0487	0.0442	0.0356
Evaporation	0.0007	0.0014	0.0009	0.0030
Residue Weight	0.0260	0.0473	0.0433	0.0326

TOTAL 0.1492 GMS      0.0733      0.0759

Total Particulate = 0.1827 g  
 = 182.7 mg



METHOD 5H FLOW RATE (STACK) CALCULATIONS

(Put general info in col B, data info in col H.)

Lab name: NORTHWEST TESTING LABS, INC. Yhc 1=cat,2=ncat : 1  
 Stv manu: MARKS CUSTOM STOVES Wc (if supplied) :  
 Model no: K-400 FREESTANDING Burn rate (kg/hr): 1.39  
 Tst Date: APRIL 17, 1989 Run Number : 6

run time (min)	O2 (%)	CO2 (%)	CO (%) (1.-1.12)	Fo	Stack Gas Flow Rate		
					(dscfh)	(dscfm)	(dsm3/hr)
0	7.90	12.30	0.01	1.06	357.28	5.95	10.13
10	11.10	9.30	0.01	1.05			
20	9.50	10.80	0.01	1.06			
30	7.90	12.30	0.02	1.06			
40	6.80	13.30	0.04	1.06			
50	7.50	12.60	0.03	1.06			
60	6.80	13.30	0.04	1.06			
70	5.20	14.80	0.04	1.06			
80	5.40	14.60	0.04	1.06			
90	5.00	15.00	0.05	1.06			
100	5.20	14.80	0.04	1.06			
110	5.40	14.60	0.04	1.06			
120	2.70	16.90	0.50	1.06			
130	3.00	16.80	0.25	1.06			
140	2.60	16.40	1.50	1.06			
150	0.70	16.80	4.00	1.07			
160	1.40	17.10	2.15	1.07			
170	2.40	17.30	0.35	1.06			
180	2.40	17.30	0.35	1.06			
190	2.70	17.00	0.30	1.06			
200	3.70	16.10	0.13	1.06			
210	5.40	14.60	0.02	1.06			
220	5.90	14.10	0.02	1.06			
230	6.60	13.50	0.02	1.06			
240	9.00	11.30	0.02	1.05			
250	10.00	10.30	0.01	1.06			
260	10.20	10.10	0.01	1.06			
270	10.30	10.00	0.01	1.06			
280	10.60	9.80	0.01	1.05			
290	11.00	9.40	0.01	1.05			
300	11.80	8.60	0.01	1.06			
310	11.80	8.60	0.01	1.06			
320	12.10	8.30	0.01	1.06			
330	10.40	9.90	0.01	1.06			
340	9.90	10.40	0.01	1.06			
350	9.20	11.00	0.01	1.06			
360	9.40	10.90	0.01	1.05			
370	9.20	11.00	0.01	1.06			
375	9.20	11.00	0.01	1.06			

Method 5H Proportionality Rate and Sample Volume Calculation  
 (put general info in col. C; Pb,Y,& unit info in col. G)

=====

Lab name: NORTHWEST TESTING LAB., INC.                      Units 1=metric,  
 Stv manu: MARKS CUSTOM STOVES                              2=English:     2.0  
 Model no: K-400 FREESTANDING                                 Y, DGM:        0.971  
 Tst date: APRIL 17, 1989                                      Pb (mm,in. Hg): 29.9  
 Run no :                6.0

NOTE: Input raw data below, use F9 for CALC.

-----

run time (min)	tracer conc (ppm,%)	DGM rdg (m3,ft3)	DGM temp (C,F)	DGM dH (mm H2O) (in.H2O)	dDGM vol std (m3,ft3)	PR (%)	Sample vol std (m3,ft3)
0	360.0	590.901	68	0.010			
10	375.0	591.850	71	0.010	0.922	102.1	35.604
20	330.0	592.790	73	0.012	0.908	104.7	
30	307.0	593.780	75	0.014	0.953	96.7	
40	307.0	594.870	75	0.014	1.045	98.7	
50	285.0	595.950	74	0.017	1.035	97.8	
60	285.0	597.100	72	0.017	1.105	96.8	
70	300.0	598.270	71	0.015	1.128	98.9	
80	307.0	599.390	73	0.015	1.082	99.8	
90	300.0	600.510	71	0.015	1.078	101.8	
100	292.0	601.630	71	0.016	1.082	99.8	
110	300.0	602.770	71	0.015	1.101	98.9	
120	315.0	603.910	72	0.014	1.101	101.6	
130	300.0	604.980	72	0.015	1.032	99.9	
140	322.0	606.090	72	0.013	1.070	98.7	
150	307.0	607.120	72	0.015	0.993	98.3	
160	322.0	608.220	72	0.013	1.061	100.1	
170	322.0	609.250	73	0.013	0.993	98.3	
180	330.0	610.280	74	0.013	0.991	98.2	
190	337.0	611.310	74	0.012	0.989	100.4	
200	330.0	612.250	73	0.013	0.903	93.6	
210	337.0	613.280	74	0.012	0.991	100.6	
220	337.0	614.240	74	0.012	0.922	95.6	
230	345.0	615.180	74	0.011	0.903	93.6	
240	352.0	616.110	75	0.011	0.893	94.8	
250	375.0	617.030	74	0.010	0.882	95.5	
260	367.0	617.920	74	0.010	0.855	98.6	
270	382.0	618.820	73	0.009	0.864	97.6	
280	375.0	619.690	73	0.010	0.837	98.4	
290	390.0	620.620	73	0.009	0.895	103.2	
300	405.0	621.520	72	0.008	0.866	103.9	
310	405.0	622.370	72	0.008	0.820	102.1	
320	420.0	623.230	71	0.008	0.829	103.3	
330	420.0	624.070	71	0.008	0.811	104.8	
340	420.0	624.920	71	0.008	0.821	106.1	
350	420.0	625.760	71	0.008	0.811	104.8	
360	420.0	626.600	71	0.008	0.811	104.8	
370	420.0	627.440	70	0.008	0.811	104.8	
375	420.0	627.861	70	0.008	0.407	105.3	

NORTHWEST TESTING LABORATORIES  
Woodstove Emission Testing

PAGE 1 - STOVE INFORMATION AND PRE-TEST DATA

Stove Manufacturer: Marks Custom Stoves

Stove Model: K-400FS

Stove I.D. Number: 184

Run Number: 6

Date: 4-17-89

Expected Burn Rate: Med. High

STOVE

Weight: 502.1 lb.

Platform Scale Audit?: OK

Primary Air Control Setting: 5/16" open

Blower: On Off Auto. N/A

Flue Pipe Gauge: 24

Flue Pipe Diameter In.: 8 in.

Pictures: Yes  No

Operating Instructions: Written

Stove Manual: Verbal  Other

Stack Cleaned: Yes  No

CATALYST Yes  No

Catalyst Brand: Applied Ceramics

Catalyst I.D.: Firecat, 2 1/2 x 7 1/2 x 3, 16 cell

Catalyst Age: 50+ hrs.

Catalyst Provided: Marks Custom Stoves

AMBIENT

Dry Bulb Reading: 69 °F

Wet Bulb Reading: 57 °F

Relative Humidity: 47 %

Baro. 29.94 in Hg.

% Moisture 1.2 % Volume     

CONTINUOUS ANALYZERS

Audited by: T. Palumbo

Leak Tested by: T. Palumbo

PARTICULATE TRAIN

Probe Length & Type: 6" Pyrex

Nozzle Size: .62 in.

II @ .65

II Magnelic Range, 0-1 in H<sub>2</sub>O

Leakage Rate: 1.002 FT.<sup>3</sup>/min.

TRACER GAS

Gas Used: SO<sub>2</sub>

Rotameter No.: 601

Rotameter Rdg.: 60

Ball Read: 55

CC/Min.: 70.62

ft.<sup>3</sup>/hr. 1.5

(cc/min. ÷ 472 = ft.<sup>3</sup>/hr.)

Injection System Rate

Checked: Yes:  No:

SIGNED BY: T. Palumbo

DATE: 4-17-89



PAGE 2 - FUEL DATA

Stove Manufacturer: Mark's Custom Stoves Run Number: 6  
 Stove Model: K-400FS Expected Burn Rate: Med High  
 Stove I.D. Number: 1124 Calculated Charge Wt.: 24.8  
 Technician: T. Palma Coal Bed Wt. Lbs.: 4.9  
 HHV Sample: Yes X No       
 (Saw Dust Catch & Block)     

I. Fuel Moisture Content, % (Dry Basis):

1. <u>19.2, 19.2, 19.2</u>	11. <u>19.2, 19.2, 19.2</u>	21. <u>    </u>
2. <u>19.2, 19.2, 19.2</u>	12. <u>19.2, 19.2, 19.2</u>	22. <u>    </u>
3. <u>19.2, 19.2, 19.2</u>	13. <u>    </u>	23. <u>    </u>
4. <u>19.8, 20.5, 20.3</u>	14. <u>    </u>	24. <u>    </u>
5. <u>20.3, 20.9, 19.2</u>	15. <u>    </u>	25. <u>    </u>
6. <u>19.2, 19.2, 19.2</u>	16. <u>    </u>	26. <u>19.2, 20.3, 19.8</u>
7. <u>19.2, 19.2, 19.2</u>	17. <u>    </u>	27. <u>19.8, 20.3, 19.2</u>
8. <u>19.2, 19.2, 19.2</u>	18. <u>    </u>	28. <u>24.8, 24.3, 24.8</u>
9. <u>19.2, 19.2, 19.2</u>	19. <u>    </u>	29. <u>24.8, 24.8, 24.3</u>
10. <u>19.2, 19.2, 19.2</u>	20. <u>    </u>	30. <u>24.3, 24.3, 24.3</u>

II. Test Fuel:

1. No. of 2 x 4's: 0 5. Species: D.F.  
 2. No. of 4 x 4's: 5 6. Moisture Content, % Ave. (Dry Basis): 22.62  
 3. Total No. of Fuel Pieces: # 26 → # 30 7. Length, In.: 19"  
 4. Weight, Lbs.: 23.4

III. Pre-Burn Fuel:

1. No. of 2 x 4's: 12 5. Species: D.F.  
 2. No. of 4 x 4's: 0 6. Moisture Content, % Ave. (Dry Basis): 19.47  
 3. Total No. of Fuel Pieces: # 1 → # 12 7. Length, In.: 21" ÷ 3 = 7"  
 4. Weight, Lbs.: 25.6

IV. Kindling Fuel:

1. No. of 2 x 4's: 0 5. Species: D.F.  
 2. No. of 4 x 4's: 1 1/2 6. Moisture Content, % Ave. (Dry Basis): 21.02  
 3. Total No. of Fuel Pieces:      7. Length, In.: 15"  
 4. Weight, Lbs.: 4.4

Date: 4-19-89

Attention: Mike Cave

Subject: Analysis on one (1) wood fuel sample received 4-17-89.

Item: Wood Fuel

Reference: Marks Custom stoves  
K-400 FS  
194-6  
Med. High

REPORT:

Analysis:

Moisture, %, as received .....	<u>15.6</u>
Moisture, %, dry basis .....	<u>18.5</u>
Density, g/cm <sup>3</sup> , dry basis .....	<u>0.43</u>
Higher Heat of Combustion, BTU/lb., dry basis .....	<u>8585</u>

Robert W. Hardesty

Report Number: 321591

**WOOD/FUEL**  
(ON NTL STOVE DISK)

0800 chemical \$170

PAGE 3 - STOVE OPERATION LOG

Stove Mfg.: Marks Custom Stoves Date: 4-17-89  
Stove Model: K-400FS Technician: T. Palmer  
Stove I.D. Number: 184  
Run Number: 6

24 Hr. Time

OPERATION

09:50 Lit 4.4 lbs of kindling Door Airt  
By-pass open Air 1/100<sup>th</sup> open  
09:55 Added #1 Pre-Burn 25.6 lbs  
09:58 Shut Door + By-pass  
10:15 Set Air controls 5/16" open  
10:20 Started Pre-Burn Readings  
10:57 Stoked Fire  
11:07 Stoked Fire  
11:30 Added Test Fuel 23.4 lbs  
Air + By-pass 100% open  
11:32 Shut Door + By-pass  
11:35 Set Air controls 5/16" open, both sides

Stove Mfg.: Marks Custom Stoves Run Number: 6 Date: 4-17-89 4.7 → 5.  
 Stove Model: K-400FS Air Control Setting: 5/16" open

Data Set No.	Elapsed 24/Hr. Time	TEMPERATURES										Fuel Wt/lb	Prim. Temp. (7)	Cat. Temp. (8)	Cat. Temp. (16)
		Amb. (1)	Stove Surfaces					LS(6)	Fuel						
			T(2)	B(3)	R(4)	RS(5)	LS(6)								
1	10:20	64	887	386	542	669	529	14.3	694	1046					
2	10:25	66	881	430	523	635	530	13.7	685	1025					
3	10:30	66	879	453	571	626	530	12.4	679	1010					
4	10:35	65	878	466	506	625	530	11.6	687	1022					
5	10:40	67	826	473	536	624	530	10.2	717	987					
6	10:45	67	815	478	531	611	532	9.2	719	981					
7	10:50	67	794	484	526	602	535	8.5	735	1018					
8	10:55	66	799	487	525	599	530	7.9	710	1031					
9	11:00	66	793	486	579	597	543	7.5	702	1025					
10	11:05	67	767	491	575	598	538	7.1	688	1060					
11	11:10	68	762	495	533	615	533	6.3	694	939					
12	11:15	69	766	503	533	611	533	5.7	704	1006					
13	11:20	69	756	505	529	606	534	5.4	694	1048					
14	11:25	66	731	498	520	589	547	5.1	672	1026					
				Test		Fuel	Address at	4.9 lbs							

← STOKED  
← STOKED

SIGNED: [Signature] DATE: 4-17-89

Stove Mfg.: Marks Cast Iron Stoves

Stove Model: K-400FS

Stove I.D. No.: 184

Run No.: 6

Date: 4-17-89

+ 274 = 1.9

+ 416 = 1.25

Data Set No.	ΔT	24 hr. Time	Test Fuel Wt. Lb.	TEMPERATURES										Catl. or Secondary Comb. (8)	Catl. or Secondary Comb. (16)	Flue		Dry Gas		Oven Temp. °F (13)	Imp. Temp. °F (14)	Tracer Temp. °F (15)
				Amb. (1)		570.0 °F Stove Surfaces				LS(6)	Primary Comb. (7)	db (9)	wb (10)			In (11)	Out (12)					
				T(2)	B(3)	R(4)	RS(5)	R(3)	R(4)									RS(5)	LS(6)			
1	0	11:30	21.4	68	714	497	516	581	542	667	1000	268	125	66	70	228	32	67				
2	10	11:40	22.2	67	672	505	475	477	472	489	939	307	141	71	71	227	32	68				
3	20	11:50	21.6	68	577	506	471	418	419	457	874	264	138	76	70	227	32	70				
4	30	12:00	20.9	68	558	487	469	396	390	457	963	270	139	80	69	227	32	71				
5	40	12:10	19.8	67	599	466	464	408	386	469	1014	285	144	82	68	228	32	71				
6	50	12:20	18.9	69	626	452	465	416	386	471	1005	286	144	76	71	228	32	67				
7	60	12:30	18.0	67	667	479	466	420	397	489	1063	294	146	72	71	229	32	65				
8	70	12:40	17.0	67	678	472	477	443	412	509	1073	305	148	72	70	229	32	64				
9	80	12:50	15.9	67	695	471	483	458	428	527	1094	316	149	76	69	230	32	66				
10	90	13:00	14.8	68	723	428	475	483	448	548	1121	319	150	75	68	230	32	64				
11	100	13:10	13.8	69	721	426	400	492	457	553	1120	323	149	74	67	229	32	65				
12	110	13:20	12.8	69	729	420	407	504	460	566	1105	321	148	77	65	228	32	68				
13	120	13:30	11.7	69	778	411	419	523	471	593	1094	323	149	79	64	233	32	69				
14	130	13:40	10.7	68	792	413	428	533	475	616	1152	328	150	80	64	235	32	70				
15	140	13:50	9.7	69	804	424	447	520	543	685	1105	323	147	80	64	236	32	69				
16	150	14:00	8.7	70	818	452	457	567	579	714	1024	320	150	80	64	237	32	69				
17	160	14:10	7.3	71	808	437	469	619	586	758	1057	309	146	79	65	237	32	69				
18	170	14:20	6.4	70	811	447	480	637	588	753	1025	304	140	81	65	236	32	71				
19	180	14:30	5.6	72	806	458	488	641	594	728	1085	299	138	81	66	237	32	71				
20	190	14:40	4.9	72	797	467	494	631	596	728	1105	300	138	81	66	234	32	70				

6064 1537 1347

DATE: 4-17-89

SIGNED BY: J. K. [Signature]

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 5 -- STOVE TEST DATA

Stove Mfg.: Marks Custom Stoves  
 Stove Model: E-400FS  
 Stove I.D. No.: 184  
 Run No.: 6  
 Date: 4-17-89

Data Set No.	ΔT	24 hr. Time	Test Fuel Wt. Lb.	TEMPERATURES										Catl. or Secondary Comb. (8)	Catl. or Secondary Comb. (16)	Flue		Dry Gas		Oven Temp °F (13)	Imp. Temp. °F (14)	Tracer Temp. °F (15)
				Stove Surfaces			Primary Comb. (7)	db (9)	wb (10)	In (11)	Out (12)											
				Amb. (1)	T(2)	B(3)						R(4)	RS(5)			LS(6)						
21	200	14:50	4.7	72	784	472	497	623	596	730	1092		276	104	79	66	212	34	71			
22	210	15:00	3.8	72	744	477	501	610	573	720	1057		273	127	80	67	233	34	71			
23	220	15:10	3.7	72	710	476	494	588	578	697	1039		282	127	80	67	231	34	70			
24	230	15:20	2.9	73	698	482	487	573	564	684	1027		277	125	80	67	257	35	71			
25	240	15:30	2.6	73	659	476	481	558	551	671	843		267	119	81	68	234	36	71			
26	250	15:40	2.4	73	620	470	477	532	532	649	868		248	113	80	68	257	37	72			
27	260	15:50	2.2	72	586	461	461	518	505	637	836		246	111	80	68	279	37	71			
28	270	16:00	2.0	73	569	453	457	511	503	622	832		246	110	77	69	242	38	69			
29	280	16:10	1.8	74	552	447	449	500	488	605	815		238	108	76	70	246	40	68			
30	290	16:20	1.6	74	537	429	443	491	477	589	802		235	107	76	69	246	41	68			
31	300	16:30	1.5	74	522	424	433	473	455	567	764		228	104	75	69	248	42	68			
32	310	16:40	1.4	72	496	422	426	463	441	546	747		222	101	75	68	248	43	69			
33	320	16:50	1.3	73	480	417	418	453	427	531	733		218	104	74	68	248	45	68			
34	330	17:00	1.1	73	471	409	403	450	416	524	759		222	110	74	68	248	46	68			
35	340	17:10	.9	73	464	401	424	475	412	532	721		216	109	74	68	248	47	67			
36	350	17:20	.6	73	465	389	405	493	421	534	736		217	110	74	67	248	48	67			
37	360	17:30	.4	72	473	375	465	508	436	568	743		222	110	74	67	248	49	67			
38	370	17:40	.1	74	476	365	477	570	444	569	732		217	107	74	66	248	51	67			
39	375	17:45	.0	73	476	361	483	571	445	526	726		219	106	74	66	248	52	68			
			Avg	71	645	440	440	513	485	598	900		274		77	68			69			

SIGNED BY: [Signature] DATE: 4-17-89  
 455.2°F  
 ΔT = -114.8°F  
 Avg EXHA = 505°F

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 6 - PARTICULATE TRAIN OPERATION

Stove Mfg.: Marks Custom Stoves  
Stove Model: K-400ES  
Stove I.D. No.: 184  
Run No.: 6

Date: 4-17-89  
Expected Burn Rate: Med High  
Oven Temp. Setting: 2480F  
Tracer Rota, mm: 60  
Tracer Pressure in H<sub>2</sub>O: 1.2

Data Point	24 hr. Time	Elap. Time Δt	SO <sub>2</sub>		CO <sub>2</sub> Scale	CO %	O <sub>2</sub> %	Orifice ΔH In H <sub>2</sub> O	Dry Gas Meter ft <sup>3</sup>	Vacuum in Hg	Stove Static Pressure In H <sub>2</sub> O	Comments
			Scale	ppm								
1	11:30	0	24	360	49	0.01	7.91	0.010	590.901	4.5	0.050	
2	11:40	10	25	325	37	.01	11.09	0.010	591.85	4.5	0.060	
3	11:50	20	22	330	43	.01	9.5	0.012	592.79	4.5	0.060	
4	12:00	30	20.5	307	49	.02	7.9	0.014	593.78	4.5	0.055	
5	12:10	40	20.5	307	53	.04	6.83	0.014	594.87	4.5	0.060	
6	12:20	50	19	285	50.5	.03	7.50	0.017	595.95	4.5	0.065	
7	12:30	60	19	285	53	.04	6.83	0.017	597.10	4.5	0.065	
8	12:40	70	20	300	59	.04	5.24	0.015	598.27	4.5	0.065	
9	12:50	80	20.5	307	58.5	.04	5.37	0.015	599.39	4.5	0.065	
10	13:00	90	20	300	60	.05	4.97	0.015	600.51	4.5	0.065	
11	13:10	100	19.5	292	59	.04	5.24	0.016	601.63	4.5	0.065	
12	13:20	110	20	300	58.5	.04	5.37	0.015	602.77	4.5	0.065	
13	13:30	120	21	315	67.5	.50	2.17	0.014	603.91	4.5	0.065	
14	13:40	130	20	300	67	.25	2.99	0.015	604.98	4.5	0.065	
15	13:50	140	21.5	322	65.5	1.50	2.63	0.013	606.09	4.5	0.060	
16	14:00	150	20.5	307	67	4.0	1.71	0.015	607.12	4.5	0.060	
17	14:10	160	21.5	322	68.5	2.15	1.94	0.013	608.22	4.5	0.060	
18	14:20	170	21.5	322	69	.35	2.4	0.013	609.25	4.5	0.060	
19	14:30	180	22	330	69	.35	2.4	0.013	610.28	4.5	0.060	
20	14:40	190	22.5	337	68	.30	2.7	0.012	611.31	4.5	0.055	
21	14:50	200	22	330	64.5	.13	3.73	0.013	612.25	4.5	0.055	
22	15:00	210	22.5	337	58.5	.02	5.39	0.012	613.28	4.5	0.050	
23	15:10	220	22.5	337	56.5	.02	5.92	0.012	614.24	4.5	0.050	
24	15:20	230	23	345	54	.02	6.88	0.011	615.18	4.5	0.050	
25	15:30	240	23.5	352	45	.02	8.96	0.011	616.11	4.5	0.050	

SIGNED: [Signature] DATE: 4-17-89 1.475

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 6 - PARTICULATE TRAIN OPERATION

Stove Mfg.: Marks Custom Stoves  
 Stove Model: 6-400 FS  
 Stove I.D. No.: 6  
 Run No.: 6  
 Date: 4-17-89  
 Expected Burn Rate: Med High  
 Oven Temp. Setting: 2480°F  
 Tracer Rota, mm: 60  
 Tracer Pressure in H<sub>2</sub>O: .12

Data Point	24 hr. Time	Elap. Time Δt	SO <sub>2</sub>		CO <sub>2</sub> Scale	CO %	O <sub>2</sub> %	Orifice ΔH In H <sub>2</sub> O	Dry Gas Meter ft <sup>3</sup>	Vacuum in Hg	Stove Static Pressure In H <sub>2</sub> O	Comments
			Scale	ppm								
1	15:40	250	25	375	41	.01	10.03	.010	617.03	<.5	.050	
2	15:50	260	24.5	367	40.5	.01	10.16	.010	617.92	<.5	.050	
3	16:00	270	25.5	382	40	.01	10.29	.009	618.82	<.5	.040	
4	16:10	280	25	375	39	.01	10.56	.010	619.69	<.5	.040	
5	16:20	290	26	370	37.5	.01	10.96	.009	620.62	<.5	.040	
6	16:30	300	27	405	34.5	.01	11.75	.008	621.52	<.5	.040	
7	16:40	310	27	405	34.5	.01	11.75	.008	622.37	<.5	.040	
8	16:50	320	28	420	33	.01	12.15	.008	623.27	<.5	.040	
9	17:00	330	28	420	39.5	.01	10.43	.008	624.07	<.5	.040	
10	17:10	340	28	420	41.5	.01	9.9	.008	624.92	<.5	.040	
11	17:20	350	28	420	44	.01	9.23	.008	625.76	<.5	.035	
12	17:30	360	28	420	43.5	.01	9.37	.008	626.60	<.5	.035	
13	17:40	370	28	420	44	.01	9.23	.008	627.44	<.5	.035	
14	17:45	375	28	420	44	.01	9.23	.008	627.861	<.5	.035	
15					51.44	0.26		0.012	36.96		-0.052	
16			avg		12.86							
17												
18												
19												
20												
21												
22												
23												
24												
25												


SIGNED: [Signature] DATE: 4-17-89



NORTHWEST TESTING LABORATORIES, INC.  
 Woodstove Emission Testing

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400 FS  
 Stove I.D. No.: 184  
 Run No.: 6  
 Date: 4-17-89


	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:		PRE-Test Calibration		
ZERO GAS:	0.0	0.0	NA	0.0
AUDIT GAS:	59.9	5.01	}	54.2
DESIRED:	59.9	5.01		54.2
PERCENT DIFFERENCE:	0.0%	0.0%	↓	0.0%
TIME (24 HOUR):	11:00	11:00		11:00

SIGNED:   
 DATE: 4-17-89

NORTHWEST TESTING LABORATORIES, INC.  
 Woodstove Emission Testing

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400FS  
 Stove I.D. No.: 184  
 Run No.: 6  
 Date: 4-17-89


	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:		120		
ZERO GAS:	0.0	0.0	N/A	0.5
AUDIT GAS:	59.9	5.01	}	34.8
DESIRED:	59.9	5.01		34.2
PERCENT DIFFERENCE:	0.0%	0.0%	✓	3.2%
TIME (24 HOUR):	13:30	13:30		13:30

SIGNED:   
 DATE: 4-17-89

NORTHWEST TESTING LABORATORIES, INC.  
 Woodstove Emission Testing

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400 FS  
 Stove I.D. No.: 184  
 Run No.: 6  
 Date: 4-17-89

	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:		240		
ZERO GAS:	0.0	0.0	NA	0.5
AUDIT GAS:	59.9	5.01	}	3.48
DESIRED:	59.9	5.01		34.2
PERCENT DIFFERENCE:	0.0%	0.0%	↓	3.2%
TIME (24 HOUR):	15:30	15:30		15:30

SIGNED:   
 DATE: 4-17-89

NORTHWEST TESTING LABORATORIES  
Woodstove Emmission Testing

PAGE 7 - POST TEST DATA

Stove Mfg.: Marks Custom Stoves Run No.: 6  
 Stove Model: K-400FS Date: 4-17-89  
 Stove I.D. No.: 184 Time: 18:00

Analyzer Audit

	Scale Readings			
	CO <sub>2</sub>	O <sub>2</sub>	CO	SO <sub>2</sub>
Zero Gas	<u>0.0</u>	<u>N/A</u>	<u>0.0</u>	<u>0.5</u>
Audit Gas	<u>59.9</u>	<u>✓</u>	<u>5.01</u>	<u>74.8</u>
Desired	<u>59.9</u>	<u>✓</u>	<u>5.01</u>	<u>74.2</u>
% Difference	<u>0.0%</u>	<u>✓</u>	<u>0.0%</u>	<u>3.2%</u>
% Drift Check:				
Zero Drift	<u>0.0%</u>		<u>0.0%</u>	<u>0.5%</u>
Mid Level Drift	<u>0.0%</u>		<u>0.0%</u>	<u>0.6%</u>
Leak Test Results	<u>OK</u>			<u>→</u>

Particulate Train  
 Leakage Rate: .001 ft<sup>3</sup>/min.  
 Extra Filters Used: N/A

Ambient

Tdb 72 °F 29.945  
 Twb 58 °F 1.2  
 Pbaro 29.95 in Hg.  
 Moisture 1.2 % By Volume  
 Relative Humidity, % 42

SIGNED: [Signature] DATED: 4-17-89

SAMPLE EXTRACTION DATA

Stove Mfg.: Marks Custom Stoves Test: 7  
 Stove Model: K-400 FS Test Cycle: High  
 Date: 4-18-89 Stove I.D. No.: 184  
 Technician: D Windsor

Vv

	CONDENSED WATER VOLUME, GMS			
	Modified Temp. 100 ml H2O	Standard Imp 100 ml Hz	Modified Imp. Dry	Modified Imp. 200 Gms Silica Gel
Gross Weight	621.6	609.2	487.3	742.6
Initial Weight	563.4	607.5	487.3	738.2
Net Weight	58.2	1.7	0.0	4.4

TOTAL 64.3 GMS

W

	PARTICULATE CATCH, GMS			
	OVEN FILTER(S)		TRAIN FILTER(S)	
Gross Weight	8046			7840
Initial Weight	7619			7768
Net Weight	0.0427			0.0072

TOTAL

TOTAL 0.0499 GMS

#1505

	Front Catch Probe	Rear Catch Impingers	DCM	H2O	TOTAL
	Beaker, ml	45ml	125ml	150ml	
Gross, Weight	95.4469	101.4671	96.0613	104.0679	
Initial Weight	95.4213	101.4259	96.0361	104.0515	
Net Weight	0.0256	0.0432	0.0252	0.0164	
Evaporation	0.0004	0.0011	0.0009	0.0026	
Residue Weight	0.0252	0.0421	0.0243	0.0138	

TOTAL 0.1054 GMS

0.0673

0.0381

Total Particulate = 0.1553 g  
 = 155.3 mg



METHOD 5H FLOW RATE (STACK) CALCULATIONS  
(Put general info in col B, data info in col H.)

Lab name: NORTHWEST TESTING LABS, INC.                    Yhc 1=cat,2=ncat :                    1  
Stv manu: MARKS CUSTOM STOVES                            Wc (if supplied) :  
Model no: K-400 FREESTANDING                            Burn rate (kg/hr):                    4.73  
Tst Date: APRIL 18, 1989                                 Run Number                            :                    7

---

run time (min)	O2 (%)	CO2 (%)	CO (%) (1.-1.12)	Fo	Stack Gas Flow Rate		
					(dscfh)	(dscfm)	(dsm3/hr)
0	3.90	15.80	0.45	1.06	1028.27	17.14	29.15
10	2.10	16.40	2.35	1.07			
20	3.00	16.50	0.62	1.06			
30	2.80	16.50	1.00	1.06			
40	1.63	17.40	1.40	1.06			
50	1.62	17.50	1.20	1.06			
60	4.10	15.80	0.20	1.06			
70	5.20	14.80	0.10	1.06			
80	4.80	15.10	0.08	1.06			
90	6.04	14.00	0.03	1.06			
100	9.35	10.90	0.04	1.06			
110	10.14	10.10	0.04	1.06			

Method 5H Proportionality Rate and Sample Volume Calculation  
 (put general info in col. C; Pb,Y,& unit info in col. G)

```

=====
Lab name: NORTHWEST TESTING LAB., INC.           Units 1=metric,
Stv manu: MARKS CUSTOM STOVES                   2=English:      2.0
Model no: K-400 FREESTANDING                     Y, DGM:        0.971
1st date: APRIL 18, 1987                         Ph (mm,in. Hg): 30.0
Run no  :      7.0
    
```

NOTE: Input raw data below, use F9 for CALC.

run time (min)	tracer conc (ppm,%)	DGM rdg (m3,ft3)	DGM temp (C,F)	DGM dH (mm H2O) (in.H2O)	dDGM vol std (m3,ft3)	PR (%)	Sample vol std (m3,ft3)
0	187.0	627.913	75	0.023			
10	172.0	629.400	76	0.028	1.427	103.7	17.244
20	180.0	631.000	76	0.025	1.532	102.4	
30	165.0	632.480	76	0.030	1.417	99.1	
40	157.0	634.090	76	0.034	1.542	98.9	
50	165.0	635.800	76	0.031	1.638	99.9	
60	157.0	637.430	75	0.034	1.561	100.1	
70	157.0	639.140	75	0.034	1.641	100.1	
80	157.0	640.820	74	0.033	1.612	98.3	
90	157.0	642.490	75	0.033	1.605	97.9	
100	157.0	644.190	74	0.033	1.631	99.5	
110	157.0	645.895	74	0.033	1.639	100.0	



NORTHWEST TESTING LABORATORIES  
Hoods/ stove Emission Testing

PAGE 1 - STOVE INFORMATION AND PRE-TEST DATA

Stove Manufacturer: Marks Custom Stoves  
Stove Model: K-400 FS  
Stove I.D. Number: 184  
Run Number: 7  
Date: 4-18-89  
Expected Burn Rate: High

STOVE

Weight: 502.1 lb.  
Platform Scale Audit?: OK  
Primary Air Control Setting: 2" open Both Sides  
Blower: On OFF Auto. N/A   
Flue Pipe Gauge: 24  
Flue Pipe Diameter in.: 8 in.  
Pictures: Yes  No   
Operating Instructions: Other  written  
Stove Manual Verbal Other   
Stack Cleaned: Yes  No

CATALYST Yes  No

Catalyst Brand: Applied Ceramics  
Catalyst I.D.: Firecat, 2 1/2 x 7 1/2 x 3, 16 cell  
Catalyst Age: 50+ hrs  
Catalyst Provided: Marks Custom Stoves

AMBIENT

Dry Bulb Reading 74 °F  
Wet Bulb Reading 65 °F  
Relative Humidity 62 %  
Baro. 29.99 in Hg.

% Moisture 1.8 % Volume

CONTINUOUS ANALYZERS

Audited by: T. Palysner  
Leak Tested by: T. Palysner

PARTICULATE TRAIN

Probe Length & Type 6" Pyrex  
Nozzle Size 1.62 in.  
Inlet 6"  
Magnehelic Range, 0-7 in H2O  
Leakage Rate: 0.011 Ft.3/min.

TRACER GAS

Gas Used: SO2  
Rotameter No.: 601  
Rotameter Rdg.: 60  
Ball Read: 55  
CC/Min.: 70.62  
ft.3/hr. 11.5  
(cc/min. ÷ 472 = ft.3/hr.)  
Injection System Rate  
Checked: Yes  No

SIGNED BY: T. Palysner

DATE: 4-18-89

PAGE 2 - FUEL DATA

Stove Manufacturer: Marks Custom Stoves Run Number: 7  
Stove Model: K-400FS  
Stove I.D. Number: 184  
Technician: T. Palmer  
Expected Burn Rate: High  
Calculated Charge Wt.: 24.8  
Coal Bed Wt. Lbs.: 4.7  
HHV Sample: Yes  No   
(Saw Dust Catch & Block)

I. Fuel Moisture Content, % (Dry Basis):

1. <u>19.2</u>	11. <u>19.2</u>	21. _____
2. <u>19.2</u>	12. <u>19.8</u>	22. _____
3. <u>19.2</u>	13. <u>19.2</u>	23. _____
4. <u>21</u>	14. <u>19.2</u>	24. _____
5. <u>20.5</u>	15. <u>21</u>	25. _____
6. <u>20</u>	16. <u>20.5</u>	26. <u>23.7</u>
7. <u>19.2</u>	17. <u>20</u>	27. <u>23.1</u>
8. <u>19.8</u>	18. <u>20.7</u>	28. <u>20.9</u>
9. <u>19.8</u>	19. <u>21</u>	29. <u>19.2</u>
10. <u>19.2</u>	20. _____	30. <u>24.3</u>
		<u>21.5</u>
		<u>23.7</u>

II. Test Fuel:

1. No. of 2 x 4's: 0  
2. No. of 4 x 4's: 5  
3. Total No. of Fuel Pieces: # 26 → # 30  
4. Weight, Lbs.: 23.4  
5. Species: D.F.  
6. Moisture Content, % Ave. (Dry Basis): 22.43  
7. Length, In.: 20"

III. Pre-Burn Fuel:

1. No. of 2 x 4's: 12  
2. No. of 4 x 4's: 0  
3. Total No. of Fuel Pieces: # 1 → # 12  
4. Weight, Lbs.: 23.9  
# 2 = 6.3  
5. Species: D.F.  
6. Moisture Content, % Ave. (Dry Basis): 20.3  
7. Length, In.: 21" ÷ 3 = 7"

IV. Kindling Fuel:

1. No. of 2 x 4's: 0  
2. No. of 4 x 4's: 1 1/2  
3. Total No. of Fuel Pieces: \_\_\_\_\_  
4. Weight, Lbs.: 4.4  
5. Species: D.F.  
6. Moisture Content, % Ave. (Dry Basis): 19.02  
7. Length, In.: 16"

Date: 4-20-89

Attention: Mike Cave

Subject: Analysis on one (1) wood fuel sample received 4-18.

Item: Wood Fuel

Reference: Marks Custom Stoves  
K-400 FS  
184-7  
High

REPORT:

Analysis:

Moisture, %, as received .....	<u>18.0</u>
Moisture, %, dry basis .....	<u>21.9</u>
Density, g/cm <sup>3</sup> , dry basis .....	<u>0.57</u>
Higher Heat of Combustion, BTU/lb., dry basis .....	<u>8615</u>

Robert W Hardaker

Report Number: 321591

**WOOD/FUEL**  
(ON NTL STOVE DISK)

D800 charges <sup>5170</sup>



PAGE 3 - STOVE OPERATION LOG

Stove Mfg.: Marks Custom Stoves Date: 4-18-89  
Stove Model: K-400 FS Technician: T. Palmer  
Stove I.D. Number: 184  
Run Number: 7

24 Hr. Time

OPERATION

10:52 Lit 4.4 lbs of kindling, Door Air  
Air controls open 2" each side  
By-Pass open  
10:53 Shut Door  
11:00 Added #1 Pre-Burn  
11:05 Shut By-Pass  
11:10 Started Pre-Burn Readings  
11:32 Added 6.3 lb of Pre-Burn  
12:07 Added 5.4 lbs  
12:30 Added Test Fuel 23.4 lbs  
12:31+30 Shut Door & By-Pass

Stove Mfg.: Marks Custom Stoves Run Number: 7  
 Stove Model: K-400 FS Date: 4-18-89  
 Stove I.D. No.: 184 Air Control Setting: 2" open

Data Set No.	Elapsed 24/Hr. Time	TEMPERATURES										Fuel Wt/lb	Prim. Temp. (7)	Cat. Temp. (8)	Cat. Temp. (16)	
		Amb. (1)	T(2)	B(3)	R(4)	RS(5)	LS(6)	Stove Surfaces								
1	11:10	66	596	185	122	577	447	19.5	496	1108						
2	11:15	68	814	275	173	600	450	14.6	639	1196						
3	11:20	69	890	325	417	616	580	14.0	690	1222						
4	11:25	70	951	397	474	636	580	11.5	760	1168						
5	11:30	72	985	477	573	663	628	9.7	799	1227						
6	11:35	71	958	484	657	708	671	13.7	772	1228						
7	11:40	71	997	530	616	720	655	11.7	782	1300						
8	11:45	76	1024	560	610	712	704	9.2	878	1327						
9	11:50	77	1048	583	616	755	726	8.4	1056	1298						
10	11:55	79	1059	614	644	790	837	6.9	1015	1297						
11	12:00	80	1072	634	671	800	843	5.9	979	1306						
12	12:05	79	1047	656	694	808	810	5.7	983	1292						
13	12:10	78	955	666	711	767	792	5.1	896	1228						
14	12:15	77	1004	675	675	692	769	7.6	784	928						
15	12:20	80	1023	681	701	785	804	6.5	944	1257						
16	12:25	80	1056	686	712	798	823	5.5	997	1304						
	12:30		Added	Test Fuel				4.7								

4.7-7 5.9  
 = STOKED +  
 Added  
 6.3 lbs  
 = Added  
 5.4

SIGNED: [Signature] DATE: 4-18-89

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400 FS  
 Stove I.D. No.: 184  
 Run No.: 7  
 Date: 4-18-89

+ 116

Data Set No.	24 hr. Time	Test Fuel Wt. lb.	TEMPERATURES										Flue		Dry Gas		Oven Temp °F (13)	Imp. Temp. °F (14)	Tracer Temp. °F (15)		
			Amb. (1)	Stove Surfaces			823/8		Primary Comb. (7)	CatL. or Secondary Comb. (8)	CatL. or Secondary Comb. (16)	db (9)	wb (10)	In (11)	Out (12)						
ΔT			T(2)	B(3)	R(4)	RS(5)	LS(6)														
1	12:30	21.4	81	1032	687	721	821	856	1118	1302				456	158	77	77	247	52	72	
2	12:40	20.9	81	979	686	578	675	675	659	1280				470	165	75	76	229	52	72	
3	12:50	18.0	87	1029	695	557	624	667	742	1298				476	166	76	76	232	52	72	
4	13:00	15.4	87	1037	676	536	657	703	836	1319				476	168	77	75	236	52	71	
5	13:10	12.4	83	1043	647	554	694	805	1006	1311				487	171	77	74	238	53	71	
6	13:20	9.7	83	1041	620	593	778	882	1203	1346				484	169	78	73	238	53	71	
7	13:30	7.2	83	1031	589	625	914	910	1076	1306				464	167	78	72	240	54	70	
8	13:40	5.0	83	1023	561	698	918	890	1035	1294				455	166	78	71	245	54	71	
9	13:50	3.7	84	969	550	676	906	880	966	1281				427	161	78	70	244	54	70	
10	14:00	1.9	85	870	572	220	934	873	1014	1185				412	157	79	70	245	54	71	
11	14:10	.8	85	867	579	764	907	839	917	1089				400	150	79	69	242	53	71	
12	14:20	.0	84	792	607	763	892	800	821	1008				384	148	79	69	240	53	71	
		avg	83	981	624	643	802	815	949	1252				449		77	73				71

SIGNED BY: J. Adams DATE: 4-18-89  
 ΔT = -63.0°F  
 Avg skin = 773°F

NORTHWEST TESTING LABORATORIES, INC.  
Woodstove Emission Testing

PAGE 6 - PARTICULATE TRAIN OPERATION

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400 FS  
 Stove I.D. No.: 184  
 Run No.: 7  
 Date: 4-18-89  
 Expected Burn Rate: High  
 Oven Temp. Setting: 248°F  
 Tracer Rota, mm: 60  
 Tracer Pressure in H<sub>2</sub>O: .12

Data Point	24 hr. Time	Elap. Time Δt	SO2 ppm		CO2 Scale	CO %	O2 %	Drifrice ΔH In H2O	Dry Gas Meter ft 3	Vacuum in Hg	Stove Static Pressure In H2O	Comments
			Scale	ppm								
1	12:30	0	12.5	187	63	.45	3.93	.023	627.913	5.5	.090	
2	12:40	10	11.5	172	65.5	2.35	3.11	.028	629.40	5.5	.095	
3	12:50	20	12	180	66	.62	3.03	.025	631.00	5.5	.090	
4	13:00	30	11	165	66	1.0	2.8	.030	632.48	5.5	.095	
5	13:10	40	10.5	157	67.5	1.40	1.63	.034	634.09	5.5	.095	
6	13:20	50	11	165	70	1.20	1.62	.031	635.80	5.5	.090	
7	13:30	60	10.5	157	63	.20	4.1	.034	637.43	5.5	.090	
8	13:40	70	10.5	157	59	1.0	5.2	.034	639.14	5.5	.090	
9	13:50	80	10.5	157	60.5	1.08	4.82	.033	640.82	5.5	.085	
10	14:00	90	10.5	157	56	1.03	6.04	.033	642.49	5.5	.085	
11	14:10	100	10.5	157	43.5	1.04	9.35	.033	644.19	5.5	.085	
12	14:20	110	10.5	157	40.5	1.04	10.14	.033	645.895	5.5	.080	
13												
14												
15					60.21	0.63		0.031	17.982		-0.090	
16			avg		15.05							
17												
18												
19												
20												
21												
22												
23												
24												
25												


SIGNED: [Signature] DATE: 4-18-89



NORTHWEST TESTING LABORATORIES, INC.  
 Woodstove Emission Testing

Stove Mfg.: Marks Custom Stoves  
 Stove Model: K-400FS  
 Stove I.D. No.: 184-7  
 Run No.: 7  
 Date: 4-18-89

	CO <sub>2</sub>	CO	O <sub>2</sub>	SO <sub>2</sub>
ANALYZER AUDIT:		PRE-Test Calibration		
ZERO GAS:	0.0	0.0	NA	0.0
AUDIT GAS:	59.9	5.01	}	34.2
DESIRED:	59.9	5.01		34.2
PERCENT DIFFERENCE:	0.0%	0.0%		↓
TIME (24 HOUR):	12:00	12:00		12:00

SIGNED:   
 DATE: 4-18-89

NORTHWEST TESTING LABORATORIES  
Woodstove Emission Testing

PAGE 7 - POST TEST DATA

Stove Mfg.: Mark Custom Stoves  
 Stove Model: K-400FS  
 Stove I.D. No.: 184  
 Run No.: 7  
 Date: 4-18-89  
 Time: 14:35

Analyzer Audit

Scale Readings

	CO <sub>2</sub>	O <sub>2</sub>	CO	SO <sub>2</sub>	Particulate Train
Zero Gas	<u>0.0</u>	<u>NA</u>	<u>0.0</u>	<u>0.5</u>	Leakage Rate: <u>.002</u> ft <sup>3</sup> /min.
Audit Gas	<u>59.3</u>		<u>4.98</u>	<u>55.0</u>	Extra Filters Used: <u>NA</u>
Desired	<u>59.9</u>		<u>5.01</u>	<u>34.2</u>	
% Difference	<u>1.0%</u>		<u>0.6%</u>	<u>3.8%</u>	
% Drift Check:			<u>0.0%</u>	<u>0.5%</u>	
Zero Drift	<u>0.0%</u>		<u>0.3%</u>	<u>0.8%</u>	
Mid Level Drift	<u>0.6%</u>				
Leak Test Results	<u>OK</u>				

Ambient

Tdb 85 °F  
 Twb 68 °F  
 Pbaro 29.94 in Hg. 29.965  
 Moisture 1.7 % BY Volume 1.75  
 Relative Humidity, % 42

SIGNED: [Signature] DATED: 4-18-89