

Myren Consulting, Inc.

**United States
Environmental Protection Agency
Woodheater Certification Program
Woodheater Certification Test Report**

**Kuma Stove and Iron Works
Kuma Wood Classic
Model HT-2
Noncatalytic Wood Stove**

September 30, 1999

Myren Consulting, Inc.

Office:

**512 Williams Lake Road
Colville, WA 99114
(509)684-1154
Fax: (509)685-2262**

Laboratory:

**501-C Williams Lake Road
Colville, WA 99114
(509)685-9458**

* * * * *

CONFIDENTIAL

* * * * *

The data and information in this test report is confidential, proprietary information and is not to be released to and/or discussed with any party who is not authorized by the manufacturer or the testing laboratory to receive such data.

* * * * *

CONFIDENTIAL

* * * * *

TABLE OF CONTENTS

	<u>Section(s)</u>	<u>Page(s)</u>
Introduction		
Title Page	Introduction	i
Confidentiality Statement		ii
Table of Contents		iii
Field Observation Checklist		v
Report Certification		vi
Test Report (Data) Page Number Index		vii
Individual Test Run Page Number Index		x
Statement of Confidentiality		xi
Test Series Information and Discussion		xii
Summary and Discussion of Results		
Weighted Average Calc Sheets	Data Summary	1-3
Cap Graph		4
Data Summary		5-7
Stove/Cat Aging Data	Aging	vari
Individual Test Runs (Raw Data)		
See Introduction, Individual Test Run	<0.8 kg/Hr	vari
Page Index for a complete, sequential list	0.8-1.25 kg/Hr	vari
of the data and data sequence in the	1.26-1.90 kg/Hr	vari
individual test runs	>1.90 kg/Hr	vari
Calibration Data	Cal Data	vari
See Test Report (Data) Page Number Index,		
Item 14, for a complete, sequential listing		
of the data in this section.		
Stove QC		
Wood Heater Description/Stove QC	Stove QC	1-2
Useable Firebox Volume Dimensions and Calculations		3
Primary Air Inlet Dimensions and Settings		5
Secondary Air Inlet Dimensions and Settings		5
Blueprints		
Promotional (Sales) Brochure	Blueprints	vari
Laboratory verified blueprints		vari
Manual		
Manufacturer's Written Test Instructions	Manual	1-2
Manufacturer's Operators Manual		vari
Storage		
Storage Location	Storage	1
Sealing Information		1

Photos:

This section contains two photographs of the fuel load for each test run and two color photographs (side and front view) of the wood heater tested and any other photographs pertinent to testing the unit.

Photos

vari

REPORT CERTIFICATION

The sampling and analysis for the woodstove described in this report was carried out under my direction and supervision.

Date 9/30/99 Signature Albert V. Myrum Jr.

Date _____ Signature _____

I have reviewed all of the testing data and results found in this test report and hereby certify that the test report is authentic and accurate.

Date 9/30/99 Signature Albert V. Myrum Jr.

Field Observation Checklist

Unit Name: Kuma Wood Classic Date: 9/30/99

Manufacturer Name: Kuma Stove and Iron Works

Manufacturer Address: 450 Old Highway 95
Rathdrum, ID 83858

Manufacturer Phone: 208 762 8002 Fax: 208 762 5862

Observers & Affiliation: _____

Myren Consulting's Field Team:

Supervisor: Ben Myren John Palm

Other Members: Ron Schenck Ilse Myren

Orion Myren Thyer Myren

Test Location: 501-C Williams Lake Road, Colville, WA 99114

(509)685-9458

Test Site Elevation: 1645 Feet

Lab:
501-C Williams Lake Road
Colville, WA 99114
(509)685-9458

Office:
512 Williams Lake Road
Colville, WA 99114
(509)684-1154
Fax: (509)685-2262

PAGE NUMBER INDEX

	<u>Section</u>	<u>Location</u>
1. Summary Table of Burn Rate and Emission Rate Results	Data Summary	Weight Avg Calc Sheet, pp.1-4
2. Summary Table of Other Data	Data Summary	Data Summary Sheets, pp 5-7
3. Wood Heater Description	Stove QC	Wood Heater Description, p.1 (vari)
4. Manufacturer's Testing Instructions	Operators Manual	P.1 of Section
5. Test Chamber Installation Description	Installation Description	P. 1
6. Wood Heater/Catalyst Aging Documentation	Stove/Cat Aging	
7. Wood Heater Dimensions and Useable Firebox Volume	Stove QC	
8. Pretest Burn Procedures	Individual Test Runs	Data Sheets #9, 9A, 9A-1, 9A-2, 13
9. Pretest Facility Measurements	Individual Test Runs	Data Sheets #8, 16
10. Test Fuel Measurements	Individual Test Runs	Data Sheet #8
A. Load Wt.	Individual Test Runs	Data Sheet #10
B. Load Moisture	Individual Test Runs	Data Sheet #11
C. Wood Density	Individual Test Runs	
11. Test Fuel Crib Description	Photographs	
A. Photographs	Individual Test Run	Data Sheet #9A, 9A-1, or 9A-2
B. Wood Type and Line Drawing	Individual Test Run	Data Sheets #9, 9A, 9A-1, 9A-2, 13
12. Test Run Heater Operation and Air Supply Settings	Individual Test Run	
13. Calibrations		
A. Platform Scale		
1. Initial	Cal Data P. 1	
2. Semi Annual	Cal Data P. 2	
3. Pre and Post Test	Individual Test Run	Data Sheet #16

B. Analytical Balance		
1. Initial	Cal Data	P. 3
2. Semi Annual	Cal Data	P. 4
3. Pre Weighing Check	Individual Test Run	Data Sheet #4
C. Temperature		
1. Thermocouples	Cal Data	P. 5
2. Thermocouple Readout		
a. Semi annual	Cal Data	P. 6
b. Daily Check	Individual Test Run	Data Sheet #16
3. Dry Gas Meter	Cal Data	P. 7
D. Anemometer	Cal Data	P. 11
E. Barometer	Cal Data	P. 12
F. Draft Gauge	Cal Data	P. 13
G. Humidity Gauge Calibration (Sling Psychrometer)		
H. Dry Gas Meter		
1. Initial	Cal Data	P. 14
2. Semi Annual	Cal Data	P. 15
3. Post Certification Test	Cal Data	P. 16
4. Transfer Standard Calibration	Cal Data	P. 17
5. Wet Test Meter Calibration	Cal Data	P. 18
J. Combustion Gas (CO ₂ , O ₂ , CO) Train Response Check	Cal Data	P. 20
L. CO Analyzer		
1. Calibration	Cal Data	P. 22
2. Zero/Span Control Chart	Cal Data	P. 23
3. Pre and Post Test Zero/Span	Individual Test Run	Data Sheet #15-3
M. CO ₂ Analyzer		
1. Calibration	Cal Data	P. 24
2. Zero/Span Control Chart	Cal Data	P. 25
3. Pre and Post Test Zero/Span	Individual Test Run	Data Sheet #15-1
N. O ₂ Analyzer (Optional)		
1. Calibration	Cal Data	P. 26
2. Zero/Span Control Chart	Cal Data	P. 27
3. Pre and Post Test Zero/Span	Individual Test Run	Data Sheet #15-2
P. Calibration Gas Certificates of Analysis		
1. The Pre and Post Test Zero/Span Audits	Individual Test Runs	Data Sheets #15-1,15-2,15-3,15-4

2. Method 3 Verification of Analysis (CO ₂ , O ₂ , CO, N ₂)	Cal Data	
14. Quality Checks		
A. Leak Checks		
1. Particulate Sampling Train	Individual Test Runs	P. 1 of Data Sheet #2
2. Combustion Gas (CO ₂ , O ₂ , CO) (CEM) Train	Individual Test Runs	Data Sheet #16
B. Proportional Checks	Individual Test Runs	Table 1
		Computer Printout
15. Sample Calculations		
A. Weighted Average Emission Rate	Data Summary	Weighted Average Calc Sheets, pp.1-3
B. Dry Burn Rate	Individual Test Runs	Data Sheet #8 Computer Printout
16. Raw Test Data		
17. Analytical Data		
A. Filter and Beaker Tares	Individual Test Runs	Data Sheets 1 - 16
B. Solvent Blanks	Individual Test Runs	Data Sheets #4-1, 4-2
C. Particulate Catches	Individual Test Runs	Data Sheet #4-3, 5-3
1. Gross	Individual Test Runs	Data Sheets #5-1, 5-2
2. Blanks	Individual Test Runs	Data Sheets #5-3
3. Net	Individual Test Runs	Data Sheet #6
D. Constant Weight Weighings	Individual Test Runs	Data Sheet #4-3

M5G-1 INDIVIDUAL TEST RUN PAGE INDEX
The Data Sheets in the Individual Test Runs
Are Organized in the Following Sequence

A. Computer Printouts

Table 1 Field Data - Sampling Interval Data
Table 1 Field Data
Table 1 Field Data Averages
Table 1 Calculations
Table 1 Proportional Rate Variation

B. Raw Data Sheets

	No. of Pages
Data Sheet #2 Meterbox Data Sheets	variable
Data Sheet #4 Scale Sheets	
#4-1 Initial Filter Weights	variable
#4-2 Initial Beaker Weights	variable
#4-3 Constant Weights	variable
#4-4 Scale QA Checks	variable
Data Sheet #5 Particulate Catch Processing Sheet	
#5-1 Front and Back Half Catch	1
#5-3 Blank Catch	1
Data Sheet #6 Net Particulate Catch Calc Sheet	1
Data Sheet #8 Miscellaneous Test Data	1
Data Sheet #9 Stove Operating Data	1
Data Sheet #9A 1-4 Stove Operating Data	variable
Data Sheet #10 Fuel Moisture	1
Data Sheet #11 Wood Density	1
Data Sheet #12 Burn Rate and Flue Gas Data	variable
Data Sheet #13 Pre Burn Data	variable
Data Sheet #14 Temperature Data	variable
Data Sheet #15 Pre and Post Test Zero/Span Audits	
#15-1 CO ₂	1
#15-2 O ₂	1
#15-3 CO	1
Data Sheet #16 Quality Checks	1

STATEMENT OF CONFIDENTIALITY

As a condition of being allowed to visit the woodstove testing facility and/or observe a woodstove test(s) at Myren Consulting, Inc.'s testing laboratory located at Suite 106, 12810 NE 178th St., Woodinville, WA 98072, I hereby agree not to release or divulge any information about the design engineering principals used at Myren Consulting, the testing facility, the testing personnel or the testing procedures (other than the information found in the Standard Method for Measuring the Emissions and Efficiencies of Residential Woodstoves promulgated by the Oregon Department of Environmental Quality (DEQ) and/or Methods 28, 28A, 5G and 5H promulgated by the United States Environmental Protection Agency (EPA) to any other individual or firm unless specifically authorized to do so by an authorized person from Myren Consulting.

SIGNED: _____
Name

Title

Affiliation

Date

SIGNED: _____
Name

Title

Affiliation

Date

Test Series Information and Discussion

Unit: Kuma Wood Classic Noncatalytic Woodstove

Model #: HT-2

Manufacturer: Kuma Stove and Iron Works

Date Received: 9/8/99 Date(s) Aged: 9/8 & 9/99

Test Dates: 9/11, 13, 14, 15, 16, 17 and 18/1999

Sampling Methods Used: M28, 5G-1 Number of Test Runs: 7

The Kuma Wood Classic Noncatalytic Wood Stove
manufactured by Kuma Stove and Iron Works

of Rathdrum, ID was tested by Myren Consulting, Inc. using the United States Environmental Protection Agency's (EPA) Method 28, "Certification and Auditing of Wood Heaters", Method 5G-1 "Determination of Particulate Emissions from Wood Heaters from a Dilution Tunnel Location." And, if applicable, Method 28A, "Measurement of Air to Fuel Ratio and Minimum Achievable Burn Rates for Wood Fired Appliances". (See the Federal Register/ Vol. 53, No. 38/ Friday, February 26, 1988/ pp. 5860-5926.) The Particulate Matter (PM) emission data, if present, was calculated as specified in the Wood Heater New Source Performance Standard (NSPS).

If computed and reported, Oregon Overall Efficiency (%OE) for each run was calculated using the computer program supplied by the State of Oregon's Department of Environmental Quality (DEQ) as part of the "Standard Method for Measuring the Emissions and Efficiency of Residential Woodstoves". The weighted average overall efficiency was calculated using the overall efficiency data for each run and the EPA Burn Rate Probabilities for calculating weighted averages.

All events pertinent to the test data and test results are recorded on the data sheets in the individual test runs, particularly on pp. 9, 9A, 9A-1 and 12.

Any deviations made or noted from the promulgated methods other than those which were accepted and certified by the EPA and/or the DEQ during the laboratory accreditation process are listed and discussed below.

A brief note about how the particulate samples were processed is necessary to help the reviewer understand the net catch values. Experience has shown that the small portions of the filters left on the frits in the M5G-1 filter housing apparatus are full of static electricity and when these small portions are removed to a plastic petri dish, they quickly adhere to the dish. Trying to recapture this material during weighing causes it to disintegrate into smaller and smaller pieces, making obtaining accurate catch weights difficult. Thus, it was decided to place this material in with the particulate captured with the acetone wash, where it shows up as catch. Some of the filter material was already following this pathway. Thus, there may be negative filter weight catches, particularly for the back half filter, that are used during the particulate emission rate calculation process. However, the filter material lost off the filters is accounted for in the acetone catch.

The following pages contain (1) a diagram showing the height and location of the stack components and sampling ports, (2) a diagram of the EPA M5G-1 dilution tunnel components in Myren Consulting Inc.'s laboratory, (3) copy(s) of the certification test notifications sent to EPA for the week(s) the unit was tested and (4) a discussion of test results.

Seven(7) test runs were conducted on the unit during the certification test series. The reasons for the three(3) additional runs are as follows:

1. Run 3, a medium high, broke Delta T and had to be repeated.
2. Run 5 is the Fan Confirmation Test (FCT).
3. Run 7 is an additional High burn. During the first high burn (Run 6), the wood fell and partially blocked the air flow from the Lower Primary Air Orifice (LPAO). This reduced the dry burn rate (DBR) and thus the heat or BTU/hr output. The manufacturer then elected to do an additional high burn and try for a higher DBR and heat output, which is what happened in Run 7.

While the fan confirmation test's emissions are higher than either the medium low or the medium high, they are within EPA's +1.0 g/hr spec based upon the weighted average for the two runs. The weighted average of the medium low and the medium high is 3.954 g/hr.

The Kuma Wood Classic because it is loaded end to end or north-south has a tendency to have "bad" wood falls. When this happens the air flow from the LPAO is either partially or completely blocked for a period of time. When this happens during a test, the result is a much lower DBR than expected and/or breaking the Delta T limit of $\pm 125^{\circ}$ F. Since this normally happens after the wood has reached

Kuma Discussion

the charcoal stage, the impact on emissions is minimal. What the consumer will notice is a longer DBR. What a stove tester sees is problems due to test requirements. Thus the "bad" in quotation marks. As noted above, Runs 3 and 6 both had wood falls that impacted test results in such a way as to require the run to be repeated. Run 2 also had a wood fall that resulted in a longer than expected test, but the run did not exceed the Delta T limit, so it is acceptable as far as EPA is concerned.

Stack Ht. 186.75" 15.48'


15.0 ± 1 ft. (M28, 4.1.1)

SO₂ Sampling Probe Ht. N/A

13.5 ft. ± 0.5 ft (MSH, 5.1.5.2)

Stack Measurements And Sampling Port Locations

Top View Detail



SO₂ Injection Probe Ht. N/A

9.5 ft ± 0.5 ft (MSH, 5.1.5.1)

STEEL Flue Pipe Ht 106.5" 8.5 ± 0.5 ft (M28, 4.1.1) 8.875'

Particulate Sampling Probe

Ht. N/A 8.0 ± 0.5 ft (MSH, 5.1.2)

100.75" = 8.40"
WET BULB/Dry Bulb Probe Ht
(NO SPECIFICATION GIVEN)

Stack Temperature Probe Ht.
8.5 ± 0.5 ft (DEQ, 3.2.1)
107.375" = 8.95'


Flow Rate Measurement System Probe
Ht. 100" 7.5 ± 1.0 ft (MSH, 5.1.6)
8.33'

CUTAWAY DETAIL ON BAROMETRIC OIL SEAL

Static Pressure Probe Ht 7"

< 1.0 ft above flue connector (M28, 6.2.3)

Stove Ht at the flue collar 34"



Unit Kuma Wood Classic



Date 9/11/99

Technician A.T. Myren

MYREN
CONSULTING
INC

Dilution Tunnel
Schematic

9/9/97



- A: Class A Rain Cap
- B: 36" of 10" ID Class A Chimney
- C: 18" of 10" ID " " "
- Class A
- E: 10" Self Cleaning Full Closure
Blast Gate
- F: 10" 22ga Black Steel Pipe "T"
- G: Dilution Tunnel Hood
- H: 10" to 8" Black Steel Pipe Reducer
- I: 12" of 8" Black Steel Pipe
- J: 8" Self Cleaning Full Closure
Blast Gate
- K: Mixing Baffles
- L: 5 1/4" of 8" Black Steel Pipe
- M: 8" 90° Black Steel Pipe Elbow
- N: 8" to 6" Black Steel Pipe Reducer
- O: 19 1/2" of Black Steel Pipe
- P: 6" Black Steel Pipe T Section
- Q: 6" Self Cleaning Full Closure
Blast Gate (for adjusting flows)
- R: 100 7/8" 6" Black Steel Pipe
- S: 2 1/4" diameter Bleed Hole
- T: Dayton Blower
- U: 6" Black Steel Pipe (Exhaust)

NOT to SCALE

Dimensions shown
are actual

TOTAL TUNNEL Length = 22.635'
Hood Entrance to Sampling Port

Myren Consulting, Inc.
512 Williams Lake Road
Colville, WA 99114

Date: 7/29/99

Faxed: 7/29/99

Mr. Robert Marshall
Woodheater Certification Program
Manufacturing, Energy and Transportation Division (223A)
Office of Compliance, U.S. EPA
1200 Pennsylvania Ave. NW
Washington, D.C. 20044

Dear Mr. Marshall:

RE: WOODHEATER CERTIFICATION TEST NOTIFICATION

This letter is to notify EPA that

Name: Kuma Stove and Iron Works

Address: 450 Old Highway 95, Rathdrum, ID 83858

Contact Person: Mark Freeman

Phone: 208 762 3002 has scheduled or canceled _____ the

Unit Name: Kuma Model #: Wood Classic

for certification testing at Myren Consulting's lab starting on

9/6/99 and ending on about 9/12/99 or

has scheduled additional runs on the above unit starting on

_____ and ending on _____

NOTE: If this is a cancellation notice, the cancellation is for the notification dated

_____ and is only for the dates shown. All other current notifications

are still in effect. The next scheduled test period for this unit is _____.

Sincerely,

Ben

Ben Myren

Myren Consulting, Inc.
512 Williams Lake Road
Colville, WA 99114

Date: 7/29/99

Faxed: 7/29/99

Mr. Robert Marshall
Woodheater Certification Program
Manufacturing, Energy and Transportation Division (223A)
Office of Compliance, U.S. EPA
1200 Pennsylvania Ave. NW
Washington, D.C. 20044

Dear Mr. Marshall:

RE: WOODHEATER CERTIFICATION TEST NOTIFICATION

This letter is to notify EPA that

Name: Kuma Stove and Iron Works

Address: 450 Old Highway 95, Rathdrum, ID 83858

Contact Person: Mark Freeman

Phone: 208 762 9002 has scheduled X or canceled _____ the

Unit Name: Kuma Model #: Wood Classic

for certification testing at Myren Consulting's lab starting on

9/13/99 and ending on about 9/19/99 or

has scheduled additional runs on the above unit starting on

_____ and ending on _____

NOTE: If this is a cancellation notice, the cancellation is for the notification dated

_____ and is only for the dates shown. All other current notifications

are still in effect. The next scheduled test period for this unit is _____.

Sincerely,

Ben

Ben Myren

EPA WEIGHTED AVERAGES CALCULATIONS
EPA WEIGHTED AVERAGE PARTICULATE EMISSION RATE

The weighted average particulate emission rate (\overline{PM}) for the

Kuma Wood Classic Noncatalytic Wood Stove

manufactured by Kuma Stove and

Iron Works

is 3.3 g/hr.

EPA WEIGHTED AVERAGE OVERALL EFFICIENCY

The weighted average overall efficiency (\overline{OE}) for the

Kuma Wood Classic

is (default) 63 %.

II. EPA TEST RESULTS

* Denotes runs used in weighted average calculations

Run #	Dry Burn Rate/kg/hr	Grams/Hour	Overall Efficiency
<u>1</u>	<u>0.934</u>	<u>3.606</u>	
<u>2</u>	<u>1.007</u>	<u>2.876</u>	
<u>4</u>	<u>1.678</u>	<u>3.059</u>	
<u>6</u>	<u>3.017</u>	<u>3.689</u>	
<u>7</u>	<u>3.982</u>	<u>12.332</u>	
<u>5¹</u>	<u>1.213</u>	<u>3.720</u>	
<u>3²</u>	<u>1.260</u>	<u>1.930</u>	

- Notes: 1. Run 5 = Fan Confirmation Test
2. Run 3 broke Delta J.

III. EPA CUMULATIVE PROBABILITY CALCULATIONS

	Act. Dry	Low Dry	
$P_n =$	$[\text{Hi Prob.} - \text{Low Prob.}]$	$[\text{Burn Rate} - \text{Burn Rate}]$	$+ \text{Low Prob.} = P_n$
	.05		
$P_1 =$	$[.328 - .300]$	$[.934 - .900]$	$+ .300 = .3190$
	.05		
$P_2 =$	$[.407 - .380]$	$[1.007 - 1.000]$	$+ .380 = .3838$
	.05		
$P_3 =$	$[.840 - .825]$	$[1.678 - 1.650]$	$+ .825 = .8334$
	.05		
$P_4 =$	$[.985 - .984]$	$[3.017 - 3.000]$	$+ .984 = .9843$
	.05		
$P_5 =$	$[.994 - .994]$	$[3.982 - 3.950]$	$+ .994 = .9940$
	.05		
$P_6 =$	$[\quad - \quad]$	$[\quad - \quad]$	$+ \quad = \quad$
	.05		
$P_7 =$	$[\quad - \quad]$	$[\quad - \quad]$	$+ \quad = \quad$
	.05		
$P_8 =$	$[\quad - \quad]$	$[\quad - \quad]$	$+ \quad = \quad$
	.05		
$P_9 =$	$[\quad - \quad]$	$[\quad - \quad]$	$+ \quad = \quad$
	.05		
$P_{10} =$	$[\quad - \quad]$	$[\quad - \quad]$	$+ \quad = \quad$
	.05		
$P_{11} =$	$[\quad - \quad]$	$[\quad - \quad]$	$+ \quad = \quad$
	.05		
$P_{12} =$	$[\quad - \quad]$	$[\quad - \quad]$	$+ \quad = \quad$
	.05		
$P_{13} =$	$[\quad - \quad]$	$[\quad - \quad]$	$+ \quad = \quad$
	.05		
$P_{14} =$	$[\quad - \quad]$	$[\quad - \quad]$	$+ \quad = \quad$
	.05		
$P_{15} =$	$[\quad - \quad]$	$[\quad - \quad]$	$+ \quad = \quad$
	.05		

$K_1 = P_2 - P_0 =$	<u>.3838</u>	-	<u>.000</u>	=	<u>.3838</u>
$K_2 = P_3 - P_1 =$	<u>.8334</u>	-	<u>.3190</u>	=	<u>.5144</u>
$K_3 = P_4 - P_2 =$	<u>.9843</u>	-	<u>.3838</u>	=	<u>.6005</u>
$K_4 = P_5 - P_3 =$	<u>.9940</u>	-	<u>.8334</u>	=	<u>.1606</u>
$K_5 = P_6 - P_4 =$	<u>1.0000</u>	-	<u>.9843</u>	=	<u>.0157</u>
$K_6 = P_7 - P_5 =$	_____	-	_____	=	_____
$K_7 = P_8 - P_6 =$	_____	-	_____	=	_____
$K_8 = P_9 - P_7 =$	_____	-	_____	=	_____
$K_9 = P_{10} - P_8 =$	_____	-	_____	=	_____
$K_{10} = P_{11} - P_9 =$	_____	-	_____	=	_____
$K_{11} = P_{12} - P_{10} =$	_____	-	_____	=	_____
$K_{12} = P_{13} - P_{11} =$	_____	-	_____	=	_____
$K_{13} = P_{14} - P_{12} =$	_____	-	_____	=	_____
$K_{14} = P_{15} - P_{13} =$	_____	-	_____	=	_____
$K_{15} = P_{16} - P_{14} =$	_____	-	_____	=	_____

IV. EPA WEIGHTED AVERAGES CALCULATIONS

The following formula is the one set out in Equation 28-1, Section 8.1, Method 28 and is to be used to calculate both the weighted average particulate emission rate (PM) and the weighted average overall efficiency (OE) as shown below. The formula uses interpolated probabilities for a given heat output demand calculated from the values listed in Table 28-1(2) in Method 28.

$$\overline{PM} = \frac{K_1 PM_1 + K_2 PM_2 + K_3 PM_3 + \dots + K_n PM_n}{K_1 + K_2 + K_3 \dots + K_n}$$

Where \overline{PM} = The EPA weighted average particulate matter (PM) emission rate in grams per hour (g/hr).
 $K_1, K_2, K_3, \dots, K_n$ = The weighting factors for the individual test runs as determined in III above.
 $PM_1, PM_2, PM_3, \dots, PM_n$ = The particulate emission rates for the individual test runs as listed in II above.

And

$$\overline{OE} = \frac{K_1 OE_1 + K_2 OE_2 + K_3 OE_3 + \dots + K_n OE_n}{K_1 + K_2 + K_3 + \dots + K_n}$$

Where \overline{OE} = The EPA weighted average overall efficiency in percent (%).
 $K_1, K_2, K_3, \dots, K_n$ = The weighting factors for the individual runs as determined in III above.
 $OE_1, OE_2, OE_3, \dots, OE_n$ = The overall efficiencies for the individual test runs as listed in II above.


IV.A. EPA WEIGHTED AVERAGE PARTICULATE EMISSIONS CALCULATIONS

$$\overline{PM} = \frac{.3838 + .5144 + .6005 + .1606 + .0157 + .0157}{() + () + () + () + () + ()} = \frac{1.6750}{1.3840 + 1.4794 + 1.8369 + .5925 + .1936 + .6750} = 3.28 \text{ g/hr} = 3.3 \text{ g/hr}$$

IV.B. EPA WEIGHTED AVERAGE OVERALL EFFICIENCY CALCULATIONS

$$\overline{OE} = \frac{() + () + () + () + () + ()}{() + () + () + () + () + ()} = \frac{8}{() + () + () + () + () + ()}$$

Unit: Kuma Wood Classic



Woodstove Data Summary

	Run #	1	2	4	6	7	5'	3 ²
<u>Particulate Emissions:</u>								
Concentration:	grains/dscf:							
	grams/m ³ :							
Emission Rate:	grams/hr:	3.606	2.876	3.059	3.689	12.332	3.720	1.930
Emission Factor:	gms/kg:							
(dry fuel weight basis)								
Front Half Catch:	% of total							
Total Mass Captured:		47.9	33.9	21.1	15.2	49.6	37.9	16.1
Frt & Bck Halves:								
<u>Efficiency Values:</u>								
Overall Applance Efficiency								
Combustion Efficiency								
Heat Transfer Efficiency								
Heat Output:								
EPA Avg. BTU/hr for test cycle		11,265	12,143	20,232	36,385	48,012	14,630	15,188
<u>Fuel Burn Rates:</u>								
Avg Kg/hr for test cycle								
(Wet basis)		1.135	1.223	2.038	3.670	4.846	1.472	1.528
Avg Kg/hr for test cycle								
(Dry basis)		0.934	1.007	1.678	3.017	3.982	1.213	1.260

Notes: 1. Run 5 = Fan Confirmation Test.
2. Run 3 broke Delta T.

	1	2	4	6	7	5	3
<u>Fuel Moisture Content:</u>							
Kindling (Wet basis)	11.608	11.478	11.479	10.634	18.094	11.479	11.478 %
Pretest Fuel (Wet basis)	17.565	17.372	18.195	17.321	17.628	17.848	18.574 %
Test Fuel (Wet basis)	17.714	17.632	17.660	17.790	17.831	17.555	17.582 %

Air/Fuel Ratio:

lbs air/lbs fuel

Average Stack Gas Composition:

Avg. % CO ₂								
Avg. % O ₂								
Avg. % CO								
Avg. % Excess Air								
Avg. % Moisture								

Average Stack Gas Flow Rate:

Stack flow rate - EPA CMB
 CHO balance
 Tracer Gas

Draft (Static)	-0.356	-0.088	-0.054	-0.077	-0.092	-0.045	-0.047	dscfm
Proportionality - Average	99.97	100.02	100.15	100.04	100.18	100.02	98.98	%

Average Stack Gas Emission Factors:

CO - g/Kg
 g/hr

	1	2	4	6	7	5	3
<u>Average Temperatures:</u>							
Stack Gas	255	269	256	556	587	299	276 OF
Primary Combustion Chamber Gas	734	778	887	1027	1011	818	815 OF
Secondary Combustion Chamber Gas	936	929	1090	1257	1323	1006	1000 OF
Catalytic Combustor Exit Gas	N/A	N/A	N/A	N/A	N/A	N/A	N/A OF
Stove Top	877	899	492	655	707	432	448 OF
Stove Left Sidewall	434	459	532	672	710	480	512 OF
Stove Back	267	261	298	375	422	339	283 OF
Stove Right Sidewall	431	433	510	644	681	461	466 OF
Stove Bottom	377	391	424	452	458	417	397 OF
Stove Temperature Change	-114.0	-109.0	-59.4	-32.8	+20.8	-58.8	-135.8 OF

Test Chamber Environment:

Avg. Barometric Pressure	28.766	28.721	28.498	28.640	28.613	28.480	28.607 in Hg
Avg. Temperature	76	76	77	69	71	76	82 OF
Avg. & Ambient Moisture	1.325	1.50	1.675	1.725	1.50	1.60	1.80 & H ₂ O
Avg. & Relative Humidity	41.5	50.0	48.0	56.5	48.0	52.5	52.5 RH
Avg. Air Velocity	00.0	00.0	00.0	00.0	00.0	00.0	00.0 m/sec
Avg. Dilution Tunnel Draft (If Applicable)	00.0	00.0	00.0	00.0	00.0	00.0	00.0 in/H ₂ O

Test Fuel Weight and Burn Time:

Density (Dry basis)	.4214	.4885	.4999	.5256	.4162	.5231	.4625 gm/cm ³
Coal Bed Weight	8.2	3.6	3.6	3.0	3.4	3.2	3.4 lbs.
Pre Test Fuel Wt (Inc Kindling)	46.5	47.2	47.0	53.4	52.6	47.0	47.9 lbs.
Test Fuel Load Weight	14.6	14.6	14.6	14.7	14.6	14.6	14.6 lbs.
Total Test Cycle Burn Time	350	325	195	109	82	270	260 min.

DILUTION TUNNEL CALCULATIONS
3/31/96

File Name: KumaEPA 1

Stove Manufacturer: Kuma

Model Number: Wood Classic

Lab Name: MYREN

Test Date: 9/11/99

Run Number: EPA 1

Meter Box Y Factor: 1.0151

Barometric pressure (in): 28.766

Gas meter temp (ave): 88

delta H(ave): 0.900

Gas meter initial reading: 355.700

Gas meter final reading: 550.492

Front catch (acetone) mg: 8.6

first filter catch (mg): 38.6

second filter catch (mg): 0.7

tunnel flow (ave cfm): 143.403

Emission Rate(g/hr): 2.279

Emission Rate(M5H) : 3.606

vs/VmTs: 0.0082

vs ave: 837.179

Tunnel average temp (°f): 98.250

Test time(min): 350

Fuel Load(lb. wet): 14.6

Wood moisture(%wet): 17.714

Burn rate(dry kg/hr): 0.934

Samp vol(scf): 183.510

front filter number: 824

back filter number: 823

acetone beaker number: 24

PRELIMINARY RESULTS

FINAL RESULTS

AUDITED

Wood Classic

EPA 1

9/11/99

0.934

2.279

3.605646784

ADJ

MYREN CONSULTING CERTIFICATION TEST DATA

Run Time (min)	PITOT DELTAP (- INCH H2O)	TNL TEMP (°F)	GAS METER RDG (ft3)	GAS METER TEMP (°F)	GAS METER DELTA H (in.H2O)	TUNNEL VELOCIT (ft/min)	PROP RATE (%)	dDGM vol std (ft3)
0	0.040	97	355.700	80	0.900	836.26		
10	0.040	107	361.269	80	0.900	843.73	103.3	5.324
20	0.040	104	366.849	82	0.900	841.50	101.6	5.315
30	0.040	106	372.410	83	0.900	842.99	101.7	5.287
40	0.040	108	377.967	84	0.900	844.48	101.6	5.274
50	0.040	109	383.498	86	0.900	845.22	100.8	5.230
60	0.040	110	389.068	87	0.900	845.96	101.4	5.257
70	0.040	110	394.620	87	0.900	845.96	101.0	5.240
80	0.040	110	400.189	87	0.900	845.96	101.3	5.256
90	0.040	108	405.755	87	0.900	844.48	100.9	5.253
100	0.040	106	411.333	88	0.900	842.99	100.7	5.255
110	0.040	104	416.910	88	0.900	841.50	100.5	5.254
120	0.040	102	422.482	88	0.900	840.00	100.3	5.249
130	0.040	101	428.059	89	0.900	839.26	100.2	5.245
140	0.040	100	433.624	89	0.900	838.51	99.9	5.233
150	0.040	99	439.208	89	0.900	837.76	100.1	5.251
160	0.040	98	444.792	89	0.900	837.01	100.0	5.251
170	0.040	98	450.368	89	0.900	837.01	100.0	5.244
180	0.040	97	455.950	89	0.900	836.26	99.9	5.249
190	0.040	97	461.528	90	0.900	836.26	99.7	5.236
200	0.040	96	467.102	90	0.900	835.51	99.5	5.232
210	0.040	96	472.675	90	0.900	835.51	99.6	5.231
220	0.040	95	478.250	90	0.900	834.76	99.4	5.233
230	0.040	95	483.812	90	0.900	834.76	99.3	5.221
240	0.040	94	489.383	90	0.900	834.00	99.3	5.229
250	0.040	94	494.965	90	0.900	834.00	99.6	5.240
260	0.040	94	500.552	91	0.900	834.00	99.5	5.235
270	0.040	93	506.113	91	0.900	833.25	98.8	5.211
280	0.040	92	511.663	90	0.900	832.50	98.7	5.210
290	0.040	90	517.220	90	0.900	830.99	98.6	5.216
300	0.040	89	522.765	89	0.900	830.23	98.5	5.215
310	0.040	90	528.405	89	0.900	830.99	100.5	5.304
320	0.040	88	533.875	88	0.900	829.47	97.2	5.153
330	0.040	87	539.419	87	0.900	828.72	98.7	5.233
340	0.040	87	544.975	88	0.900	828.72	98.8	5.234
350	0.040	86	550.492	87	0.900	827.96	98.1	5.207

DATA SUMMARY

MODEL :

RUN:

DATE:

DBR:

GPH UNADJ

ADJ

DATE 9/11/1999 PAGE 1 OF 2

MODEL # Wood Classic

RUN # EPA 1

METER BOX # 511-M

METER Y 1.0151

FILTER # (F) 824 (R) 823

PRE TEST LEAK RATE = .000 CFM @ -16.25 IN. HG .357/.357

FILTER SIZE: 110 mm

POST TEST LEAK RATE = .000 CFM @ -12.00 IN. HG .526/.526

PROBE LENGTH 24" glass

TIME		METER READING CU. FT.	PITOT dp	TNL TEMP. (°F)	METER TEMP. (°F)	GAS METER dh	VAC IN. Hg	VELOCITY TRAVERSE			
CLOCK	ELAPSED							POINT	LOCATION	ΔP	TEMP
1310	00	355.700	-040	97	80	0.90	0	N-1	0.5"	-037	103
20	10	361.269	-040	107	80	.90	0	2	1.5"	-040	103
30	20	366.849	-040	104	82	.90	0	3	4.5"	-035	102
40	30	372.410	-040	106	83	.90	0	4	5.5"	-035	102
50	40	377.967	-040	108	84	.90	0	W-1	0.5"	-037	103
1400	50	383.498	-040	109	86	.90	0	2	1.5"	-040	103
10	60	389.068	-040	110	87	.90	0	3	4.5"	-040	103
20	70	394.620	-040	110	87	.90	0	4	5.5"	-035	103
30	80	400.189	-040	110	87	.90	0	Avg.		<u>0374</u>	<u>102.750</u>
40	90	405.755	-040	108	87	.90	0	Pilot Leak Check			
50	100	411.333	-040	106	88	.90	0	Pre	<input checked="" type="checkbox"/>		Post <input checked="" type="checkbox"/>
1500	10	416.910	-040	104	88	.90	0	Cp = <u>0.99</u>	N		
10	20	422.482	-040	102	88	.90	0		1		
20	30	428.059	-040	101	89	.90	0		2		
30	40	433.624	-040	100	89	.90	0		3		
40	50	439.208	-040	99	89	.90	0		4		
50	60	444.792	-040	98	89	.90	0				
1600	70	450.368	-040	98	89	.90	0				
10	80	455.950	-040	97	89	.90	0				
20	90	461.528	-040	97	90	.90	0				

Pilot Leak Check
Pre Post

Cp = 0.99
 N
 1
 2
 3
 4
 → W 1 2 (3) 4

*-point of Avg. delta p

$$Q_s = \left(\frac{\sqrt{(\Delta P \times BP)}}{T(^{\circ}R)} \right) \times 3167.2 =$$

138.52 ✓ cfm

BP = START 28.78 in Hg

60 28.77
 120 28.77
 180 28.76
 240 28.76
 300 28.77
 350 28.75

$\bar{X} = 28.766$

Ave
 8.1

0392

0011

DATE 9/11/1999 PAGE 2 OF 2

MODEL # Wood Classic RUN # EPA 1

METER BOX # 511-M

METER Y 1.0151

FILTER # (F)824 (R)823

PRE TEST LEAK RATE = .000 CFM @ -16.25 IN. HG, 357/357

FILTER SIZE: 110 mm

POST TEST LEAK RATE = .000 CFM @ -12.00 IN. HG, 526/526

PROBE LENGTH 24" glass

TIME		METER READING CU.FT.	PITOT dp	TNL TEMP. (°F)	METER TEMP. (°F)	GAS METER dh	VAC IN. Hg
CLOCK	ELAPSED						
1630	200	467.102	-040	96	90	.90	0
40	10	472.675	-040	96	90	.90	0
50	20	478.250	-040	95	90	.90	0
1700	30	483.812	-040	95	90	.90	0
10	40	489.383	-040	94	90	.90	0
20	50	494.965	-040	94	90	.90	0
30	60	500.552	-040	94	91	.90	0
40	70	506.113	-040	93	91	.90	0
50	80	511.663	-040	92	90	.90	0
1800	90	517.220	-040	90	90	.90	0
10	300	522.765	-040	89	89	.90	0
20	10	528.405	-040	90	89	.90	0
30	20	533.875	-040	88	88	.90	0
40	30	539.419	-040	87	87	.90	0
50	40	544.975	-040	87	88	.90	0
1900	(50)	550.492	-040	86	87	.90	0
	60						
	70						
	80						
	90						

VELOCITY TRAVERSE			
POINT	LOCATION	ΔP	TEMP
N-1	0.5"	<u>-037</u>	<u>103</u>
2	1.5"	<u>-040</u>	<u>103</u>
3	4.5"	<u>-035</u>	<u>102</u>
4	5.5"	<u>-035</u>	<u>102</u>
W-1	0.5"	<u>-037</u>	<u>103</u>
2	1.5"	<u>-040</u>	<u>103</u>
3	4.5"	<u>-040</u>	<u>103</u>
4	5.5"	<u>-035</u>	<u>103</u>
		Avg. <u>.0374</u>	<u>102.75</u>

Pilot Leak Check
Pre Post

Cp = 0.99
N
1
2
3
4
→ W 1 2 (3/4)

*-point of Avg. delta p

$$Q_s = \left(\frac{\sqrt{\Delta P \times BP}}{T(^{\circ}R)} \right) \times 3167.2 =$$

13852 cfm

BP = START 28.78 in Hg

60 28.77
120 28.77
180 28.76
240 28.76
300 28.77
350 28.75

$$\bar{X} = \underline{28.766}$$

WOODSTOVE DATA SHEET #4-1: INITIAL FILTER WEIGHTS (TARE WEIGHTS)

Into Dessicator: Date 7/18/99 Time 12:00 By ATM Front Half Back Half

Manufacturer: St. Lawrence & Sons Size: 11 cm Lot. No.: Z8951 Grade: #25 Glass
Order No. 06220

Filter #	First Wt	Date	Time	By	Second Wt	Date	Time	By	Third Wt	Date	Time	By
801	.7864	7/18/99	1110	gm	.7867	7/18/99	1747	ATM				
802	.8101		1111	gm	.8106		1746	ATM				
803	.7927		1112	gm	.7931		1744	ATM				
804	.7988		1113	" "	.7993		1743	ATM				
805	.7836		1114	" "	.7839		1742	ATM				
806	.7752		1115		.7762		1741	ATM				
807	.7948		1116		.7951		1740	ATM				
808	.8028		1117		.8031		1739	ATM				
809	.8098		1118		.8100		1738	ATM				
810	.8120		1119		.8124		1737	ATM				
811	.8093		1120		.8096		1736	ATM				
812	.7992		1121		.7995		1734	ATM				
813	.7832		1122		.7835		1733	ATM				
814	.7820		1123		.7823		1732	ATM				
815	.7949		1124		.7952		1731	ATM				
816	.8229		1125		.8232		1730	ATM				
817	.8129		1340		.8129		1729	ATM				
818	.8157		1341		.8159		1728	ATM				
819	.8001		1342		.8002		1727	ATM				
820	.7967		1343		.7967		1726	ATM				
821	.7980		1344		.7978		1725	ATM				
822	.7862		1345		.7871		1724	ATM				
823	.8039		1346		.8039		1722	ATM				
824	.7843		1347		.7843		1721	ATM				
825	.7811	✓	1219	✓	.7811	✓	1720	ATM				

Checked by ATM Date: 7/22/99 Time 09:00

QA REWEIGH

Filter #	WT	Date	Time	By
801	.7863	7/22/99	2150	J...
809	.8100	7/22/99	2150	J...
819	.8002	7/22/99	2152	J...

BALANCE ROOM ENVIRONMENTAL CONDITIONS

WB	DB	%RH	Date	Time	By
49	77	45	6/19/99	1100	ATM
63	77	45	7/18/99	1604	ATM
64	80	41	7/22/99	2145	ATM

Post Weighing Section Serial Check

1st 2nd 3rd
0.0000 .0000 1.0001 .0000
1.0000 1.0001 1.0001 1.0000

WOODSTOVE DATA SHEET #4-2:
INITIAL BEAKER WEIGHTS (TARE WEIGHTS)

Into Dessicator: Date: 8/20/99 Time: 1500 By: A. J. Myren

Glass
↓

Beaker #	First Wt	Date	Time	By	Second Wt	Date	Time	By	Third Wt	Date	Time	By
1	65.4841	8/27	2059	Sm	65.4845	8/30/99	1211	ATM				
2	66.1509	8/27	2118	Sm	66.1514		1204	ATM				
3	67.8582		2116	Sm	67.8578		1207	ATM				
4	67.5890		2108	Sm	67.5891		1210	ATM				
6	67.4270		2119	Sm	67.4274		1213	ATM				
7	65.5444		2105	Sm	65.5446		1220	ATM				
8	66.0219		2221	Sm	66.0218		1205	ATM				
9	66.9297		2120	Sm	66.9296		1215	ATM				
10	66.0906		2114	Sm	66.0902		1209	ATM				
11	65.7072		2112	Sm	65.7020		1217	ATM	65.7028	9/8/99	1717	Sm
13	57.8946	✓	2110	Sm	57.8948	✓	1218	ATM				
									65.7021	9/11	1232	ATM
									65.7022	9/13	1934	Sm
20	73.3159	8/27	2125	Sm	73.3160	8/31/99	1320	ATM				
21	71.0002	8/27	2126	Sm	71.0003	✓	1325	ATM				
22	71.8322	9/11/99	1240	ATM	71.8322	9/13	1719	Sm				
23	70.7376	8/27	2131	Sm	70.7382	8/30/99	1259	ATM	70.7376	9/8	1715	Sm
24	73.2173	8/27	2130	Sm	73.2182		1301	ATM	73.2176	9/8	1713	Sm
25					72.6505	✓	1253	ATM	72.6504	9/8	1716	Sm
26	71.7865	8/27	2132	Sm	71.7868	8/31/99	1322	ATM				
27	72.3294	9/11/99	1235	ATM	72.3294	9/8	1718	Sm				
28	70.5955	8/27	2127	Sm	70.5956	8/31/99	1324	ATM				
29	71.5183	8/27	2133	Sm	71.5185	✓	1318	ATM				
30	70.7845	8/27	2128	Sm	70.7855	8/30/99	1302	ATM	70.7851	9/8	1714	Sm
31	69.6653	8/27	2129	Sm	69.6655	8/31/99	1327	ATM				
23	70.7375	9/11	1233	ATM								
24	73.2175	9/11	1242	ATM								

cont. 23
cont. 24

Checked By: A. J. Myren Date: 9/11/13/99 Time: ATM

QA REWEIGH

Beaker #	WT	Date	Time	By

BALANCE ROOM ENVIRONMENTAL CONDITIONS

WB	DB	IRH	Date	Time	By
68	83	46	8/27/99	2052	ATM
67	81	48	8/30/99	1154	ATM
63	76	48	8/31/99	1310	ATM
70	84	47	9/8/99	1705	ATM
69	84	46	9/11/99	1202	ATM
24	77	49	9/13/99	1926	ATM

WOODSTOVE DATA SHEET #4-2:
INITIAL BEAKER WEIGHTS (TARE WEIGHTS)

Into Dessicator: Date: 6/1/99 Time: 1400 By: A.T. Myrum

Beaker #	First Wt	Date	Time	By	Second Wt	Date	Time	By	Third Wt	Date	Time	By
1	65.4847	7/1/99	1636	OBM	65.4847	7/18/99	1612	ATM	← B KAN K			
2	66.1504		1638	OBM	66.1506	↓	1614	ATM	7/18/99			
3	67.8572		1640	OBM	67.8567	↓	1616	ATM				
4	67.5887		1642	OBM	67.5880	↓	1618	ATM				
6	67.4268		1644	OBM	67.4266	↓	1620	ATM				
7	65.5436		1648	OBM	65.5437	↓	1622	ATM				
8	66.0212		1650	OBM	66.0211	↓	1623	ATM				
9	66.6299		1652	OBM	66.6295	↓	1625	ATM				
10	66.0889		1654	OBM	66.0888	↓	1627	ATM				
11	65.7015		1656	OBM	65.7013	↓	1628	ATM				
12	56.0655		1658	OBM	56.0653	↓	1632	ATM				
13	57.8948		1700	OBM	57.8944	↓	1630	ATM				

111111111111

Checked By: A.T. Myrum Date: 7/18/99 Time: 1800

QA REVIEW

Beaker #	WT	Date	Time	By

BALANCE ROOM ENVIRONMENTAL CONDITIONS

WB	DB	IRH	Date	Time	By
65	78	49	7/17/99	1825	ATM
63	77	45	7/18/99	1604	ATM

WOODSTOVE DATA SHEET #4-3: CONSTANT FINAL WEIGHTS

WST5-Form9, Pg1, Rev4/90
 Unit KUMA Wood
 Run # EPA 1
 Date: 9/11/99

FINAL BEAKER WEIGHTS

Beaker #	Into Dessic	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By
24	✓	9/14/99	1900	ATM	73.2262	9/16	0855	ATM	73.2261	9/19	1320	TM				

FINAL FILTER WEIGHTS

Filter #	Into Dessic	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By
824	.8235	9/11/99	1936	ATM	.8229	9/12	2106	ATM	.8229	9/13/99	1940	DM	.8229	9/14	2026	DM
823	.8050	9/11/99	1936	ATM	.8047	9/12	2107	ATM	.8043	9/12/99	1935	DM	.8046	9/14	2033	ATM

QA REWEIGH: FINAL WEIGHTS

Date	Beaker #	Final Wt	By

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighing Session	Date	Time	By	WB	DB	ZRH
1	9/12	2058	ATM	70	84	49
2	9/13	1926	ATM	64	77	49
3	9/14	2025	ATM	68	84	44
4	9/16	0845	ATM	69	84	46
5	9/16	1655	ATM	70	84	49

SCALE ROOM ENVIRONMENTAL CONDITIONS

	6	7	8	9	Comments	
	9/18	1217	AMM	65	79	48

Blank
7/18/99

WOODSTOVE DATA SHEET #4-3: CONSTANT FINAL WEIGHTS

WST5-Form 9, Pgt. Rev 4/99
Unit: Kump Wood Classic
Run #
Date: 7/18/99

FINAL BEAKER WEIGHTS

Beaker #	Into Dessic	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By
1	✓	7/18/99	1435	ATM	65.4852	8/14/99	1715	ATM	65.4846	8/18/99	1742	0877	65.4847	8/19	1642	ATM

FINAL FILTER WEIGHTS

Filter #	Into Dessic	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By

QA REWEIGH: FINAL WEIGHTS

Date	Beaker #	Final Wt	By
Date	Filter #	Final WT	By

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighing Session	Date	Time	By	WB	DB	%RH
1	8/4	1705	ATM	69	83	49
2	8/8	1700	ATM	64	78	46
3	8/9	1615	ATM	69	84	46
4						
5						

SCALE ROOM ENVIRONMENTAL CONDITIONS

6					
7					
8					
9					
Comments					

WOODSTOVE DATA SHEET #4-4

SCALE QA SHEET

Scale Mettler

Model AE100
SN K04827

Dates From 1/9/99

Through 7/17/99

Level	Recalibrated	100g Weight	10g Weight	1.0g Weight	100mg Weight	20mg Weight	Date	Time	Tech	Wet Bulb	Dry Bulb	% RH
✓	Yes	99.9999	10.0001	1.0002	.1003	.0203	1/9/99	1243	ATM	58	70	48
✓	No	100.0002	10.0000	1.0000	.1000	.0200	1/14/99	1113	ATM	62	75	47
✓	Yes	99.9999	10.0002	1.0000	.0999	.0201	1/23/99	1100	ATM	63	72	48
✓	Yes	99.9999	10.0000	1.0000	.1000	.0201	1/24/99	1318	ATM	59	71	48
✓	Yes	99.9999	10.0002	1.0000	.1000	.0200	2/1/99	0910	ATM	55	67	39
✓	Yes	99.9999	10.0001	1.0001	.1002	.0201	2/2/99	0937	ATM	60	72	46
✓	Yes	99.9999	10.0001	1.0001	.1001	.0200	2/3/99	1555	ATM	60	72	47
✓	Yes	99.9999	10.0000	1.0001	.1001	.0201	2/4/99	1235	ATM	62	76	45
✓	Yes	99.9998	10.0000	1.0000	.1000	.0200	2/10/99	1600	ATM	63	72	45
✓	Yes	99.9999	10.0000	1.0001	.1000	.0200	2/19/99	0246	ATM	64	78	46
✓	No	99.9999	10.0000	1.0000	.1000	.0200	2/21/99	1312	ATM	62	70	41
✓	No	99.9999	10.0000	1.0001	.1000	.0200	3/5/99	1935	ATM	64	80	41
✓	Yes	99.9999	10.0000	1.0000	.1001	.0200	3/6/99	1133	ATM	64	79	43
✓	Yes	99.9999	10.0000	1.0001	.1000	.0200	3/13/99	1520	ATM	65	70	44
✓	Yes	99.9999	10.0001	1.0001	.1001	.0200	3/14/99	1355	ATM	63	78	43
✓	No	99.9999	10.0000	1.0000	.1000	.0200	3/16/99	1623	ATM	66	81	43
✓	No	99.9999	10.0000	1.0001	.1000	.0200	3/16/99	2025	ATM	65	77	39
✓	Yes	99.9999	10.0000	1.0001	.1001	.0200	3/17/99	1615	ATM	62	71	44
✓	Yes	99.9999	10.0000	1.0001	.1000	.0200	3/18/99	2140	ATM	66	84	43
✓	Yes	99.9999	10.0000	1.0000	.1000	.0200	3/20/99	1300	ATM	64	84	32
✓	Yes	99.9999	10.0000	1.0001	.1001	.0201	3/21/99	2215	ATM	61	74	47
✓	Yes	99.9999	10.0000	1.0001	.1001	.0200	3/22/99	2127	ATM	65	75	42
✓	Yes	99.9999	10.0000	1.0001	.1000	.0200	3/23/99	1115	ATM	69	77	46
✓	Yes	99.9999	10.0000	1.0002	.1001	.0201	3/24/99	1120	ATM	77	79	43
✓	Yes	99.9999	10.0000	1.0002	.1001	.0201	3/29/99	2038	ATM	87	72	42
✓	No	99.9999	10.0002	1.0002	.1001	.0202	3/30/99	0610	ATM	66	70	47
✓	No	99.9999	10.0000	1.0000	.1001	.0201	3/31/99	1200	ATM	67	70	44
✓	No	99.9999	10.0000	1.0000	.1001	.0201	4/5/99	1730	ATM	64	80	41
✓	Yes	99.9999	10.0001	1.0001	.1001	.0201	4/6/99	1030	ATM	61	70	44
QA	Scale	4/6/97	50.0000	5.0000	.5000	.1000						
✓	No	100.0003	10.0001	1.0001	.1001	.0201	4/6/99	1720	ATM			
✓	Yes	99.9998	10.0001	1.0001	.1001	.0200	4/7/99	1724	ATM	65	85	33
✓	No	99.9999	10.0000	1.0001	.1001	.0201	4/8/99	1346	ATM	67	80	30
✓	Yes	99.9999	10.0000	1.0000	.1000	.0200	4/16/99	1230	ATM	66	84	42
✓	Yes	99.9999	10.0000	1.0000	.1000	.0200	4/17/99	1625	ATM	68	84	43
✓	No	99.9999	10.0000	1.0000	.1000	.0200	5/19/99	1050	ATM	49	72	45
✓	Yes	99.9999	10.0001	1.0003	.1001	.0202	7/17/99	1825	ATM	65	78	49

WOODSTOVE DATA SHEET #4-4

SCALE QA SHEET

Scale Mettler

Model AE100
SN K04827

Dates From 7/13/99

Through 9/16/99

Level	Recalibrated	100g Weight	10g Weight	1.0g Weight	100mg Weight	20mg Weight	Date	Time	Tech	Wet Bulb	Dry Bulb	% RH
✓	No	99.99996	10.0000	1.0001	1.0000	0.2001	7/13/99	16:04	ATM	63	77	45
✓	Yes	99.99997	10.0000	1.0001	1.0001	0.2001	7/19/99	18:35	ATM	64	77	49
✓	No	99.99998	10.0000	1.0002	1.0002	0.2002	7/20/99	18:54	ATM	71	85	80
✓	Yes	99.99997	10.0000	1.0001	1.0001	0.2001	7/21/99	13:06	ATM	69	81	50
✓	Yes	99.99998	10.0000	1.0000	1.0000	0.2000	7/22/99	21:45	ATM	64	80	41
✓	No	99.99998	10.0000	1.0000	1.0000	0.2000	7/23/99	07:45	ATM	62	76	45
✓	Yes	99.99998	10.0000	1.0000	1.0000	0.2000	7/24/99	13:40	ATM	66	80	47
✓	Yes	99.99998	10.0000	1.0000	1.0000	0.2000	8/3/99	21:17	ATM	70	81	49
✓	Yes	99.99998	10.0000	1.0000	1.0000	0.2000	8/4/99	17:05	ATM	69	83	49
✓	No	99.99998	10.0000	1.0000	1.0000	0.2000	8/5/99	21:06	ATM	65	78	49
✓	Yes	99.99998	10.0000	1.0000	1.0000	0.2000	8/6/99	15:36	ATM	68	81	50
✓	No	99.99999	10.0000	1.0001	1.0001	0.2001	8/7/99	15:13	ATM	66	80	47
✓	Yes	99.99996	10.0000	1.0000	1.0001	0.2001	8/8/99	17:00	ATM	64	73	46
✓	Yes	99.99997	10.0000	1.0001	1.0001	0.2001	8/9/99	12:25	ATM	68	82	48
✓	No	99.99998	10.0000	1.0001	1.0001	0.2001	8/9/99	16:15	ATM	69	84	46
✓	Yes	99.99998	10.0000	1.0000	1.0000	0.2000	8/10/99	13:27	ATM	70	81	49
✓	Yes	99.99998	10.0000	1.0000	1.0000	0.2000	8/11/99	10:43	ATM	67	81	48
✓	Yes	99.99996	10.0000	1.0001	1.0001	0.2001	8/12/99	20:30	ATM	64	83	46
✓	Yes	99.99997	10.0000	1.0001	1.0000	0.2000	8/13/99	12:30	ATM	64	80	47
✓	Yes	99.99998	10.0000	1.0002	1.0002	0.2002	8/14/99	19:29	ATM	63	76	48
✓	Yes	99.99998	10.0000	1.0001	1.0001	0.2001	8/16/99	11:35	ATM	64	77	48
✓	Yes	99.99998	10.0000	1.0001	1.0001	0.2001	8/17/99	17:50	ATM	68	82	46
✓	No	99.99998	10.0000	1.0001	1.0001	0.2001	8/17/99	16:50	ATM	70	84	47
✓	Yes	99.99998	10.0000	1.0000	1.0000	0.2000	8/21/99	20:32	ATM	64	83	46
✓	No	99.99998	10.0000	1.0002	1.0001	0.2002	8/30/99	11:54	ATM	67	81	48
✓	Yes	99.99998	10.0000	1.0000	1.0000	0.2000	8/31/99	13:00	ATM	63	76	48
✓	Yes	99.99998	10.0000	1.0000	1.0000	0.2000	8/31/99	18:04	ATM	65	79	44
✓	Yes	99.99998	10.0000	1.0000	1.0000	0.2000	9/2/99	10:32	ATM	60	74	43
✓	Yes	99.99998	10.0000	1.0002	1.0002	0.2002	9/8/99	17:03	ATM	70	84	47
✓	Yes	99.99998	10.0000	1.0002	1.0002	0.2002	9/11/99	12:03	ATM	69	81	46
✓	Yes	99.99998	10.0000	1.0001	1.0001	0.2001	9/12/99	20:58	ATM	70	81	49
✓	Yes	99.99998	10.0000	1.0000	1.0000	0.2000	9/13/99	13:26	ATM	61	77	47
✓	Yes	99.99998	10.0000	1.0002	1.0002	0.2002	9/14/99	13:35	ATM	61	75	47
✓	Yes	99.99998	10.0000	1.0002	1.0002	0.2002	9/14/99	8:25	ATM	64	78	44
✓	Yes	99.99998	10.0000	1.0001	1.0001	0.2001	9/15/99	08:20	ATM	62	76	42
✓	No	99.99998	10.0000	1.0001	1.0001	0.2001	9/16/99	08:45	ATM	64	78	46
✓	No	99.99998	10.0000	1.0000	1.0000	0.2000	9/16/99	16:53	ATM	70	84	49

Unit: Kuma Wood Classic
 Run: EPA 1
 Date: 9/11/1999
 Technicians: ATM RLS
 WST20, Form 5

Woodstove Particulate
 Catch Processing Sheet
 Woodstove Data Sheet #5
 EPA M5G-1

Filters

(F)
 Filter # 824
 Final Wt .8229 g
 Tare Wt .7843 g
 Net Wt .0386 g

Beaker # 24
 Ml 30
 Desc. Acetone

Final Wt. 73,2261 g
 Tare Wt. 73,21751 g
 Net Wt. .0086 g

(R)
 Filter # 823
 Final Wt .8046 g
 Tare Wt .8039 g
 Net Wt .0007 g

Beaker # _____
 Ml _____
 Desc. _____

Final Wt. _____ g
 Tare Wt. _____ g
 Net Wt. _____ g

Acetone Blank Calculation:

Blankz done 7/18/99

Blank Beaker # 1
 Ml 50
 Desc Acetone

Final Wt. 65.4847
 Tare Wt 65.4847
 Net Wt .0000

.0000 g ÷ 50 ml = .0000 g/ml

Particulate Catch Calculation

Filter:
 Filter:

Beakers: .0086
 Total Catch

- (30 x .0000)
 Ml of Acetone
 Blank Value/Ml of Acetone

.0386 g
.0007 g
.0086 g

Total Catch = .0479 g

Unit Kuma Wood Classic
 Run # EPA 1
 Date 9/11/1999
 Technician ATM RLS
 WST6-Form1, Rev8/96

MISCELLANEOUS TEST DATA
 WOODSTOVE DATA SHEET #8

Useable Firebox Dimensions: See QC Section Useable Volume: 2,228 ft³

Dilution Tunnel Draft (If applicable): Start 00.0 Stop 00.0

Test Chamber Air Velocity: Start: 00.0 Stop: 00.0 Avg: 00.0

Wet Bulb/ Start: WB: 58 °F DB: 72 °F 1.25% Amb Moisture 41 %RH

Dry Bulb Stop: WB: 62 °F DB: 77 °F 1.40% Amb Moisture 42 %RH

$\bar{X} = 1.325$ % Ambient Moisture $\bar{X} = 41.5$ % Relative Humidity (RH)

Empty Stove Wt: 419.3 lbs.

Stove Wt with Stack (Inc. Oil Seal) Wet: 510.7 lbs. Dry: 509.0 lbs.

Empty Stove Wt with Stack and Ash Ash: — lbs. Total: — lbs.

Kindling Wt. Paper: 0.3 lbs. Wood: 4.0 lbs.

Pre Burn Fuel Wt. 14.0 + 14.0 + 14.2 Total: 42.2 lbs. ✓

Total Kindling and Pre Burn Fuel Wt. 46.5 lbs. ✓

Coal Bed Wt-lbs: Range (572.6 - 572.0) 3.6 - 3.0 lbs. Actual: 3.2 lbs.

Allowable Amount of Charcoal that can be removed:

Coal Bed Wt. Range 3.6 + 3.0 $12 \times .25 =$.8 lbs.
 Upper Wt. Lower Wt.

Test Fuel Wt-lbs: Ideal 15.5 lbs. Range: 17.1 - 14.1 lbs. Actual: 14.6 lbs.

Test Fuel Size (pcs.) (.75 x 1.5 x 5" Flanges) 16 Pcs. ✓

2 x 4's x 16 1/16 " 3 Pcs 6.7 lbs. 45.9 % ✓

4 x 4's x 16 1/16 " 2 Pcs 7.9 lbs. 54.1 % ✓

Est. Dry Burn Rate (Kg/Hr.) $\frac{14.6 - (14.6 \times 17.714)}{2.2046} \times \frac{60}{350} =$ 0.9342 Est. Dry Burn Rate (Kg/Hr) ✓

Est EPA Heat Output (HO_E) (19,140) x $\frac{63}{100} \times .9342 =$ 11,265 Est Heat Output (HO_E) BTU's/Hr ✓

Comments:

Stove Operating Data
Woodstove Test Data Sheet #9
Cold Start

Unit: KUHA WOOD CLASSIC
Run: EPA 1
Date: 9/11/99
Technician(s): ATH, PLS.
Data Sheet #9 - Rev 1/98-Pg.2

Fire Started: 0825 P.D.S.T.

Warm up and Preburn: Primary Air: Wide open from ignition until the start of preburn when the primary air control(s) was (were) adjusted to the run setting of 3/8" OPEN. At the run setting until the start of the test.

Secondary Air: No Controls. Naturally Drafted,

Secondary Burn/Cat Bypass: N/A

Charcoal Bed Preparation: Broke up, raked and leveled the coal bed prior to the addition of each warm up/pre burn fuel charge. Starting 1130 before the start of the test, broke up, raked and leveled the coal bed. In stove for 33 seconds.

Test: Door wide open during loading 0 min 58 sec, then closed,


Primary Air: Wide open during the start of the test until 4:55. Adjusted to the run setting of 3/8" open between 4:55 and 5:00. At the run setting of 3/8" open at 5:00 into the run.

Secondary Air: No Controls, Naturally drafted,

Secondary Burn/Cat Bypass: N/A

Fan: ON/OFF during the warm up, ON/OFF High during the preburn, ON/OFF at the start of the test, ON/OFF for the first 30 minutes of the test, ON/OFF high at 30 minutes into the test, ON/OFF for the rest of the test.

Test Run Anomalies: Start after shut down was a little slower than expected,

Note: 3/8" open = rod at 3/4" from side of heat shield.
3/8" = stop.


WOODSTOVE OPERATING DATA
 WOODSTOVE DATA SHEET #9A-1

Wood Data: Kindling: A mix of the below grades.

	Size	Mill	Grade	Species
Pre Burn	2X4	CANYON Lumber	# 2 & Better	D. Fir SFC GRN
Test Fuel	2X4	CANYON Lumber	# 2 & Better	D. Fir SFC GRN
	4X4	R.I.B. CONST.	# 1	D. Fir SFC GRN

All grades WCLB Rules unless otherwise noted.

Warm up Information:

- 1st Warm up/Pre Burn Fuel charge (14.0 lbs) added at 0845.
- 2nd Warm up/Pre Burn Fuel charge (14.0 lbs) added at 0946.
- 3rd Warm up/Pre Burn Fuel charge (14.2 lbs) added at 1046.
- 4th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____.
- 5th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____.
- 6th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____.
- 7th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____.
- 8th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____.

The coals were scooped out of the stove immediately prior to adding the 3rd pre burn/warm up fuel charge. The stove lost 1.7 lbs. 3.0 lbs, of coals were put back in the stove after the scoop.

All pre burn/warm up fuel pieces were ~~_____~~ 16" inches long. All preburn pieces/fuel charges were "ricked" in the stove. The pieces in the bottom layer in each rick contained 2 pcs that were 16 inches long and were loaded flat and perpendicular to the door. The pieces in the second layer in each rick were loaded on their side (edge) approximately parallel to the door and contained 4 pcs 16 inches long. The third layer (and fourth layer if present) was loaded flat, perpendicular to the door and contained 2 pcs 16 inches long. The majority of the pieces in each rick were in the second layer which had an approximate 0.5-1.0" space between pieces. (The loading directions indicate the direction of the longest dimension on each piece relative to the loading door opening.) Each pre burn/warm up fuel charge normally weighs within the weight range allowed for the actual test fuel charge


WOODSTOVE OPERATING DATA
WOODSTOVE DATA SHEET #9A-2

Unit Kuma Wood Classic
Run # EPA 1
Date 9/11/1999
Technician ATM RLS
Page 2 of 4
WST7-Form2-A, Rev 6/90


Warm up Information (cont.):

Each warm up/preburn fuel charge was ricked in exactly (as much as possible) the same manner and the weight of each rick was usually within the allowable weight range for the test fuel charge. The physical arrangement and alignment of each rick was designed to accomplish three (3) things: (1) The bottom layer was nestled firmly into the coal bed and was as close to being level with the bottom of the stove as possible, thus providing a stable loading platform for the rest of the rick, keeping it in a ricked state (as opposed to a collapsed or fallen down state) until the rick reached the charcoal stage and sags or collapses of its own accord. (2) It enhances the flow of primary air through the ricked preburn fuel charge, for the primary air would flow through the spaces between the pieces in the first layer and then up through the spaces between the pieces in the second, third and, if present, fourth layers. (3) It maximized, as much as possible, the surface to volume ratio of each preburn fuel charge, thereby allowing the fire immediate access to as much wood surface as possible and, thereby, insuring uniform charcoalization. All three of these enhance combustion and so get the stove as hot as possible during the warm up period, thereby maximizing the amount of heat (BTU's) stored in the stove. The actual preburn was not started until the stove surface temperatures had maximized and stabilized, thus indicating that the amount of heat stored in the stove had peaked. For this stove, the thermal storage was monitored using the TOP

surface temperature(s) and the peak value(s) obtained were 975 OF.



Front View



Top View

The arrows indicate the direction of the air flow through the rick.

The primary air was adjusted to the run setting of 3/8" open 4.8 lbs above the upper charcoal bed weight.

WOODSTOVE OPERATING DATA
WOODSTOVE DATA SHEET #9A-3

Unit Kuma Wood Classic
Run # EPA 1
Date 9/11/99
Technician ATM RLS
Page 3 of 4
WST5-Form2-Rev11/89

Additional Comments:


Test Start Sequence:

- ① Turned fan off.
② Opened primary air control wide open
③ opened door
④ loaded test fuel
⑤ cleared coals away from the LPAD
⑥ Photograph
⑦ closed door.

Total Elapsed Time: 0:58

Test Fuel Charge Loading Information:

Test Fuel Charge and Loading Sequence Diagram



FRONT

of stove view

4 X 4's: 3 & 5

2 X 4's: 1, 2 & 4

Loading Sequence: 1, 2, 3, 4 & then 5 last

Driest Pcs in Load 2 & 4, 3

Loaded the test fuel charge on an essentially level, medium sized, hot coal bed (in appearance, color and temperature for a Low (≤ 1.0 kg/hr) burn rate. Load 0:58 Ignition 1:01:35

1:10 Flames (VC) to baffle. 1:55 Flames spreading over tops of 4x4's, + some flames on L. side of fuel load. 2:33 Secondaries starting to flow forward, past 1st Tube. 3:00 Front Tube starting to ignite (flickers), 3:29 Flames Full width of the fuel load. 3:54 Gas Balance.

5:00 Flames \downarrow Maintained a hot pocket with flames & VC to baffle, plus secondaries on top of 3 & 5.

6:25 Out of balance. No Secondaries. Just an occasional flicker. 8:02 Steady Secondary flickers/flames above 3.

8:26 Secondaries also above 5.

8:50 Secondaries full width above 3 & 5. Balance 4.7/69

9:16 Flames/secondaries forward to front tube.

9:35 Flames/secondaries past front tube on L & C.

WOODSTOVE OPERATING DATA
 WOODSTOVE DATA SHEET #9A-4

Additional Comments:

- 10:25 Front Tube igniting on L above 5.
 10:45 Almost in balance
 * 10:55 Gas Balance - barely 7.4/1.72
 11:37 Flames on the left side of L strike
 Secondaries do not seem to have as much velocity
 as before.
 14:10 Secondary flickers on front tube above 3
 15:00 Under Canyon center sprays all eq.
 16:00 VC flames ↑
 17:40 Secondaries have spread to right over Pe 1
 18:45 Flames starting to come forward past front tube
 w/ 2nd flickers off front tube - full width
 25:00 Flickers along (on) front tube increasing.
 26:00 CO₂ ↑ CO → then ↑
 Looks like LPAO air has burnt to far back to
 quickly. Front portion of fuel load not igniting
 properly.
 28:45 CO ↓ slowly.
 30:00 Fan On High 11.3/1.73 Burn still hasn't
 really gotten going.
 31:30 CO finally ↓ a slower start than anticipated.
 33:45 Rear of front tube dull orange.

FUEL MOISTURE
WOODSTOVE TEST DATA SHEET #10

Unit: KUMA Wood Classic
Run: EPA 1
Date: 9/11/1999
Technician: ATM DLS
WST1-Form7-Rev11/89

Room Temperature: 72 °F

Correction Factor: 0

NOTE: Record readings to the nearest 0.5% moisture
Uncor Values are corrected for temperature: Yes No
Time Test Fuel Moisture Readings taken at: 10:45
Calibration Checks: X Y 12.5 12.7 22.0 22.0

Pc #	Dimen	Use	Top		Bottom		Side		Piece Avg Corrected
			Uncor	Cor	Uncor	Cor	Uncor	Cor	
1	2x4x8'	K	12.5	13.3	12.5	13.3	12.0	12.8	13.133
2									
3									
4	2x4x10'	P	19.0	20.3	19.0	20.3	19.5	19.8	20.133
5	2x4x8'		18.5	19.8	18.5	19.8	19.5	20.9	20.167
6	2x4x8'		19.0	20.3	20.0	21.4	20.5	22.0	21.233
7	2x4x10'	v	22.0	23.7	22.0	23.7	22.0	23.7	23.700
8									85.233
9									
10	2x4-16 1/16"	T	18.0	19.2	18.0	19.2	18.0	19.2	19.200
11	"		19.5	20.9	20.0	21.4	19.5	20.9	21.067
12	"	v	22.5	24.3	22.5	24.3	22.5	24.3	24.300
13									
14	4x4-16 1/16"	T	21.5	23.1	22.0	23.7	22.0	23.7	23.500
15	"	v	18.0	19.2	18.0	19.2	19.0	20.3	19.567
16									107.634
17									
18									
19	5x1.5x.75	Spacers	19.5	20.9	20.0	21.4	20.0	21.4	21.233
20									OUT-SPACERS

	Kindling	Pretest Fuel	Test Load
% Moisture - Dry Basis:	13.133% ✓	21.308% ✓	21.527% ✓
% Moisture - Wet Basis:	11.719% ✓	17.565% ✓	17.714% ✓

1608

To obtain Wet from Dry: $\frac{100 \times \% \text{ Dry Rdg.}}{100 + \% \text{ Dry Rdg.}} = \% \text{ Moisture, Wet Basis}$

Acceptable Ranges: 16-20% wet; 19-25% dry
(17.5 - 22.5 on Meter [Uncor reading] at 70°F)

Key for Use: K= Kindling P= Pretest Fuel T= Test Fuel

WOOD DENSITY DETERMINATION
WOODSTOVE TEST DATA SHEET #11

Unit: Kuma Wood Classic
Run#: EPA 1
Date: 9/11/1999
Technician: ATM KLS
WST2-form11-Rev 6/90

Wood Piece: Nominal Dimensions: 3 1/2" x 3 1/2" x 1 1/2" in
Depth (D): in 1.556 cm 3.952 ✓
Width (W): in 3.537 cm 8.984 ✓
Length (L): 3.487 cm in ✓
3.498 cm in ✓
3.491 cm in ✓
3.502 cm in ✓
Length \bar{X} = in 3.495 ✓ cm 8.877 ✓
Volume: 315.176 cm³ ✓
(D X W X L)

MOISTURE: Room Temperature: 70 °F Correction Factor: 0

Uncorrected Meter Readings Corrected for temperature: Yes No

NOTE: Record moisture meter readings to the nearest 0.5%

	Uncor	Cor	%
Top:	19.5	20.9	%
Bottom:	19.5	20.9	%
Side:	19.0	20.3	%
\bar{X} :		20.700	%

Avg % Moisture (Dry) 20.700 % ✓

Aug % Moisture (Wet) 17.150 % ✓

Scale: Levelled In Out

Zeroed: In Out

Wet Weight: 156.4 g Dry Weight: 132.8 g

% Moisture Dried Basis: 15.090 % ✓
[1 - (Dry Wt ÷ Wet Wt)] X 100

Into Dryer Date 9/11/99 Time 1035 Temp 214 °F
Out of Dryer Date 9/22/99 Time 1559 Temp 214 °F

(Minimum Time in Dryer: 24 hrs.) Minimum Dryer Temp 100°C (212°F)

Density = 132.8 g (dry wt) ÷ 315.176 cm³ (volume) = 0.4214 g/cm³

Pellet Fuel Moisture Content Determination

Tare Beaker Wt. _____ g

Wet Wt: _____ g - _____ g = _____ g

Gross Wet Wt. Tare Beaker Wt. Net Wet Wt.

Dry Wt: _____ g - _____ g = _____ g

Gross Dry Wt. Tare Beaker Wt. Net Dry Wt.

% Moisture Dried Basis: _____ %

[1 - (Net Dry Wt ÷ Net Wet Wt.)] X 100

END WT: 572.2 lbs.

Minute Time	Scale Wt	lbs Left	Burn Rate	CO ₂		CO		Tel	Wet Bulb	Bal	T/C(1)/T/C(2)		T/C(3)		Static Press.	Comments
				v.	%CO ₂	v.	%CO				Dry Bulb	% H ₂ O	Calc W/B	Stack		
0	576.8	14.6	0	277	6.87	22.6	1.14		86	6.0	9.0	4.1	109	237	7.033	Flow
5	575.9	13.7	.9	374	9.19	13.9	0.71		96	12.9	108	5.2	132	478	7.067	SO ₂ 1.5
10	575.5	13.3	.4	191	4.75	12.4	0.64		88	7.4	98	4.2	116	307	7.047	CO ₂ 1.5
15	575.0	12.8	.5	333	8.25	15.2	0.78	246 BAL 11 MIN	90	10.6	111	4.0	117	317	7.050	SO ₂ 1.5
20	574.4	12.2	.6	337	8.35	14.7	0.74		96	11.3	125	4.6	118	315	7.050	SO ₂ 1.5
25	573.8	11.6	.6	372	9.22	16.3	0.84		102	11.0	130	5.8	121	327	7.052	
30	573.2	11.0	.6	425	10.52	17.0	0.86		110	12.2	134	7.8	129	347	7.053	
35	572.6	10.4	.6	492	12.17	10.9	0.55		123	12.3	137	11.5	126	373	7.057	
40	571.8	9.6	.8	647	13.53	6.0	0.30		126	12.6	138	13.0	141	392	7.059	
45	571.1	8.9	.7	572	14.15	4.4	0.23		128	12.8	139	14.0	143	400	7.060	
50	570.5	8.3	.6	661	13.87	6.8	0.30		127	12.7	137	13.5	143	405	7.060	
55	579.9	7.7	.6	552	13.65	4.2	0.22		126	12.6	136	13.0	141	402	7.060	
60	579.3	7.1	.6	555	13.73	2.9	0.16		125	12.5	136	13.0	141	399	7.050	Flow
65	578.7	6.5	.6	559	13.83	3.6	0.19		124	12.4	135	12.5	140	399	7.060	SO ₂ 1.5
70	578.1	5.9	.6	660	13.85	2.4	0.13		123	12.3	135	12.0	140	395	7.059	SO ₂ 1.5
75	577.6	5.4	.5	559	13.83	2.5	0.14		122	12.2	134	12.0	139	393	7.058	SO ₂ 1.5
80	577.1	4.9	.5	570	12.86	4.0	0.20		119	11.9	132	10.5	135	378	7.058	SO ₂ 1.5
85	576.7	4.5	.4	600	12.27	6.4	0.28		117	11.7	130	10.0	134	367	7.056	
90	576.3	4.1	.4	462	11.43	8.3	0.43		115	11.5	127	9.1	132	353	7.055	
95	576.0	3.8	.3	481	10.67	13.1	0.67		112	11.2	124	8.5	130	343	7.052	
100	575.7	3.5	.3	379	9.39	19.4	0.98	246 BAL	109	10.9	120	8.1	127	320	7.050	
105	575.5	3.3	.2	342	8.48	20.6	1.04		106	10.6	116	7.4	123	297	7.048	
110	575.3	3.1	.2	325	8.06	20.1	1.01		103	10.3	112	6.8	121	284	7.045	
115	575.2	3.0	.1	302	7.49	20.9	1.06		99	9.9	108	6.0	117	272	7.042	
120															7.040	Flow
125															1623	

8500

1073

BURN TEST AND FLUE GAS DATA
 WOODS-GOVE DATA SHEET #12
 WST2-Form 14 Rev 1/88
 ENO Wt.: 512.2 lbs.

Unit: KUMA wood classic Date: 9/11/99
 Run: EPA1 Technician(s): ATH RLS.
 Page: 3 of 3

Minute Time	Scale Wt	lbs left	Burn Rate	CO2		O2		CO		T/C(1) T/C(2)		T/C(3)		SO2 v.	PPM	Static Press.	Comments
				v.	%CO2	v.	%O2	Wet Bulb	Dry Bulb	% H2O	Calc W/B	Stack					
120	515.1	2.9	.1	29.6	7.34	48.8	12.19	1.15	6.4	9.7	10.6	5.6	11.6	26.5		7.037	Flow
125	515.0	2.8	.1	28.5	7.07	50.0	12.49	1.09	6.5	9.4	10.4	5.0	11.3	25.8		7.036	SO2 1.5
130	514.9	2.7	.1	27.9	6.92	50.5	12.62	1.10	6.3	9.1	10.4	4.4	11.1	25.7		7.035	SO2 1.5
135	514.8	2.6	.1	28.0	6.95	50.9	12.72	0.99	7.0	8.9	10.5	4.1	11.0	24.7		7.035	SO2 1.5
140	514.7	2.5	.1	27.7	6.87	50.9	12.72	1.03	6.7	8.8	10.5	4.0	10.9	24.3		7.035	SO2 1.5
145	514.6	2.4	.1	26.6	6.60	52.2	13.04	1.02	6.5	8.7	10.5	3.7	10.8	23.9		7.034	
150	514.6	2.4	0	25.9	6.43	52.7	13.16	1.06	6.1	8.6	10.4	3.5	10.7	23.6		7.033	
155	514.5	2.3	.1	25.3	6.28	53.9	13.46	1.04	6.0	8.6	10.4	3.5	10.6	23.1		7.032	
160	514.4	2.2	.1	26.3	6.53	52.7	13.16	0.98	6.7	8.5	10.4	3.4	10.6	22.9		7.032	
165	514.3	2.1	.1	25.9	6.43	53.1	13.26	1.07	6.0	8.5	10.4	3.4	10.5	22.6		7.031	
170	514.3	2.1	0	24.1	5.99	54.7	13.66	1.20	5.0	8.5	10.4	3.4	10.5	22.3		7.030	
175	514.2	2.0	.1	23.6	5.86	54.9	13.71	1.33	4.4	8.4	10.3	3.3	10.4	21.9		7.030	
180	514.1	1.9	.1	22.6	5.62	55.6	13.89							28.6.7		7.000	Flow
185	514.1	1.9	0	22.1	5.49	56.3	14.06	1.49	3.8	8.4	10.3	3.3	10.4	21.6		7.029	SO2 1.5
190	514.0	1.8	.1	21.8	5.42	55.9	13.96	1.55	3.5	8.4	10.3	3.3	10.3	21.4		7.029	SO2 1.5
195	513.9	1.7	.1	21.9	5.44	55.8	13.94	1.72	3.2	8.4	10.2	3.3	10.3	21.1		7.028	SO2 1.5
200	513.9	1.7	0	21.7	5.39	56.0	13.99	1.80	3.0	8.4	10.2	3.3	10.3	21.0		7.028	SO2 1.5
205	513.8	1.6	.1	22.1	5.49	56.1	14.01	1.82	3.0	8.4	10.2	3.3	10.3	20.8		7.027	
210	513.7	1.5	.1	22.6	5.62	55.8	13.94	1.55	3.5	8.4	10.2	3.3	10.3	20.6		7.026	
215	513.7	1.5	0	22.7	5.64	55.6	13.89	1.52	3.7	8.4	10.2	3.3	10.3	20.5		7.026	
220	513.6	1.4	.1	22.5	5.59	55.7	13.91	1.59	3.5	8.4	10.1	3.3	10.3	20.4		7.026	
225	513.6	1.4	0	22.4	5.57	55.9	13.96	1.60	3.5	8.4	10.1	3.3	10.1	20.1		7.025	
230	513.5	1.3	.1	22.2	5.52	55.8	13.94	1.61	3.5	8.4	10.1	3.3	10.1	20.0		7.025	
235	513.4	1.2	.1	21.7	5.39	56.2	14.04	1.67	3.3	8.4	10.0	3.4	10.0	19.9		7.025	
240	513.4	1.2	.1	21.7	5.39	56.2	14.04	1.77	3.0	8.4	10.0	3.4	10.0	19.8		7.025	
245	513.4	1.2	.1											24.7.2		7.319	

Pre Burn (factor wt.)
4.8 lbs/lp 517.4 lbs.
Test Sheet wt: Range lbs.

PRE BURN DATA
RECORD SHEET #13
WST2-Form1.6

BARD'S PRESSURE "V9"
28.78

Unit: Cuma Wood Classic Date: 9/11/199
Run: EPA 1 of 1 Technician(s): ATM RLS

Minute	Scale Weight	Burn Rate	Stack	Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn Catalytic	Room Temp	Static	Comments
0	577.4	0	680	957	618	438	612	467	925	1577	75	-0.89	Primary Air Set at 3/8" OPEN
5	516.5	.9	533	875	647	430	626	468	903	1445	77	-0.77	Secondary Air Set at N/A
10	515.8	.7	475	809	653	425	626	468	936	1387	76	-0.70	Fan: ON HIGH
15	515.2	.6	440	747	658	422	620	465	946	1357	76	-0.66	TUNNEL ON AT: 1112
20	514.7	.5	421	696	658	419	612	459	1059	1317	75	-0.63	Buckets FALD
25	514.3	.4	402	655	657	419	605	453	1019	1356	76	-0.61	ANALYZERS SPANNED
30	514.0	.3	366	603	654	415	596	447	1038	1194	76	-0.55	Pumps turned on at: 1145
35	513.7	.3	352	560	641	406	584	441	977	1208	76	-0.53	RAKE COALS
40	513.6	.1	332	536	629	396	573	437	960	1185	75	-0.51	AT
45	513.5	.1	317	501	615	387	561	432	944	1142	75	-0.47	Check WB/DB:
50	513.4	.1	304	471	601	378	550	429	927	1117	75	-0.46	
55	513.3	.1	295	457	590	371	540	427	912	1119	75	-0.43	Probe IN Turbine 1.
60	513.2	.1	288	435	578	365	531	427	898	1099	75	-0.42	
65	513.1	.1	282	425	567	359	524	427	888	1074	75	-0.41	
70	513.0	.1	271	408	557	353	515	428	863	995	75	-0.40	
75	513.0	0	267	397	546	347	505	430	847	977	75	-0.39	
80	512.9	.1	262	388	538	341	497	431	843	973	75	-0.37	
85	512.8	.1	259	381	529	336	489	432	833	979	75	-0.37	
90	512.7	.1	256	375	522	331	481	433	826	968	75	-0.36	
95	512.6	.1	253	371	515	326	475	433	819	979	74	-0.35	
100	512.5	.1	251	367	510	323	469	435	816	1007	75	-0.35	
105	512.5	0	248	366	505	319	465	436	807	991	75	-0.34	
110	512.4	.1	245	363	501	315	460	436	802	982	75	-0.34	
115	512.3	.1	239	355	496	310	455	437	794	870	75	-0.33	
120	512.2	.1	237	348	491	305	451	437	785	858	75	-0.33	
125													440.6
130													406.4

Hot Box On

T/C#-3

11

10

9

8

7

6

5

4

3

2

1

0

BURN RATE AND FLUE GAS DATA
 WOOD PILE DATA SHEET #12
 WST2 - Jan 14 Rev 1/88
 ENO WT. 612.2 lbs

Unit: KUNA WOOD CLASSIC Date: 9/11/94
 Technician(s): A.T.M. J.R.L.S.
 Page: 3 of 3

Minute Time	Scale Wt. lbs	lbs left	Burn Rate	CO2		O2		T/C(1) T/C(2)			T/C(3)			SO2 V.	Static Press.	Comments			
				v.	%CO2	v.	%O2	Tel	CO	Bal	Wet Bulb	Dry Bulb	% H2O				Calc W/B	Stack	PPM
240	513.4	1.2	0	.217	5.39	55.7	13.91		38.3	1.91	2.8	84	99	3.4	101	197	7.025	Flow	
245	513.3	1.1	0	.200	4.98	57.6	14.39		37.6	1.88	2.6	84	99	3.4	101	195	7.025	SO2 1.5	
250	513.3	1.1	0	.196	4.88	57.7	14.41		40.1	2.01	2.4	84	99	3.4	101	194	7.025	SO2 1.5	
255	513.2	1.0	0	.193	4.80	57.8	14.44		41.1	2.05	2.3	84	99	3.4	101	193	7.025	SO2 1.5	
260	513.1	.9	0	.182	4.53	60.2	15.04		33.7	1.70	2.7	83	98	3.3	100	191	-0.024	Wood Fe11	
265	513.1	.9	0	.175	4.36	60.4	15.09		33.8	1.70	2.6	83	98	3.3	100	188	-0.023	FORWARD	
270	513.0	.8	0	.180	4.48	60.2	15.04		33.2	1.67	2.7	83	98	3.3	100	187	7.022		
275	513.0	.8	0	.190	4.73	59.2	14.79		30.7	1.65	2.9	83	97	3.3	101	186	7.022		
280	512.9	.7	0	.192	4.78	59.0	14.74		33.2	1.68	2.8	83	96	3.3	101	185	7.022		
285	512.9	.7	0	.191	4.75	59.0	14.74		34.4	1.71	2.8	82	96	3.2	100	184	7.022		
290	512.8	.6	0	.183	4.56	59.5	14.86		37.3	1.86	2.4	82	95	3.2	100	183	7.022	Wood Forward with	
295	512.8	.6	0	.184	4.58	60.2	15.04		34.6	1.83	2.6	82	94	3.2	100	182	7.022	bright Combs	
300	512.7	.5	0	.187	4.65	59.9	14.96										-0.278	Flow	
305	512.7	.5	0	.182	4.53	60.2	15.04		31.3	1.58	2.9	81	94	3.1	100	181	-0.022	No WT Loss	
310	512.7	.5	0	.186	4.63	61.0	15.24		32.5	1.63	2.8	81	93	3.1	100	181	-0.022	13 1/2 mms.	
315	512.6	.4	0	.208	5.17	58.9	14.71		27.5	1.39	3.3	80	93	3.0	100	181	-0.020	Round Combs	
320	512.5	.3	0	.204	5.07	58.6	14.64		23.7	1.19	4.3	81	93	3.1	100	187	-0.023	1 1/2 Forward	
325	512.5	.3	0	.197	4.90	59.4	14.84		26.8	1.35	3.8	80	92	3.0	100	189	-0.024	LPD	
330	512.4	.2	0	.187	4.65	60.2	15.04		26.0	1.31	3.7	79	91	2.9	99	188	-0.024		
335	512.4	.2	0	.189	4.70	60.0	14.99		26.7	1.35	3.4	78	90	2.9	98	187	-0.024		
340	512.3	.1	0	.186	4.63	60.3	15.06		26.7	1.34	3.5	78	89	2.9	97	187	-0.024		
345	512.3	.1	0	.183	4.56	60.6	15.14		22.2	1.36	3.4	77	89	2.7	95	186	-0.024		
350	512.2	.0	0	.175	4.36	61.9	15.46		28.4	1.43	3.2	77	89	2.7	95	185	-0.024		
355	512.2	.0	0	.175	4.36	61.9	15.46		27.3	1.41	3.1	77	88	2.7	95	184	-0.024		
																		-0.255	
																		2.525	
																		-0.0356	

Unit: KUMAHARA CLASSIC Date: 9/11/99
Run: EPA1 Technician(s): ATM PLS.
Page: 2 of 3

T/C#	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Minute	Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn	Room Temp	Tunnel	C. Gas Box	Impinger Out	5G-1 Filter	5G-1 Condenser	Com-der	Hot Box
120	414	528	308	520	376	853	971	77	102	248	40	88	38	1136	248
125	398	518	305	515	378	844	953	77	101	248	40	88	38	1102	248
130	387	509	302	510	380	832	932	76	101	248	40	88	38	1091	248
135	378	500	300	504	382	828	921	76	100	248	40	88	37	968	248
140	372	493	296	497	384	818	912	77	100	248	40	88	37	950	248
145	364	485	292	489	385	806	893	77	99	248	38	88	37	931	248
150	359	478	288	481	386	791	875	76	99	249	37	88	37	929	248
155	351	470	285	473	387	773	861	76	99	250	36	88	37	928	248
160	345	463	282	466	388	768	869	76	98	250	36	88	37	916	249
165	340	457	279	460	388	761	853	76	98	250	36	88	37	919	250
170	336	451	276	455	388	742	828	76	98	250	36	89	37	931	250
175	331	444	274	450	388	733	812	76	98	250	36	89	37	935	250
180	327	437	272	444	388	722	787	77	97	250	37	89	37	896	250
185	322	431	270	439	387	711	775	76	97	250	37	89	37	878	250
190	318	424	268	433	385	708	765	76	97	249	37	89	37	854	250
195	314	418	265	429	383	697	757	76	97	249	38	89	37	841	250
200	311	412	263	425	382	693	767	76	96	249	38	89	38	838	250
205	308	407	261	421	380	687	757	76	96	249	38	89	38	834	250
210	304	402	258	417	378	686	749	77	96	248	38	89	38	835	249
215	302	398	256	414	376	684	742	76	96	249	38	89	38	836	250
220	299	394	255	411	375	681	732	76	95	249	38	89	38	840	249
225	296	391	254	408	374	684	725	76	95	250	38	89	38	831	249
230	294	388	257	404	373	681	713	76	95	250	39	90	38	815	249
235	291	385	258	400	372	678	706	76	95	250	39	89	38	803	249
240	288	382	255	398	370	675	698	710	95	250	39	89	38	803	249
245	285	380	253	396	368	672	695	708	94	250	39	89	38	803	249

8061 19,683 6626 10,865 9163 17,861 19,633 1830

TEMPERATURES
RECORD SHEET #14
WST2-Form14 Rev7/96

Unit: KUMA Wood Date: 9/11/199
 Run: EPA Technician(s):
 Page: 1 of 3

T/C#	Minute Time	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
		Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn	Room Temp	Tunnel	C. Gas Box	Impinger Out	5G-1 Filter	5G-1 Condenser	←	Hot Box
0	13	348	491	305	457	437	785	858	75	97	248	38	85	52	786	249
5	15	339	472	315	440	437	728	985	74	115	248	38	86	37	1111	248
10	20	421	468	305	430	436	670	940	75	107	248	38	87	37	721	248
15	25	428	464	300	416	431	657	1318	75	104	249	39	88	37	926	249
20	30	432	448	296	411	426	668	1366	75	104	250	39	88	37	910	249
25	35	460	445	293	410	419	691	1397	75	104	250	39	88	37	900	249
30	40	489	445	290	414	412	720	1489	75	106	250	39	88	37	1000	250
35	45	530	465	296	426	405	756	1557	75	106	250	40	88	37	1021	249
40	50	573	465	266	437	398	788	1575	75	108	250	40	88	37	1012	249
45	55	604	477	259	450	393	820	1596	75	109	250	40	88	37	1036	249
50	140	617	488	255	463	388	840	1578	76	109	250	40	88	38	1069	249
55	05	613	497	255	476	383	862	1466	76	110	250	40	88	38	1107	249
60	10	5849	5610	3415	5224	4965	8985	16065	77	110	250	40	88	38	1113	249
65	15	608	505	257	490	380	876	1432	77	110	250	40	88	38	1131	249
70	20	608	511	259	500	377	888	1434	77	110	249	40	88	38	1146	248
75	25	608	518	262	509	375	902	1386	76	110	248	40	88	38	1280	248
80	30	609	527	266	517	373	941	1396	76	110	248	40	88	38	1253	248
85	35	609	534	271	522	372	988	1446	76	110	248	40	88	38	1292	248
90	40	601	545	277	525	371	1085	1386	77	109	248	40	88	38	1323	248
95	45	575	554	285	527	370	1048	1261	77	108	249	40	88	38	1353	248
100	50	553	557	293	527	369	952	1213	77	107	249	40	88	38	1342	248
105	55	522	556	299	526	369	927	1130	77	106	249	40	88	38	1345	248
110	50	481	553	306	524	370	908	1056	77	105	249	40	88	38	1277	248
115	55	454	547	310	523	372	889	1016	77	104	249	40	88	38	1187	248
116	05	430	538	310	522	374	863	986	77	103	248	40	88	38		
		6660	6445	3395	6212	4472	4267	15142	921							

19,504 12,055 6810 11,436 9437 20,252 31,207 1823

Date: 9/11/99
Technician(s): ATM, J.S.
Page: 3 of 3

T/C#	Minute	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
	Time	Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn	Room Temp	Tunnel	C. Gas Box	Impinger Out	5G-1 Filter	5G-1 Condenser	Hot Box	
240	110	290	382	259	396	371	676	699	77	94	250	39	89	38	788	249
245	15	287	380	259	392	370	662	689	76	94	250	39	89	38	768	249
250	20	285	376	258	387	369	656	683	76	94	250	39	89	38	761	249
255	25	282	374	254	383	368	653	677	77	94	251	39	89	38	761	249
260	30	279	369	254	379	366	629	668	76	94	251	39	89	38	716	247
265	35	276	365	250	376	365	620	661	75	93	250	39	88	38	716	244
270	40	273	361	248	372	362	621	650	75	93	249	39	88	38	705	242
275	45	270	357	246	369	360	623	646	75	92	249	39	88	38	717	241
280	50	267	353	246	366	358	622	642	75	92	248	39	88	38	729	242
285	55	266	351	246	365	357	626	638	75	91	247	39	88	38	728	242
290	00	263	348	246	362	357	619	633	75	90	246	40	87	38	717	242
295	05	262	346	245	360	356	613	628	75	90	246	39	87	38	700	241
300	10	260	330	303	450	435	762	714	907							
300	10	259	343	243	358	354	610	626	75	89	245	40	86	37	739	240
305	15	258	341	241	355	353	608	624	75	89	244	39	86	38	740	239
310	20	256	339	239	353	351	605	705	74	90	244	39	85	38	669	239
315	25	261	338	236	350	354	589	746	74	89	243	40	85	38	636	239
320	30	265	336	231	347	352	579	750	73	88	243	40	85	39	627	239
325	35	267	335	226	344	348	576	724	74	88	242	40	84	38	628	238
330	40	266	334	221	342	345	569	704	74	87	242	40	84	39	622	237
335	45	266	332	217	339	341	566	729	74	87	242	40	84	39	617	237
340	50	267	331	212	335	336	564	709	74	87	241	40	84	39	613	237
345	55	265	332	209	332	333	559	699	74	87	241	40	83	39	606	236
350	00	264	329	207	331	331	550	676	73	86	241	40	83	39	597	236
355	05	289	369	248	378	380	637	769	74	86		DEFLECT	83	39		
		267	330	189	305	267	521	664	74	86		DEFLECT	83	39		
		271	343	267	431	377	734	930	76	86		DEFLECT	83	39		
											-71		STOP	406		
													STOP	292		
																-114.0

REAR 17 18

AT

738
802

912

918

1002

1014

1102

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-1

Site: Myren Consulting, Woodinville, WA Date: 9/11/99 Analyte: CO₂

Source: Kuma Wood Classic Run #: EPA 1

Zero Cyl #: 719 430 Conc. 00.0 % CO₂ Cyl Press: 1860 psi

Certified by: Oxarc Date: 4/1/99

Span Cyl #: 250-794 Conc. 12.5 % CO₂ Cyl Press: 1325 psi

Certified by: Oxarc Date: 3/26/99

Analyzer: Make: Horiba Model: PIR-2000 SN: 607024

Range: 0 - 25.0% CO₂ Analyzer Output: 0 - 1.0 v.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter:

EPA Span Value = 25.0% CO₂

EPA Control Limits = + 2.5% of 25.0% CO₂ = + 0.625% CO₂

Pre Run Audit: By: PLS Time: 1145 Temp: 75 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	.000	00.0	00.0	.000	0.446	0.446	+0.18
Span	50.0	.500	12.5	49.8	.499	12.345	-0.1535	-1.23

Comments:

Post Run Audit: By: A.T. Myren Time: 1955 Temp: 77 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	.000	00.0	00.0	.000	0.446	0.446	+0.18
Span	50.0	.500	12.5	49.25	.499	12.345	-0.1535	-1.23

Comments:

+ Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Exp \% (ppm)}} \times 100$

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-2

Site: Myren Consulting, Woodinville, WA Date: 9/11/99 Analyte: O₂

Source: Kuma Wood Classic Run #: EPA 1

Zero Cyl #: 719 480 Conc. 00.0 % O₂ Cyl Press: 1860 psi

Certified by: Oxarc Date: 4/1/99

Span Cyl #: 250-794 Conc. 12.5 % O₂ Cyl Press: 1325 psi

Certified by: Oxarc Date: 3/26/99

Analyzer: Make: Taylor Model: OA 137 SN: 137/4772

Range: 0 - 25.0% O₂ Analyzer Output: 0 - 100 mv.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter: _____

EPA Span Value = 25.0% O₂

EPA Control Limits = + 2.5% of 25.0% O₂ = + 0.625% O₂

Pre Run Audit: By: RLS Time: 1145 Temp: 75 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ%
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	00.0	00.0	00.0	00.0	00050	+0.0050	+0.02
Span	12.5	50.0	12.5	12.5	50.0	12.4908	-0.0092	-0.07

Comments:

Post Run Audit: By: ANT. Myren Time: 1955 Temp.: 77 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ%
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	00.0	00.0	00.0	00.0	00050	+0.0050	+0.02
Span	12.5	50.0	12.5	12.5	49.9	12.4658	-0.03421	-0.27

Comments:

+ Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Exp \% (ppm)}} \times 100$

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-3

Site: Myren Consulting, Woodinville, WA Date: 9/11/99 Analyte: CO

Source: Kuma Wood Classic Run #: EPA 1

Zero Cyl #: 719 430 Conc. 00.0 % CO Cyl Press: 1860 psi

Certified by: Oxarc Date: 4/1/99

Span Cyl #: 250-794 Conc. 2.50 % CO Cyl Press: 1325 psi

Certified by: Oxarc Date: 3/26/99

Analyzer: Make: Infra Red Model: 702 D SN: 113

Range: 0 - 10.0% CO Analyzer Output: 0 - 100 mv.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter: _____

EPA Span Value = 5.0% CO

EPA Control Limits = +2.5% of 5.0% CO = + 0.125% CO

Pre Run Audit: By: RIS Time: 1145 Temp: 75 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	00.0	00.0	0.00	00.0	70093	-0.0093	-0.19
Span	2.50	50.0	2.50	2.50	50.0	24914	-0.0086	-0.34

Comments:

Post Run Audit: By: A.T. Myren Time: 1955 Temp.: 77 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	00.0	00.0	0.00	00.0	70093	-0.0093	-0.19
Span	2.50	50.0	2.50	2.50	49.9	24864	-0.0136	-0.54

Comments:

+ Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Exp \% (ppm)}} \times 100$

Unit: Kuma Wood Classic
 Run: EPA 1
 Date: 9/11/199
 Technicians: ATM / RLS
 WST6-Form3-Rev11/89

QUALITY CHECKS
 WOODSTOVE DATA SHEET #16

Ambient = Tr: _____ °F T/C#30: _____ °F
 Thermocouple Check (at ambient): T/C#1: 65 °F; T/C#2: 65 °F;
 T/C #3: 65 °F; T/C #4: 66 °F; T/C #5: 66 °F;
 T/C #6: 66 °F; T/C #7: 66 °F; T/C #8: 66 °F;
 T/C #9: 66 °F; T/C #10: 67 °F; T/C #11: 67 °F;
 T/C #12: 66 °F; T/C #13: 66 °F; T/C #14: 67 °F;
 T/C #15: 66 °F; T/C #16: 66 °F; T/C #17: 65 °F;
 T/C #18: _____ °F; T/C #19: _____ °F; T/C #20: _____ °F;
 T/C #21: _____ °F; T/C #22: _____ °F; T/C #23: _____ °F;
 T/C #24: _____ °F; T/C #25: _____ °F; T/C #26: _____ °F;

Comments: _____

Thermocouple Readout: Pretest Zero/Span Check and Calibration:
 Zero (0°F) : 002 °F Adj to: 000 °F Post Test Check Zero (0°F): 001 °F % Difference +0.05%
 Span (2000°F): 2000 °F Adj to: 2000 °F Span (2000°F): 2000 °F 0.00
 (Allowable % Difference = 1.5%. Use formulas on Woodstove Data Sheet #15 to calculate % Difference)

Thermocouple Readout Pretest Linearity Check
 0°F = 000 °F; 200°F = 200 °F; 400°F = 401 °F;
 600°F = 600 °F; 800°F = 800 °F; 1000°F = 1001 °F;
 1200°F = 1201 °F; 1400°F = 1400 °F; 1600°F = 1600 °F;
 1800°F = 1800 °F; 2000°F = 2000 °F

Combustion Gas (CO₂, O₂, CO) Train Leak Check: Pre Post ATM
 Draft (Static) Gauge Zero Check: Pre Post _____

Scale Check Pre (Wt, #'s): 510.7 - 525.7 5.0 lbs OK PLS.
 Post (Wt, #'s): 517.0 - 512.0 5.0 lbs / 5.0 lbs OK ATM

Stack cleaned prior to the run: Yes No _____
 Tunnel cleaned prior to the run: Yes No _____

MYREN CONSULTING CERTIFICATION TEST DATA

DILUTION TUNNEL CALCULATIONS
3/31/96

File Name: KuamEPA2

Stove Manufacturer: Kuma

Model Number: Wood Classic

Lab Name: MYREN

Test Date: 9/13/99

Run Number: EPA 2

Meter Box Y Factor: 1.0151

Barometric pressure (in): 28.7214

Gas meter temp (ave): 91

delta H(ave): 0.900

Gas meter initial reading: 551.000

Gas meter final reading: 732.230

Front catch (acetone) mg: 5.9

first filter catch (mg): 26.6

second filter catch (mg): 1.4

tunnel flow (ave cfm): 142.556

Emission Rate(g/hr): 1.735

Emission Rate(M5H) : 2.876

vs/VmTs: 0.0088

vs ave: 842.157

Tunnel average temp (°f): 104.029

Test time(min): 325

Fuel Load(lb. wet): 14.6

Wood moisture(%wet): 17.632

Burn rate(dry kg/hr): 1.007

Burn rate(dry kg/hr): 169.520

Samp vol(scf): 932

front filter number: 825

back filter number: 25

acetone beaker number: 25

PRELIMINARY RESULTS

FINAL RESULTS

AUDITED

Wood Classic

EPA 2

9/13/99

1.007

1.735

2.875732785

ADJ

RUN TIME (min)	PITOT DELTAP (- INCH H2O)	TNL TEMP (°F)	GAS METER RDG (ft3)	GAS METER TEMP (°F)	GAS METER DELTA H (in.H2O)	TUNNEL VELOCIT (ft/min)	PROP RATE (%)	dDGM vol std (ft3)
0	0.040	99	551.000	78	0.900	838.41		
10	0.040	114	556.552	79	0.900	849.58	104.1	5.310
20	0.040	110	562.102	81	0.900	846.62	101.6	5.288
30	0.040	114	567.625	83	0.900	849.58	101.8	5.243
40	0.040	114	573.156	85	0.900	849.58	101.2	5.231
50	0.040	114	578.680	86	0.900	849.58	100.9	5.215
60	0.040	116	584.233	87	0.900	851.06	101.6	5.233
70	0.040	116	589.775	88	0.900	851.06	101.0	5.213
80	0.040	114	595.328	89	0.900	849.58	100.7	5.214
90	0.040	113	600.904	90	0.900	848.84	100.9	5.226
100	0.040	110	606.491	91	0.900	846.62	100.5	5.227
110	0.040	108	612.059	92	0.900	845.13	99.9	5.200
120	0.040	106	617.655	92	0.900	843.64	100.2	5.226
130	0.040	105	623.240	92	0.900	842.90	100.0	5.216
140	0.040	104	628.837	92	0.900	842.15	100.1	5.227
150	0.040	103	634.427	92	0.900	841.40	99.9	5.220
160	0.040	102	640.022	93	0.900	840.66	99.7	5.215
170	0.040	102	645.622	93	0.900	840.66	99.9	5.220
180	0.040	101	651.220	93	0.900	839.91	99.7	5.218
190	0.040	101	656.819	93	0.900	839.91	99.8	5.219
200	0.040	100	662.428	94	0.900	839.16	99.6	5.219
210	0.040	100	668.030	94	0.900	839.16	99.6	5.212
220	0.040	100	673.628	94	0.900	839.16	99.5	5.209
230	0.040	100	679.227	94	0.900	839.16	99.5	5.210
240	0.040	99	684.811	94	0.900	838.41	99.1	5.196
250	0.040	99	690.383	94	0.900	838.41	99.0	5.185
260	0.040	99	695.961	94	0.900	838.41	99.1	5.190
270	0.040	98	701.542	95	0.900	837.66	98.8	5.184
280	0.040	98	707.115	94	0.900	837.66	98.9	5.186
290	0.040	97	712.694	94	0.900	836.91	98.8	5.191
300	0.040	96	718.276	94	0.900	836.16	98.8	5.194
310	0.040	96	723.855	94	0.900	836.16	98.8	5.191
320	0.040	95	729.425	94	0.900	835.40	98.5	5.183
325	0.040	94	732.230	94	0.900	834.65	99.1	2.610
350						0.00	0.0	0.000
						0.00	0.0	0.000

DATA SUMMARY

MODEL :

RUN:

DATE:

DBR:

GPH UNADJ

ADJ

DATE 9/13/1999 PAGE 1 OF 2

MODEL # Wood Classic RUN # EPA 2

METER BOX # 511-M

METER Y 1.0151

FILTER # (F) 932 (R) 825

PRE TEST LEAK RATE = .000 CFM @ -15.75 IN. HG. .656/.656

FILTER SIZE: 110 mm

POST TEST LEAK RATE = .000 CFM @ -14.50 IN. HG. .063/.063

PROBE LENGTH 24" glass

TIME		METER READING CU. FT.	PITOT dp	TNL TEMP. (°F)	METER TEMP. (°F)	GAS. METER dh	VAC IN. Hg	VELOCITY TRAVERSE			
CLOCK	ELAPSED							POINT	LOCATION	ΔP	TEMP
1225	00	551.000	-040	99	78	.90	0	N-1	0.5"	-040	103
35	10	556.552	-040	114	79	.90	0	2	1.5"	-040	103
45	20	562.102	-040	110	81	.90	0	3	4.5"	-040	104
55	30	567.625	-040	114	83	.90	0	4	5.5"	-036	104
1305	40	573.156	-040	114	85	.90	0	W-1	0.5"	-038	104
15	50	578.680	-040	114	86	.90	0	2	1.5"	-041	104
25	60	584.233	-040	116	87	.90	0	3	4.5"	-040	104
35	70	589.775	-040	116	88	.90	0	4	5.5"	-037	104
45	80	595.328	-040	114	89	.90	0	Avg. -039			103.750
55	90	600.904	-040	113	90	.90	0	Pilot Leak Check Pre <input checked="" type="checkbox"/> Post <input checked="" type="checkbox"/>			
1405	00	606.491	-040	110	91	.90	0	Cp = 0.99			
15	10	612.059	-040	108	92	.90	0	→ W 1 2 3 4 (3/4)			
25	20	617.655	-040	106	92	.90	0	*-point of Avg. delta p			
35	30	623.240	-040	105	92	.90	0	Qs = $\sqrt{\frac{(\Delta P \times BP)}{T(^{\circ}R)}} \times 3167.2 =$			
45	40	628.837	-040	104	92	.90	0	<u>141.277</u> cfm			
55	50	634.427	-040	103	92	.90	0	BP = <u>START 28.77</u> in Hg			
1505	60	640.022	-040	102	93	.90	0	60 28.75			
15	70	645.622	-040	102	93	.90	0	120 28.74			
25	80	651.220	-040	101	93	.90	0	180 28.72			
35	90	656.819	-040	101	93	.90	0	240 28.70			
								300 28.69			
								325 28.68			
								X = 28.7214 ✓			

27.4 17

DATE 9/13/99

PAGE 2 OF 2

MODEL # WOOD CLASSIC RUN # EPA 2

METER BOX # 511M

METER Y 1.0157

FILTER # (F) R2 (R) R25

PRE TEST LEAK RATE = .000 CFM @ -15.75 IN. HG, .656/.656

FILTER SIZE: 110 MM

POST TEST LEAK RATE = .000 CFM @ -14.50 IN. HG, .063/.063

PROBE LENGTH 24" Glass

TIME		METER READING CU. FT.	PITOT dp	TNL TEMP. (°F)	METER TEMP. (°F)	GAS METER dh	VAC IN. Hg	VELOCITY TRAVERSE				
CLOCK	ELAPSED							POINT	LOCATION	ΔP	TEMP	
1545	00	662.428	-040	100	94	.90	0	N-1	0.5"	-040	103	
55	10	668.030	-040	100	94	.90	0	2	1.5"	-040	103	
1605	20	673.628	-040	100	94	.90	0	3	4.5"	-040	104	
15	30	679.227	-040	100	94	.90	0	4	5.5"	-036	104	
25	40	684.811	-040	99	94	.90	0	W-1	0.5"	-038	104	
35	50	690.383	-040	99	94	.90	0	2	1.5"	-041	104	
45	60	695.961	-040	99	94	.90	0	3	4.5"	-040	104	
55	70	701.542	-040	98	95	.90	0	4	5.5"	-037	104	
1705	80	707.115	-040	98	94	.90	0	Avg.			103.75	
15	90	712.694	-040	97	94	.90	0	Pilot Leak Check				
25	00	718.276	-040	96	94	.90	0	Pre	<input checked="" type="checkbox"/>		Post	<input checked="" type="checkbox"/>
35	10	723.855	-040	96	94	.90	0	Cp =	0.99	N	1	
45	20	729.425	-040	95	94	.90	0	→	W 1 2	2	3	
1750	30	732.230	-040	94	94	.90	0			4	4	
1805	40	(181.230)						* - point of Avg. delta p				
15	50							Qs = $\frac{\sqrt{(\Delta P \times BP)}}{T(^{\circ}R)} \times 3167.2 =$				
25	60							141.297 cfm				
35	70							BP = Start 28.77 in Hg				
45	80							60 28.75				
55	90							120 28.74				
								150 28.72				
								240 28.73				
								300 28.69				
								325 28.68				
								X = 28.7214				

WOODSTOVE DATA SHEET #4-1: INITIAL FILTER WEIGHTS (TARE WEIGHTS)

Into Dessicator: Date 1/8/99 Time 12:00 By ATM Front Half Back Half

Manufacturer: Schleicher & Schuell Size: 11 cm Lot.No.: ZB951 Grade: #25 Glass
Order No. 06220

Filter #	First Wt	Date	Time	By	Second Wt	Date	Time	By	Third Wt	Date	Time	By
801	.7864	7/19/99	1110	Om.	.7867	7/18/99	1747	ATM				
802	.8101		1111	om.	.8106		1746	ATM				
803	.7927		1112	om.	.7931		1744	ATM				
804	.7988		1113	" "	.7993		1743	ATM				
805	.7836		1114	" "	.7839		1742	ATM				
806	.7758		1115		.7762		1741	ATM				
807	.7948		1116		.7951		1740	ATM				
808	.8028		1117		.8031		1739	ATM				
809	.8098		1118		.8100		1738	ATM				
810	.8120		1119		.8124		1737	ATM				
811	.8093		1120		.8096		1736	ATM				
812	.7992		1121		.7995		1734	ATM				
813	.7832		1122		.7835		1733	ATM				
814	.7820		1123		.7823		1732	ATM				
815	.7949		1124		.7952		1731	ATM				
816	.8229		1125		.8232		1730	ATM				
817	.8129		1340		.8129		1729	ATM				
818	.8157		1341		.8159		1728	ATM				
819	.8001		1342		.8003		1727	ATM				
820	.7967		1343		.7967		1726	ATM				
821	.7980		1344		.7978		1725	ATM				
822	.7868		1345		.7871		1724	ATM				
823	.8039		1346		.8039		1722	ATM				
824	.7843		1347		.7843		1721	ATM				
825	.7811	✓	1248	✓	.7811	✓	1720	ATM	←			

Checked by A.T. Nguyen Date: 7/22/99 Time 0900

QA REWEIGH

Filter #	WT	Date	Time	By
801	.7863	7/22/99	2150	Jw
809	.8100	7/22/99	2151	Jw
819	.8002	7/22/99	2152	Jw

BALANCE ROOM ENVIRONMENTAL CONDITIONS

WB	DB	%RH	Date	Time	By
49	72	45	6/19/99	1051	APM
63	77	45	7/18/99	1604	ATM
64	80	41	7/22/99	2145	ATM

Post Weighing Session Scale Check
 1st 2nd 3rd
 0.0000 .0000 1.0001 .0000
 1.0000 1.0001 1.0001 1.0000

WOODSTOVE DATA SHEET #4-1: INITIAL FILTER WEIGHTS (TARE WEIGHTS)

Into Dessicator: Date 1/9/99 Time 1445 By ATM Front Half Back Half

Manufacturer: Schletterer & Scheel // Size: 11 cm Lot.No.: Z8951 Grade: #25 Glass
Order No: 06220

Filter #	First Wt	Date	Time	By	Second Wt	Date	Time	By	Third Wt	Date	Time	By
926	.7740	3/6/99	11:40	T.M.	.7739	3/15/99	1652	ATM				
927	.7938		11:41	T.M.	.7938		1651	ATM				
928	.7985		11:42	T.M.	.7985		1650	ATM				
929	.7909		11:43	T.M.	.7912		1649	ATM				
930	.7948		11:44	T.M.	.7950		1648	ATM				
931	.8041		11:45	T.M.	.8042		1647	ATM				
932	.7917		11:46	T.M.	.7918		1646	ATM				
933	.8047		11:47	T.M.	.8048		1645	ATM				
* 934	.7981		11:48	T.M.	.7918		1644	ATM	.7917	3/16/99	2130	Jaw
935	.7861		11:49	T.M.	.7861		1643	ATM				
936	.7827		11:50	T.M.	.7828		1643	ATM				
937	.7935		11:51	T.M.	.7933		1642	ATM				
938	.8086		11:52	T.M.	.8084		1641	ATM				
939	.8060		11:53	T.M.	.8058		1640	ATM				
940	.8151		11:54	T.M.	.8151		1639	ATM				
941	.8252		11:55	T.M.	.8249		1638	ATM				
942	.7982		11:56	T.M.	.7983		1637	ATM				
943	.7822		11:57	T.M.	.7822		1636	ATM				
* 944	.7938		11:58	T.M.	.7968		1635	ATM	.7968	3/16/99	2131	Jaw
945	.7944		11:59	T.M.	.7943		1635	ATM				
946	.7852		12:00	T.M.	.7850		1634	ATM				
947	.7731		12:01	T.M.	.7735		1633	ATM				
948	.7938		12:02	T.M.	.7940		1632	ATM				
949	.7838		12:03	T.M.	.7837		1631	ATM				
950	.8040		12:04	T.M.	.8038		1630	ATM				

Checked by Jaw

Date: 3/16/99 Time 2133

QA REWEIGH

Filter #	WT	Date	Time	By
929	.7912	3/16/99	2136	Jaw
941	.8248	3/16/99	2134	Jaw
949	.7837	3/16/99	2133	Jaw

BALANCE ROOM ENVIRONMENTAL CONDITIONS

WB	DB	%RH	Date	Time	By
64	79	43	3/16/99	1135	ATM
66	81	45	3/15/99	1622	ATM
65	82	39	3/16/99	2025	ATM

Post Test Weighing Session Scale Check
 1st 2nd 3rd QC
 0.0000 0.0000 0.0000 Δ.0001
 1.0000 1.0000 1.0000 0.9999

WOODSTOVE DATA SHEET #4-2:
INITIAL BEAKER WEIGHTS (TARE WEIGHTS)

Into Dessicator: Date: 8/20/99 Time: 1500 By: A. T. Myren

Glass

Beaker #	First Wt	Date	Time	By	Second Wt	Date	Time	By	Third Wt	Date	Time	By
1	65.4841	8/27	2059	SM	65.4835	8/30/99	1211	ATM				
2	66.1509	8/27	2118	SM	66.1514		1204	ATM				
3	67.8582		2116	SM	67.8578		1207	ATM				
4	67.5870		2108	SM	67.5891		1210	ATM				
6	67.4270		2119	SM	67.4274		1213	ATM				
7	65.5444		2105	SM	65.5446		1220	ATM				
8	66.0219		2221	SM	66.0218		205	ATM				
9	66.9297		2120	SM	66.9296		1215	ATM				
10	66.0906		2114	SM	66.0902		1209	ATM				
11	65.7072		2112	SM	65.7020		1217	ATM	65.7028	9/8/99	1717	SM
13	57.8946	✓	2110	SM	57.8948	✓	1218	ATM				
									65.7021	9/11	1232	SM
									65.7022	9/13	1934	SM
20	73.3159	8/27	2125	SM	73.3160	8/31/99	1320	ATM				
21	71.0002	8/27	2126	SM	71.0003	✓	1325	ATM				
22	71.8322	9/11/99	1240	ATM	71.8322	9/13	1719	SM				
23	70.7376	8/27	2131	SM	70.7382	8/30/99	1259	ATM	70.7376	9/8	1715	SM
24	73.2173	8/27	2130	SM	73.2182		1301	ATM	73.2176	9/8	1713	SM
25					72.6505	✓	1257	ATM	72.6504	9/8	1716	SM
26	71.7865	8/27	2132	SM	71.7868	8/31/99	1322	ATM				
27	72.3294	9/11/99	1235	ATM	72.3294	9/8	1718	SM				
28	70.5955	8/27	2127	SM	70.5956	8/31/99	1324	ATM				
29	71.5183	8/27	2133	SM	71.5185	✓	1318	ATM				
30	70.7845	8/27	2128	SM	70.7855	8/30/99	1302	ATM	70.7851	9/8	1714	SM
31	69.6652	8/27	2129	SM	69.6655	8/31/99	1327	ATM				
23	70.7375	9/11	1233	ATM								
24	73.2175	9/11	1242	ATM								

cont. 23
cont. 24

Checked By: A. T. Myren

Date: 9/11 & 13/99 Time: ATM

QA REWEIGH

Beaker #	WI	Date	Time	By

BALANCE ROOM ENVIRONMENTAL CONDITIONS

WB	DB	ZRH	Date	Time	By
68	83	46	8/27/99	2052	ATM
67	81	48	8/30/99	1154	ATM
63	76	48	8/31/99	1310	ATM
70	84	47	9/9/99	1705	ATM
69	84	46	9/11/99	1202	ATM
24	77	49	9/13/99	1926	ATM

WOODSTOVE DATA SHEET #4-2:
INITIAL BEAKER WEIGHTS (TARE WEIGHTS)

Into Dessicator: Date: 6/1/99 Time: 1400 By: A.T. Myrum

Beaker #	First Wt	Date	Time	By	Second Wt	Date	Time	By	Third Wt	Date	Time	By
1	65.4847	7/17/99	1636	OBM	65.4847	7/18/99	1612	ATM	← B	KAN	K	
2	66.1904		1638	OBM	66.1506	↓	1614	ATM	7/	13/99		
3	67.8572		1640	OBM	67.8567	↓	1616	ATM				
4	67.5887		1642	OBM	67.5880	↓	1618	ATM				
6	67.4268		1644	OBM	67.4266	↓	1620	ATM				
7	65.5436		1648	OBM	65.5437	↓	1622	ATM				
8	66.0212		1660	OBM	66.0211	↓	1623	ATM				
9	66.6299		1652	OBM	66.6295	↓	1625	ATM				
10	66.0889		1654	OBM	66.0888	↓	1627	ATM				
11	65.7015		1656	OBM	65.7013	↓	1628	ATM				
12	56.0655		1658	OBM	56.0653	↓	1632	ATM				
13	57.8948		1700	OBM	57.8944	↓	1630	ATM				

11111111111111111111

Checked By: A.T. Myrum Date: 7/18/99 Time: 1800

QA REVIEW

Beaker #	WT	Date	Time	By

BALANCE ROOM ENVIRONMENTAL CONDITIONS

WB	DB	ZRH	Date	Time	By
65	78	49	7/17/99	1825	ATM
63	77	45	7/18/99	1604	ATM

WOODSTOVE DATA SHEET #4-3: CONSTANT FINAL WEIGHTS

WST5-Form9, r81, Rev4/90
 Unit KUN... Wood C
 Run # EPA 2
 Date: 9/13/99

FINAL BEAKER WEIGHTS

Beaker #	Into Dessic	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By	
25	✓	9/13/99	0810	AM	72.6563	9/16	0857	AM	72.6563	9/18	1318	PM					

FINAL FILTER WEIGHTS

Filter #	Into Dessic	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By
932		9/13	1820	ATM	.8187	9/14	2040	AM	.8188	9/17	2059	PM	.8187	9/18	1255	AM
825		9/13	1820	ATM	.7827	9/14	2042	AM	.7826	9/17	2055	PM	.7825	9/18	1250	AM

QA REWEIGH: FINAL WEIGHTS

Date	Beaker #	Final Wt	By

SCALE ROOM ENVIRONMENTAL CONDITIONS

Session	Date	Time	By	WB	DB	ZRH
1	9/14	2025	AM	68	84	44
2	9/16	2045	ATM	69	84	46
3	9/17	2015	AM	66	79	49
4	9/18	1217	ATM	65	78	48
5						

SCALE ROOM ENVIRONMENTAL CONDITIONS

6						
7						
8						
9						
Comments						

WOODSTOVE DATA SHEET #4-3: CONSTANT FINAL WEIGHTS

Blank
7/18/99

WST5-Form9, rgl, Rev4/99
Unit KUMHO Wood Classic
Run #
Date: 7/1 1999

FINAL BEAKER WEIGHTS

Beaker #	Into Dessic	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By
1	✓	7/18/99	1435	ATM	65.4852	8/4/99	1715	ATM	65.4846	8/8/99	1742	0811	65.4849	8/9	1642	ATM

FINAL FILTER WEIGHTS

Filter #	Into Dessic	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By

QA REWEIGH: FINAL WEIGHTS

Date	Beaker #	Final Wt	By
Date	Filter #	Final WT	By

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighing Session	Date	Time	By	WB	DB	ZRH
1	8/4	1705	ATM	69	83	49
2	8/8	1700	ATM	64	78	46
3	8/9	1615	ATM	69	84	46
4						
5						

SCALE ROOM ENVIRONMENTAL CONDITIONS

6	7	8	9	Comments

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale Mettler

Model AE100
SN K04827

Dates From 1/9/99

Through 7/17/99

Level	Recalibrated	100g Weight	10g Weight	1.0g Weight	100mg Weight	20mg Weight	Date	Time	Tech	Wet Bulb	Dry Bulb	% RH
✓	Yes PO	99.9999	10.0001	1.0002	.1003	.0203	1/9/99	12:43	ATM	58	75	48
✓	No	100.0002	10.0000	1.0000	1.0000	1.0000	1/14/99	11:13	ATM	62	75	47
✓	Yes PO	99.9999	10.0002	1.0000	.0999	.0201	1/23/99	11:00	ATM	63	77	48
✓	Yes	99.9999	10.0000	1.0000	1.0000	1.0000	1/24/99	13:18	ATM	59	74	45
✓	Yes	99.9996	10.0002	1.0000	1.0000	1.0000	2/1/99	09:10	ATM	55	69	39
✓	Yes	99.9997	10.0001	1.0001	1.0002	1.0001	2/2/99	09:39	ATM	60	73	46
✓	Yes	99.9999	10.0001	1.0001	1.0001	1.0001	2/2/99	15:55	ATM	63	76	48
✓	Yes	99.9999	10.0000	1.0001	1.0001	1.0001	2/7/99	12:35	ATM	62	76	45
✓	Yes	99.9998	10.0000	1.0000	1.0000	1.0000	2/10/99	16:00	ATM	63	77	45
✓	Yes	99.9998	10.0000	1.0001	1.0000	1.0000	2/19/99	02:46	ATM	64	78	46
✓	No	99.9999	10.0000	1.0000	1.0000	1.0000	2/21/99	13:12	ATM	65	80	44
✓	No	99.9997	10.0000	1.0001	1.0000	1.0000	2/5/99	19:35	ATM	64	80	41
✓	Yes PM	99.9997	10.0000	1.0000	1.0001	1.0000	2/6/99	11:33	ATM	64	79	43
✓	Yes	99.9997	10.0000	1.0001	1.0000	1.0000	3/13/99	15:26	ATM	65	80	44
✓	Yes	99.9999	10.0001	1.0001	1.0001	1.0001	3/14/99	13:55	ATM	63	78	43
✓	No	100.0001	10.0000	1.0000	1.0000	1.0000	3/15/99	16:22	ATM	66	81	43
✓	Yes	99.9997	10.0000	1.0001	1.0000	1.0000	3/16/99	20:25	ATM	65	82	39
✓	Yes	99.9996	10.0000	1.0001	1.0001	1.0001	3/17/99	16:15	ATM	62	77	42
✓	Yes	99.9997	10.0000	1.0001	1.0000	1.0000	3/18/99	21:40	ATM	68	84	43
✓	Yes	99.9997	10.0000	1.0000	1.0000	1.0000	3/20/99	13:00	ATM	64	84	32
✓	Yes	99.9999	10.0000	1.0001	1.0001	1.0001	3/21/99	22:15	ATM	61	74	47
✓	Yes	99.9997	10.0000	1.0000	1.0001	1.0000	3/22/99	21:22	ATM	65	83	33
✓	Yes	99.9997	10.0000	1.0001	1.0000	1.0000	3/23/99	11:15	ATM	69	84	46
✓	Yes	99.9997	10.0000	1.0002	1.0001	1.0001	3/24/99	11:20	ATM	77	89	43
✓	Yes	99.9999	10.0000	1.0002	1.0001	1.0001	3/29/99	20:38	ATM	83	92	45
✓	No	99.9999	10.0002	1.0002	1.0001	1.0002	3/30/99	06:10	ATM	66	80	47
✓	No	99.9999	10.0000	1.0000	1.0001	1.0001	3/31/99	10:00	Sum	64	80	41
✓	No	99.9996	10.0000	1.0000	1.0001	1.0001	4/5/99	17:30	ATM	64	80	41
✓	Yes	99.9997	10.0001	1.0001	1.0001	1.0001	4/6/99	10:30	ATM	61	75	44
QC Services	Audit	4/6/97					Scale Calibration					
✓	No	100.0003	10.0001	1.0001	1.0001	1.0001	4/6/99	17:30	ATM	65	85	33
✓	Yes	99.9998	10.0001	1.0001	1.0001	1.0001	4/7/99	17:24	ATM	63	80	50
✓	No	99.9996	10.0000	1.0001	1.0001	1.0001	4/8/99	13:46	ATM	66	82	48
✓	Yes	99.9997	10.0000	1.0000	1.0000	1.0000	4/16/99	12:30	ATM	63	81	43
✓	Yes	99.9997	10.0000	1.0000	1.0000	1.0000	4/17/99	16:25	ATM	63	81	43
✓	Yes	99.9997	10.0000	1.0000	1.0000	1.0000	5/19/99	10:50	ATM	63	72	45
✓	No	99.9999	10.0000	1.0000	1.0000	1.0000	5/17/99	18:25	ATM	65	78	49
✓	Yes	99.9996	10.0001	1.0002	1.0001	1.0002			ATM			

WOODSTOVE DATA SHEET #4-4

SCALE QA SHEET

Dates From 7/18/99

Through 9/16/99

Scale Mettler
Model AE100
SN K04827

Level	Recali- brated	100g Weight	10g Weight	1.0g Weight	100mg Weight	20mg Weight	Date	Time	Tech	Wet Bulb	Dry Bulb	% RH
✓	No	99.9997	10.0000	1.0001	1.0000	.0201	7/18/99	16:04	ATM	63	77	45
✓	Yes	99.9997	10.0000	1.0001	1.0001	.0201	7/19/99	18:35	ATM	64	77	49
✓	Yes	99.9996	10.0000	1.0003	1.0002	.0202	7/20/99	18:54	ATM	71	85	80
✓	Yes	99.9997	10.0001	1.0001	1.0001	.0201	7/21/99	1:50	ATM	69	84	50
✓	Yes P.O.	99.9996	9.9999	1.0000	1.0001	.0200	7/22/99	2:45	ATM	64	80	41
✓	Yes	99.9996	10.0000	1.0000	1.0000	.0200	7/23/99	0:45	ATM	62	76	45
✓	No	99.9998	10.0000	1.0000	1.0000	.0200	7/24/99	13:40	ATM	66	80	47
✓	Yes P.O.	would not calibrate					8/3/99	2:17	ATM	70	84	47
✓	Yes	99.9998	10.0001	1.0002	1.0000	.0201	8/4/99	1:05	ATM	69	83	49
✓	No	99.9998	10.0001	1.0001	1.0000	.0200	8/5/99	2:06	ATM	65	78	49
✓	Yes	99.9998	10.0000	1.0000	1.0000	.0200	8/6/99	15:36	ATM	68	81	50
✓	No	99.9999	10.0000	1.0001	1.0000	.0200	8/7/99	15:15	ATM	66	80	47
✓	Yes	99.9996	10.0001	1.0000	1.0001	.0201	8/8/99	1:00	ATM	64	73	46
✓	Yes	99.9997	10.0000	1.0001	1.0000	.0200	8/9/99	12:25	ATM	68	82	48
✓	No	99.9997	10.0001	1.0001	1.0001	.0200	8/9/99	16:15	ATM	69	84	46
✓	Yes	99.9997	10.0000	1.0000	1.0000	.0200	8/10/99	13:27	ATM	67	84	49
✓	Yes	99.9998	10.0000	1.0000	1.0001	.0200	8/11/99	10:43	ATM	67	81	48
✓	Yes	99.9996	10.0000	1.0001	1.0001	.0201	8/14/99	20:35	ATM	64	78	46
✓	Yes	99.9997	10.0000	1.0001	1.0000	.0200	8/13/99	12:30	ATM	64	80	47
✓	Yes	99.9998	10.0001	1.0002	1.0002	.0201	8/14/99	19:29	ATM	63	76	48
✓	Yes	99.9998	10.0000	1.0001	1.0001	.0201	8/16/99	11:35	ATM	64	77	48
✓	Yes	99.9998	10.0001	1.0001	1.0001	.0201	8/17/99	17:50	ATM	68	83	46
✓	Yes	99.9998	10.0000	1.0001	1.0001	.0200	8/18/99	16:50	ATM	70	84	47
✓	No	99.9999	10.0001	1.0000	1.0000	.0201	8/22/99	20:52	ATM	68	83	47
✓	No	99.9999	10.0001	1.0002	1.0001	.0202	8/30/99	11:54	ATM	67	81	48
✓	Yes	99.9997	9.9999	1.0000	1.0001	.0200	8/31/99	13:10	ATM	63	76	48
✓	Yes	99.9997	10.0000	1.0000	1.0000	.0200	8/31/99	18:44	ATM	65	79	44
✓	Yes	99.9998	10.0000	1.0000	1.0000	.0200	9/2/99	10:32	ATM	60	74	43
✓	Yes	99.9998	10.0000	1.0002	1.0002	.0200	9/8/99	1:06	ATM	70	84	47
✓	Yes	99.9996	10.0001	1.0002	1.0001	.0201	9/11/99	12:02	ATM	69	84	46
✓	Yes	99.9996	10.0000	1.0001	1.0001	.0201	9/12/99	20:58	ATM	70	84	49
✓	Yes	99.9997	10.0001	1.0000	1.0000	.0201	9/13/99	19:26	ATM	64	77	44
✓	Yes	99.9997	10.0001	1.0002	1.0002	.0202	9/14/99	13:35	ATM	64	77	44
✓	Yes	99.9997	10.0001	1.0002	1.0002	.0202	9/14/99	20:15	ATM	64	77	44
✓	Yes	99.9998	10.0001	1.0002	1.0002	.0202	9/15/99	08:20	ATM	64	77	44
✓	Yes	99.9998	10.0001	1.0001	1.0001	.0201	9/15/99	08:20	ATM	64	77	44
✓	Yes	99.9998	10.0001	1.0001	1.0001	.0201	9/16/99	08:45	ATM	64	77	44
✓	No	99.9998	10.0000	1.0000	1.0000	.0200	9/16/99	16:55	ATM	64	77	44

Unit: Kuma Wood Classic
 Run: EPA 2
 Date: 9/13 1999
 Technicians: ATM RLS
 WST20, Form 5

Woodstove Particulate
 Catch Processing Sheet
 Woodstove Data Sheet #5
 EPA M5G-1

Filters

Filter # (F) 932 Beaker # 25 Final Wt. 72.6563 g ✓
 Final Wt. .8184 g ✓ MI 25 Tare Wt. 72.6504 g ✓
 Tare Wt. .7918 g ✓ Desc. Acetone Net Wt. .0059 g ✓
 Net Wt. .0266 g ✓

Filter # (E) 825 Beaker # _____ Final Wt. _____ g
 Final Wt. .7825 g ✓ MI _____ Tare Wt. _____ g
 Tare Wt. .7811 g ✓ Desc. _____ Net Wt. _____ g
 Net Wt. .0014 g ✓

Acetone Blank Calculation: Blank done 7/18/99

Blank Beaker # 1 Final Wt. 65.4847
 MI 50 Tare Wt. 65.4847
 Desc Acetone Net Wt. .0000
.0000 g ÷ 50 ml = .0000 g/ml

Particulate Catch Calculation

Filter: .0266 g ✓
 Filter: .0014 g ✓
 Beakers: .0059 - (25)(.0000) = .0059 g ✓
 Total Catch Ml of Acetone
 Blank Value/Ml of Acetone
 Total Catch = .0339 g ✓

Unit Kuma Wood Classic
 Run # EPA 2
 Date 9/13/1999
 Technician ATM RLS
 WST6-Form1, Rev8/96

MISCELLANEOUS TEST DATA
 WOODSTOVE DATA SHEET #8

Useable Firebox Dimensions: See QC Section Useable Volume: 2.228 ft³

Dilution Tunnel Draft (If applicable): Start 00.0 Stop 00.0

Test Chamber Air Velocity: Start: 00.0 Stop: 00.0 Avg: 00.0

Wet Bulb/ Start: WB: 62 °F DB: 74 °F 1.5 % Amb Moisture 50 %RH

Dry Bulb Stop: WB: 62 °F DB: 74 °F 1.5 % Amb Moisture 50 %RH

$\bar{x} = 1.5$ % Ambient Moisture $\bar{x} = 50$ % Relative Humidity (RH)

Empty

Stove Wt:

419.3 lbs.

Empty

Stove Wt with Stack (Inc. Oil Seal) Wet: 570.9 lbs. Dry: 509.2 lbs.

Empty

Stove Wt with Stack and Ash Ash: — lbs. Total: — lbs.

Kindling Wt.

Paper: 0.3 lbs. Wood: 4.2 lbs.

Pre Burn Fuel Wt. 14.1 + 14.3 + 14.3 Total: 42.7 lbs. ✓

Total Kindling and Pre Burn Fuel Wt. 47.2 lbs. ✓

Coal Bed Wt-lbs: Range (572.8 - 572.2) 3.6 - 3.0 lbs. Actual: 3.6 lbs.

Allowable Amount of Charcoal that can be removed:

Coal Bed Wt. Range 3.6 + 3.0 $12 \times .25 =$ 1.8 lbs.

Test Fuel Wt-lbs: Ideal 15.6 lbs. Range: 17.1 - 14.1 lbs. Actual: 14.6 lbs.

Test Fuel Size (pcs.) (.75 x 1.5 x 5" Flanges) 16 Pcs.

2 x 4's x 15 ¹⁵/₁₆ " 3 Pcs 6.5 lbs. 44.5 % ✓

4 x 4's x 15 ¹⁵/₁₆ " 2 Pcs 8.1 lbs. 55.5 % ✓

Est. Dry Burn Rate (Kg/Hr.) $\frac{14.6 - (14.6 \times .17630)}{2.2046} \times \frac{60}{325} =$ 1.0070 Est. Dry Burn Rate (Kg/Hr) ✓

Est EPA Heat Output (HO_E) (19,140) x $\frac{63}{100} \times 1.007 =$ 12,143 Est Heat Output (HO_E) BTU's/Hr ✓

Comments:

Stove Operating Data
Woodstove Test Data Sheet #9
Cold Start

Unit: KUMA WOOD CLASSIC
Run: EPA 2
Date: 7/13/99
Technician(s): ATH, PLS.
Data Sheet #9 - Rev 1/98-Pg.2

Fire Started: 0805 P.D.S.T.

Warm up and Preburn: Primary Air: Wide open from ignition until the start of preburn when the primary air control(s) was (were) adjusted to the run setting of 7/16" OPEN. At the run setting until the start of the test.

Secondary Air:

No Controls, Naturally drafted

Secondary Burn/Cat Bypass: N/A

Charcoal Bed Preparation: Broke up, raked and leveled the coal bed prior to the addition of each warm up/pre burn fuel charge. Starting 1:30 before the start of the test, broke up, raked and leveled the coal bed. In stove for 34 seconds.

Test: Door wide open during loading _____ min 40 sec, then closed,

Primary Air: Wide open during the start of the test until 4:55. Adjusted to the run setting of 7/16" between 4:55 and 5:00. At the run setting of 7^R/16 open at 5:00 into the run.

Secondary Air:

No Controls, Naturally drafted.

Secondary Burn/Cat Bypass: N/A

Fan: ON OFF during the warm up, ON OFF High during the preburn, ON OFF at the start of the test, ON OFF for the first 30 minutes of the test, ON OFF high at 30 minutes into the test, ON OFF for the rest of the test.

Test Run Anomalies:

DBR was slower than expected.

Unit Kuma Wood Classic
 Run # EPA 2
 Date 9/13/1999
 Technician ATM RLS
 Page 1 of 4
 WST7-Form2-A, Rev10/88

WOODSTOVE OPERATING DATA
 WOODSTOVE DATA SHEET #9A-1

Wood Data: Kindling: A mix of the below grades

	Size	Mill	Grade	Species
Pre Burn	2X4	CANYON Lumber	# 2 & Better	D. Fir SFC GRN
Test Fuel	2X4	CANYON Lumber	# 2 & Better	D. Fir SFC GRN
	4X4	R.I.B. CONST.	# 1	D. Fir SFC GRN

All grades WCLB Rules unless otherwise noted.

Warm up Information:

1st Warm up/Pre Burn Fuel charge (14.1 lbs) added at 0825.
 2nd Warm up/Pre Burn Fuel charge (14.3 lbs) added at 0926.
 3rd Warm up/Pre Burn Fuel charge (14.3 lbs) added at 1025.
 4th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____.
 5th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____.
 6th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____.
 7th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____.
 8th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____.

The coals were scooped out of the stove immediately prior to adding the 3 pre burn/warm up fuel charge. The stove lost 1.7 lbs. 3.0 lbs. of coals were put back in the stove after the scoop.


All pre burn/warm up fuel pieces were ~~_____~~ 16" inches long. All preburn pieces/fuel charges were "ricked" in the stove. The pieces in the bottom layer in each rick contained 2 pcs that were 16 inches long and were loaded flat and perpendicular to the door. The pieces in the second layer in each rick were loaded on their side (edge) approximately parallel to the door and contained 4 pcs 16 inches long. The third layer (and fourth layer if present) was loaded flat, perpendicular to the door and contained 2 pcs 16 inches long. The majority of the pieces in each rick were in the second layer which had an approximate 0.5-1.0" space between pieces. (The loading directions indicate the direction of the longest dimension on each piece relative to the loading door opening.) Each pre burn/warm up fuel charge normally weighs within the weight range allowed for the actual test fuel charge

WOODSTOVE OPERATING DATA
WOODSTOVE DATA SHEET #9A-2


Unit Kuma Wood Classic
Run # EPA 2
Date 9/13/1999
Technician ATM RLS
Page 2 of 4
WST7-Form2-A, Rev 6/90

Warm up Information (cont.):

Each warm up/preburn fuel charge was ricked in exactly (as much as possible) the same manner and the weight of each rick was usually within the allowable weight range for the test fuel charge. The physical arrangement and alignment of each rick was designed to accomplish three (3) things: (1) The bottom layer was nestled firmly into the coal bed and was as close to being level with the bottom of the stove as possible, thus providing a stable loading platform for the rest of the rick, keeping it in a ricked state (as opposed to a collapsed or fallen down state) until the rick reached the charcoal stage and sags or collapses of its own accord. (2) It enhances the flow of primary air through the ricked preburn fuel charge, for the primary air would flow through the spaces between the pieces in the first layer and then up through the spaces between the pieces in the second, third and, if present, fourth layers. (3) It maximized, as much as possible, the surface to volume ratio of each preburn fuel charge, thereby allowing the fire immediate access to as much wood surface as possible and, thereby, insuring uniform charcoalization. All three of these enhance combustion and so get the stove as hot as possible during the warm up period, thereby maximizing the amount of heat (BTU's) stored in the stove. The actual preburn was not started until the stove surface temperatures had maximized and stabilized, thus indicating that the amount of heat stored in the stove had peaked. For this stove, the thermal storage was monitored using the TOP surface temperature(s) and the peak value(s) obtained were 950 of.



Front View



Top View

The arrows indicate the direction of the air flow through the rick.

The primary air was adjusted to the run setting of 7/16" open 4.8 lbs above the upper charcoal bed weight.

WOODSTOVE OPERATING DATA
WOODSTOVE DATA SHEET #9A-3


Unit KAMA Wood Class: C
Run # EPA 2
Date 9/13/99
Technician ATM
Page 3 of 4
WST5-Form2-Rev11/89

Additional Comments: Test Start Sequence: ① Turned fan off.
② Opened primary air control wide open ③ opened door
④ loaded test fuel ⑤ cleared coals away from in front of the LPOO ⑥ Photograph ⑦ closed door.

TOTAL Elapsed Time: 0:40 Secs.

Test Fuel Charge Loading Information:

Test Fuel Charge and Loading Sequence Diagram



Loaded the test fuel charge on an essentially level, medium/large sized, hot coal bed (in appearance, color and temperature for a medium low burn rate. Ignition 10:25 Load 01:40 11:15 VC to baffle, 11:45 VC flames curling down on top of 4X4's, 11:36 Flames on Left side of L, Shake (flickers), 11:45 Flames in front of R, Canyon, 2:15, Secondaries / flames above 3 & 5 coming forward past the front tube, 2:22 Front tube starting to ignite,

* 3:23 Gas Balance

5:00 13.4% CO₂ / 20% CO

Flames ↓, Maintained a hot pocket with VC to baffle, plus Secondaries / flames on top of 3 & 5, Front tube flashing in / off plus flames on top L. Side of Pc 5, Maintained balance after shut down,

WOODSTOVE OPERATING DATA
 WOODSTOVE DATA SHEET #9A-4

Additional Comments:

- 6:45: Still in balance, but CO↑ to 0.81%
- 7:30: 2nds / flames full width of 3rds.
- 8:05: right at Balance
- 8:14: In / Out of balance
- 8:20: In balance & CO ↓
- 9:04: In / Out again.
- 10:19: 9.0 / .85 ✓
- 11:00: CO₂ ↑ CO ↓
- 12:20: CO₂ ↓ CO ↑
- 15:19: Just in balance
- 15:45: Flames on the left side of h. Stacks
- 17:30: All flames ↑ a little
- 18:25: Front tube flickering on / off.
- 18:50: Flames / 2nds starting over
- 20:50: Taking off
- 23:45: 11.8 / .52 - hammer going down,
- 26:00: 13.5 / .24 - LPAO blowing a little. But
 stove is burning OK, ✓
- 30:00: Fan On high. ✓

FUEL MOISTURE
WOODSTOVE TEST DATA SHEET #10

Unit: Kuma Wood Classic
Run: EPA 2
Date: 9/13/1999
Technician: ATM DLS
WST1-Form7-Rev11/89

Room Temperature: 69 °F

Correction Factor: 0

NOTE: Record readings to the nearest 0.5% moisture
Uncor Values are corrected for temperature: Yes No
Time Test Fuel Moisture Readings taken at: 1035
Calibration Checks: X Y 12.5 12.0 22.0 22.5

Pc #	Dimen	Use	Top		Bottom		Side		Piece Avg Corrected
			Uncor	Cor	Uncor	Cor	Uncor	Cor	
1	2x4x8'	K	12.0	12.8	12.0	12.8	12.5	13.3	(12.967)
2									
3									
4	2x4x10'	P	18.5	19.8	18.5	19.8	18.0	19.2	19.600
5	2x4x8'		21.5	23.1	21.0	22.6	20.5	22.0	22.567
6	"		21.5	23.1	21.5	23.1	20.5	22.0	22.733
7	"	↓	18.0	19.2	18.0	19.2	18.0	19.2	19.300
8									(84.100)
9									
10	2x4-15 ^{15/16}	T	18.0	19.2	18.0	19.2	18.0	19.2	19.200
11	"		19.5	20.9	19.0	20.3	18.5	19.8	20.333
12	"	↓	22.5	24.3	22.0	23.7	22.5	24.3	24.100
13									
14	4x4-15 ^{9/16}	T	19.0	20.3	19.0	20.3	19.0	20.3	20.300
15	"	↓	21.5	23.1	21.5	23.1	21.5	23.1	23.100
16									(107.033)
17									
18									
19	5x1.5x.75 Spacers		20.5	22.0	20.0	21.4	20.5	22.0	21.800
20									OUT-SPACERS

	Kindling	Pretest Fuel	Test Load
% Moisture - Dry Basis:	12.967%	21.025%	21.407%
% Moisture - Wet Basis:	11.478%	17.372%	17.632%

To obtain Wet from Dry: $\frac{100 \times \% \text{ Dry Rdg.}}{100 + \% \text{ Dry Rdg.}} = \% \text{ Moisture, Wet Basis}$

Acceptable Ranges: 16-20% wet; 19-25% dry
(17.5 - 22.5 on Meter [Uncor reading] at 70°F)

Key for Use: K= Kindling P= Pretest Fuel T= Test Fuel

WOOD DENSITY DETERMINATION
WOODSTOVE TEST DATA SHEET #11

Unit: KUMA Wood CLASSIC
Run#: EPA 2
Date: 9/13/1999
Technician: ATM RLS
WST2-form11-Rev 6/90

Wood Piece: Nominal Dimensions: 3 1/2" x 3 1/2" x 1 1/2" in
Depth (D): in 1.533 cm 3.894
Width (W): in 3.531 cm 8.969
Length (L): 3.439 cm in
3.445 cm in
3.432 cm in
3.463 cm in
Length \bar{X} = in 3.445 cm 8.750
Volume: 305.596 cm³
(D X W X L)

MOISTURE: Room Temperature: 69 °F Correction Factor: 0

Uncorrected Meter Readings Corrected for temperature: Yes No

NOTE: Record moisture meter readings to the nearest 0.5%

	Uncor	Cor	
Top:	18.0	19.2	%
Bottom:	18.0	19.2	%
Side:	18.0	19.2	%
\bar{X} :		19.200	%

Avg % Moisture (Dry) 19.200 %

Avg % Moisture (Wet) 16.107 %

Scale: Leveled In Out

Zeroed: In Out

Wet Weight: 157.8 g Dry Weight: 134.0 g

% Moisture Dried Basis: 15.032 %
[1 - (Dry Wt ÷ Wet Wt)] X 100

	Date	Time	Temp	°F
Into Dryer	<u>9/13/99</u>	<u>1040</u>	<u>213</u>	
Out of Dryer	<u>9/22/99</u>	<u>1548</u>	<u>214</u>	

(Minimum Time in Dryer: 24 hrs.) Minimum Dryer Temp 100°C (212°F)

Density = 134.0 g (dry wt) ÷ 305.596 cm³ (volume) = 0.4385 g/cm³

Pellet Fuel Moisture Content Determination

Tare Beaker Wt. _____ g

Wet Wt: _____ g - _____ g = _____ g

Gross Wet Wt. Tare Beaker Wt. Net Wet Wt.

Dry Wt: _____ g - _____ g = _____ g

Gross Dry Wt. Tare Beaker Wt. Net Dry Wt.

% Moisture Dried Basis: _____ %

[1 - (Net Dry Wt ÷ Net Wet Wt.)] X 100

END WT: 522.8 lbs.

Minute	Scale Wt	lbs Left	Burn Rate	CO ₂		O ₂		CO		T/C(1) T/C(2)		T/C(3)		Stack	SO ₂	Static Press.	Comments
				v.	%CO ₂	v.	%O ₂	v.	%CO	Wet Bulb	Dry Bulb	% H ₂ O	Calc W/B				
0	527.4	14.6	0	298	7.39	49.4	12.34	1.00	7.4	86	92	248		-0.35		Flow	
5	526.4	13.6	1.0	475	11.75	26.7	6.67	0.22	53.4	88	109	308		-0.74		SO ₂ 1.5	
10	525.8	13.0	1.6	361	8.94	45.3	11.32	0.86	10.4	92	115	376		-0.58		SO ₂ 1.5	
15	525.2	12.4	1.6	363	8.99	44.4	11.09	0.81	11.1	96	117	356		-0.57		SO ₂ 1.5	
20	524.6	11.8	1.6	409	10.13	39.7	9.92	0.67	15.1	100	120	365		-0.58		SO ₂ 1.5	
25	524.0	11.2	1.6	445	11.07	35.7	8.92	0.67	16.4	103	122	384		-0.60			
30	523.2	10.4	1.8	519	13.58	28.2	7.05	0.25	54.3	106	123	414		-0.62			
35	522.1	9.8	1.6	568	14.05	26.6	6.65	0.22	63.9	107	124	382		-0.63			
40	521.9	9.1	1.7	557	13.78	27.8	6.95	0.21	65.6	108	123	421		-0.62			
45	521.3	8.5	1.6	554	13.70	27.7	6.92	0.23	59.6	107	122	412		-0.62			
50	520.7	7.9	1.6	565	13.97	26.9	6.72	0.29	48.2	107	121	413		-0.61			
55	520.0	7.2	1.7	577	14.27	25.7	6.42	0.21	67.9	107	121	415		-0.61			
60	519.3	6.5	1.7	582	14.39	25.0	6.25	0.17	84.7	107	120	473.4		-0.61		Flow	
65	518.7	5.9	1.6	597	14.76	23.2	5.80	0.21	70.3	107	120	415		-0.61		SO ₂ 1.5	
70	518.2	5.4	1.5	555	13.73	28.0	7.00	0.12	114.4	107	118	419		-0.61		SO ₂ 1.5	
75	517.7	4.9	1.5	621	12.89	31.1	7.77	0.13	99.1	107	116	405		-0.60		SO ₂ 1.5	
80	517.2	4.4	1.5	514	12.72	31.1	7.77	0.15	84.8	106	114	391		-0.58		SO ₂ 1.5	
85	516.8	4.0	1.4	575	12.74	30.4	7.60	0.10	123.4	105	112	383		-0.57			
90	516.4	3.6	1.4	479	11.85	33.8	8.45	0.16	74.1	104	110	384		-0.56			
95	516.2	3.4	1.2	388	9.61	43.0	10.74	0.51	18.8	103	108	368		-0.55			
100	516.0	3.2	1.2	329	7.98	47.9	11.97	0.85	9.4	102	105	344		-0.51			
105	515.8	3.0	1.2	271	6.73	57.7	12.92	1.13	6.0	101	101	320		-0.47			
110	515.7	2.9	1.1	267	6.63	57.9	12.97	1.20	5.5	100	99	296		-0.44			
115	515.5	2.7	1.2	267	6.63	57.7	12.92	1.19	5.6	99	99	283		-0.42			
120	515.5	2.7	1.2	267	6.63	57.7	12.92	1.19	5.6	99	99	275		-0.40			
125	515.5	2.7	1.2	267	6.63	57.7	12.92	1.19	5.6	99	99	498.3		-0.32			

9077

1,345

T/C#	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Minute/Time	Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn	Room Temp	Tunnel	C. Gas Box	Impinger Out	5G-1 Filter	5G-1 Condenser	Hot Box	
0	358	497	318	462	443	817	914	72	99	250	36	87	51	797	248
5	367	485	325	454	442	703	1120	72	120	250	36	88	37	1088	248
10	513	497	314	445	441	598	1368	72	114	250	37	88	37	810	248
15	514	468	309	436	438	704	1331	73	111	250	37	88	38	1001	249
20	525	464	305	430	434	730	1360	72	110	250	37	88	38	939	250
25	547	467	302	428	429	766	1366	73	111	250	38	88	37	1024	250
30	597	465	301	429	424	788	1432	73	114	250	38	88	37	1143	250
35	635	484	280	443	419	814	1393	73	114	250	38	88	38	1088	250
40	641	500	267	453	415	848	1396	73	114	250	38	88	38	1072	250
45	639	514	257	462	410	880	1395	73	114	250	38	88	37	1102	249
50	639	528	253	473	406	922	1444	74	114	250	38	88	37	1123	249
55	644	534	253	486	403	998	1394	74	114	250	39	88	37	1111	249
60	649	588	248	510	570	9648	15913	87	116	250					
65	648	549	257	499	401	1020	1420	74	116	250	39	88	38	1091	248
70	656	558	260	509	399	1106	1463	74	116	250	39	88	38	1128	248
75	657	517	264	520	399	1092	1332	74	116	250	39	88	38	1218	249
80	624	574	270	527	398	1087	1303	74	115	250	39	88	38	1166	250
85	608	579	275	530	397	1008	1247	75	114	250	39	88	37	1127	250
90	609	582	281	532	395	1004	1200	75	114	250	39	88	38	1214	250
95	598	583	286	536	395	990	1191	75	113	250	39	88	38	1131	250
100	559	581	289	539	396	967	1181	75	112	250	39	88	38	1048	250
105	570	578	290	535	397	937	1095	76	110	249	39	88	38	1044	250
110	470	570	289	524	397	886	1032	76	109	249	39	88	38	1064	250
115	441	558	285	513	396	861	1006	76	108	249	39	88	38	1020	250
116	424	545	282	504	395	844	975	76	107	249	39	88	38	1047	249
	6753	6824	3328	6268	4765	11802	17445	900							
	13,712	14,707	6812	11,669	9869	21,450	30,358	1794							

TEMPERATURES
RECORD SHEET #14
WST2-Form14 Rev7/96

Unit: KUMA WOOD CLASSIC Date: 9/13/99
Run: EPA 2 Technician(s): ATH, RLS
Page: 2 of 3

T/C#	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Minute/Time	Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn Catalytic	Room Temp	Tunnel	C. Gas Box	Impinger Out	5G-1 Filter	5G-1 Condenser	Gen-dar	HOT BOX
120	481	531	277	497	394	831	936	76	106	249	39	88	38	1026	249
125	392	520	273	491	393	816	918	76	106	249	40	88	38	1028	249
130	381	508	268	483	391	799	897	76	105	250	40	88	38	1027	250
135	371	498	265	478	390	783	877	76	105	250	40	88	38	994	250
140	362	487	264	472	388	770	862	76	104	250	40	88	38	957	250
145	356	477	263	468	386	761	857	76	104	250	37	88	38	929	250
150	350	468	262	464	385	750	837	76	103	250	36	88	38	877	250
155	342	459	259	457	383	740	823	76	103	250	36	88	38	870	250
160	335	450	256	449	381	732	810	76	102	250	37	88	38	869	250
165	329	443	253	442	381	722	799	76	102	250	37	88	38	872	249
170	326	436	252	436	381	717	794	76	102	250	37	88	38	870	249
175	323	421	252	431	382	715	789	76	101	249	37	88	38	877	249
180	319	415	252	427	382	713	773	76	101	249	37	88	38	901	249
185	316	401	251	423	382	712	765	77	101	249	37	88	38	907	249
190	312	417	252	419	382	714	758	77	101	248	37	88	38	937	249
195	311	413	252	416	381	712	755	76	100	249	37	88	38	952	249
200	309	411	253	414	381	715	753	76	100	249	37	88	38	969	248
205	308	409	254	411	380	721	749	77	100	249	37	88	38	994	249
210	306	407	256	409	379	722	744	76	100	250	37	88	38	966	250
215	304	406	257	407	378	720	742	76	100	250	37	88	38	955	250
220	302	405	258	405	378	738	792	77	100	250	37	88	38	840	250
225	302	405	256	402	377	747	791	77	99	250	37	88	38	830	250
230	301	405	254	399	378	744	768	76	100	250	37	88	38	832	250
235	299	405	251	395	379	752	758	77	100	251	38	88	38	806	250
240	297	404	251	392	378	870	914	918	100	251	38	88	38		
245	295	403	251	391	377	870	914	918	100	251	38	88	38		
250	293	402	251	390	376	870	914	918	100	251	38	88	38		
255	291	401	251	389	375	870	914	918	100	251	38	88	38		
260	289	400	251	388	374	870	914	918	100	251	38	88	38		
265	287	399	251	387	373	870	914	918	100	251	38	88	38		
270	285	398	251	386	372	870	914	918	100	251	38	88	38		
275	283	397	251	385	371	870	914	918	100	251	38	88	38		
280	281	396	251	384	370	870	914	918	100	251	38	88	38		
285	279	395	251	383	369	870	914	918	100	251	38	88	38		
290	277	394	251	382	368	870	914	918	100	251	38	88	38		
295	275	393	251	381	367	870	914	918	100	251	38	88	38		
300	273	392	251	380	366	870	914	918	100	251	38	88	38		
305	271	391	251	379	365	870	914	918	100	251	38	88	38		
310	269	390	251	378	364	870	914	918	100	251	38	88	38		
315	267	389	251	377	363	870	914	918	100	251	38	88	38		
320	265	388	251	376	362	870	914	918	100	251	38	88	38		
325	263	387	251	375	361	870	914	918	100	251	38	88	38		
330	261	386	251	374	360	870	914	918	100	251	38	88	38		
335	259	385	251	373	359	870	914	918	100	251	38	88	38		
340	257	384	251	372	358	870	914	918	100	251	38	88	38		
345	255	383	251	371	357	870	914	918	100	251	38	88	38		
350	253	382	251	370	356	870	914	918	100	251	38	88	38		
355	251	381	251	369	355	870	914	918	100	251	38	88	38		
360	249	380	251	368	354	870	914	918	100	251	38	88	38		
365	247	379	251	367	353	870	914	918	100	251	38	88	38		
370	245	378	251	366	352	870	914	918	100	251	38	88	38		
375	243	377	251	365	351	870	914	918	100	251	38	88	38		
380	241	376	251	364	350	870	914	918	100	251	38	88	38		
385	239	375	251	363	349	870	914	918	100	251	38	88	38		
390	237	374	251	362	348	870	914	918	100	251	38	88	38		
395	235	373	251	361	347	870	914	918	100	251	38	88	38		
400	233	372	251	360	346	870	914	918	100	251	38	88	38		
405	231	371	251	359	345	870	914	918	100	251	38	88	38		
410	229	370	251	358	344	870	914	918	100	251	38	88	38		
415	227	369	251	357	343	870	914	918	100	251	38	88	38		
420	225	368	251	356	342	870	914	918	100	251	38	88	38		
425	223	367	251	355	341	870	914	918	100	251	38	88	38		
430	221	366	251	354	340	870	914	918	100	251	38	88	38		
435	219	365	251	353	339	870	914	918	100	251	38	88	38		
440	217	364	251	352	338	870	914	918	100	251					

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-1

Site: Myren Consulting, Woodinville, WA Date: 9/13/99 Analyte: CO₂

Source: Kuma Wood Classic Run #: EPA 2

Zero Cyl #: 719 430 Conc. 00.0 % CO₂ Cyl Press: 1850 psi

Certified by: Oxarc Date: 4/1/99

Span Cyl #: 250-794 Conc. 12.5 % CO₂ Cyl Press: 1320 psi

Certified by: Oxarc Date: 3/26/99

Analyzer: Make: Horiba Model: PIR-2000 SN: 607024

Range: 0 - 25.0% CO₂ Analyzer Output: 0 - 1.0 v.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter:

EPA Span Value = 25.0% CO₂

EPA Control Limits = + 2.5% of 25.0% CO₂ = + 0.625% CO₂

Pre Run Audit: By: RLS Time: 1110 Temp: 74 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	.000	00.0	00.0	.000	.0446	.0446	+0.18
Span	50.0	.500	12.5	49.8	.498	12.3218	-.1782	-1.43

Comments:

Post Run Audit: By: RLS Time: 1830 Temp: 76 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	.000	00.0	00.0	.000	.0446	.0446	+0.18
Span	50.0	.500	12.5	49.6	.495	12.2479	-.2521	-2.02

Comments:

+ Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Exp \% (ppm)}} \times 100$

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-2

Site: Myren Consulting, Woodinville, WA Date: 9/13/99 Analyte: O₂

Source: Keweenaw Wood Classic Run #: EPA 2

Zero Cyl #: 719 430 Conc. 00.0 % O₂ Cyl Press: 1350 psi

Certified by: Oxarc Date: 4/1/99

Span Cyl #: 250-794 Conc. 12.5 % O₂ Cyl Press: 1320 psi

Certified by: Oxarc Date: 3/26/99

Analyzer: Make: Taylor Model: OA 137 SN: 137/4772

Range: 0 - 25.0% O₂ Analyzer Output: 0 - 100 mv.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter: _____

EPA Span Value = 25.0% O₂

EPA Control Limits = + 2.5% of 25.0% O₂ = + 0.625% O₂

Pre Run Audit: By: RLS Time: 1110 Temp: 74 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ%
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	00.0	00.0	00.0	00.0	00.050	+0.0050	+0.02
Span	12.5	50.0	12.5	12.5	49.9	12.465	-0.0342	+0.27

Comments:

Post Run Audit: By: RLS Time: 1830 Temp.: 76 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ%
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	00.0	00.0	00.0	00.0	00.050	+0.0050	+0.02
Span	12.5	50.0	12.5	12.5	49.7	12.4158	-0.0842	-0.67

Comments:

+ Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Exp \% (ppm)}} \times 100$

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-3

Site: Myren Consulting, Woodinville, WA Date: 4/13/99 Analyte: CO

Source: Kuma Wood Classic Run #: EPA 2

Zero Cyl #: 719 430 Conc. 00.0 % CO Cyl Press: 1850 psi

Certified by: Oxarc Date: 4/1/99

Span Cyl #: 250-794 Conc. 2.5 % CO Cyl Press: 1320 psi

Certified by: Oxarc Date: 3/26/99

Analyzer: Make: Infra Red Model: 702 D SN: 113

Range: 0 - 10.0% CO Analyzer Output: 0 - 100 mv.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter: _____

EPA Span Value = 5.0% CO

EPA Control Limits = +2.5% of 5.0% CO = + 0.125% CO

Pre Run Audit: By: RLS Time: 1110 Temp: 74 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	00.0	00.0	0.00	00.0	0.0093	-0.0093	-0.19
Span	2.50	50.0	2.50	2.50	49.9	2.4864	-0.0136	-0.54

Comments:

Post Run Audit: By: RLS Time: 1830 Temp.: 76 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	00.0	00.0	0.00	00.0	0.0093	-0.0093	-0.19
Span	2.50	50.0	2.50	2.49	49.7	2.4764	-0.0236	-0.94

Comments:

+ Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Exp \% (ppm)}} \times 100$

Unit: Kuma Wood Classic

Run: EPA 2

Date: 9/13/199

Technicians: ATM / RLS

WST6-Form3-Rev11/89

QUALITY CHECKS
WOODSTOVE DATA SHEET #16

Ambient = Tr: _____ °F T/C#30: _____ °F

Thermocouple Check (at ambient): T/C#1: 64 °F; T/C#2: 64 °F;

T/C #3: 65 °F; T/C #4: 65 °F; T/C #5: 65 °F;

T/C #6: 66 °F; T/C #7: 66 °F; T/C #8: 66 °F;

T/C #9: 66 °F; T/C #10: 67 °F; T/C #11: 66 °F;

T/C #12: 66 °F; T/C #13: 65 °F; T/C #14: 65 °F;

T/C #15: 66 °F; T/C #16: 65 °F; T/C #17: 66 °F;

T/C #18: 65 °F; T/C #19: _____ °F; T/C #20: _____ °F;

T/C #21: _____ °F; T/C #22: _____ °F; T/C #23: _____ °F;

T/C #24: _____ °F; T/C #25: _____ °F; T/C #26: _____ °F;

Comments: _____

Thermocouple Readout: Pretest Zero/Span Check and Calibration:

Zero (0°F) : 001 °F Adj to: 000 °F Post Test Check Zero (0°F): 001 °F % Difference +0.05%

Span (2000°F): 1999 °F Adj to: 2000 °F Span (2000°F): 2000 °F 0

(Allowable % Difference = 1.5%. Use formulas on Woodstove Data Sheet #15 to calculate % Difference)

Thermocouple Readout Pretest Linearity Check

0°F = 000 °F; 200°F = 201 °F; 400°F = 399 °F;

600°F = 599 °F; 800°F = 800 °F; 1000°F = 1000 °F;

1200°F = 1200 °F; 1400°F = 1400 °F; 1600°F = 1599 °F

1800°F = 1800 °F; 2000°F = 2000 °F

Combustion Gas (CO₂, O₂, CO) Train Leak Check: Pre Post

Draft (Static) Gauge Zero Check: Pre Post

Scale Check Pre (Wt, #'s): 570.9-575.9 5.0 lbs. OK (RLS)
Post (Wt, #'s): 572.8-577.8 5.0 lbs. OK (RLS)

Stack cleaned prior to the run: Yes _____ No

Tunnel cleaned prior to the run: Yes _____ No

DILUTION TUNNEL CALCULATIONS

MYREN CONSULTING CERTIFICATION TEST DATA

3/31/96

Kuliv, EPA4

File Name: KumaEPA4
 Stove Manufacturer: Kuma
 Model Number: Wood Classic
 Lab Name: MYREN
 Test Date: 9/15/99
 Run Number: EPA 4
 Meter Box Y Factor: 1.0151
 Barometric pressure (in): 28.498
 Gas meter temp (ave): 92
 delta H(ave): 0.900
 Gas meter initial reading: 878.200
 Gas meter final reading: 987.420
 Front catch (acetone) mg: 7.4
 first filter catch (mg): 14
 second filter catch (mg): -0.3
 tunnel flow (ave cfm): 147.109
 Emission Rate(g/hr): 1.869
 Emission Rate(M5H): 3.059
 vs/VmTs: 0.0154
 vs ave: 877.296
 Tunnel average temp (°F): 104.952
 Test time(min): 195
 Fuel Load(lb. wet): 14.6
 Wood moisture(%wet): 17.660
 Burn rate(dry kg/hr): 1.678
 Samp vol(scf): 101.108
 front filter number: 936
 back filter number: 935
 acetone beaker number: 28

PRELIMINARY RESULTS

FINAL RESULTS

DATA SUMMARY

MODEL : Wood Classic
 RUN: EPA 4
 DATE: 9/15/99
 DBR: 1.678
 GPH UNADJ: 1.869
 ADJ: 3.058516319

RUN TIME (min)	PITOT DELTAP (- INCH H2O)	TNL TEMP (°F)	GAS METER RDG (ft3)	GAS METER TEMP (°F)	GAS METER DELTA H (in.H2O)	TUNNEL VELOCIT (ft/min)	PROP RATE (%)	dJGM vol std (ft3)
0	0.043	94	878.200	83	0.900	868.77		
10	0.043	109	883.805	83	0.900	880.45	103.6	5.280
20	0.043	112	889.375	85	0.900	882.77	101.7	5.227
30	0.043	116	894.950	87	0.900	885.85	101.9	5.213
40	0.043	117	900.540	88	0.900	886.62	101.8	5.217
50	0.043	117	906.115	92	0.900	886.62	100.7	5.166
60	0.043	116	911.715	91	0.900	885.85	101.1	5.198
70	0.043	113	917.310	92	0.900	883.54	100.4	5.184
80	0.043	109	922.930	93	0.900	880.45	100.3	5.198
90	0.043	107	928.513	93	0.900	878.90	99.6	5.164
100	0.043	104	934.121	94	0.900	876.58	99.5	5.178
110	0.043	102	939.735	93	0.900	875.02	99.7	5.192
120	0.043	101	945.335	95	0.900	874.24	99.5	5.180
130	0.043	100	950.935	95	0.900	873.46	99.0	5.161
140	0.043	99	956.555	95	0.900	872.68	99.3	5.179
150	0.043	99	962.164	96	0.900	872.68	99.0	5.160
160	0.043	99	967.765	96	0.900	872.68	98.8	5.153
170	0.043	98	973.380	97	0.900	871.90	98.7	5.156
180	0.043	97	978.990	96	0.900	871.12	98.7	5.161
190	0.043	98	984.500	97	0.900	871.90	97.1	5.060
195	0.043	97	987.420	97	0.900	871.12	102.6	2.681
220						0.00	0.0	0.000
230						0.00	0.0	0.000
240						0.00	0.0	0.000
250						0.00	0.0	0.000
260						0.00	0.0	0.000
270						0.00	0.0	0.000
280						0.00	0.0	0.000
290						0.00	0.0	0.000
300						0.00	0.0	0.000
310						0.00	0.0	0.000
320						0.00	0.0	0.000
330						0.00	0.0	0.000
340						0.00	0.0	0.000
350						0.00	0.0	0.000

METER BOX # 511-M METER Y 1.0151 FILTER # (F) 936 (R) 935

PRE TEST LEAK RATE = .000 CFM @ -15.75 IN. HG, 938/938 FILTER SIZE: 110 MM

POST TEST LEAK RATE = .000 CFM @ -15.50 IN. HG, 055/055 PROBE LENGTH 24" glass

TIME	CLOCK ELAPSED	METER READING CU. FT.	PITOT dp	TNL TEMP. (°F)	METER TEMP. (°F)	GAS METER dh	VAC IN. HG
1405	00	878.200	-043	94	83	.90	0
35	10	883.805	-043	109	83	.90	0
45	20	889.375	-043	112	85	.90	0
55	30	894.950	-043	116	87	.90	0
1305	40	900.540	-043	117	88	.90	0
15	50	906.115	-043	117	92	.90	0
25	60	911.715	-043	116	91	.90	0
35	70	917.310	-043	113	92	.90	0
45	80	922.930	-043	109	93	.90	0
55	90	928.513	-043	107	93	.90	0
1405	00	934.121	-043	104	94	.90	0
15	10	939.735	-043	102	93	.90	0
25	20	945.335	-043	101	95	.90	0
35	30	950.935	-043	100	95	.90	0
45	40	956.555	-043	99	95	.90	0
55	50	962.164	-043	99	96	.90	0
1505	60	967.765	-043	99	96	.90	0
15	70	973.380	-043	98	97	.90	0
25	80	978.990	-043	97	96	.90	0
35	90	984.500	-043	98	97	.90	0

POINT	LOCATION	ΔP	TEMP
N-1	0.5"	.033	99
2	1.5"	.039	99
3	4.5"	.049	99
4	5.5"	.041	99
W-1	0.5"	.039	100
2	1.5"	.042	100
3	4.5"	.049	100
4	5.5"	.040	100
Avg. .040 99.500			
559.50			

Pitot Leak Check Pre Post

Cp = 0.99

W 1 2 3 4

3%

*point of Avg. delta p

OS - $(\Delta P \times BP) \times 3167.2 =$

142.692 cm

BP = Static 38.53 In Hg

X = 26.498

142 2 95

DATE 9/15/99

PAGE 2 OF 2

MODEL # WOOD CLASSIC RUN # BPH 4

METER BOX # 511M

METER Y 1.0151

FILTER # (F1936 (R) 935

PRE TEST LEAK RATE = 1.000 CFM @ -15.75 IN. HG 938/938

FILTER SIZE: 110 HM

POST TEST LEAK RATE = 1.000 CFM @ -15.50 IN. HG 1055/1055

PROBE LENGTH 24" Glass

TIME	CLOCK ELAPSED	METER READING CU.FT.	PILOT dp	INL. TEMP. (°F)	METER TEMP. (°F)	GAS METER dh	VAC IN. HG	POINT LOCATION		VELOCITY TRAVERSE
								ΔP	TEMP	
15:40	195	987.420	-1413	97	97	90	0	N-1	0.5 -0.03	99
10		(189.220)						2	1.5 -0.039	99
20								3	4.5 -0.42	99
30								4	5.5 -0.41	99
40								W-1	0.5 -0.039	100
50								2	1.5 -0.42	100
60								3	4.5 -0.42	100
70								4	5.5 -0.40	100
80									Avg. -0.40	589.5
90										
90										

Pilot Leak Check
Pre Post

CP = 0.99
N 1 2 3 4
* 12 W →

-point of Avg. delta p

$$OS = \left(\sqrt{\Delta P \times BP} \right) \times 3167.2 - T(R)$$

147.592 CFM

BP = Short 8853 in Hg
 60 98.51
 120 98.50
 180 98.48
 240 98.47

X = 28.496

WOODSTOVE DATA SHEET #4-1: INITIAL FILTER WEIGHTS (TARE WEIGHTS)

Into Desiccator: Date 1/9/99 Time 1445 By ATM Front Half Back Half

Manufacturer: Schletter's Scheel / Size: 11cm Lot.No.: Z8951 Grade: #25 Glass

Order No.: 06220

Filter #	Wt	Date	Time	By	Wt	Date	Time	By
926	7240	3/6/99	1140	TM	1652	3/15/99	1652	ATM
927	7938		1141	TM	1651			ATM
928	7985		1142	TM	1650			ATM
929	7909		1143	TM	1649			ATM
930	7948		1144	TM	1648			ATM
931	8041		1145	TM	1647			ATM
932	7917		1146	TM	1646			ATM
933	8047		1147	TM	1645			ATM
934	7981		1148	TM	1644			ATM
935	7861		1149	TM	1643			ATM
936	7822		1150	TM	1643			ATM
937	7935		1151	TM	1642			ATM
938	8086		1152	TM	1641			ATM
939	8060		1153	TM	1640			ATM
940	8151		1154	TM	1639			ATM
941	8252		1155	TM	1638			ATM
942	7982		1156	TM	1637			ATM
943	7822		1157	TM	1636			ATM
944	7938		1158	TM	1635			ATM
945	7944		1159	TM	1635			ATM
946	7822		1200	TM	1635			ATM
947	7731		1201	TM	1634			ATM
948	7936		1202	TM	1633			ATM
949	7838		1203	TM	1632			ATM
950	8040		1204	TM	1630			ATM

Checked by *Jim M...* Date: 3/16/99 Time 2133

BALANCE ROOM ENVIRONMENTAL CONDITIONS

WB	DB	%RH	Date	Time	By
64	79	43	3/6/99	1135	ATM
66	81	45	3/15/99	1622	ATM
65	82	39	3/16/99	2025	ATM

QA REWEIGH

Filter #	WT	Date	Time	By
929	7912	3/16/99	2136	Jim
941	8248	3/16/99	2134	Jim
949	7837	3/16/99	2133	Jim

Post Test Weighing Session Scale Check
 1st 3rd QC
 0.0000 0.0000 0.0001 1.0000
 0.0000 0.0000 0.0000 1.0000

INITIAL BEAKER WEIGHTS (TAKE WEIGHTS)

Into Descicator: Dates: 8/20/99 Time: 1500 By: A.T. Myerson

Beaker # First Second Third

Beaker #	First	Second	Third
1	65.4841	65.4845	65.7022
2	66.1509	66.1514	65.7028
3	67.5582	67.5591	
4	67.5870	67.5878	
5	67.5870	67.5878	
6	67.4270	67.4274	
7	65.5444	65.5446	
8	66.0219	66.0218	
9	66.0227	66.0219	
10	66.0906	66.0902	
11	65.7072	65.7020	
13	57.8946	57.8948	

Beaker #	First	Second	Third
20	73.3159	73.3160	
21	71.0002	71.0003	
22	71.8302	71.8322	
23	70.7376	70.7382	
24	73.2173	73.2182	
25		72.6505	
26	71.7865	71.7868	
27	72.3294	72.3294	
28	70.5955	70.5956	
29	71.5183	71.5185	
30	70.7845	70.7855	
31	69.6653	69.6655	
33	70.2375	70.2375	
34	73.2175	73.2175	

Checked By: A.T. Myerson Date: 9/11/99 Time: 1319

QA REVIEW

Balance Room Environmental Conditions

Beaker #	WT	Date	Time	By
68	83	8/27/99	2052	ATM
67	81	8/30/99	1154	ATM
63	76	8/31/99	1310	ATM

WT	Date	Time	By
70	84	9/8/99	1705
71	84	9/11/99	1202
72	79	9/13/99	1926

cont 23

BS

Class

Dates From 1/9/99
Through 7/17/99

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale Mettler
Model AE100
SN K04827

Level	Recall- brated	100g Weight	10g Weight	1.0g Weight	100mg Weight	20mg Weight	Date	Time	Tech	Wet Bulb	Dry Bulb	% RH
V	Yes	99,9999	10,0001	1,0002	10003	02003	1/9/99	1243	ATM	62	70	47
V	No	100,0002	10,0000	1,0000	1000	0200	1/14/99	1113	ATM	62	75	47
V	Yes	99,9998	10,0002	1,0000	0999	0201	1/23/99	1100	ATM	63	72	42
V	Yes	99,9999	10,0000	1,0000	1000	0201	1/24/99	1318	ATM	59	74	45
V	Yes	99,9999	10,0002	1,0000	1000	0200	2/1/99	0910	ATM	55	69	39
V	Yes	99,9999	10,0001	1,0001	1002	0201	2/2/99	0939	ATM	60	73	46
V	Yes	99,9999	10,0001	1,0001	1001	0200	2/3/99	1555	ATM	63	76	48
V	Yes	99,9999	10,0000	1,0000	1001	0201	2/7/99	1235	ATM	62	76	45
V	Yes	99,9999	10,0000	1,0000	1000	0200	2/10/99	1600	ATM	63	73	45
V	Yes	99,9999	10,0000	1,0001	1000	0200	2/19/99	0246	ATM	64	78	46
V	No	99,9999	10,0000	1,0000	1000	0200	2/21/99	1312	ATM	65	80	44
V	No	99,9999	10,0000	1,0001	1000	0200	2/21/99	1312	ATM	64	79	43
V	Yes	99,9999	10,0000	1,0000	1000	0200	3/5/99	1935	ATM	64	80	44
V	Yes	99,9999	10,0000	1,0000	1001	0200	3/5/99	1135	ATM	64	79	43
V	Yes	99,9999	10,0000	1,0000	1000	0200	3/13/99	1526	ATM	65	80	44
V	Yes	99,9999	10,0000	1,0001	1000	0200	3/14/99	1355	ATM	63	78	43
V	Yes	99,9999	10,0000	1,0001	1000	0200	3/15/99	1612	ATM	66	81	45
V	Yes	99,9999	10,0001	1,0001	1001	0200	3/16/99	2025	ATM	65	82	45
V	No	100,0001	10,0002	1,0002	1000	0200	3/16/99	2025	ATM	65	82	45
V	Yes	99,9999	10,0000	1,0001	1000	0200	3/17/99	1615	ATM	62	77	42
V	Yes	99,9999	10,0000	1,0001	1000	0200	3/18/99	2140	ATM	68	84	43
V	Yes	99,9999	10,0000	1,0000	1000	0200	3/20/99	1300	ATM	64	84	43
V	Yes	99,9999	10,0000	1,0001	1001	0201	3/21/99	2215	ATM	61	74	42
V	Yes	99,9999	10,0000	1,0000	1001	0200	3/22/99	2102	ATM	65	85	43
V	Yes	99,9999	10,0000	1,0001	1000	0200	3/23/99	1115	ATM	69	84	46
V	Yes	99,9999	10,0000	1,0002	1000	0200	3/24/99	1120	ATM	77	99	43
V	Yes	99,9999	10,0000	1,0002	1001	0201	3/24/99	2038	ATM	59	72	45
V	Yes	99,9999	10,0000	1,0002	1001	0201	3/28/99	0610	ATM	66	80	42
V	No	99,9999	10,0000	1,0000	1001	0201	3/30/99	1220	ATM	64	80	41
V	No	99,9999	10,0000	1,0000	1001	0201	4/6/99	1330	ATM	64	80	41
V	Yes	99,9999	10,0001	1,0001	1001	0200	4/8/99	1346	ATM	63	80	41
V	No	99,9999	10,0000	1,0001	1001	0200	4/17/99	1230	ATM	66	82	42
V	Yes	99,9999	10,0000	1,0000	1000	0200	4/17/99	1625	ATM	68	84	43
V	No	99,9999	10,0000	1,0000	1000	0200	6/19/99	1050	ATM	59	72	45
V	Yes	99,9999	10,0001	1,0002	1001	0202	7/17/99	1825	ATM	65	83	42
QC Services	Audit	4/6/99	- w.t.	Scale Check	4/6/99	1030			ATM	61	75	44
V	No	100,0003	10,0001	1,0001	1001	0201	4/6/99	1730	ATM	65	85	43
V	Yes	99,9999	10,0001	1,0001	1001	0200	4/8/99	1346	ATM	63	80	41
V	No	99,9999	10,0000	1,0001	1001	0200	4/17/99	1230	ATM	66	82	42
V	Yes	99,9999	10,0000	1,0000	1000	0200	4/17/99	1625	ATM	68	84	43
V	No	99,9999	10,0000	1,0000	1000	0200	6/19/99	1050	ATM	59	72	45
V	Yes	99,9999	10,0001	1,0002	1001	0202	7/17/99	1825	ATM	65	83	42

WOODSTOVE DATA SHEET #4-4
SCALE FROM QA SHEET

Scale Mettler
Model AE100
SN K04827

Dates From 7/18/99
Through 9/16/99

Level	Recall- brated	100g Weight	10g Weight	1.0g Weight	100mg Weight	20mg Weight	Date	Time	Tech	Wet Bulb	Dry Bulb	% RH
V	No	99.9997	10.0000	1.0001	1.0000	0.201	7/18/99	16:04	ATM	63	77	49
V	Yes	99.9997	10.0000	1.0001	1.0001	0.201	7/19/99	18:35	ATM	64	77	49
V	Yes	99.9997	10.0000	1.0002	1.0002	0.202	7/20/99	18:54	ATM	71	85	80
V	Yes	99.9997	10.0001	1.0001	1.0001	0.201	7/21/99	15:06	ATM	69	84	50
V	Yes	99.9997	10.0000	1.0000	1.0000	0.200	7/22/99	21:45	ATM	64	80	41
V	Yes	99.9998	10.0000	1.0000	1.0000	0.200	7/23/99	07:45	ATM	62	76	45
V	Yes	99.9998	10.0000	1.0000	1.0000	0.200	7/24/99	13:49	ATM	66	80	47
V	Yes	99.9998	10.0001	1.0000	1.0000	0.201	8/3/99	20:17	ATM	70	84	47
V	No	99.9998	10.0001	1.0001	1.0000	0.200	8/5/99	21:06	ATM	65	83	49
V	No	99.9998	10.0000	1.0000	1.0000	0.200	8/6/99	15:36	ATM	68	88	59
V	No	99.9999	10.0000	1.0000	1.0000	0.200	8/7/99	15:15	ATM	66	80	47
V	Yes	99.9997	10.0001	1.0000	1.0001	0.201	8/8/99	13:00	ATM	64	73	47
V	Yes	99.9997	10.0000	1.0000	1.0000	0.200	8/9/99	12:25	ATM	68	82	48
V	Yes	99.9997	10.0000	1.0001	1.0001	0.200	8/9/99	16:15	ATM	69	84	46
V	No	99.9997	10.0001	1.0001	1.0001	0.200	8/10/99	13:27	ATM	67	81	49
V	Yes	99.9997	10.0000	1.0000	1.0001	0.200	8/11/99	10:43	ATM	67	81	49
V	Yes	99.9997	10.0000	1.0001	1.0001	0.201	8/11/99	20:35	ATM	64	78	46
V	Yes	99.9997	10.0000	1.0001	1.0001	0.201	8/11/99	20:35	ATM	64	78	46
V	Yes	99.9997	10.0000	1.0001	1.0001	0.201	8/13/99	12:30	ATM	64	78	46
V	Yes	99.9997	10.0001	1.0002	1.0002	0.201	8/14/99	19:29	ATM	63	76	48
V	Yes	99.9997	10.0000	1.0001	1.0001	0.201	8/16/99	11:35	ATM	64	77	48
V	Yes	99.9997	10.0000	1.0001	1.0001	0.201	8/18/99	13:50	ATM	68	83	46
V	Yes	99.9997	10.0000	1.0001	1.0001	0.200	8/18/99	16:50	ATM	70	84	47
V	Yes	99.9997	10.0000	1.0002	1.0002	0.201	8/19/99	19:29	ATM	68	83	46
V	No	99.9997	10.0001	1.0000	1.0000	0.201	8/22/99	20:52	ATM	68	83	46
V	No	99.9997	10.0001	1.0000	1.0000	0.200	8/30/99	11:54	ATM	67	81	48
V	No	99.9997	10.0000	1.0000	1.0000	0.200	8/31/99	13:10	ATM	63	76	48
V	Yes	99.9997	10.0000	1.0000	1.0000	0.200	8/31/99	18:04	ATM	65	79	44
V	Yes	99.9997	10.0000	1.0000	1.0000	0.200	8/2/99	10:32	ATM	60	74	43
V	Yes	99.9997	10.0000	1.0000	1.0000	0.200	9/8/99	17:05	ATM	70	84	47
V	Yes	99.9997	10.0001	1.0000	1.0000	0.201	9/11/99	12:03	ATM	69	84	47
V	Yes	99.9997	10.0000	1.0000	1.0000	0.201	9/12/99	8:05	ATM	70	84	49
V	Yes	99.9997	10.0001	1.0000	1.0000	0.200	9/13/99	19:36	ATM	64	77	49
V	Yes	99.9997	10.0001	1.0000	1.0000	0.200	9/14/99	18:35	ATM	61	73	49
V	Yes	99.9997	10.0001	1.0000	1.0000	0.200	9/15/99	8:25	ATM	64	78	49
V	Yes	99.9997	10.0001	1.0000	1.0000	0.201	9/16/99	08:45	ATM	64	78	46
V	No	99.9997	10.0000	1.0000	1.0000	0.200	9/16/99	16:55	ATM	70	84	46

Unit: Kuma Hood Classic
 Run: EPA 4
 Date: 9/15/1999
 Technicians: ATN RLS
 MST20, Form 5

Woodstove Particulate
 Catch Processing Sheet
 Woodstove Data Sheet #5
 RPA M5G-1

Filters

Filter #	MI	Desc.	Final Wt.	Tare Wt.	Net Wt.
(E) 936	28	Acetone	7968	7828	0140
(E) 935	50	Acetone	7858	7861	-0003

Acetone Blank Calculation: Blank done 7/18/99

Blank Beaker #	MI	Desc.	Final Wt.	Tare Wt.	Net Wt.
1	50	Acetone	65,4847	65,4847	0000

8 : 50 MI = 0000 g/ml

Particulate Catch Calculation

Filter #	MI of Acetone	Blank Value/MI of Acetone	Total Catch
Filter:	0140	-0003	0140
Filter:	0074	-0003	0074
Beakers:	0074	(0074)(0000)	0074
			Total Catch = 0211

Unit Kama Wood Classic
 Run # EPA 4
 Date 9/15/1999
 Technician Jim PLS JPL
 MST6-Form1, Rev 8/96
 MISCELLANEOUS TEST DATA
 WOODSTOVE DATA SHEET #8

Useable Firebox Dimensions: See QC Section Useable Volume: 2,328 ft³

Dilution Tunnel Draft (If applicable): Start 00.0 Stop 00.0

Test Chamber Air Velocity: Start: 00.0 Stop: 00.0 Avg: 00.0

Wet Bulb/Start: WB: 67 ° F DB: 80 ° F 1.5 % Amb Moisture 50 % RH
 Dry Bulb Stop: WB: 69 ° F DB: 84 ° F 1.85 % Amb Moisture 46 % RH

Empty Stove Wt: 419.3 lbs.
 $\bar{X} = 1.675$ % Ambient Moisture
 $\bar{X} = 48$ % Relative Humidity (RH)

Stove Wt With Stack and Ash: — lbs. Total: — lbs.

Kindling Wt.: Paper: 0.3 lbs. Wood: 4.0 lbs. Total: 4.3 lbs.

Pre Burn Fuel Wt.: 14.1 + 14.1 + 14.5 Total: 42.7 lbs.

Total Kindling and Pre Burn Fuel Wt.: 42.0 lbs.

Coal Bed Wt-Lbs: Range (57.8 - 57.2) 3.6 - 3.0 lbs. Actual: 3.4 lbs.

Allowable Amount of Charcoal that can be removed: 3.6 lbs.

Coal Bed Wt. Range: 3.6 + 3.0 = 12 * .25 = 8 lbs.

Test Fuel Wt-Lbs: Ideal: 15.6 lbs. Range: 17.1 - 14.1 lbs. Actual: 14.6 lbs.

Test Fuel Size (pcs.): (.75 x 1.5 x 5" Ranges) 16 pcs.

2 x 4's x 15/4 " 3 pcs 6.2 lbs. 42.5 %

4 x 4's x 15/4 " 2 pcs 8.4 lbs. 57.5 %

Est. Dry Burn Rate (KG/Hr.): 14.6 - (14.6 x 17.1) x 60 = 1.678

Est. EPA Heat Output (HOE) (19,140) x 63 = 1,678

Est Heat Output (HOE) BTU's/Hr: 20,332

Comments:

Unit: RUMA WOOD CLASSIC
Run: EPA 4
Date: 9/15/99
Technician(s): ATH, BLS, J.R.
Data Sheet #9 - Rev 1/98-Pg.2

Stove Operating Data
Woodstove Test Data Sheet #9
Cold Start
Fire Started: 0755 P.D.S.T.

Warm up and Preburn: Primary Air: Wide open from ignition until the start of preburn when the primary air control(s) was (were) adjusted to the run setting of 11/16 open. At the run setting until the start of the test.

Secondary Air:

No controls. Naturally Drafted.

Secondary Burn/Cat Bypass:

N/A

Charcoal Bed Preparation: Broke up, raked and leveled the coal bed prior to the addition of each warm up/pre burn fuel charge. Starting 1130 before the start of the test, broke up, raked and leveled the coal bed. In stove for 35 seconds.

Test: Door wide open during loading 1 min 01 sec, then

closed. Door closed at 0144, but then reopened to take photograph

Primary Air: Wide open during the start of the test until 4:55.

Adjusted to the run setting of 11/16 open between 4:55 and 5:00. At the run setting of 11/16 open at 5:00 into the run.

Secondary Air: No controls. Naturally drafted

Secondary Burn/Cat Bypass:

N/A

Fan: ON/OFF during the warm up, ON/OFF during the preburn, ON/OFF at the start of the test, ON/OFF for the first 1:30 minutes of the test, ON/OFF high at 30 minutes into the test, ON/OFF for the rest of the test.

Test Run Anomalies: None

WOODSTOVE OPERATING DATA
 WOODSTOVE DATA SHEET #9A-1

Wood Data: Kindling: A mix of the below grades

Size	Mill	Grade	Species
2x4	CANYON LUMBER	# 2 & Better	D.F.A. SFC GEN
2x4	CANYON LUMBER	# 2 & Better	D.F.R. SFC GEN
4x4	R.I.B. CONST.	# 1	D.F.R. SFC GEN

All grades WCLB Rules unless otherwise noted.

Warm up Information:

- 1st Warm up/Pre Burn Fuel charge (14.1 lbs) added at 0835
- 2nd Warm up/Pre Burn Fuel charge (14.1 lbs) added at 0928
- 3rd Warm up/Pre Burn Fuel charge (14.5 lbs) added at 1037
- 4th Warm up/Pre Burn Fuel charge () lbs) added at
- 5th Warm up/Pre Burn Fuel charge () lbs) added at
- 6th Warm up/Pre Burn Fuel charge () lbs) added at
- 7th Warm up/Pre Burn Fuel charge () lbs) added at
- 8th Warm up/Pre Burn Fuel charge () lbs) added at

The coals were scooped out of the stove immediately prior to adding the 3 pre burn/warm up fuel charge. The stove lost 1.5 lbs. After the scoop, 3.0 lbs. of coals were put back in the stove.


All pre burn/warm up fuel pieces were "ricked" in the stove. The pieces in the bottom layer in each rick contained 2 pcs that were 16 inches long and were loaded flat and perpendicular to the door. The pieces in the second layer in each rick were loaded on their side (edge) approximately parallel to the door and contained 4 pcs 16 inches long. The third layer (and fourth layer if present) was loaded flat, perpendicular to the door and contained 2 pcs 16 inches long. The majority of the pieces in each rick were in the second layer which had an approximate 0.5-1.0" space between pieces. (The loading directions indicate the direction of the longest dimension on each piece relative to the loading door opening.) Each pre burn/warm up fuel charge normally weighs within the weight range allowed for the actual test fuel charge.

Warm up Information (cont.):

Each warm up/preburn fuel charge was ricked in exactly (as much as possible) the same manner and the weight of each rick was usually within the allowable weight range for the test fuel charge. The physical arrangement and alignment of each rick was designed to accomplish three (3) things: (1) The bottom layer was nestled firmly into the coal bed and was as close to being level with the bottom of the stove as possible, thus providing a stable loading platform for the rest of the rick, keeping it in a ricked state (as opposed to a collapsed or fallen down state) until the rick reached the charcoal stage and sags or collapses of its own accord. (2) It enhances the flow of primary air through the ricked preburn fuel charge, for the primary air would flow through the spaces between the pieces in the first layer and then up through the spaces between the pieces in the second, third and, if present, fourth layers. (3) It maximized, as much as possible, the surface to volume ratio of each preburn fuel charge, thereby allowing the fire immediate access to as much wood surface as possible and, thereby, insuring uniform charcoalization. All three of these enhance combustion and so get the stove as hot as possible during the warm up period, thereby maximizing the amount of heat (BTU's) stored in the stove. The actual preburn was not started until the stove surface temperatures had maximized and stabilized, thus indicating that the amount of heat stored in the stove had peaked. For this stove, the thermal storage was monitored using the 100 surface temperature(s) and the peak value(s) of 950 obtained were _____.

_____ of _____
The primary air was adjusted to the run setting
of "1/16 open" 6.7 lbs above the upper charcoal bed weight.

The arrows indicate the direction of the air flow through the rick.




Additional Comments:

① Turned Fan Off.
② opened primary air control wide open ③ gained fl.
door ④ loaded test fuel into stove, ⑤ closed comb
away from left ⑥ closed door ⑦ reopened door
⑧ Photograph ⑨ closed door again.

Total Elapsed Time: 1:01

Test Fuel Charge Loading Information:

Test Fuel Charge and Loading Sequence Diagram



of stove view

Stove

4 X 4's: 3 #5
2 X 4's: 1, 2 #4

Loading Sequence: 1, 2, 3, 4, 5

Driest Pcs in Load 2 #4, 3

Loaded the test fuel charge on an essentially level, Medium to large

sized, hot coal bed (in appearance, color and temperature

for a Medium high, burn rate. Ignition: 0133 Door closed and

Time 1101, VC to baffle 1110 Flames on the left side of
L. Stove 1125, 1139 VC, curving down on tops of 3 #5,
1145 Flames past front tube on X side, 1116 Flames
formed in center 0138 Front tube igniting CO gas
High 1.05% Thru ↑

* 3:11 Gas Balance
5100 Flames
Maintained hot pocket w/ VC to baffle
Flames/secondary above 3 #5, Flames past front tube,
Front Tube on/off, but steady, singing in balance,
+ Flames on L side 1 Stove,

WOODSTOVE OPERATING DATA
 WOODSTOVE DATA SHEET #9A-4

Additional Comments:

6:50 Flames on front tube decreasing (↓) some.
 CO ↓, was up to 0.80%
 7:03 CO ↑ ↓ ↓ ↓ ↓ - a whole series of primary secondary
 pipe flops. But never got out of control & stayed
 in gas balance.
 8:13 CO ↓ 1.70 / 9.4% CO₂
 Steady CO % , CO₂ % slowly ↓
 11:20 CO ↓, CO₂ ↓ / 10.3 / 6.8
 11:30 Flames adjusting to spread over pc 1 on R side.
 12:17 Front tube adjusting again - on/off.
 14:49 11.5 / 0.4
 16:30 13.0 / 2.0 - OK from here on out.
 30:00 was a CO spike between 05:30 mins.
 Fan on high

Unit: Kama Wood Clinic
 Run: EPA 4
 Date: 9/15/1999
 Technician: BTM 215 J.P.
 MSTI-Form7-R&V11/89

FUEL MOISTURE
 WOODSTOVE TEST DATA SHEET #10

Room Temperature: 70 of
 Correction Factor: 0

NOTE: Record readings to the nearest 0.5% moisture

Uncor values are corrected for temperature: Yes No

Time Test Fuel Moisture Readings taken at: _____

Calibration Checks: X - Y - 12.5 18.5 22.0 22.5

Pc	#	Dimen	Use	Top			Bottom			Side			Piece Avg
				Uncor	Cor	Test	Uncor	Cor	Test	Uncor	Cor	Test	
1		24x8'	K	18.0	18.8	18.0	18.0	18.8	18.5	18.3	18.3	18.3	18.967
2													
3													
4		24x8'	P	21.0	22.6	20.5	22.0	21.4	20.0	21.4	21.4	22.000	22.000
5		"		19.0	20.3	20.0	21.4	19.0	20.3	20.3	20.667	20.667	20.667
6		"		22.0	23.7	23.0	23.7	22.0	23.7	23.7	23.700	23.700	23.700
7		"		21.0	22.6	21.0	22.6	21.0	22.6	22.6	22.600	22.600	22.600
8													88.967
9													
10		24x15 1/4"	T	18.0	19.2	18.0	19.2	18.0	19.2	19.2	19.200	19.200	19.200
11		"		19.5	20.9	19.5	20.9	19.0	20.3	20.3	20.700	20.700	20.700
12		"		22.0	23.7	22.0	23.7	22.0	23.7	23.7	23.700	23.700	23.700
13													
14		4x4-15 1/4"	T	18.0	19.2	19.0	20.3	19.0	20.3	20.3	19.933	19.933	19.933
15		"		22.0	23.7	22.0	23.7	22.0	23.7	23.7	23.700	23.700	23.700
16													107.333
17													
18													
19		5x15x15 Spacers		20.5	22.0	20.5	22.0	20.0	22.0	21.4	21.800	21.800	21.800
20													21.800

Kindling	Pretest Fuel	Test Load
18.967%	22.247%	21.447%
11.478%	18.195%	17.657%

To obtain Wet from Dry: $100 \times \% \text{ Dry Rdg.} = \% \text{ Moisture, Wet Basis}$
 $100 + \% \text{ Dry Rdg.}$

Acceptable Ranges: 16-20% Wet; 19-25% Dry
 (17.5 - 22.5 on Meter [Uncor reading] at 70°F)

Key for Use: K = Kindling P = Pretest Fuel T = Test Fuel

WOOD DENSITY DETERMINATION
WOODSTOVE TEST DATA SHEET #11

Unit: Kuma Wood Classic
Run#: EPA 4
Date: 9/15/1999
Technician: ATM
MST2-form11-Rev 6/90

Wood Piece: Nominal Dimensions: $3\frac{1}{2}'' \times 3\frac{1}{2}'' \times 1\frac{1}{2}''$

Depth (D): 3.450 in
Width (W): 3.498 in
Length (L): 3.450 in

Volume: 306.875 cm³
(D X W X L)

Length $X = 11.3774$ in
8.824 cm

Depth (D): 1.533 in
3.894 cm

Width (W): 3.576 in
8.931 cm

MOISTURE: Room Temperature: 70 Of correction factor: 0

Uncorrected Meter Readings Corrected for temperature: Yes No

NOTE: Record moisture meter readings to the nearest 0.5%

Uncor	Cor
Top: 19.0	20.3
Bottom: 19.0	20.3
Side: 18.5	19.8
X: 20.133	%

Avg % Moisture (Dry) 20.133 %
Avg % Moisture (Wet) 16.759 %

Scale: Levelled In Out
Zeroed: In Out

Wet Weight: 182.2 g Dry Weight: 153.4 g
% Moisture Dried Basis: 15.807 %
[1 - (Dry Wt / Wet Wt)] X 100

Date: 9/15/99
Time: 10:15
Temp: 214
Into Dryer: 9/15/99
Out of Dryer: 9/22/99
In Dryer: 24 hrs. Minimum Dryer Temp 100°C (212°F)
Density = 153.4 g / 306.875 cm³ = 0.4999 g/cm³
(dry wt) (volume)

Pellet Fuel Moisture Content Determination

Tare Beaker Wt. _____ g
Wet Wt: _____ g
Gross Wet Wt. _____ g
Tare Beaker Wt. Net Wet Wt. _____ g

Tare Beaker Wt. _____ g
Dry Wt: _____ g
Gross Dry Wt. _____ g
Tare Beaker Wt. Net Dry Wt. _____ g

% Moisture Dried Basis: _____ %
[1 - (Net Dry Wt / Net Wet Wt)] X 100

END Wt: 570.8 lbs.

Unit: Keama Wood Classic Date: 9/15/17
 Run: EPA 4 Page: 1 of 2
 Technician(s): JP

Minute	Scale Wt	lbs Left	Burn Rate	CO ₂		O ₂		Tel	CO		Wet Bulb	Dry Bulb	H ₂ O %	Calc W/B	Stack	SO ₂ PPM	Static Press.	Comments	
				v.	%CO ₂	v.	%O ₂		v.	%CO									Bal
0	327.4	14.6	0	26.5	6.58	22.4	13.09		18.6	0.95	6.9	87	130	2.8	110	385	-0.45	Flow	
5	326.4	13.6	1.0	47.8	11.83	29.3	7.32	54.5	4.6	0.33	51.4	96	141	4.2	133	528	-0.28	SO ₂ 1.5	
10	325.6	12.8	1.8	38.3	9.49	41.7	10.49		13.6	0.21	13.4	113	163	5.1	129	422	-0.66	SO ₂ 1.5	
15	324.9	12.1	1.7	49.9	10.37	38.4	9.59		12.8	0.65	16.0	118	163	6.6	131	429	-0.69	SO ₂ 1.5	
20	324.0	11.2	1.9	53.9	13.33	24.6	6.90		4.3	0.23	58.0	123	170	11.5	142	468	-0.69	SO ₂ 1.5	
25	323.1	10.3	1.9	62.7	14.02	25.4	6.35		5.5	0.29	48.4	126	175	12.0	143	486	-0.72		
30	322.2	9.4	1.9	61.0	15.08	20.6	5.15		9.5	0.49	30.8	128	181	12.5	145	504	-0.75		
35	321.3	8.5	1.9	58.9	14.57	22.6	5.65		9.1	0.47	31.0	128	185	12.5	145	499	-0.74		
40	320.5	7.7	1.8	59.2	14.64	22.8	5.70		5.5	0.29	30.5	127	185	12.0	144	501	-0.73		
45	319.6	6.8	1.9	61.5	15.21	20.2	5.05		9.0	0.46	33.1	127	188	12.0	145	509	-0.74		
50	318.8	6.0	1.8	60.0	14.84	22.6	5.65		3.0	0.16	92.7	146	187	11.5	144	502	-0.73		
55	318.0	5.2	1.8	58.6	14.49	23.5	5.87		2.6	0.14	103.5	125	185	11.5	141	490	-0.72		
60	317.3	4.5	1.7	56.8	14.05	24.9	6.22		1.8	0.10	140.5	123	183	11.0	141	479	-0.71	Flow	
65	316.7	3.9	1.6	51.5	12.94	29.5	7.37		3.3	0.17	24.9	129	178	10.5	140	458	-0.68	SO ₂ 1.5	
70	316.2	3.4	1.5	49.4	10.50	38.6	9.64		3.4	0.18	58.3	117	171	8.5	134	429	-0.64	SO ₂ 1.5	
75	315.8	3.0	1.4	39.3	9.23	40.6	10.14		4.0	0.22	44.2	114	165	8	133	467	-0.62	SO ₂ 1.5	
80	315.5	2.7	1.3	35.9	8.90	44.2	11.04		6.9	0.35	25.4	110	159	6.8	130	386	-0.60		
85	315.2	2.4	1.3	33.5	8.30	46.5	11.62		6.4	0.33	25.2	105	152	5.9	125	366	-0.57		
90	314.9	2.1	1.3	32.8	8.13	47.0	11.94		7.6	0.40	20.3	103	149	5.6	123	355	-0.55		
95	314.7	1.9	1.2	29.9	6.92	51.2	12.29		12.8	0.66	10.5	100	145	4.9	121	341	-0.53		
100	314.6	1.8	1.1	26.6	6.60	52.5	13.12	94.7	17.7	0.89	9.4	98	142	4.6	119	329	-0.50		
105	314.4	1.6	1.2	23.6	5.86	54.9	13.91		20.6	1.04	5.6	95	139	4.0	116	315	-0.50		
110	314.3	1.5	1.1	21.3	5.30	56.7	14.12		22.8	1.14	4.6	92	135	3.6	113	303	-0.49		
115	314.2	1.4	1.1	21.9	5.22	56.8	14.19		22.9	1.15	4.6	90	133	3.2	112	296	-0.46		

19,085

1,526

444.2

168.3

Minute Time	Scale Wt	lbs Left	Burn Rate	CO ₂		O ₂		Tel	CO		T/C(1)/T/C(2)		T/C(3)		SO ₂	PPM	Static Press.	Comments			
				v.	%CO ₂	v.	%O ₂		v.	%CO	Bal	Wet Bulb	Dry Bulb	% H ₂ O					Calc W/B	Stack	
120	574.1	1.3	.1	.209	5.20	57.4	14.34				22.2	1.12	4.6	89	181	3.1	111	289	-045	Flow	
125	574.0	1.2	.1	.192	4.78	58.9	14.21				24.2	1.25	3.8	88	130	3.1	110	281	-043	SO ₂ 1.5	
130	573.9	1.1	.1	.190	4.73	59.2	14.29				26.8	1.35	3.5	88	129	3.1	110	272	-043	SO ₂ 1.5	
135	573.8	1.0	.1	.195	4.85	58.4	14.59				25.7	1.28	3.8	87	128	2.9	109	273	-042	SO ₂ 1.5	
140	573.7	.9	.1	.192	4.90	58.4	14.59				27.6	1.40	3.5	87	127	2.9	108	270	-042	SO ₂ 1.5	
145	573.7	.9	0	.209	5.20	57.2	14.29				26.6	1.34	3.9	87	128	2.9	107	262	-044		
150	573.6	.8	.1	.196	4.88	58.5	14.61				29.2	1.46	3.3	87	127	2.9	107	263	-040		
155	573.5	.7	.1	.194	4.83	58.4	14.59				29.1	1.45	3.3	87	126	2.9	106	259	-039		
160	573.4	.6	.1	.174	4.41	59.4	14.91				31.1	1.55	2.8	87	125	2.9	106	255	-038		
165	573.3	.5	.1	.184	4.58	58.8	14.69				32.7	1.61	2.8	87	125	2.9	106	257	-037		
170	573.2	.4	.1	.185	4.61	58.9	14.71				31.6	1.60	2.9	87	124	3.0	107	249	-037		
175	573.2	.4	0	.183	4.56	59.6	14.89				29.9	1.49	3.1	86	123	2.9	106	246	-037		
180	573.1	.3	.1	.186	4.63	59.0	14.74				29.6	1.48	3.1	86	123	2.9	105	244	-037	SO ₂ 1.5	
185	573.0	.2	.1	.187	4.65	58.9	14.71				30.0	1.50	3.1	87	124	2.9	105	243	-036	SO ₂ 1.5	
190	572.9	.1	.1	.187	4.65	58.9	14.71				30.1	1.51	3.1	87	123	3.0	105	244	-035	SO ₂ 1.5	
195	572.8	0	.1	.186	4.63	59.0	14.74				30.4	1.54	3.0	87	122	3.1	105	240	-035	SO ₂ 1.5	
200	45																				
205	50																				
210	55																				
215	60																				
220	05																				
225	10																				
230	15																				
235	20																				

Handwritten notes and circled values:
 (3180)
 (1484) FLOW
 (968)
 (14233)
 (352)
 (1143)
 (2153)
 (1054)

TEMPERATURES
RECORD SHEET #14
WST2-Form14 Rev7/96

Unit: Kumho Nodd Classic Date: 9/15/11
 Run: EPA 4 Technician(s): J.P. Rev. 5/12
 Page: 1 of 2 ATN, Rev. 5/12

T/C#	Minute/Time	Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn	Room Temp	Tunnel	C. Gas Box	Impinger Out	5G-1 Filter	5G-1 Condenser	HOT Box
0	12:25	383	514	300	506	440	833	941	74	94	249	39	78	53	878
5	30	392	503	318	496	442	716	1063	74	115	249	39	81	36	1167
10	35	543	501	314	480	442	717	1255	74	109	250	39	84	36	1065
15	40	522	492	312	468	441	721	1411	74	109	250	39	85	36	1072
20	45	630	499	311	466	439	741	1578	74	112	250	39	86	36	1038
25	50	684	509	311	472	435	783	1578	75	114	250	39	87	36	1072
30	55	724	521	313	491	433	822	1650	75	116	250	39	88	36	1104
35	1:00	733	546	302	512	430	865	1615	76	117	250	39	88	36	1113
40	05	726	565	295	534	429	918	1650	75	117	250	39	88	36	1132
45	10	741	578	291	548	428	1022	1332	75	118	250	39	88	36	1159
50	15	740	590	291	563	428	1055	1324	76	117	250	39	88	36	1185
55	20	744	601	294	572	429	1034	1284	77	117	250	39	88	36	1242
60	25	708	611	300	589	430	1155	1229	76	116	250	40	88	36	1254
65	30	685	618	302	592	432	1072	1295	76	115	250	40	88	36	1276
70	35	637	620	313	605	434	983	1250	77	113	249	40	88	36	1245
75	40	594	618	316	606	436	960	1242	76	111	249	40	88	36	1195
80	45	569	611	319	600	439	969	1199	76	109	249	40	88	37	1234
85	50	643	601	322	590	442	944	1191	77	107	250	39	88	37	1246
90	55	529	593	324	584	444	942	1169	77	107	250	39	88	37	1246
95	1:00	499	585	322	572	442	992	1092	78	105	250	38	88	36	1201
100	05	474	579	322	562	442	998	1044	77	104	250	38	88	36	1171
105	10	445	573	324	553	449	999	1002	78	103	250	38	88	36	1073
110	15	424	564	319	541	450	958	961	78	102	250	38	88	36	1013
116	20	418	555	313	529	450	949	942	77	102	250	38	88	36	1000

14,117 13,550 7463 13,061 10,517 23,158 30,217 1822

TEMPERATURES
 RECORD SHEET #14
 MST2-Form14 Rev7/96

Unit: Kuma Wood Classic Date: 9/15/99
 Run: EP44 Technician(s): ATY, BLS, JP
 Page: 2 of 2

T/C#	Minute/Time	Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn	Room Temp	Tunnel	C. Gas Box	Impinger Out	5G-1 Filter	5G-1 Condenser	Comt. Temp	Hot Box
130	30	382	532	303	506	446	899	906	78	101	250	39	88	37	915	250
130	35	372	528	298	496	443	884	885	78	100	250	39	88	37	906	250
135	40	368	512	293	486	441	877	872	77	100	250	39	88	37	902	250
140	45	362	502	288	472	438	865	875	78	99	250	39	88	37	905	250
145	50	352	499	283	469	435	864	868	78	99	250	39	88	37	883	250
150	55	352	491	281	463	433	844	856	78	99	250	39	88	37	852	250
155	55	348	484	272	452	431	826	842	77	99	250	39	88	37	843	250
160	05	349	472	274	451	429	725	812	79	99	250	39	89	37	820	250
165	10	337	469	271	445	426	782	810	78	98	249	39	89	37	822	249
170	15	332	461	270	439	422	772	800	78	98	249	39	89	37	835	250
175	20	329	455	269	435	419	783	794	78	98	249	39	89	37	832	249
180	25	324	448	262	431	415	796	790	79	97	249	39	89	37	832	249
185	30	322	442	265	427	414	800	784	79	97	249	39	89	37	822	249
190	35	322	438	264	425	412	734	776	78	98	249	39	89	37	823	250
195	40	318	434	263	422	409	799	771	80	97	249	39	89	37	824	250
200	45	318	434	263	422	409	799	771	80	97	249	39	89	37	824	250
205	50	318	434	263	422	409	799	771	80	97	249	39	89	37	824	250
210	55	318	434	263	422	409	799	771	80	97	249	39	89	37	824	250
215	1:00	318	434	263	422	409	799	771	80	97	249	39	89	37	824	250
220	05	318	434	263	422	409	799	771	80	97	249	39	89	37	824	250
225	10	318	434	263	422	409	799	771	80	97	249	39	89	37	824	250
230	15	318	434	263	422	409	799	771	80	97	249	39	89	37	824	250
235	20	318	434	263	422	409	799	771	80	97	249	39	89	37	824	250

STOP! START!
 AT! 498.6
 -59.4

REF 1700

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-1

Site: Myren Consulting, Woodinville, WA Date: 9/15/99 Analyte: CO₂

Source: Kuma Wood Classic Run #: EPA 4

Zero cyl #: 719 430
Conc. 00.0 % CO₂ - Cyl Press: 1850 psi
Date: 4/1/99

Certified by: Oxarc
Span cyl #: 350 - 794
Conc. 12.5 % CO₂ - Cyl Press: 1310 psi
Date: 3/26/99

Analyzer: Make: Horiba Model: PIR-2000 SN: 607024

Range: 0 - 25.0% CO₂ Analyzer Output: 0 - 1.0 v.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter:

EPA Span Value = 25.0% CO₂
EPA Control Limits = + 2.5% of 25.0% CO₂ = + 0.625% CO₂

Pre Run Audit: By: RLS Time: 1110 Temp: 72

Audit Results

Point #	Expected Response		Actual Response		+ Conc. Difference %
	Meter	DVM	Meter	DVM	
Zero	00.0	.000	00.0	.000	+0.0446 +0.18
Span	50.0	.500	49.4	.491	-0.3508 -2.81

Comments:

Post Run Audit: By: RLS Time: 1555 Temp: 78

Audit Results

Point #	Expected Response		Actual Response		+ Conc. Difference %
	Meter	DVM	Meter	DVM	
Zero	00.0	.000	00.0	.000	+0.0446 +0.18
Span	50.0	.500	49.4	.491	-0.3508 -2.81

Comments:

Span 50.0 1500 12.5 49.4 488 12.0953 -0.4247 -3.40

Zero 00.0 .000 00.0 .000 00.0 .0446 +0.18

Point # Meter DVM % Meter DVM % + Conc. Difference %

Expected Response Actual Response

Audit Results

Post Run Audit: By: RLS Time: 1555 Temp: 78

Audit Results

Comments:

+ Conc. Difference = Act % - Exp (Std) %

Zero % Difference = Act % (ppm) - Exp % (ppm) x 100

Full Scale Value

Span % Difference = Act % (ppm) - Exp % (ppm) x 100

Exp % (ppm)

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-2

Site: Myren Consulting, Woodinville, WA Date: 2/15/99 Analyte: 02
Source: King's Hill Run #: EPA 4

Zero Cyl #: 719 430 Certified by: Oxarc Date: 4/1/99
Span Cyl #: 250-794 Certified by: Oxarc Date: 3/26/99
Conc. 00.0 % O₂ Cyl Press: 1850 psi
Conc. 12.5 % O₂ Cyl Press: 1310 psi

Analyzer: Make: Taylor Model: OA 137 SN: 137/4772
Range: 0 - 25.0% O₂ Analyzer Output: 0 - 100 mv.
Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter:

EPA Span Value = 25.0% O₂
EPA Control Limits = + 2.5% of 25.0% O₂ = + 0.625% O₂

Pre Run Audit: By: PLS Time: 1110 Temp.: 72 of

Audit Results

Point #	Expected Response		Actual Response		+ Conc. Difference	Δ %
	Meter	DVM	Meter	DVM		
Span	12.5	50.0	12.5	49.4	-0.1591	-1.27
Zero	00.0	00.0	00.0	00.1	+0.0300	+0.12

Comments:

Post Run Audit: By: PLS Time: 1555 Temp.: 78 of

Audit Results

Point #	Expected Response		Actual Response		+ Conc. Difference	Δ %
	Meter	DVM	Meter	DVM		
Span	12.5	50.0	12.5	49.4	-0.1591	-1.27
Zero	00.0	00.0	00.0	00.0	+0.0050	+0.02

Comments:

+ Conc. Difference = Act % - Exp (Std) %
Zero % Difference = Act % (ppm) - Exp % (ppm) X 100
Full Scale Value
Span % Difference = Act % (ppm) - Exp % (ppm) X 100
Exp % (ppm)

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-3

Site: Myren Consulting, Woodinville, WA Date: 9/15/99 Analyte: CO
Source: Kumar Wood Classic Run #: EPA 4

Zero cyl #: 719 430
Cyl Press: 1850 psi
Date: 4/1/99
Certified by: OXARC

Span cyl #: 250-794
Cyl Press: 1310 psi
Date: 3/26/99
Certified by: OXARC

Analyzer: Make: Infra Red Model: 702 D SN: 113
Range: 0 - 10.0% CO Analyzer Output: 0 - 100 mv.
Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter:

EPA Span Value = 5.0% CO
EPA Control Limits = +2.5% of 5.0% CO = + 0.125% CO

Pre Run Audit: By: PLS Time: 1110 Temp.: 72 OF

Point #	Expected Response		Actual Response		+ Conc. Difference	Δ %
	Meter	DVM	Meter	DVM		
Zero	00.0	00.0	00.0	00.0	-1.0093	-0.19
Span	2.50	50.0	2.50	50.0	-1.0086	-0.34

Comments:

Post Run Audit: By: PLS Time: 1555 Temp.: 78 OF

Point #	Expected Response		Actual Response		+ Conc. Difference	Δ %
	Meter	DVM	Meter	DVM		
Zero	00.0	00.0	00.0	00.1	-1.0043	-0.09
Span	2.50	50.0	2.47	48.5	-1.0836	-3.34

Comments:

+ Conc. Difference = Act % - Exp (Std) %
Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Exp \% (ppm)}} \times 100$

Unit: Kuma Wood Clin
 Run: EPA 4
 Date: 9/15/1999
 Technicians: AM / JTS
 MST6-Form3-Rev11/89

QUALITY CHECKS
 WOODSTOVE DATA SHEET #16

Ambient = Tr: _____

Thermocouple Check (at ambient): T/C#1: 66 OF; T/C#2: 66 OF; T/C#3: 67 OF; T/C#4: 67 OF; T/C#5: 66 OF; T/C#6: 66 OF; T/C#7: 67 OF; T/C#8: 66 OF; T/C#9: 67 OF; T/C#10: 68 OF; T/C#11: 67 OF; T/C#12: 66 OF; T/C#13: 66 OF; T/C#14: 66 OF; T/C#15: 66 OF; T/C#16: 66 OF; T/C#17: 67 OF; T/C#18: 66 OF; T/C#19: 66 OF; T/C#20: 66 OF; T/C#21: 66 OF; T/C#22: 66 OF; T/C#23: 66 OF; T/C#24: 66 OF; T/C#25: 66 OF; T/C#26: 66 OF

Thermocouple Readout: Pretest Zero/Span Check and Calibration:
 Zero (0°F) OF: 001 OF; Adj to: 000 OF; Post Test Check (0°F): 001 OF; % Difference: +0.05%
 Span (2000°F): 2000 OF; Adj to: 2000 OF; Span (2000°F): 2000 OF; (Allowable % Difference = 1.5%. Use formulas on Woodstove Data Sheet #15 to calculate % Difference)

Thermocouple Readout Pretest Linearity Check
 0°F = 000 OF; 200°F = 200 OF; 400°F = 400 OF; 600°F = 599 OF; 800°F = 800 OF; 1000°F = 1000 OF; 1200°F = 1800 OF; 1400°F = 1400 OF; 1600°F = 1599 OF; 1800°F = 1800 OF; 2000°F = 2000 OF

Combustion Gas (CO₂, O₂, CO) Train Leak Check: Pre Post
 Draft (Static) Gauge Zero Check: Pre Post
 Scale Check Pre (Wt, #'s): 510.7-515.7 S.O lbs, OK (ALS)
 Post (Wt, #'s): 512.4-517.4 S.O lbs, OK (ALS)

Stack cleaned prior to the run: Yes No
 Tunnel cleaned prior to the run: Yes No

DILUTION TUNNEL CALCULATIONS

3/31/96

MYREN CONSULTING CERTIFICATION TEST DATA

Kumraepa6

File Name:	KumaEPA6	PITOT	GAS METER RDG	GAS METER TEMP	GAS METER DELTA H	TUNNEL VELOCIT	PROP RATE	DDGM Vol std
Stove Manufacturer:	Kuma	DELTA H (- INCH H2O)	(#3)	(°F)	(in.H2O)	(ft/min)	(%)	(ft3)
Model Number:	Wood Classic	TEMP	TEMP	TEMP	VELOCIT	RATE	Vol std	
Lab Name:	MYREN	(°F)	(°F)	(°F)				
Test Date:	9/17/99							
Run Number:	EPA 6							
Meter Box Y Factor:	1.0151							
Barometric pressure (in):	28.64							
Gas meter temp (ave):	85							
delta H(avg):	0.900							
Gas meter initial reading:	140.902							
Gas meter final reading:	201.559							
Front catch (acetone) mg:	10.2							
first filter catch (mg):	10							
second filter catch (mg):	-4.9							
tunnel flow (ave cfm):	143.836							
Emission Rate(g/h):	2.343							
Emission Rate(M5H) :	3.689							
vs/VmTs:	0.0264							
vs ave:	897.157							
Tunnel average temp (°):	133.833							
Test time(min):	109							
Fuel Load(lb. wet):	14.7							
Wood moisture(%wet):	17.790							
Burn rate(dry kg/hr):	3.017							
Samp vol(scf):	57.139							
front filter number	940							
back filter number	939							
acetone beaker number	23							
PRELIMINARY RESULTS								
FINAL RESULTS								
DATA SUMMARY								
MODEL :	Wood Classic							
RUN:	EPA 6							
DATE:	9/17/99							
DBR:	3.017							
GPH UNADJ	2.343							
ADJ	3.689477713							
	350							

DATE 9/17/1999

PAGE 1 OF 1

MODEL * Wood Classic

RUN # EPH 6

METER BOX # 511-M

METER Y 1.0151

FILTER # (F) 940 (R) 939

PRE TEST LEAK RATE = .000 CFM @ -150 IN. HG. 488/488

FILTER SIZE: 110 MM

POST TEST LEAK RATE = .000 CFM @ -140 IN. HG. 099/099

PROBE LENGTH 34" glass

TIME	CLOCK	ELAPSED	METER READING CU.FT.	PILOT dp	T.M. TEMP. (°F)	METER TEMP. (°F)	GAS METER dp	VAC IN. Hg	VELOCITY TRAVERSE	
									POINT	LOCATION ΔP TEMP
0940	50	00	140.402	-043	124	77	.90	0	N-1	0.5 1034 127
1000	50	10	146.455	-043	149	78	.90	0	2	1.5 1040 139
1000	20	20	152.005	-043	154	80	.90	0	3	4.5 1049 158
1100	10	30	159.559	-043	154	83	.90	0	4	5.5 1039 127
1100	20	40	163.135	-043	150	84	.90	0	W-1	0.5 1040 139
1100	30	50	168.681	-043	144	86	.90	0	2	1.5 1043 131
1100	40	60	174.240	-043	135	87	.90	0	3	4.5 1043 130
1100	50	70	179.795	-043	128	88	.90	0	4	5.5 1041 130
1200	10	80	185.364	-043	122	89	.90	0		Avg. -040 128.875
1200	20	90	191.005	-043	119	89	.90	0		Pilot Leak Check Post
1200	30	100	196.537	-043	116	89	.90	0		
1200	40	110	201.559	-043	114	90	.90	0		
1300	50	120	206.657							
1300	60	130								
1300	70	140								
1300	80	150								
1300	90	160								
1300	100	170								
1300	110	180								
1300	120	190								
1300	130	200								
1300	140	210								
1300	150	220								
1300	160	230								
1300	170	240								
1300	180	250								
1300	190	260								
1300	200	270								
1300	210	280								
1300	220	290								
1300	230	300								

CP = 0.99
 W 1 2 3 4
 ← M I 2
 (3/4)

Pilot Leak Check Post

Avg. -040 128.875
 5.5 1041 130
 4.5 1043 130
 1.5 1043 131
 0.5 1040 139
 5.5 1039 127
 4.5 1049 158
 1.5 1040 139
 0.5 1034 127

POINT LOCATION ΔP TEMP

FILTER # (F) 940 (R) 939

RUN # EPH 6

MODEL * Wood Classic

PARTICULATE SAMPLING DATA

X = 28.6400

BP = 28.65 in Hg
 6.0 28.64
 1.85 28.63
 1.86 28.64
 1.86 28.64
 3.00

point of Avg. delta p
 (ΔP x BP) / (1.8) x 3167.2 =
 139.719 cfm

CP = 0.99
 W 1 2 3 4
 ← M I 2
 (3/4)

Pilot Leak Check Post

Avg. -040 128.875
 5.5 1041 130
 4.5 1043 130
 1.5 1043 131
 0.5 1040 139
 5.5 1039 127
 4.5 1049 158
 1.5 1040 139
 0.5 1034 127

POINT LOCATION ΔP TEMP

FILTER # (F) 940 (R) 939

RUN # EPH 6

MODEL * Wood Classic

PARTICULATE SAMPLING DATA

X = 28.6400

BP = 28.65 in Hg
 6.0 28.64
 1.85 28.63
 1.86 28.64
 1.86 28.64
 3.00

point of Avg. delta p
 (ΔP x BP) / (1.8) x 3167.2 =
 139.719 cfm

CP = 0.99
 W 1 2 3 4
 ← M I 2
 (3/4)

Pilot Leak Check Post

Avg. -040 128.875
 5.5 1041 130
 4.5 1043 130
 1.5 1043 131
 0.5 1040 139
 5.5 1039 127
 4.5 1049 158
 1.5 1040 139
 0.5 1034 127

POINT LOCATION ΔP TEMP

FILTER # (F) 940 (R) 939

RUN # EPH 6

MODEL * Wood Classic

PARTICULATE SAMPLING DATA

WOODSTOVE DATA SHEET #4-1: INITIAL FILTER WEIGHTS (TARE WEIGHTS)

Into Desiccator: Date 1/9/99 Time 1445 By ATM Front Half Back Half

Manufacturer: Scherbert Schele // Size: 11cm Lot.No.: Z8961 Grade: #25 G/ass

Order No.: 06220

Filter #	Wt	Date	Time	By	Filter #	Wt	Date	Time	By
926	7.710	3/6/99	1140	TM	162	1.652	3/5/99	1652	ATM
927	7.938		1141	TM	161	1.651			ATM
928	7.985		1142	TM	160	1.650			ATM
929	7.909		1143	TM	1649	1.649			ATM
930	7.948		1144	TM	1648	1.648			ATM
931	8.041		1145	TM	1647	1.647			ATM
932	7.917		1146	TM	1646	1.646			ATM
933	8.047		1147	TM	1645	1.645			ATM
934	7.981		1148	TM	1644	1.644			ATM
935	7.861		1149	TM	1643	1.643			ATM
936	7.827		1150	TM	1643	1.643			ATM
937	7.935		1151	TM	1642	1.642			ATM
938	8.086		1152	TM	1641	1.641			ATM
939	8.060		1153	TM	1640	1.640			ATM
940	8.151		1154	TM	1639	1.639			ATM
941	8.252		1155	TM	1638	1.638			ATM
942	7.982		1156	TM	1637	1.637			ATM
943	7.822		1157	TM	1636	1.636			ATM
944	7.938		1158	TM	1635	1.635			ATM
945	7.944		1159	TM	1635	1.635			ATM
946	7.852		1200	TM	1634	1.634			ATM
947	7.731		1201	TM	1633	1.633			ATM
948	7.936		1202	TM	1632	1.632			ATM
949	7.838		1203	TM	1631	1.631			ATM
950	8.040		1204	TM	1630	1.630			ATM

→
→

Checked by *[Signature]* Date: 3/16/99 Time 2133

Filter #	Wt	Date	Time	By	Filter #	Wt	Date	Time	By
926	7.710	3/6/99	1140	TM	162	1.652	3/5/99	1652	ATM
927	7.938		1141	TM	161	1.651			ATM
928	7.985		1142	TM	160	1.650			ATM
929	7.909		1143	TM	1649	1.649			ATM
930	7.948		1144	TM	1648	1.648			ATM
931	8.041		1145	TM	1647	1.647			ATM
932	7.917		1146	TM	1646	1.646			ATM
933	8.047		1147	TM	1645	1.645			ATM
934	7.981		1148	TM	1644	1.644			ATM
935	7.861		1149	TM	1643	1.643			ATM
936	7.827		1150	TM	1643	1.643			ATM
937	7.935		1151	TM	1642	1.642			ATM
938	8.086		1152	TM	1641	1.641			ATM
939	8.060		1153	TM	1640	1.640			ATM
940	8.151		1154	TM	1639	1.639			ATM
941	8.252		1155	TM	1638	1.638			ATM
942	7.982		1156	TM	1637	1.637			ATM
943	7.822		1157	TM	1636	1.636			ATM
944	7.938		1158	TM	1635	1.635			ATM
945	7.944		1159	TM	1635	1.635			ATM
946	7.852		1200	TM	1634	1.634			ATM
947	7.731		1201	TM	1633	1.633			ATM
948	7.936		1202	TM	1632	1.632			ATM
949	7.838		1203	TM	1631	1.631			ATM
950	8.040		1204	TM	1630	1.630			ATM

Balance Room Environmental Conditions

WB	DB	%RH	Date	Time	By
64	39	43	3/6/99	1135	ATM
66	81	45	3/15/99	1622	ATM
65	82	39	3/16/99	2025	ATM

QA Remeigh

Filter #	WT	Date	Time	By
929	7.912	3/6/99	2136	SM
941	8.248	3/6/99	2134	SM
949	7.837	3/16/99	2133	SM

Post Test Weighing Session Beate Chade
1st 3rd 3rd QC
0.0000 0.0000 0.0000 Δ.0001
1.0000 1.0000 1.0000 Δ.9999

Into Descicator: Date: 8/20/99 Time: 1500 By: A. J. Myron

Beaker # First Second Third

Beaker #	Wt	Date	Time	By	Wt	Date	Time	By	Wt	Date	Time	By
1	65.4841	8/27	2059	SJ	65.4845	8/30/99	1211	ATM				
2	66.1509	8/27	2118	SJ	66.1514			ATM				
3	67.8588			SJ	67.8593			ATM				
4	67.5890			SJ	67.5891			ATM				
6	67.470			SJ	67.4734			ATM				
7	65.5444			SJ	65.5446			ATM				
8	66.0299			SJ	66.0298			ATM				
9	66.0297			SJ	66.0296			ATM				
10	66.0906			SJ	66.0902			ATM				
11	65.7072			SJ	65.7080			ATM				
13	57.8946			SJ	57.8948			ATM				
	65.7021	9/11	1232	SJ								
	65.7022	9/13	1934	SJ								
20	73.3159	8/27	2125	SJ	73.3160	8/31/99	1300	ATM				
21	71.0002	8/27	2126	SJ	71.0003			ATM				
22	71.8302	9/11/99	1240	ATM	71.8322	9/13	1719	SJ				
23	70.7376	8/27	2131	SJ	70.7382	8/30/99	1259	ATM				
24	73.2173	8/27	2130	SJ	73.2182			ATM				
25					72.6505			ATM				
26	71.7865	8/27	2132	SJ	71.7868	8/31/99	1302	ATM				
27	72.3294	9/11/99	1235	ATM	72.3294	9/8	1718	SJ				
28	70.5955	8/27	2127	SJ	70.5956	8/31/99	1304	ATM				
29	71.5183	8/27	2133	SJ	71.5185			ATM				
30	70.7845	8/27	2128	SJ	70.7855	8/30/99	1300	ATM				
31	69.6652	8/27	2129	SJ	69.6655	8/31/99	1303	ATM				
32	70.2375	9/11	1238	ATM								
34	73.2125	9/11	1242	ATM								

Class

Checked By: A. J. Myron Date: 9/11 & 13/99 Time: 1500

BALANCE ROOM ENVIRONMENTAL CONDITIONS

WB	DB	TRH	Date	Time	By
70	84	72	9/8/99	1705	ATM
79	84	76	9/11/99	1202	ATM
63	76	78	9/31/99	1310	ATM

Beaker #	WT	Date	Time	By

70 84 72 9/8/99 1705 ATM
 79 84 76 9/11/99 1202 ATM
 63 76 78 9/31/99 1310 ATM

cut 24
cut 23

Into Dessicator: Date: 6/1/99
By: A.T. Myrum

Checked By: A.T. Myrum
Date: 7/18/99
Time: 1800

Beaker #	Wt	Date	Time	By	Second	Wt	Date	Time	By	Third	Wt	Date	Time	By
1	66.4947	7/18/99	1636	ATM	65.4817	7/18/99	1612	ATM	←	1614	ATM	7/18/99	1614	←
2	66.1514		1638	ATM	66.506		1614	ATM	↑	1618	ATM		1618	ATM
3	67.8572		1640	ATM	67.8567		1620	ATM	↑	1622	ATM		1622	ATM
4	67.5887		1642	ATM	67.5880		1620	ATM	↑	1623	ATM		1623	ATM
5	67.4268		1644	ATM	67.4266		1620	ATM	↑	1625	ATM		1625	ATM
6	67.9268		1644	ATM	67.4266		1620	ATM	↑	1627	ATM		1627	ATM
7	65.5426		1648	ATM	65.5437		1620	ATM	↑	1628	ATM		1628	ATM
8	66.6212		1650	ATM	66.0211		1620	ATM	↑	1632	ATM		1632	ATM
9	66.5299		1652	ATM	66.6295		1620	ATM	↑	1635	ATM		1635	ATM
10	66.0889		1654	ATM	66.0888		1620	ATM	↑	1637	ATM		1637	ATM
11	65.7015		1656	ATM	65.7013		1620	ATM	↑	1638	ATM		1638	ATM
12	66.0655		1658	ATM	66.0653		1620	ATM	↑	1639	ATM		1639	ATM
13	57.8948		1700	ATM	57.8944		1630	ATM	↑					

Wt	Date	Time	By
63	7/18/99	1604	ATM
65	7/17/99	1825	ATM

Wt	Date	Time	By
63	7/18/99	1604	ATM
65	7/17/99	1825	ATM

Balance Room Environmental Conditions

QA Service

|||||

WOODSTOVE DATA SHEET #4-3: CONSTANT FINAL WEIGHTS

FINAL BEAKER WEIGHTS

Beaker #	Into Desicc	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By
33	✓	9/23/99	2105	AMM	70.7449g	9/24	1157	AMM	90.7476g	9/27/99	2010	Jun				

WST5-Form9, Tgl, Rev4/90
 Unit Kanna Wood Caseid
 Run # EYA 6
 Date: 9/17/99

FINAL FILTER WEIGHTS

Filter #	Into Desicc	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By
9410	.8261	9/17	1137	AMM	.8054	9/18	1259	AMM	.8252	9/19	1305	AMM	.8251	9/23	2045	Jun
939	.8014	9/17	1138	AMM	.8010	9/18	1301	AMM	.8011	9/19	1305	AMM	.8009	9/23/99	2045	Jun

QA REWEIGH: FINAL WEIGHTS

Date	Beaker #	Final Wt	By
Date	Filter #	Final WT	By

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighting	Session	Date	Time	By	WB	DB	%RH
1		9/18	1217	AMM	65	78	418
2		9/19	1245	AMM	62	75	417
3		9/23	2008	AMM	65	79	417
4		9/24	1145	AMM	64	77	419
5							

SCALE ROOM ENVIRONMENTAL CONDITIONS

6				
7				
8				
9				
Comments				

WOODSTOVE DATA SHEET #4-3: CONSTANT FINAL WEIGHTS

PINAL BEAKER WEIGHTS

Beaker #	Into Desicc	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By
1	✓	7/21/99	1435	ATM	65.4852	8/4/99	1715	ATM	65.4846	8/8/99	1742	OBH	65.4849	8/9	1642	ATM

Blank
7/15/99

WSTS-Form9, Pg1, Rev4/99
Unit: Kuma Wood Cleanair
Run #
Date: 9/1/99

PINAL FILTER WEIGHTS

Filter #	Into Desicc	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By

QA REMEICH: FINAL WEIGHTS

Date	Beaker #	Final Wt	By
Date	Filter #	Final Wt	By

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighting Session	1999	Date	Time	By	WB	DB	%RH
1	8/4	1705	ATM		69	83	49
2	8/8	1700	ATM		64	78	46
3	8/9	1615	ATM		69	84	46
4							
5							

SCALE ROOM ENVIRONMENTAL CONDITIONS

6	7	8	9	Comments

Dates From 1/9/99
Through 7/17/99

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale Mettler
Model AE100
SN K04827

Level	Recall- brated	100g Weight	10g Weight	1.0g Weight	100mg Weight	20mg Weight	Date	Time	Tech	Wet Bulb	Dry Bulb	% RH
✓	Yes	99.9999	10.0001	1.0002	.1003	.0203	1/9/99	1243	ATM	58	70	48
✓	No	100.0002	10.0000	1.0000	.1000	.0200	1/14/99	1113	ATM	62	75	47
✓	Yes	99.9998	10.0002	1.0000	.0999	.0201	1/23/99	1100	ATM	63	72	48
✓	Yes	99.9999	10.0000	1.0000	.1000	.0201	1/24/99	1318	ATM	59	74	45
✓	Yes	99.9999	10.0002	1.0000	.1000	.0200	2/1/99	0910	ATM	55	69	39
✓	Yes	99.9999	10.0001	1.0001	.1002	.0201	2/2/99	0939	ATM	60	73	46
✓	Yes	99.9999	10.0001	1.0001	.1001	.0200	2/2/99	1555	ATM	63	76	48
✓	Yes	99.9999	10.0000	1.0001	.1001	.0201	2/4/99	1235	ATM	62	76	45
✓	Yes	99.9998	10.0000	1.0000	.1000	.0200	2/10/99	1600	ATM	63	76	45
✓	Yes	99.9998	10.0000	1.0001	.1000	.0200	2/19/99	0246	ATM	64	78	46
✓	No	99.9999	10.0000	1.0000	.1000	.0200	2/21/99	1913	ATM	64	80	44
✓	No	99.9999	10.0000	1.0001	.1000	.0200	3/5/99	1935	ATM	64	80	44
✓	Yes	99.9999	10.0000	1.0000	.1001	.0200	3/6/99	1135	ATM	64	79	43
✓	Yes	99.9999	10.0000	1.0001	.1000	.0200	3/13/99	1526	ATM	65	80	44
✓	Yes	99.9999	10.0000	1.0001	.1001	.0200	3/14/99	1855	ATM	63	78	43
✓	Yes	99.9999	10.0001	1.0001	.1001	.0200	3/15/99	1622	ATM	66	81	45
✓	No	100.0001	10.0000	1.0000	.1000	.0200	3/16/99	2025	ATM	65	82	39
✓	Yes	99.9992	10.0000	1.0001	.1000	.0200	3/17/99	1615	ATM	62	77	42
✓	Yes	99.9996	10.0000	1.0001	.1001	.0200	3/18/99	2140	ATM	68	84	43
✓	Yes	99.9999	10.0000	1.0001	.1000	.0200	3/20/99	1300	ATM	64	84	43
✓	Yes	99.9999	10.0000	1.0000	.1000	.0200	3/21/99	2215	ATM	61	74	37
✓	Yes	99.9999	10.0000	1.0000	.1001	.0200	3/22/99	2122	ATM	65	83	33
✓	Yes	99.9997	10.0000	1.0001	.1000	.0200	3/23/99	1115	ATM	69	84	44
✓	Yes	99.9997	10.0000	1.0002	.1001	.0201	3/24/99	1120	ATM	72	89	43
✓	Yes	99.9999	10.0000	1.0002	.1001	.0201	3/29/99	2038	ATM	57	72	45
✓	No	99.9999	10.0002	1.0002	.1001	.0202	3/30/99	0610	ATM	66	80	43
✓	No	99.9999	10.0000	1.0000	.1001	.0201	3/21/99	1200	ATM	64	80	41
✓	No	99.9996	10.0000	1.0000	.1001	.0201	4/15/99	1730	ATM	64	80	41
✓	Yes	99.9997	10.0001	1.0001	.1001	.0201	4/16/99	1030	ATM	61	75	44
QC	Sealances	100.0003	10.0001	1.0001	.1001	.0201	4/16/99	1330	ATM	65	85	33
✓	Yes	99.9998	10.0001	1.0001	.1001	.0200	4/7/99	1724	ATM	65	85	33
✓	No	99.9996	10.0000	1.0001	.1001	.0201	4/8/99	1346	ATM	63	82	32
✓	Yes	99.9999	10.0000	1.0000	.1000	.0200	4/16/99	1230	ATM	66	84	32
✓	Yes	99.9999	10.0000	1.0000	.1000	.0200	4/17/99	1625	ATM	68	84	32
✓	No	99.9999	10.0000	1.0000	.1000	.0200	4/19/99	1050	ATM	49	72	45
✓	No	99.9996	10.0001	1.0002	.1001	.0202	5/17/99	1825	ATM	65	83	49

Dates From 7/18/99
Through 9/16/99

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale Mettler
Model AE100
SN K04827

Level	Recall- brated	100g Weight	10g Weight	1.0g Weight	100mg Weight	20mg Weight	Date	Time	Tech	Wet Bulb	Dry Bulb	% RH
V	No	99.9996	10.0000	1.0001	100.00	0.201	7/18/99	16:04	ATM	63	77	49
V	YES	99.9997	10.0000	1.0001	100.00	0.201	7/19/99	18:35	ATM	64	77	49
V	Yes	99.9996	10.0000	1.0002	100.00	0.203	7/20/99	18:54	ATM	64	85	80
V	Yes	99.9997	10.0001	1.0001	100.00	0.201	7/21/99	18:06	ATM	69	84	50
V	Yes P.O.	99.9998	9.9999	1.0000	100.00	0.200	7/22/99	21:45	ATM	64	80	41
V	Yes	99.9998	10.0000	1.0000	100.00	0.200	7/23/99	07:45	ATM	62	76	45
V	No	99.9998	10.0000	1.0000	100.00	0.200	7/24/99	18:46	ATM	66	80	47
V	YES P.O.	Would not calibrate					8/31/99	21:17	ATM	70	84	47
V	Yes	99.9998	10.0001	1.0002	100.00	0.201	8/4/99	19:05	ATM	69	83	49
V	No	99.9998	10.0001	1.0001	100.00	0.200	8/5/99	21:06	ATM	65	78	49
V	Yes	99.9998	10.0000	1.0000	100.00	0.200	8/6/99	15:36	ATM	68	81	50
V	No	99.9999	10.0000	1.0000	100.00	0.200	8/7/99	15:15	ATM	66	80	47
V	Yes	99.9999	10.0000	1.0002	100.00	0.201	8/8/99	19:00	ATM	64	83	48
V	Yes	99.9999	10.0000	1.0001	100.00	0.200	8/9/99	19:25	ATM	68	83	48
V	Yes	99.9999	10.0001	1.0001	100.00	0.200	8/9/99	16:15	ATM	69	84	46
V	Yes	99.9999	10.0000	1.0000	100.00	0.200	8/10/99	13:21	ATM	68	84	46
V	No	99.9999	10.0000	1.0000	100.00	0.200	8/11/99	10:43	ATM	67	81	48
V	Yes	99.9999	10.0000	1.0000	100.00	0.200	8/11/99	20:35	ATM	64	80	46
V	Yes	99.9999	10.0000	1.0001	100.00	0.201	8/11/99	12:30	ATM	64	80	47
V	Yes	99.9999	10.0000	1.0001	100.00	0.200	8/13/99	19:29	ATM	64	80	47
V	Yes	99.9998	10.0001	1.0002	100.00	0.201	8/14/99	11:35	ATM	63	76	48
V	Yes	99.9998	10.0000	1.0001	100.00	0.201	8/16/99	13:50	ATM	64	83	48
V	Yes	99.9998	10.0000	1.0001	100.00	0.200	8/17/99	16:50	ATM	70	84	49
V	No	99.9999	10.0001	1.0000	100.00	0.201	8/22/99	20:52	ATM	69	83	46
V	No	99.9999	10.0001	1.0002	100.00	0.202	8/30/99	11:54	ATM	67	81	48
V	No	99.9998	9.9999	1.0000	100.00	0.200	8/31/99	13:10	ATM	63	76	48
V	Yes	99.9997	10.0000	1.0000	100.00	0.200	9/1/99	16:44	ATM	65	79	44
V	Yes	99.9998	10.0000	1.0000	100.00	0.200	9/2/99	10:32	ATM	60	74	43
V	Yes	99.9998	10.0000	1.0002	100.00	0.200	9/8/99	19:05	ATM	70	84	47
V	YES	99.9996	10.0001	1.0002	100.00	0.201	9/11/99	12:02	ATM	69	84	46
V	Yes	99.9996	10.0000	1.0000	100.00	0.201	9/12/99	20:58	ATM	70	84	49
V	Yes	99.9996	10.0001	1.0000	100.00	0.200	9/13/99	19:26	ATM	69	84	49
V	Yes	99.9997	10.0001	1.0002	100.00	0.202	9/14/99	13:35	ATM	61	73	49
V	Yes	99.9997	10.0001	1.0002	100.00	0.203	9/14/99	8:05	ATM	61	73	49
V	Yes	99.9997	10.0001	1.0002	100.00	0.203	9/15/99	8:15	ATM	64	76	49
V	Yes	99.9998	10.0001	1.0000	100.00	0.200	9/15/99	08:20	ATM	64	76	49
V	Yes	99.9998	10.0001	1.0001	100.00	0.201	9/16/99	08:45	ATM	64	76	46
V	No	99.9996	10.0000	1.0000	100.00	0.200	9/16/99	16:55	ATM	70	84	46

Dates From 9/17/99

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Through _____

Scale Mettler
Model AE100
SN K04827

Level	Recall- brated	100g Weight	10g Weight	1.0g Weight	100mg Weight	20mg Weight	Date	Time	Tech	Wet Bulb	Dry Bulb	% RH
V	Yes	99.9999	10.0000	1.0001	100	0.2001	9/17/99	2045	ATM	66	79	47
V	Yes	99.9999	10.0000	1.0000	100	0.2000	9/18/99	1217	ATM	65	78	48
V	No	99.9999	10.0000	1.0000	100	0.2000	9/19/99	1245	ATM	65	75	49
V	Yes	99.9999	10.0001	1.0001	100	0.2001	9/23/99	2028	ATM	64	79	47
V	Yes	99.9999	10.0000	1.0000	100	0.2001	9/21/99	1145	ATM	64	77	49
V	Yes	99.9999	10.0001	1.0001	100	0.2000	9/21/99	2000	ATM	59	87	48
V	No	99.9999	10.0000	1.0000	100	0.2000	9/23/99	1340	ATM	58	70	48

Unit: Kama Wood Classic
Run: EPD 6
Date: 9/17/99
Technicians: ATM
MST20, Form 5

Woodstove Particulate
Catch Processing Sheet #5
Woodstove Data Sheet #5
RPA M5G-1

Filters
Filter # (F) 940
Final Wt. 8.251
Tare Wt. .8151
Net Wt. .0100
Beaker # 33
MI 37
Desc. Acetone
Final Wt. 70.7476
Tare Wt. 70.7375
Net Wt. .0101

Beaker #
Filter # (E) 939
Final Wt. 8.009
Tare Wt. .8058
Net Wt. .0049
Beaker #
MI
Desc.
Final Wt.
Tare Wt.
Net Wt.

Blank done 7/18/99

Acetone Blank Calculations:

Blank Beaker # 1
MI 50
Tare Wt. 65.4847
Final Wt. 65.4847
Net Wt. .0000

10000 g = 50 ml = 10000 g/ml

Particulate Catch Calculation

Filters:
Filter:
Beakers: Total Catch MI of Acetone
MI of Acetone (37)(.0000) = .0101
Filter:
Filter:
Total Catch = .0152

Unit: Kumar Noida Clinic
 Run # EPA 6
 Date: 9/17/1999
 Technician: DMJ
 MST6-Form1, Rev 8/96

MISCELLANEOUS TEST DATA
 WOODSTOVE DATA SHEET #8

Useable Firebox Dimensions: See QC Section Useable Volume: 2.228 ft³

Dilution Tunnel Draft (If applicable): Start 00.0 Stop 00.0

Test Chamber Air Velocity: Start: 00.0 Stop: 00.0 Avg: 00.0

Wet Bulb/Start: WB: 45 ° F DB: 74 or 1.8% Amb Moisture 61 %RH
 Dry Bulb Stop: WB: 65 ° F DB: 77 or 1.65% Amb Moisture 52 %RH

Empty Stove Wt: 419.3 lbs.
 Stove Wt with Stack (Inc. Oil Seal) Wt: 510.8 lbs. Dry: 509.9 lbs.
 Empty Stove Wt with Stack and Ash: — lbs. Total: — lbs.

Kindling Wt. Paper: 0.7 lbs. Wood: 5.6 lbs. Total: 6.3 lbs.

Pre Burn Fuel Wt. 15.2 + 15.5 + 16.4 lbs. Total: 47.1 lbs.

Total Kindling and Pre Burn Fuel Wt. 53.4 lbs.

Coal Bed Wt-lbs: Range (53.5 - 52.9) 3.6 - 3.0 lbs. Actual: 3.0 lbs.

Allowable Amount of Charcoal that can be removed: 3.6 lbs. + 3.0 lbs. = 6.6 lbs.

Coal Bed Wt. Range: Upper Wt. 3.6 lbs. Lower Wt. 3.0 lbs. = 0.6 lbs.

Test Fuel Wt-lbs: Ideal 15.6 lbs. Range: 17.1 - 14.1 lbs. Actual: 14.7 lbs.

Test Fuel Size (pcs.) (.75 x 1.5 x 5" Flanges) 16 pcs.

2 x 4' s x 15 9/16 " 3 pcs 6.3 lbs. 42.9 %
 4 x 4' s x 15 9/16 " 2 pcs 8.4 lbs. 57.1 %

Est. Dry Burn Rate (Kg/Hr.) 14.7 - (14.7 x .17790) x 60 = 3.0174
 Est. Dry Burn Rate (Kg/Hr.) 2.2046

Est EPA Heat Output (HO_E) (19,140) x 63 = 3.0174 x 36,385
 Est Heat Output (HO_E) BTU's/Hr

Comments:

Stove Operating Data

Woodstove Test Data Sheet #9

Cold Start - High Burn

Fire Started: OSHT POST

Unit: Kama Wood Classic

Run: EPA 6

Date: 9/17/94

Technician(s): AMM JSP

Data Sheet #9 - Rev 1/98-Pg.5

Warm up and Preburn: Primary Air: Wide open from ignition until the start of the test. At the run setting of wide open until the start of the test. High burn.

Secondary Air: No cond. Naturally drafted.

Secondary Burn/Cat Bypass: N/A

Charcoal Bed Preparation: Broke up, raked and leveled the coal bed prior to the addition of each warm up/pre burn fuel charge. Starting 1:30 before the start of the test, broke up, raked and leveled the coal bed. In stove for 35 seconds.

Test: Door wide open during loading 54 min _____ sec, then closed.

Primary Air: Wide open from the start of the test (0:00) until the end of the test. High Burn.

Secondary Air: No cond. N. naturally drafted.

Secondary Burn/Cat Bypass: N/A

Fan: ON/OFF during the warm up, ON/OFF high during the preburn, ON/OFF at the start of the test, ON/OFF for the first 1:00 minutes of the test, ON/OFF high at 1:00 minutes into the test, ON/OFF for the rest of the test.

Test Run Anomalies:

Burn Rate was a fewer than expected.

WOODSTOVE OPERATING DATA
 WOODSTOVE DATA SHEET #9A-1

Wood Data: Kindling: A mix of the below grades

Species	Grade	Mill	Size
D.F. SFC Gen	#2 Better	CANYON LUMBER	2X4
D.F. SFC Gen	#2 Better	CANYON LUMBER	2X4
D.F. SFC Gen	#1	RI.B. CONST.	4X4

Warm up Information:

1st Warm up/Pre Burn Fuel charge (lbs) added at 0616	15.2
2nd Warm up/Pre Burn Fuel charge (lbs) added at 0715	15.5
3rd Warm up/Pre Burn Fuel charge (lbs) added at 0815	16.4
4th Warm up/Pre Burn Fuel charge (lbs) added at	
5th Warm up/Pre Burn Fuel charge (lbs) added at	
6th Warm up/Pre Burn Fuel charge (lbs) added at	
7th Warm up/Pre Burn Fuel charge (lbs) added at	
8th Warm up/Pre Burn Fuel charge (lbs) added at	


All grades WCLB Rules unless otherwise noted.

The coals were scooped out of the stove immediately prior to adding the 3rd pre burn/warm up fuel charge. The stove lost 9 lbs. 3.5 lbs. of coals were put back in the stove after the 3rd pre burn/warm up fuel pieces were added.


All pre burn/warm up fuel pieces were 16" inches long. All preburn pieces/fuel charges were "ricked" in the stove. The pieces in the bottom layer in each rick contained 2 pcs that were 16 inches long and were loaded flat and perpendicular to the door. The pieces in the second layer in each rick were loaded on their side (edge) approximately parallel to the door and contained 4 pcs 16 inches long. The third layer (and fourth layer if present) was loaded flat, perpendicular to the door and contained 3 pcs 16 inches long. The majority of the pieces in each rick were in the second layer which had an approximate 0.5-1.0" space between pieces. (The loading directions indicate the direction of the longest dimension on each piece relative to the loading door opening.) Each pre burn/warm up fuel charge normally weighs within the weight range allowed for the actual test fuel charge.

Warm up Information (cont.):

Each warm up/preburn fuel charge was ricked in exactly (as much as possible) the same manner and the weight of each rick was usually within the allowable weight range for the test fuel charge. The physical arrangement and alignment of each rick was designed to accomplish three (3) things: (1) The bottom layer was nestled firmly into the coal bed and was as close to being level with the bottom of the stove as possible, thus providing a stable loading platform for the rest of the rick, keeping it in a ricked state (as opposed to a collapsed or fallen down state) until the rick reached the charcoal stage and sags or collapses of its own accord. (2) It enhances the flow of primary air through the ricked preburn fuel charge, for the primary air would flow through the spaces between the pieces in the first layer and then up through the spaces between the pieces in the second, third and, if present, fourth layers. (3) It maximized, as much as possible, the surface to volume ratio of each preburn fuel charge, thereby allowing the fire immediate access to as much wood surface as possible and, thereby, insuring uniform charcoalization. All three of these enhance combustion and so get the stove as hot as possible during the warm up period, thereby maximizing the amount of heat (BTU's) stored in the stove. The actual preburn was not started until the stove surface temperatures had maximized and stabilized, thus indicating that the amount of heat stored in the stove had peaked. For this stove, the thermal storage was monitored using the 100 surface temperature(s) and the peak value(s) of 950 obtained were _____ of.



Front View



Top View

The arrows indicate the direction of the air flow through the rick.

The primary air was adjusted to the run setting of Wide Open 53.4 lbs above the upper charcoal bed weight.

Unit: Kumar Wood Classic
 Run # 6
 Date 9/17/99
 Technician AM
 Page 3 of 3

Additional Comments:

- ① Turned Fan off
- ② Opened Door
- ③ Loaded test fuel charge
- ④ Cleared cond. away from LPHO
- ⑤ Puff
- ⑥ Closed door

Test Start Sequence:

Total Elapsed Time: 0154

Test Fuel Charge Loading Information:

Test Fuel Charge and Loading Sequence Diagram

of stove view


FRONT

4 X 4's: 3 #5

2 X 4's: 1, 2 #4

Loading Sequence: 1, 2, 3, 4 AND then 5

Driest Pcs in Load #4, 3



Loaded the test fuel charge on an essentially level, Medium

sized, hot coal bed (in appearance, color and temperature

for a high burn rate. Lmao 0154 Duration 0133

0150 VC to buffer Fan on High @ 7:00.
 1:30 Flames / ends Forward post front tube.
 1:40 Front Tube igniting, firebox engulfed in flames.
 2:58 17/14.1

11:00	15.9 / 1.58	15.7 / 1.55	12:00	15.7 / 1.55
10:00	16.0 / 1.61	13:00	16.0 / 1.58	13:00
9:00	16.0 / 1.55	14:00	16.0 / 1.41	14:00
8:00	16.2 / 1.45	15:00	15.9 / 1.94	15:00
7:00	16.4 / 1.37	16:00	16.0 / 1.77	16:00
6:00	16.4% CO ₂ / 1.35% CO	17:00	16.0 / 1.77	17:00
5:00	16.4% CO ₂ / 1.35% CO	18:00	15.9 / 1.86	18:00
4:00	16.4% CO ₂ / 1.35% CO	19:00	15.9 / 1.94	19:00
3:00	16.4% CO ₂ / 1.35% CO	20:00	14.2 / 1.22	20:00

CO Peak 0.95%

Unit: Kuma Woodburne
 Run: EPA 6
 Date: 9/21/1999
 Technician: MIM DLS JPH
 MS11-Form7-R&V11/89

FUEL MOISTURE
 WOODSTOVE TEST DATA SHEET #10

Room Temperature: 62 of Correction Factor: +1

NOTE: Record readings to the nearest 0.5% moisture

Uncor Values are corrected for temperature: Yes No

Time Test Fuel Moisture Readings taken at: 0750

Calibration Checks: X - Y - 12.5 12.0 22.0 22.6

#	Dimen	Use	Top			Bottom			Side			Piece Avg
			Uncor	Cor	Moist	Uncor	Cor	Moist	Uncor	Cor	Moist	

1	24x8'	K	11.5	12.3	11.0	11.7	11.0	11.7	11.7	11.7	11.9	11.9
2												
3												
4	24x8'	P	18.5	19.8	19.5	20.9	18.0	20.5	20.0	20.0	20.9	20.9
5	"		18.5	19.8	18.5	19.8	18.0	19.8	19.8	19.8	19.6	19.6
6	"		19.5	20.9	19.5	20.9	20.0	20.0	20.0	20.0	20.9	20.9
7	"	↑	18.5	19.8	20.5	22.0	23.0	23.0	24.9	24.9	24.9	24.9
8												83.800
9												
10	24x15 9/16"	T	18.0	19.2	18.5	19.8	18.0	19.8	19.8	19.8	19.4	19.4
11	"		21.0	22.6	20.5	22.0	19.5	20.9	20.9	20.9	20.9	20.9
12	"	↓	23.0	24.9	21.5	23.1	21.5	23.1	23.1	23.1	23.7	23.7
13												
14	44x15 15/16"	T	18.0	19.2	19.5	20.9	20.0	21.4	21.4	21.4	20.5	20.5
15	"	↓	21.0	22.6	21.0	22.6	21.5	23.1	23.1	23.1	23.7	23.7
16												108.500
17												
18												
19	51x15x15 Spacers		20.5	22.0	20.0	21.4	20.0	21.4	21.4	21.4	21.6	21.6
20												21.600

Kindling	Pretest Fuel	Test Load
11.908%	20.950%	21.640%
10.634%	17.328%	17.790%

To obtain Wet from Dry: $100 \times \frac{\% \text{ Dry Rdg.}}{\% \text{ Moisture, Wet Basis}} = 100 + \% \text{ Dry Rdg.}$

Acceptable Ranges: 16-20% wet; 19-25% dry (17.5 - 22.5 on Meter [Uncor reading] at 70°F)

Key for Use: K = Kindling P = Pretest Fuel T = Test Fuel

Unit: Kuma Wood Clinic
Run#: EPA 6
Date: 9/17/1999
Technician: ATW
MST12-form11-Rev 6/90

Wood Piece: Nominal Dimensions: $3\frac{1}{2}$ " x $3\frac{1}{2}$ " x $1\frac{1}{2}$ " in

Depth (D): in 1.523 cm 3.868
Width (W): in 3.548 cm 9.012
Length (L): in 3.248 cm 8.225

Length (L):
3.248
3.240
3.244
3.220
in

Volume: $\frac{(D \times W \times L)}{\text{cm}^3}$ 286.710

MOISTURE: Room Temperature: 69 °F Of Correction Factor: 0

Uncorrected Meter Readings Corrected for temperature: Yes No

NOTE: Record moisture meter readings to the nearest 0.5%

Avg % Moisture (Dry) 24.100 %

Avg % Moisture (Wet) 19.420 %

Uncor	Cor
23.0	24.9
22.5	24.3
21.5	23.1
24.100	24.100

Top: 23.0 %
Bottom: 22.5 %
Side: 21.5 %
X: 24.100 %

Wet Weight: 178.5 g Dry Weight: 150.7 g
% Moisture Dried Basis: $\frac{150.7}{178.5} \times 100 = 15.574\%$

Date: 9/17/99
Time: 0800
Temp: 21.3 °F

Into Dryer: 9/17/99
Out of Dryer: 9/22/99
Minimum Time in Dryer: 24 hrs. Minimum Dryer Temp 100°C (212°F)

Density = $\frac{150.7 \text{ g (dry wt)}}{286.710 \text{ cm}^3 \text{ (volume)}} = 0.5256 \text{ g/cm}^3$

Pellet Fuel Moisture Content Determination

Tare Beaker Wt. _____ g
Gross Wet Wt. _____ g
Tare Beaker Wt. _____ g
Net Wet Wt. _____ g

Dry Wt.: _____ g
Gross Dry Wt. _____ g
Tare Beaker Wt. _____ g
Net Dry Wt. _____ g

% Moisture Dried Basis: $\frac{[1 - (\text{Net Dry Wt} / \text{Net Wet Wt.})] \times 100}{\%}$

END Wt: 512.9 lbs.

Unit: Levin's Wood Classic Date: 9/17/19
 Run: EPA 4 or 1 Technician(s): AK
 Page: 1 of 1

Minute	Scale Wt	lbs Left	Burn Rate	CO ₂		O ₂		Tel	v.	CO		Wet Bulb	Dry Bulb	RH	T/C(3)		SO ₂ PPM	Static Press.	Comments	
				v.	%CO ₂	v.	%O ₂			%CO	Bal				Calc W/B	Stack				
0	512.9	14.7	0	394	8.03	48.8	18.19													
5	512.6	13.7	1.0	628	15.53	17.6	44.0	5.8	0.30	26.8	85	139	22	126	478					
10	505.1	12.2	1.5	644	15.92	17.6	44.0	4.6	0.24	24.7	102	150	52	140	435					
15	503.8	10.9	1.3	634	15.62	17.9	44.2	9.0	0.46	34.6	126	169	12	151	629					
20	503.4	9.5	1.4	635	15.70	17.7	44.2	10.4	0.53	39.6	132	169	16	156	682					
25	501.1	8.2	1.3	648	16.02	16.9	44.3	12.0	0.86	48.3	133	171	16.5	157	696					
30	515.4	7.0	1.2	617	15.26	18.6	46.5	4.3	0.22	22.8	131	170	15	155	699					
35	518.5	5.9	1.1	637	15.75	17.7	44.2	3.3	0.18	18.8	130	170	14	154	680					
40	517.8	4.9	1.0	591	14.61	22.6	51.5	6.1	0.31	30.8	128	171	12	151	685					
45	516.9	4.0	1.9	568	14.05	27.5	61.2	1.4	0.08	12.3	124	168	12	151	654					
50	516.1	3.3	1.2	512	12.62	29.7	74.2	1.1	0.07	20.7	122	163	11	149	640					
55	515.6	2.7	1.6	441	10.92	36.2	90.4	1.0	0.06	21.1	119	160	9.5	145	613					
60	515.1	2.2	1.5	393	9.73	41.1	102.2	1.0	0.06	18.9	114	155	9.3	143	580					
65	514.6	1.7	1.5	372	9.34	43.2	107.9	1.9	0.11	88.5	108	149	7.0	138	543					
70	514.3	1.4	1.3	341	8.45	46.5	116.2	2.0	0.11	84.9	104	145	5.8	134	522					
75	514.1	1.2	1.2	258	6.41	54.6	136.4	2.7	0.15	56.3	99	140	4.9	132	502					
80	513.9	1.0	1.2	252	6.26	55.1	137.6	4.9	0.25	25.6	95	135	4.2	130	475					
85	513.7	0.8	1.2	252	6.26	55.4	138.4	7.1	0.37	16.9	90	132	3.5	127	459					
90	513.4	0.7	1.1	234	5.81	57.6	143.9	8.7	0.45	13.9	82	130	2.9	124	449					
95	513.4	0.5	1.2	214	5.32	59.5	148.6	9.2	0.50	11.6	85	128	2.6	123	440					
100	513.2	0.3	1.2	203	5.05	60.3	150.6	12.9	0.65	8.5	84	126	2.4	121	426					
105	513.1	0.2	1.1	202	5.02	60.1	150.1	14.4	0.72	7.0	83	124	2.3	121	416					
110	512.9	0.2	1.2	205	5.10	60.0	149.9	14.6	0.74	6.8	82	122	2.2	120	408					
115	512.9	0.2	1.2	205	5.10	60.0	149.9	13.7	0.69	7.4	82	122	2.3	120	405					
120	512.9	0.2	1.2	205	5.10	60.0	149.9	13.7	0.69	7.4	82	122	2.3	120	405					

SO₂ 505.0
 12.25
 551.3
 73.7
 1773
 11.12

1.36 FLOW

Pre Burn Stair Wt. PRE BURN DATA
 lbs/lp lbs. RECORD SHEET #13
 Test Stair Wt. Range WST2-Form16

BHPD
 PRESSURE 1109
 98.105

Unit: Keating Wood Chime Date: 9/12/1991
 Run: EPA 4 Technician(s): ATN
 Page: 1 of 1

Hot Box ON

Minute	Scale Weight	Burn Rate	Stack	Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn	Room Temp	Static	Comments
0	529.4	0	439	501	670	412	662	579	841	1328	69	-080	Primary Air Set at 100%
5	531.6	1.8	641	742	648	426	636	576	803	1402	69	-091	Secondary Air Set at 1/4
10	535.2	2.4	669	815	623	392	611	572	814	1512	69	-092	Ran: ON 11/5/11
15	532.8	2.4	686	908	612	386	602	502	832	1626	69	-091	TUNNEL ON AT 100%
20	528.8	2.0	710	910	624	378	618	489	922	1722	69	-092	Buckets IN 1/2
25	521.8	2.0	709	902	646	379	639	486	1011	1795	69	-090	APPLYZERS SPINNED
30	517.0	1.8	700	905	675	372	668	483	1114	1770	70	-096	Pumps turned on at: 0850
35	515.2	1.7	665	885	705	375	701	478	1149	1668	70	-085	AT
40	514.9	1.3	664	734	733	386	736	469	1164	1405	69	-078	Probe IN
45	514.9	1.3	584	734	736	380	736	468	1024	1492	70	-078	Check WB/DB: 86/101
50	514.6	1.3	573	720	729	373	725	461	1052	1593	68	-072	601.6
55	514.3	1.3	541	664	715	364	712	454	1042	1365	69	-075	581.8
60	514.0	1.3	523	620	700	359	695	448	1026	1319	67	-075	Probe IN Turn: 1
65	513.8	1.2	512	600	686	355	682	449	1013	1253	67	-075	55.44
70	513.5	1.3	571	585	672	350	670	453	999	1222	66	-073	549.0
75	513.3	1.2	496	573	669	348	661	456	989	1245	66	-071	541.4
80	513.1	1.2	484	550	662	344	652	458	961	1204	66	-071	536.0
85	512.9	1.2	478	532	655	340	643	455	950	1210	66	-070	536.0

TEMPERATURES
RECORD SHEET #14
WS12-Form14 Rev7/96

Unit: Kennel Wood Cleaning Date: 9/17/19
 Run: EPA Technician(s):
 Page: 1 of 1 ATM STP DTS

T/C#	Minute	Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn	Room Temp	Tunnel	C. Gas Box	Impinger Out	5G-1 Filter	5G-1 Condenser	Hot Air
0	0440	537	655	340	643	455	950	1410	66	121	249	37	78	56	1061
5	45	593	640	345	627	458	906	1192	67	139	250	38	79	35	1215
10	50	797	635	335	608	454	979	1596	67	149	250	39	82	35	1370
15	55	839	644	332	606	458	976	1596	68	153	250	39	85	35	1376
20	0000	857	655	332	611	450	1022	1521	67	154	250	39	86	35	1322
25	05	857	667	335	618	448	1084	1416	68	155	249	39	87	35	1436
30	10	849	684	340	628	446	1093	1394	69	154	248	39	88	35	1443
35	15	856	696	352	637	444	1104	1368	69	153	250	39	88	35	1496
40	20	826	706	368	650	440	1121	1363	69	150	250	40	88	35	1413
45	25	808	715	383	658	439	1135	1352	69	148	250	39	88	35	1338
50	30	710	720	382	670	441	1139	1329	69	144	250	38	87	35	1321
55	35	726	720	382	684	441	1126	1302	69	139	249	38	87	35	1336
60	40	717	715	392	689	442	1132	1254	69	135	248	38	86	35	1321
65	45	628	710	408	693	441	1122	1230	70	131	248	38	85	35	1321
70	50	595	703	421	690	442	1110	1241	69	128	249	38	84	36	1297
75	55	556	694	422	682	448	1073	1159	69	124	249	38	84	36	1292
80	0000	522	681	422	662	452	1050	1114	69	122	250	38	83	35	1197
85	05	509	662	413	654	460	1012	1105	70	120	249	38	81	35	1119
90	10	456	654	423	642	463	984	1080	70	119	249	38	80	36	1061
95	15	471	640	390	629	466	952	1051	70	112	249	38	79	36	1124
100	20	456	622	372	616	462	939	1026	70	116	249	38	79	36	1011
105	25	442	612	366	603	465	919	1004	71	115	248	39	79	36	999
110	30	438	605	361	592	465	914	1008	71	114	249	39	79	36	991
115	35	571	608	385	612	5016	1122	1022	71	114	249	39	79	36	991
116	35	571	608	385	612	5016	1122	1022	71	114	249	39	79	36	991

Stop! 571/1
 Stop! 493
39.8 ✓

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-1

Site: Myren Consulting, Woodinville, WA Date: 9/12/99 Analyte: CO₂

Source: Kura Wood Classic Run #: EPA 6

Zero Cyl #: 719 430 conc. 00.0% CO₂ Cyl Press: 1830 psi

Certified by: Oxarc Date: 4/1/99

Span Cyl #: 350-794 conc. 12.5% CO₂ Cyl Press: 1310 psi

Certified by: Oxarc Date: 3/26/99

Analyzer: Make: Horiba Model: PIR-2000 SN: 607024

Range: 0 - 25.0% CO₂ Analyzer Output: 0 - 1.0 v.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter:

EPA Span Value = 25.0% CO₂
EPA Control Limits = + 2.5% of 25.0% CO₂ = + 0.625% CO₂

Pre Run Audit: By: RLS Time: 0845 Temp: 70

Audit Results

Point #	Expected Response		Actual Response		+ Conc. Difference %
	Meter	DVM	Meter	DVM	
Zero	00.0	.000	00.0	.000	+0.18
Span	50.0	.500	49.5	.494	-2.21

Comments:

Post Run Audit: By: RLS Time: 1135 Temp: 71

Audit Results

Point #	Expected Response		Actual Response		+ Conc. Difference %
	Meter	DVM	Meter	DVM	
Zero	00.0	.000	00.0	.000	+0.18
Span	50.0	.500	49.5	.493	-2.11

Comments:

+ Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = Act % (ppm) - Exp % (ppm) x 100
 Full Scale Value
 Span % Difference = Act % (ppm) - Exp % (ppm) x 100
 Exp % (ppm)

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-2

Site: Myren Consulting, Woodinville, WA Date: 9/17/99 Analyte: O₂

Source: Run # EPA 6

Zero Cyl #: 719 430
 Certified by: O'Keefe
 Date: 4/1/99
 Cyl Press: 1830 psf
 Conc: 00.0 % O₂

Span Cyl #: 250-794
 Certified by: O'Keefe
 Date: 3/28/99
 Cyl Press: 1310 psf
 Conc: 12.5 % O₂

Analyzer: Make: Taylor Model: OA 137 SN: 137/4772

Range: 0 - 25.0% O₂ Analyzer Output: 0 - 100 mv.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter:

EPA Span Value = 25.0% O₂
 EPA Control Limits = + 2.5% of 25.0% O₂ = + 0.625% O₂

Pre Run Audit: By: RLS Time: 0845 Temp: 70 of

Audit Results

Point #	Expected Response		Actual Response		+ Conc. Difference	Δ %
	Meter	DVM	Meter	DVM		
Zero	00.0	00.0	00.0	00.0	+0.0050	+0.02
Span	12.5	50.0	12.5	49.6	12.3909 - .1091	-0.87

Comments:

Post Run Audit: By: RLS Time: 1135 Temp: 71 of

Audit Results

Point #	Expected Response		Actual Response		+ Conc. Difference	Δ %
	Meter	DVM	Meter	DVM		
Zero	00.0	00.0	00.0	00.0	+0.0050	+0.02
Span	12.5	50.0	12.5	49.6	12.3909 - .1091	-0.87

Comments:

+ Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = Act % (ppm) - Exp % (ppm) X 100
 Full Scale Value
 Span % Difference = Act % (ppm) - Exp % (ppm) X 100
 Exp % (ppm)

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-3

Site: Myren Consulting, Woodinville, WA Date: 3/27/99 Analyte: CO

Source: Kump 1/201 Chicago Run #: EPA 6

Zero Cyl #: 719 430 conc. 00.0 % CO Cyl Press: 1830 psi

Certified by: OXARC Date: 3/11/99

Span Cyl #: 250-794 conc. 2.5 % CO Cyl Press: 1310 psi

Certified by: OXARC Date: 3/26/99

Analyzer: Make: Infra Red Model: 702 D SN: 113

Range: 0 - 10.0% CO Analyzer Output: 0 - 100 mv.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter:

EPA Span Value = 5.0% CO
EPA Control Limits = +2.5% of 5.0% CO = + 0.125% CO

Pre Run Audit: By: RLS Time: 0845 Temp: 70 of

Audit Results

Point #	Expected Response		Actual Response		+ Conc. Difference %
	Meter	DVM	Meter	DVM	
Zero	00.0	00.0	00.0	00.0	-1.0093
Span	2.50	50.0	2.50	50.0	-1.0036

Comments:

Post Run Audit: By: RLS Time: 1135 Temp: 71 of

Audit Results

Point #	Expected Response		Actual Response		+ Conc. Difference %
	Meter	DVM	Meter	DVM	
Zero	00.0	00.0	00.0	00.1	-1.0093
Span	2.50	50.0	2.48	49.4	-1.0386

Comments:

+ Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Exp \% (ppm)}} \times 100$

Unit: Tunnel Wood Check
 Run: EPA 6
 Date: 9/13/19
 Technicians: ATM / JLS / J.P.
 MST6-Form3-Rev11/89

QUALITY CHECKS
 WOODSTOVE DATA SHEET #16

Ambient = Tr: _____ OF T/C#30: _____ OF

Thermocouple Check (at ambient): T/C#1: 62 OF; T/C#2: 62 OF;

T/C #3:	66	OF
T/C #4:	66	OF
T/C #5:	69	OF
T/C #6:	66	OF
T/C #7:	68	OF
T/C #8:	69	OF
T/C #9:	67	OF
T/C #10:	63	OF
T/C #11:	62	OF
T/C #12:	62	OF
T/C #13:	64	OF
T/C #14:	63	OF
T/C #15:	64	OF
T/C #16:	62	OF
T/C #17:	70	OF
T/C #18:	63	OF
T/C #19:	_____	OF
T/C #20:	_____	OF
T/C #21:	_____	OF
T/C #22:	_____	OF
T/C #23:	_____	OF
T/C #24:	_____	OF
T/C #25:	_____	OF
T/C #26:	_____	OF

Comments: _____

Thermocouple Readout: Pretest Zero/Span Check and Calibration:

Zero (0°F) : 001 OF to: _____ OF Post Test Check % Difference +0.05%

Span (2000°F): 1999 OF to: _____ OF Span (2000°F): 0000 OF to: _____ OF

(Allowable % Difference = 1.5%. Use formulas on Woodstove Data Sheet #15 to calculate % Difference)

Thermocouple Readout Pretest Linearity Check

0°F =	001	OF	200°F =	301	OF	400°F =	399	OF
600°F =	600	OF	800°F =	800	OF	1000°F =	1002	OF
1200°F =	1200	OF	1400°F =	1400	OF	1600°F =	1600	OF
1800°F =	1799	OF	2000°F =	1999	OF			

Combustion Gas (CO₂, CO) Train Leak Check: Pre Post

Draft (Static) Gauge Zero Check: Pre Post

Scale Check Pre (Wt, #'s): 516.9 - 511.9 = 5.0 / 5.0 = 0% AMM
 Post (Wt, #'s): 518.8 - 517.8 = 1.0 / 1.0 = 0% (25%)

Stack cleaned prior to the run: Yes _____ No

Tunnel cleaned prior to the run: Yes _____ No

METHOD 5G-1

PARTICULATE SAMPLING DATA

Kuma

LAB-

DATE 9/18/99

PAGE 1 OF 1

MODEL # Wood Classic

RUN # EPA 7

METER BOX # 511-M

METER Y 1.0151

FILTER # (F) 942 (R) 941

PRE TEST LEAK RATE = 1.0005 CFM @ -15.5 IN. HG 3023/1,803

FILTER SIZE: 110 mm

POST TEST LEAK RATE = .000 CFM @ -12.5 IN. HG 334/1,834

PROBE LENGTH 24" glass

TIME		METER READING CU. FT.	PITOT dp	TNL TEMP. (°F)	METER TEMP. (°F)	GAS METER dh	VAC IN. Hg	VELOCITY TRAVERSE			
CLOCK	ELAPSED							POINT	LOCATION	ΔP	TEMP
9:50	00	202.100	.044	125	79	.90	0	N-1	0.5"	.043	137
10:00	10	207.638	.043	162	80	.90	0	2	1.5"	.047	139
10	20	213.185	.043	166	82	.90	0	3	4.5"	.046	140
20	30	218.741	.043	160	84	.90	0	4	5.5"	.040	139
30	40	224.295	.043	154	86	.90	0	W-1	0.5"	.044	136
40	50	229.862	.043	143	87	.90	0	2	1.5"	.046	138
50	60	235.438	.043	138	88	.90	0	3	4.5"	.046	139
11:00	70	241.045	.043	131	89	.90	0	4	5.5"	.044	140
10	80	246.673	.043	127	90	.90	0	✓ Avg.	.0445	138.5	
12	82	247.799	.043	127	90	.90	0	✓		138.5	
	00							Pilot Leak Check			
	10							Pre <input checked="" type="checkbox"/> Post <input checked="" type="checkbox"/>			
	20							Cp = 0.99			
	30							N 1 2 → W 1 2 3* 3 4			
	40							* = point of Avg. delta p			
	50							$Q_s = \left(\frac{\sqrt{(\Delta P \times BP)}}{T(^{\circ}R)} \right) \times 3167.2 =$			
	60							146.154 cfm			
	70							BP = Start 28.64 in Hg			
	80							60 28.52			
	90							82 28.59			

X = 23.613

WOODSTOVE DATA SHEET #4-1: INITIAL FILTER WEIGHTS (TARE WEIGHTS)

Into Dessicator: Date 1/9/99 Time 1445 By ATM Front Half Back Half

Manufacturer: Schleicher & Schuell Size: 11cm Lot.No.: Z8951 Grade: #25 G/ASS
Order No: 06220

Filter #	First Wt	Date	Time	By	Second Wt	Date	Time	By	Third Wt	Date	Time	By
926	.7740	3/6/99	11:40	T.M.	.7739	3/15/99	1652	ATM				
927	.7938		11:41	T.M.	.7938		1651	ATM				
928	.7985		11:42	T.M.	.7985		1650	ATM				
929	.7909		11:43	T.M.	.7912		1649	ATM				
930	.7948		11:44	T.M.	.7950		1648	ATM				
931	.8041		11:45	T.M.	.8042		1647	ATM				
932	.7917		11:46	T.M.	.7918		1646	ATM				
933	.8047		11:47	T.M.	.8048		1645	ATM				
* 934	.7981		11:48	T.M.	.7918		1644	ATM	.7917	3/16/99	2130	Jm
935	.7861		11:49	T.M.	.7861		1643	ATM				
936	.7827		11:50	T.M.	.7828		1643	ATM				
937	.7935		11:51	T.M.	.7933		1642	ATM				
938	.8086		11:52	T.M.	.8084		1641	ATM				
939	.8060		11:53	T.M.	.8058		1640	ATM				
940	.8151		11:54	T.M.	.8151		1639	ATM				
941	.8252		11:55	T.M.	.8249		1638	ATM				
942	.7982		11:56	T.M.	.7983		1637	ATM				
943	.7822		11:57	T.M.	.7822		1636	ATM				
* 944	.7938		11:58	T.M.	.7968		1635	ATM	.7968	3/16/99	2131	Jm
945	.7944		11:59	T.M.	.7943		1635	ATM				
946	.7852		12:00	T.M.	.7850		1634	ATM				
947	.7731		12:01	T.M.	.7735		1633	ATM				
948	.7936		12:02	T.M.	.7940		1632	ATM				
949	.7838		12:03	T.M.	.7837		1631	ATM				
950	.8040		12:04	T.M.	.8038		1630	ATM				

Checked by Jm Myer Date: 3/16/99 Time 2133

QA REWEIGH

Filter #	WT	Date	Time	By
929	.7912	3/16/99	2136	Jm
941	.8248	3/16/99	2134	Jm
949	.7837	3/16/99	2133	Jm

BALANCE ROOM ENVIRONMENTAL CONDITIONS

WB	DB	%RH	Date	Time	By
64	79	43	3/16/99	1135	ATM
66	81	45	3/15/99	1622	ATM
65	82	39	3/16/99	2025	ATM

Post Test Weighing Session Scale Check

	1 st	2 nd	3 rd	QC
0.0000	0.0000	0.0000	0.0001	
1.0000	1.0000	1.0000	0.9999	

WOODSTOVE DATA SHEET #4-2:
INITIAL BEAKER WEIGHTS (TARE WEIGHTS)

Into Dessicator: Date: 8/20/99 Time: 1500 By: A. Timmyren

Glass

Beaker #	First Wt	Date	Time	By	Second Wt	Date	Time	By	Third Wt	Date	Time	By
1	65.4841	8/27	2059	SM	65.4835	8/30/99	1211	ATM				
2	66.1509	8/27	2118	SM	66.1514		1204	ATM				
3	67.8582		2116	SM	67.8578		1207	ATM				
4	67.5890		2108	SM	67.5891		1210	ATM				
6	67.4270		2119	SM	67.4274		1213	ATM				
7	65.5444		2105	SM	65.5446		1220	ATM				
8	66.0219		2221	SM	66.0218		205	ATM				
9	66.9297		2120	SM	66.9296		1215	ATM				
10	66.0906		2114	SM	66.0902		1209	ATM				
11	65.7072		2112	SM	65.7020		1217	ATM	65.7028	9/8/99	1717	SM
13	57.8946	✓	2110	SM	57.8948	✓	1218	ATM				
									65.7021	9/11	1232	ATM
									65.7022	9/13	1934	SM
20	73.3159	8/27	2125	SM	73.3160	8/31/99	1320	ATM				
21	71.0002	8/27	2126	SM	71.0003	✓	1325	ATM				
22	71.8322	9/11/99	1240	ATM	71.8322	9/13	1719	SM				
23	70.7376	8/27	2131	SM	70.7382	8/30/99	1259	ATM	70.7376	9/8	1715	SM
24	73.2173	8/27	2130	SM	73.2182		1301	ATM	73.2176	9/8	1713	SM
25					72.6505	✓	1257	ATM	72.6504	9/8	1716	SM
26	71.7865	8/27	2132	SM	71.7868	8/31/99	1322	ATM				
27	72.3294	9/11/99	1235	ATM	72.3294	9/8	1718	SM				
28	70.5955	8/27	2127	SM	70.5956	8/31/99	1324	ATM				
29	71.5183	8/27	2133	SM	71.5185	✓	1318	ATM				
30	70.7845	8/27	2128	SM	70.7855	8/30/99	1302	ATM	70.7857	9/8	1714	SM
31	69.6652	8/27	2129	SM	69.6655	8/31/99	1327	ATM				
23	70.7375	9/11	1233	ATM								
24	73.2175	9/11	1242	ATM								

SS

cont. 23
cont. 24

Checked By: A. Timmyren Date: 9/11/13/99 Time: ATM

QA REWEIGH

Beaker #	WT	Date	Time	By

BALANCE ROOM ENVIRONMENTAL CONDITIONS

WB	DB	ZRH	Date	Time	By
68	83	46	8/27/99	2052	ATM
67	81	43	8/30/99	1154	ATM
63	76	48	8/31/99	1310	ATM
70	84	47	9/8/99	1705	ATM
69	84	46	9/11/99	1202	ATM
24	77	49	9/13/99	1926	ATM

WOODSTOVE DATA SHEET #4-2:
INITIAL BEAKER WEIGHTS (TARE WEIGHTS)

Into Dessicator: Date: 6/1/99 Time: 1700 By: A.T. Myrum

Beaker #	First Wt	Date	Time	By	Second Wt	Date	Time	By	Third Wt	Date	Time	By
1	65.4947	7/17/99	1636	OBT	65.4847	7/18/99	1612	ATM	← B	LAN	K	
2	66.1574		1638	OBT	66.1506		1614	ATM	7/13/99			
3	67.8572		1640	OBT	67.8567		1616	ATM				
4	67.5887		1642	OBT	67.5880		1618	ATM				
6	67.4268		1644	OBT	67.4266		1620	ATM				
7	65.5436		1648	OBT	65.5437		1622	ATM				
8	66.0212		1650	OBT	66.0211		1623	ATM				
9	66.6299		1652	OBT	66.6295		1625	ATM				
10	66.0889		1654	OBT	66.0888		1627	ATM				
11	65.7015		1656	OBT	65.7013		1628	ATM				
12	56.0655		1658	OBT	56.0653		1632	ATM				
13	57.8948		1700	OBT	57.8944		1630	ATM				

11111111111

Checked By: A.T. Myrum Date: 7/18/99 Time: 1800

QA RECEIPT

BALANCE ROOM ENVIRONMENTAL CONDITIONS

Beaker #	WT	Date	Time	By

WB	DB	TRH	Date	Time	By
65	78	49	7/17/99	1825	ATM
63	77	45	7/18/99	1604	ATM

WOODSTOVE DATA SHEET #4-3: CONSTANT FINAL WEIGHTS

Blank
7/18/99

WST5-Form 9, PGI, Rev 4/90
Unit Kamin Wood Stove
Run #
Date: 7/1/99

FINAL BEAKER WEIGHTS

Beaker #	Into Dessic	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By
1	✓	7/21/99	1435	ATM	65,4852	8/4/99	1715	ATM	65,4846	8/8/99	1742	0611	65,4847	8/9	1642	ATM

FINAL FILTER WEIGHTS

Filter #	Into Dessic	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By

QA REWEIGH: FINAL WEIGHTS

Date	Beaker #	Final Wt	By

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighing Session	Date	Time	By	WB	DB	ZRH
1	8/4	1705	ATM	69	83	49
2	8/8	1700	ATM	64	78	46
3	8/9	1615	ATM	69	84	46
4						
5						

SCALE ROOM ENVIRONMENTAL CONDITIONS

6					
7					
8					
9					
Comments					

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale Mettler
Model AE100
SN K04827

Dates From 1/19/99
Through 7/17/99

Level	Recall- brated	100g Weight	10g Weight	1.0g Weight	100mg Weight	20mg Weight	Date	Time	Tech	Wet Bulb	Dry Bulb	% RH
✓	Yes	99.9999	10.0001	1.0002	.1003	.0203	1/19/99	1243	ATM	58	70	48
✓	No	100.0002	10.0000	1.0000	.1000	.0200	1/14/99	1113	ATM	62	75	47
✓	Yes	99.9998	10.0002	1.0000	.0999	.0201	1/23/99	1100	ATM	63	77	48
✓	Yes	99.9996	10.0002	1.0000	.1000	.0201	1/24/99	1318	ATM	59	74	45
✓	Yes	99.9997	10.0001	1.0001	.1002	.0200	2/1/99	0910	ATM	55	69	39
✓	Yes	99.9999	10.0001	1.0001	.1001	.0200	2/2/99	0939	ATM	60	73	46
✓	Yes	99.9999	10.0000	1.0001	.1001	.0201	2/2/99	1355	ATM	63	76	48
✓	Yes	99.9998	10.0000	1.0000	.1000	.0200	2/7/99	1235	ATM	62	76	45
✓	Yes	99.9998	10.0000	1.0000	.1000	.0200	2/10/99	1600	ATM	63	77	45
✓	Yes	99.9998	10.0000	1.0001	.1000	.0200	2/19/99	0246	ATM	64	78	46
✓	No	99.9999	10.0000	1.0000	.1000	.0200	2/21/99	1312	ATM	65	80	44
✓	No	99.9997	10.0000	1.0001	.1000	.0200	3/5/99	1435	ATM	64	80	44
✓	Yes	99.9997	10.0000	1.0000	.1001	.0200	3/6/99	1135	ATM	64	79	43
✓	Yes	99.9997	10.0000	1.0001	.1000	.0200	3/13/99	1520	ATM	65	80	44
✓	Yes	99.9997	10.0001	1.0001	.1000	.0200	3/14/99	1355	ATM	63	78	43
✓	No	100.0001	10.0000	1.0000	.1000	.0200	3/15/99	1622	ATM	66	81	45
✓	Yes	99.9997	10.0000	1.0001	.1000	.0200	3/16/99	2025	ATM	65	82	39
✓	Yes	99.9996	10.0000	1.0001	.1001	.0200	3/17/99	1615	ATM	62	77	42
✓	Yes	99.9997	10.0000	1.0001	.1000	.0200	3/18/99	2140	ATM	68	84	43
✓	Yes	99.9998	10.0000	1.0000	.1000	.0200	3/20/99	1300	ATM	64	84	32
✓	No	99.9999	10.0000	1.0001	.1001	.0201	3/21/99	2215	ATM	61	74	47
✓	Yes	99.9997	10.0000	1.0000	.1001	.0200	3/22/99	0122	ATM	65	83	33
✓	Yes	99.9997	10.0000	1.0001	.1000	.0200	3/23/99	1115	ATM	69	87	46
✓	Yes	99.9997	10.0000	1.0002	.1001	.0201	3/24/99	1120	ATM	72	89	43
✓	Yes	99.9999	10.0000	1.0002	.1001	.0201	3/29/99	2038	ATM	72	89	45
✓	No	99.9999	10.0002	1.0002	.1001	.0202	3/30/99	0610	ATM	66	80	47
✓	No	99.9999	10.0000	1.0000	.1001	.0201	3/31/99	1200	Sum	67	80	41
✓	No	99.9996	10.0000	1.0000	.1001	.0201	4/5/99	1730	ATM	64	80	41
✓	Yes	99.9997	10.0001	1.0001	.1001	.0201	4/6/99	1030	ATM	61	75	44
QC Services	Audit	4/6/97	- wt. / Scale check	9/17/97	Scale Audit							
✓	No	100.0003	10.0001	1.0001	.1001	.0201	4/6/99	1730	ATM	65	85	33
✓	Yes	99.9998	10.0001	1.0001	.1001	.0200	4/7/99	1724	ATM	67	80	50
✓	No	99.9996	10.0000	1.0001	.1001	.0201	4/8/99	1346	ATM	66	84	50
✓	Yes	99.9997	10.0000	1.0000	.1000	.0200	4/16/99	1230	ATM	66	84	43
✓	Yes	99.9997	10.0000	1.0000	.1000	.0200	4/17/99	1625	ATM	68	84	45
✓	No	99.9996	10.0000	1.0000	.0999	.0198	4/19/99	1050	ATM	72	72	45
✓	Yes	99.9996	10.0001	1.0002	.1001	.0202	5/17/99	1825	ATM	65	78	49

WOODSTOVE DATA SHEET #4-4

SCALE QA SHEET

Dates From 7/10/99

Through 9/16/99

Scale Mettler

Model AE100

SN K04827

Level	Recali- brated	100g Weight	10g Weight	1.0g Weight	100mg Weight	20mg Weight	Date	Time	Tech	Wet Bulb	Dry Bulb	% RH
✓	No	99.9996	10.0000	1.0001	.1000	.0201	7/10/99	16:04	ATM	63	77	45
✓	Yes	99.9997	10.0000	1.0001	.1001	.0201	7/19/99	18:35	ATM	64	77	49
✓	Yes	99.9996	10.0000	1.0003	.1002	.0202	7/20/99	18:59	ATM	71	85	80
✓	Yes P.O.	99.9997	10.0001	1.0001	.1001	.0201	7/21/99	13:06	ATM	69	84	50
✓	Yes	99.9996	9.9999	1.0000	.1000	.0200	7/22/99	2:45	ATM	64	80	41
✓	No	99.9996	10.0000	1.0000	.1000	.0200	7/23/99	07:45	ATM	62	76	45
✓	Yes P.O.	99.9998	10.0000	1.0000	.1000	.0200	7/24/99	13:40	ATM	66	80	47
✓	Yes	99.9998	10.0001	1.0002	.1000	.0201	8/3/99	2:17	ATM	70	84	47
✓	No	99.9998	10.0001	1.0001	.1000	.0201	8/4/99	17:05	ATM	69	83	49
✓	Yes	99.9998	10.0000	1.0001	.1000	.0200	8/5/99	2:06	ATM	65	78	49
✓	No	99.9998	10.0000	1.0000	.1000	.0200	8/6/99	15:36	ATM	68	81	50
✓	Yes	99.9999	10.0000	1.0001	.1000	.0200	8/7/99	15:15	ATM	66	80	47
✓	Yes	99.9996	10.0001	1.0002	.1001	.0201	8/8/99	17:00	ATM	64	73	46
✓	Yes	99.9997	10.0000	1.0001	.1000	.0200	8/9/99	12:25	ATM	68	82	46
✓	No	99.9997	10.0001	1.0001	.1001	.0200	8/9/99	16:15	ATM	69	84	46
✓	Yes	99.9997	10.0000	1.0000	.1000	.0200	8/10/99	13:27	ATM	67	81	49
✓	Yes	99.9996	10.0000	1.0001	.1001	.0200	8/11/99	10:43	ATM	67	81	48
✓	Yes	99.9997	10.0000	1.0001	.1001	.0201	8/11/99	20:35	ATM	64	78	46
✓	Yes	99.9998	10.0000	1.0001	.1000	.0200	8/13/99	12:30	ATM	64	80	47
✓	Yes	99.9998	10.0001	1.0002	.1002	.0201	8/14/99	19:29	ATM	63	76	48
✓	Yes	99.9998	10.0000	1.0001	.1001	.0201	8/16/99	11:35	ATM	64	77	48
✓	Yes	99.9998	10.0001	1.0001	.1001	.0201	8/17/99	17:50	ATM	68	83	46
✓	No	99.9999	10.0000	1.0001	.1001	.0200	8/18/99	16:50	ATM	70	84	47
✓	Yes	99.9999	10.0001	1.0000	.1000	.0201	8/22/99	20:52	ATM	68	83	46
✓	No	99.9999	10.0001	1.0002	.1001	.0202	8/30/99	11:54	ATM	67	81	48
✓	Yes	99.9997	9.9999	1.0000	.1000	.0200	8/31/99	13:00	ATM	63	76	40
✓	Yes	99.9997	10.0000	1.0000	.1000	.0200	8/31/99	18:44	ATM	65	79	44
✓	Yes	99.9998	10.0000	1.0000	.1000	.0200	9/2/99	10:32	ATM	60	74	43
✓	Yes	99.9998	10.0000	1.0002	.1002	.0200	9/8/99	17:05	ATM	60	74	43
✓	Yes	99.9996	10.0001	1.0002	.1001	.0201	9/11/99	12:02	ATM	69	84	46
✓	Yes	99.9996	10.0000	1.0001	.1001	.0201	9/12/99	20:58	ATM	70	84	47
✓	Yes	99.9996	10.0001	1.0000	.1000	.0201	9/13/99	13:36	ATM	69	81	49
✓	Yes	99.9997	10.0001	1.0002	.1002	.0202	9/14/99	13:35	ATM	69	81	49
✓	Yes	99.9997	10.0001	1.0002	.1002	.0202	9/14/99	20:15	ATM	69	81	49
✓	Yes	99.9998	10.0001	1.0002	.1002	.0202	9/15/99	08:20	ATM	69	81	49
✓	Yes	99.9998	10.0001	1.0001	.1001	.0201	9/16/99	08:45	ATM	69	81	49
✓	No	99.9996	10.0000	1.0000	.1000	.0200	9/16/99	16:55	ATM	70	84	49

Woodstove Particulate
 Catch Processing Sheet
 Woodstove Data Sheet #5
 EPA M5G-1

Unit: KUMA Wood Classic
 Run: EPA 7
 Date: 9/18/99
 Technicians: ATM
 Revised 1/16/98-Data Sheet #5

Filters

Filter # (Front) 942 Beaker # 27
 Final Wt. .8369 g MI 50
 Tare Wt. .7983 g Desc. Acetone
 Net Wt. .0386 g ✓

Final Wt. 72.3402 g
 Tare Wt. 72.3294 g
 Net Wt. .0108 g ✓

Filter # (Rear) 941 Beaker # _____
 Final Wt. .8251 g MI _____
 Tare Wt. .8249 g Desc. _____
 Net Wt. .0002 g ✓

Final Wt. _____ g
 Tare Wt. _____ g
 Net Wt. _____ g

Acetone Blank Calculation:

Blank Date: 7/18/99

Blank Beaker # 1

Final Wt. 65.4847 g

MI 50

Tare Wt. 65.4847 g

Desc. Acetone

Net Wt. .0000 g

.0000 g ÷ 50 ml = .0000 g/ml

Blank Residue Value Calculation:

.0000 g/ml acetone X 50 ml acetone = .0000 g
 Blank Residue Value

Total Particulate Catch Calculation

Filter: .0386 g ✓

Filter: .0002 g ✓

Beakers: .0108 g - .0000 g = .0108 g ✓

Total Catch Blank Residue Value

Total Catch = .0496 g ✓

Unit Kama Wood Classic
 Run # EPA 1
 Date 9/18/99
 Technician ATM JRP
 WST6-Form1, Rev8/96

MISCELLANEOUS TEST DATA
 WOODSTOVE DATA SHEET #8

Useable Firebox Dimensions: See QC Section Useable Volume: 2.228 ft³

Dilution Tunnel Draft (If applicable): Start .000 Stop .000

Test Chamber Air Velocity: Start: 00.0 Stop: .000 Avg: .000

Wet Bulb/ Start: WB: 62 °F DB: 75 °F 1.40 % Amb Moisture 47 %RH

Dry Bulb Stop: WB: 65 °F DB: 78 °F 1.60 % Amb Moisture 49 %RH

$\bar{X} = 1.50$ % Ambient Moisture $\bar{X} = 48.0$ % Relative Humidity (RH)

Empty Stove Wt: 419.3 lbs.

Stove Wt with Stack (Inc. Oil Seal) Wet: 510.7 lbs. Dry: 509.4 lbs.

Empty Stove Wt with Stack and Ash Ash: — lbs. Total: — lbs.

Kindling Wt. Paper: 0.5 lbs. Wood: 5.7 lbs.

Pre Burn Fuel Wt. 14.6 + 15.5 + 16.3 Total: 46.4 lbs. ✓

Total Kindling and Pre Burn Fuel Wt. 52.6 lbs. ✓

Coal Bed Wt-lbs: Range (3.6 - 3.0) 513.0 - 512.4 lbs. Actual: 3.4 lbs.

Allowable Amount of Charcoal that can be removed: 512.8

Coal Bed Wt. Range 3.6 + 3.0 $12 \times .25 =$ 0.8 lbs. ✓
 Upper Wt. Lower Wt.

Test Fuel Wt-lbs: Ideal 15.6 lbs. Range: 17.1 - 14.1 lbs. Actual: 14.6 lbs.

Test Fuel Size (pcs.) (.75 x 1.5 x 5" Flanges) 16 Pcs.

2 x 4's x 16 ^{5/8} " 3 Pcs 6.3 lbs. 43.15 % ✓

4 x 4's x 16 ^{5/8} " 2 Pcs 8.3 lbs. 56.85 % ✓

Est. Dry Burn Rate (Kg/Hr.) $\frac{14.6 - (14.6 \times .17831)}{2.2046} \times \frac{60}{82} =$ 3.9817 Est. Dry Burn Rate (Kg/Hr) ✓

Est EPA Heat Output (HOG) (19,140) x $\frac{63}{100} \times 3.9817 =$ 48,012.1 Est Heat Output (HOG) BTU's/Hr ✓

Comments:

Stove Operating Data
Woodstove Test Data Sheet #9
Cold Start - High Burn

Unit: Kumiko Wood Classic
Run: EPA 7
Date: 9/18/99
Technician(s): ATM ZRP
Data Sheet #9 - Rev 1/98-Pg.5

Fire Started: 0612 POST

Warm up and Preburn: Primary Air: Wide open from ignition until the start of the test. At the run setting of wide open until the start of the test. High burn.

Secondary Air: No Controls. Naturally Drafted.

Secondary Burn/Cat Bypass: N/A

Charcoal Bed Preparation: Broke up, raked and leveled the coal bed prior to the addition of each warm up/pre burn fuel charge. Starting 1:30 before the start of the test, broke up, raked and leveled the coal bed. In stove for 35 seconds.

Test: Door wide open during loading 0 min 55 sec, then closed

Primary Air: Wide open from the start of the test (0:00) until the end of the test. High Burn.

Secondary Air: No Controls, Naturally drafted.

Secondary Burn/Cat Bypass: N/A

Fan: ON OFF during the warm up, ON OFF High during the preburn, ON OFF at the start of the test, ON OFF for the first 1 minutes of the test, ON OFF high at 1:00 minutes into the test, ON OFF for the rest of the test.

Test Run Anomalies:

This run went much faster than expected.

WOODSTOVE OPERATING DATA
 WOODSTOVE DATA SHEET #9A-1

Wood Data: Kindling: A mix of the below grades

	Size	Mill	Grade	Species
Pre Burn	2X4	CANYON	#2 \$ ETR	D. Fir CFC GEN
Test Fuel	2X4	CANYON	#2 \$ BTR	D. Fir CFC GEN
	4X4	"	#1	D. Fir SFC, GEN

All grades WCLB Rules unless otherwise noted.

Warm up Information:

- 1st Warm up/Pre Burn Fuel charge (14.6 lbs) added at 0635.
- 2nd Warm up/Pre Burn Fuel charge (15.5 lbs) added at 0729.
- 3rd Warm up/Pre Burn Fuel charge (16.3 lbs) added at 0825.
- 4th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____.
- 5th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____.
- 6th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____.
- 7th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____.
- 8th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____.

The coals were scooped out of the stove immediately prior to adding the 3rd pre burn/warm up fuel charge. The stove lost 1.3 lbs. 3.5 lbs of coals were put back in after the scoop.


All pre burn/warm up fuel pieces were ~~_____~~ 16" inches long. All preburn pieces/fuel charges were "ricked" in the stove. The pieces in the bottom layer in each rick contained 2 pcs that were 16 inches long and were loaded flat and perpendicular to the door. The pieces in the second layer in each rick were loaded on their side (edge) approximately parallel to the door and contained 4 pcs 16 inches long. The third layer (and fourth layer if present) was loaded flat, perpendicular to the door and contained 20-3 pcs 16 inches long. The majority of the pieces in each rick were in the second layer which had an approximate 0.5-1.0" space between pieces. (The loading directions indicate the direction of the longest dimension on each piece relative to the loading door opening.) Each pre burn/warm up fuel charge normally weighs within the weight range allowed for, the actual test fuel charge 2nd & 3rd charges had 3 pcs in third layer.

WOODSTOVE OPERATING DATA
WOODSTOVE DATA SHEET #9A-2


Unit Kumuk Wood Classic
Run # EPA-7
Date Sept 18, 1999
Technicians ATM, JRP
Page 2 of 3
WST7-Form2-A, Rev 6/90

Warm up Information (cont.):

Each warm up/preburn fuel charge was ricked in exactly (as much as possible) the same manner and the weight of each rick was usually within the allowable weight range for the test fuel charge. The physical arrangement and alignment of each rick was designed to accomplish three (3) things: (1) The bottom layer was nestled firmly into the coal bed and was as close to being level with the bottom of the stove as possible, thus providing a stable loading platform for the rest of the rick, keeping it in a ricked state (as opposed to a collapsed or fallen down state) until the rick reached the charcoal stage and sags or collapses of its own accord. (2) It enhances the flow of primary air through the ricked preburn fuel charge, for the primary air would flow through the spaces between the pieces in the first layer and then up through the spaces between the pieces in the second, third and, if present, fourth layers. (3) It maximized, as much as possible, the surface to volume ratio of each preburn fuel charge, thereby allowing the fire immediate access to as much wood surface as possible and, thereby, insuring uniform charcoalization. All three of these enhance combustion and so get the stove as hot as possible during the warm up period, thereby maximizing the amount of heat (BTU's) stored in the stove. The actual preburn was not started until the stove surface temperatures had maximized and stabilized, thus indicating that the amount of heat stored in the stove had peaked. For this stove, the thermal storage was monitored using the TOP T/C surface temperature(s) and the peak value(s) obtained were 953 of.



Front View



Top View

The arrows indicate the direction of the air flow through the rick.

The primary air was adjusted to the run setting of Wide Open 52.6 lbs above the upper charcoal bed weight.

WOODSTOVE OPERATING DATA
WOODSTOVE DATA SHEET #9A-3


Unit Kuma Wood Classic
Run # EPA7
Date 9/18/99
Technician AM
Page 3 of 3
WST5-Form2-Rev11/89

Additional Comments: Test Start Sequence: ① Turned Fan Off
② Opened door ③ Loaded Test fuel ④ cleaned coals
away from air front of the LPAO ⑤ Photo ⑥ Closed door.

Total Elapsed Time: 0:55

Test Fuel Charge Loading Information:

Test Fuel Charge and Loading Sequence Diagram



FRONT of stove view

4 X 4's: 3 & 5

2 X 4's: 1, 2 & 4

Loading Sequence: 1, 2, 3, 4 and then 5

Driest Pcs in Load 2 & 4, 3

Loaded the test fuel charge on an essentially level, medium-large
sized, hot coal bed (in appearance, color and temperature
for a high burn rate. Load: 0:55 Ignition: 0:20.

This run took off like a shot and never once looked back.
Fire box was engulfed in flames by 1:55. The CO
was higher than expected due to the faster than
expected DBR.

FUEL MOISTURE
WOODSTOVE TEST DATA SHEET #10

Unit: Kane Mod Classic
Run: EPA #1
Date: 7/13/77
Technician: ATM JRP
WST1-Form7-Rev11/89

Room Temperature: 62 °F

Correction Factor: +1

NOTE: Record readings to the nearest 0.5% moisture

Uncor Values are corrected for temperature: Yes No

Time Test Fuel Moisture Readings taken at: 0736

Calibration Checks: X Y 12.5 12.0 22.0 22.8

Pc #	Dimen	Use	Top		Bottom		Side		Piece Avg Corrected
			Uncor	Cor	Uncor	Cor	Uncor	Cor	
1	2x4x10'	K	14.0	14.9	14.5	15.4	14.0	14.9	15.067
2									
3									
4	2x4x8'	P	19.5	20.9	13.5	19.8	19.0	20.3	20.333
5	↓	↓	22.0	23.7	22.0	23.7	19.0	20.3	22.567
6	↓	↓	21.0	22.6	21.0	22.6	19.0	20.3	21.833
7	↓	↓	19.0	20.3	19.5	20.9	20.0	21.4	20.867
8									85.600
9									
10	2x4x16 1/2'	T	22	23.7	21	22.6	20	21.4	22.567
11	↓	↓	18	19.2	19.5	20.9	20	21.4	20.500
12	↓	↓	19	20.3	20.5	22.0	20	21.4	21.233
13									
14	4x4x16 1/2'	T	21	22.6	22	23.7	20.5	22.0	22.767
15	↓	↓	20.5	22.0	20.5	22.0	19	20.3	21.433
16									108.500
17									
18									
19	1.75x5x7.75	T	21	22.6	20	21.4	19	20.3	21.433
20									Out Syncing

	Kindling	Pretest Fuel	Test Load
% Moisture - Dry Basis:	15.067 %	21.400 %	21.700 %
% Moisture - Wet Basis:	13.094 %	17.628 %	17.831 %

To obtain Wet from Dry: $\frac{100 \times \% \text{ Dry Rdg.}}{100 + \% \text{ Dry Rdg.}} = \% \text{ Moisture, Wet Basis}$

Acceptable Ranges: 16-20% wet; 19-25% dry
(17.5 - 22.5 on Meter [Uncor reading] at 70°F)

Key for Use: K= Kindling P= Pretest Fuel T= Test Fuel

WOOD DENSITY DETERMINATION
WOODSTOVE TEST DATA SHEET #11

Unit: Kumuk Wood-Classic
Run#: EPA 7
Date: 9/18/99
Technician: ATM
WST2-form11-Rev 6/90

Wood Piece: Nominal Dimensions: 3.5 x 3.5 x 1.5
Depth (D): IN 3.487 cm 8.857 ✓
Width (W): IN 1.530 cm 3.886 ✓
Length (L): IN 3.429 cm
IN 3.448 cm
IN 3.484 cm
IN 3.478 cm
Length \bar{X} = IN 3.460 cm 8.788 ✓
Volume: 302.468 cm³ ✓
(D X W X L)

MOISTURE: Room Temperature: 62 °F Correction Factor: +1

Uncorrected Meter Readings Corrected for temperature: Yes No

NOTE: Record moisture meter readings to the nearest 0.5%

	Uncor	Cor	
Top:	18.0	19.2 %	Avg % Moisture (Dry) <u>19.767</u> %
Bottom:	18.0	19.2 %	Aug % Moisture (Wet) <u>16.504</u> %
Side:	19.5	20.9 %	Scale: Levelled In <input checked="" type="checkbox"/> Out <input checked="" type="checkbox"/>
\bar{X} :		19.767 %	Zeroed: In <input checked="" type="checkbox"/> Out <input checked="" type="checkbox"/>

Wet Weight: 147.1 g Dry Weight: 125.9 g

% Moisture Dried Basis: 14.412 % ✓
[1 - (Dry Wt ÷ Wet Wt)] X 100

Into Dryer Date 9/18/99 Time 1200 Temp 206 °F
Out of Dryer Date 9/22/99 Time 1551 Temp 214 °F
(Minimum Time in Dryer: 24 hrs.) Minimum Dryer Temp 100°C (212°F)

Density = 125.9 g (dry wt) ÷ 302.468 cm³ (volume) = 0.4162 g/cm³ ✓

Pellet Fuel Moisture Content Determination

Tare Beaker Wt. _____ g
Wet Wt: _____ g - _____ g = _____ g
Gross Wet Wt. Tare Beaker Wt. Net Wet Wt.
Dry Wt: _____ g - _____ g = _____ g
Gross Dry Wt. Tare Beaker Wt. Net Dry Wt.
% Moisture Dried Basis: _____ %
[1 - (Net Dry Wt ÷ Net Wet Wt.)] X 100

END Wt: 512.8 lbs.

Minute Time	Scale Wt	lbs left	Burn Rate	CO ₂		O ₂		CO		T/C(1) T/C(2)		T/C(3)		SO ₂ v.	Stack	Static Press.	Comments
				v.	%CO ₂	v.	%O ₂	v.	%CO	Wet Bulb	Dry Bulb	Ball	Calc W/B				
0	527.4	14.6	0	13.5	7.81	50.0	12.49	3.2	17	45.9	83	131	2.1	125	477	-0.068	Flow
5	525.9	13.1	1.5	6.40	15.82	14.2	3.55	43.7	2.24	7.1	117	154	9.2	148	661	-0.089	SO ₂ 1.5
10	524.2	11.4	1.7	6.46	15.97	14.3	3.58	48.3	2.41	6.6	133	164	15.5	156	676	-.090	CO ₂ 1.5
15	522.5	9.7	1.7	6.59	16.71	13.3	3.33	42.8	2.12	7.7	134	165	16.0	157	713	-.091	CO ₂ 1.5
20	520.7	7.9	1.8	6.71	16.57	12.3	3.08	33.9	1.90	9.8	133	164	16.0	157	713	-.091	CO ₂ 1.5
25	519.4	6.6	1.3	6.11	15.11	18.4	4.60	21.5	1.26	12.0	131	161	15.0	155	694	-.089	
30	518.2	5.4	1.2	5.75	14.22	20.9	5.72	17.4	1.60	23.7	107	154	13.5	153	135	-.088	
35	517.2	4.4	1.0	5.79	14.32	21.8	5.49	11.6	1.58	24.7	115	157	12.5	151	154	-.086	
40	516.2	3.4	1.0	5.55	13.72	24.5	6.12	3.9	2.0	68.6	122	156	11.0	150	685	-.085	
45	515.5	2.7	.7	4.86	12.02	31.5	7.90	1.2	1.07	171.8	117	151	9.0	144	610	-.082	
50	514.9	2.1	1.6	4.24	10.60	38.1	9.52	1.0	1.07	180.0	112	146	8.0	141	578	-.079	
55	514.3	1.5	1.6	4.08	10.10	39.5	9.87	1.8	1.0	181.0	106	139	6.6	137	549	-.075	
60	513.9	1.1	.4	3.47	8.60	46.3	11.57	2.1	1.2	71.7	102	135	5.7	133	530	-.074	Flow
65	513.1	.8	.3	3.30	7.47	50.3	12.57	3.8	2.0	37.3	95	130	4.3	131	449	-.072	SO ₂ 1.5
70	513.3	.5	1.3	2.67	6.63	54.1	13.51	4.9	2.7	24.5	92	128	3.9	130	461	-.069	CO ₂ 1.5
75	513.1	.3	.2	2.65	6.57	54.3	13.56	4.9	2.6	25.3	84	125	3.4	128	464	-.068	CO ₂ 1.5
80	512.9	.1	1.2	2.62	6.50	54.7	13.66	6.4	3.3	19.7	87	123	3.0	125	457	-.065	
85	512.8	0	.1	2.53	6.28	55.6	13.89	7.0	3.6	17.4	86	122	3.0	125	411	-.064	
90																	
95																	
100																	
105																	
110																	
115																	

18.7

-1.412

-1.195

-0.0792

2878

10501

5872

18.7

2878

10501

5872

Pre Burn Start wt.
15.9 lbs
Test Start wt. Range
513.0 - 512.4 lbs.

PRE BURN DATA
RECORD SHEET #13
WST2-Form16

BARO. PRESSURE
28.62 in Hg

Unit: Kuma Wood Classic
Run: EPA 7
Page: 1 of 1

Date: 9/10/91
Technician(s): Ann JRP

513.0 - 512.4 lbs. T/C#-3

8

9 10 11

Hot Box On ✓

Minute	Scale Weight	Burn Rate	Stack	Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn Catalytic	Room Temp	Static	Comments
0	52.7	0	400	494	682	486	655	440	819	1124	69	-080	Primary Air Set at Wide Open
5	526.7	2.2	728	860	645	407	616	449	764	1579	68	-077	Secondary Air Set at —
10	524.1	2.2	740	929	628	370	606	442	738	1586	68	-076	Fan: High
15	520.9	2.0	748	939	624	347	609	436	764	1597	69	-096	TUNNEL ON AT 1 ✓
20	521.2	1.7	737	939	645	343	613	431	812	1571	68	-094	Buckets IN LD ✓
25	519.4	1.8	726	864	669	350	621	427	874	1524	67	-093	ANALYZERS SPINNED
30	517.1	1.5	723	939	697	356	633	424	962	1803	69	-092	Pumps turned on at:
35	516.7	1.2	692	897	726	371	653	425	1059	1695	68	-088	AT
40	515.8	1.1	678	868	753	387	675	426	1111	1550	68	-087	
45	515.1	.7	626	811	773	399	692	428	1152	1464	67	-083	Check WB/DB:
50	514.7	1.6	569	730	761	420	700	429	1177	1368	68	-082	
55	514.3	.4	511	624	772	456	705	435	1079	1311	67	-082	Probe IN TUNNEL
60	514.0	.3	555	632	747	426	693	438	1038	1298	67	-084	
65	513.7	.3	519	607	727	413	680	437	1019	1283	66	-084	592.8
70	513.4	.3	503	598	711	403	672	435	995	1279	66	-076	560.7
75	513.2	.2	488	560	696	397	663	439	978	1246	67	-076	547.1
80	513.0	.2	461	549	637	396	656	440	961	1214	67	-071	542.5
85	512.8	.2	475	538	632	373	650	442	953	1206	68	-068	541.0

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-1

Site: Myren Consulting, Woodinville, WA Date: 9/13/99 Analyte: CO2

Source: Kuma Wood Classic Run #: EPA 7

Zero Cyl #: 719 430 Conc. 00.0 % CO₂ Cyl Press: 1830 psi

Certified by: Oxarc Date: 4/1/99

Span Cyl #: 750 - 794 Conc. 12.5 % CO₂ Cyl Press: 1305 psi

Certified by: Oxarc Date: 3/26/99

Analyzer: Make: Horiba Model: PIR-2000 SN: 607024

Range: 0 - 25.0% CO2 Analyzer Output: 0 - 1.0 v.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter: _____

EPA Span Value = 25.0% CO₂

EPA Control Limits = + 2.5% of 25.0% CO₂ = + 0.625% CO₂

Pre Run Audit: By: A.T. Myren Time: 0909 Temp: 77 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	.000	00.0	00.0	.000	.0446	+0.0446	+0.18
Span	50.0	.500	12.5	49.0	.494	12.2232	-0.2768	-2.21

Comments:

Post Run Audit: By: A.T. Myren Time: 1145 Temp: 73 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	.000	00.0	00.0	.000	.0446	+0.0446	+0.18
Span	50.0	.500	12.5	49.0	.493	12.1984	-0.3014	-2.41

Comments:

+ Conc. Difference = Act % - Exp (Std) %
 Zero % Differece = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$
 Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Exp \% (ppm)}} \times 100$

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-2

Site: Myren Consulting, Woodinville, WA Date: 9/18/99 Analyte: O₂

Source: Kuma Wood Classic Run #: EPA 7

Zero Cyl #: 719 430 Conc. 00.0 % O₂ Cyl Press: 1830 psi

Certified by: Oxone Date: 4/1/99

Span Cyl #: 250-794 Conc. 12.5 % O₂ Cyl Press: 1305 psi

Certified by: Oxone Date: 3/26/99

Analyzer: Make: Taylor Model: OA 137 SN: 137/4772

Range: 0 - 25.0% O₂ Analyzer Output: 0 - 100 mv.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter:

EPA Span Value = 25.0% O₂

EPA Control Limits = + 2.5% of 25.0% O₂ = + 0.625% O₂

Pre Run Audit: By: A.T. Myren Time: 0909 Temp: 77 °F

Audit Results

Point #	Expected Response			Actual Response			± Conc. Difference	Δ%
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	00.0	00.0	0.1	00.1	0.0300	+0.0300	+0.12
Span	12.5	50.0	12.5	12.5	49.6	12.3909	-0.1091	-0.87

Comments:

Post Run Audit: By: A.T. Myren Time: 1145 Temp.: 73 °F

Audit Results

Point #	Expected Response			Actual Response			± Conc. Difference	Δ%
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	00.0	00.0	0.1	00.0	0.0050	+0.0050	+0.02
Span	12.5	50.0	12.5	12.5	49.6	12.3909	-0.1091	-0.87

Comments:

± Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Exp \% (ppm)}} \times 100$

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-3

Site: Myren Consulting, Woodinville, WA Date: 9/18/99 Analyte: CO

Source: Kuma Wood Classic Run #: EPA 7

Zero Cyl #: 719 430 Conc. 00.0 % CO Cyl Press: 1830 psi

Certified by: Qara Date: 4/1/99

Span Cyl #: 250-794 Conc. 250 % CO Cyl Press: 1305 psi

Certified by: Oxarc Date: 3/26/99

Analyzer: Make: Infra Red Model: 702 D SN: 113

Range: 0 - 10.0% CO Analyzer Output: 0 - 100 mv.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter: _____

EPA Span Value = 5.0% CO

EPA Control Limits = +2.5% of 5.0% CO = + 0.125% CO

Pre Run Audit: By: A.T. Myrum Time: 0909 Temp: 77 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	00.0	00.0	0.00	00.0	70093	-1.0093	-0.19
Span	250	500	2.50	2.50	50.0	24914	-1.0086	-0.34

Comments:

Post Run Audit: By: A.T. Myrum Time: 1145 Temp.: 73 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	00.0	00.0	0.00	00.1	70043	-0.0043	-0.09
Span	250	500	2.50	2.44	48.5	24164	-0.0836	-3.34

Comments:

+ Conc. Difference = Act % - Exp (Std) %

Zero % Differenece = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Exp \% (ppm)}} \times 100$

Unit: Kuma Wood Classic
 Run: EPA 7
 Date: 9/13/79
 Technicians: ATM JRP
 WST6-Form3-Rev11/89

QUALITY CHECKS
 WOODSTOVE DATA SHEET #16

Ambient = Tr: _____ °F T/C#30: _____ °F
 Thermocouple Check (at ambient): T/C#1: 61 °F; T/C#2: 61 °F;
 T/C #3: 63 °F; T/C #4: 63 °F; T/C #5: 65 °F;
 T/C #6: 65 °F; T/C #7: 64 °F; T/C #8: 65 °F;
 T/C #9: 65 °F; T/C #10: 65 °F; T/C #11: 62 °F;
 T/C #12: 62 °F; T/C #13: 62 °F; T/C #14: 65 °F;
 T/C #15: 61 °F; T/C #16: 62 °F; T/C #17: 65 °F;
 T/C #18: 62 °F; T/C #19: — °F; T/C #20: _____ °F;
 T/C #21: _____ °F; T/C #22: _____ °F; T/C #23: _____ °F;
 T/C #24: _____ °F; T/C #25: _____ °F; T/C #26: _____ °F;
 Comments: _____

Thermocouple Readout: Pretest Zero/Span Check and Calibration:
 Zero (0°F) : 001 °F Adj to: — °F Post Test Check Zero (0°F): 002 °F % Difference +0.10
 Span (2000°F): 1999 °F Adj to: 2000 °F Span (2000°F): 2000 °F _____
 (Allowable % Difference = 1.5%. Use formulas on Woodstove Data Sheet #15 to calculate % Difference)

Thermocouple Readout Pretest Linearity Check
 0°F = 001 °F; 200°F = 201 °F; 400°F = 398 °F;
 600°F = 599 °F; 800°F = 800 °F; 1000°F = 1001 °F;
 1200°F = 1200 °F; 1400°F = 1400 °F; 1600°F = 1599 °F
 1800°F = 1799 °F; 2000°F = 2000 °F

Combustion Gas (CO₂, O₂, CO) Train Leak Check: Pre Post
 Draft (Static) Gauge Zero Check: Pre Post

Scale Check Pre (Wt, #'s): 515.7 - 510.7 = 5.0 / 5.0 = 0% (ATM)
 Post (Wt, #'s): 517.1 - 512.1 = 5.0 / 5.0 = 0% (ATM)

Stack cleaned prior to the run: Yes _____ No
 Tunnel cleaned prior to the run: Yes _____ No

DILUTION TUNNEL CALCULATIONS

MYREN CONSULTING CERTIFICATION TEST DATA

3/31/96

File Name: KumaEPA5
 Stove Manufacturer: Kuma
 Model Number: Wood Classic
 Lab Name: MYREN
 Test Date: 9/16/99
 Run Number: EPA 5
 Meter Box Y Factor: 1.0151
 Barometric pressure (in.): 28.48
 Gas meter temp (ave): 93
 delta H(ave): 0.900
 Gas meter initial reading: 988.002
 Gas meter final reading: 1138.675
 Front catch (acetone) mg: 6
 first filter catch (mg): 30
 second filter catch (mg): 1.9
 tunnel flow (ave cfm): 142.767
 Emission Rate(g/hr): 2.367
 Emission Rate(M5H) : 3.720
 vs/VmTs: 0.0108
 vs ave: 840.919
 Tunnel average temp (°f): 97.643
 Test time(min): 270
 Fuel Load(lb. wet): 14.6
 Wood moisture(%wet): 17.555
 Burn rate(dry kg/hr): 1.213
 Samp vol(scf): 139.177
 front filter number: 938
 back filter number: 937
 acetone beaker number: 20

PRELIMINARY RESULTS

FINAL RESULTS

DATA SUMMARY

MODEL : Wood Classic
 RUN: EPA 5
 DATE: 9/16/99
 DBR: 1.213
 GPV UNADJ 2.367
 ADJ 3.72039511

	RUN TIME (min)	PITOT DELTAP (- INCH H2O)	TNL. TEMP (°F)	GAS METER RDG (#3)	GAS METER TEMP (°F)	GAS METER DELTA H (in.H2O)	TUNNEL VELOCIT (ft/min)	PROP RATE (%)	ddGVM vol std (#3)
	0	0.040	92	988.002	83	0.900	836.67		
	10	0.040	104	993.633	84	0.900	845.71	104.3	5.291
	20	0.040	101	999.270	85	0.900	843.46	102.6	5.287
	30	0.040	103	1004.828	86	0.900	844.96	101.6	5.203
	40	0.040	106	1010.390	88	0.900	847.21	101.7	5.188
	50	0.040	105	1015.962	90	0.900	846.46	101.0	5.178
	60	0.040	107	1021.522	91	0.900	847.96	101.1	5.158
	70	0.040	107	1027.085	92	0.900	847.96	100.8	5.151
	80	0.040	108	1032.665	92	0.900	848.71	101.3	5.167
	90	0.040	106	1038.235	93	0.900	847.21	100.4	5.149
	100	0.040	102	1043.790	94	0.900	844.21	99.5	5.125
	110	0.040	100	1049.372	94	0.900	842.71	99.9	5.150
	120	0.040	99	1054.955	95	0.900	841.95	100.0	5.151
	130	0.040	98	1060.525	96	0.900	841.20	99.3	5.121
	140	0.040	98	1066.100	96	0.900	841.20	99.5	5.125
	150	0.040	96	1071.673	95	0.900	839.69	99.2	5.133
	160	0.040	96	1077.240	96	0.900	839.69	99.1	5.118
	170	0.040	96	1082.816	95	0.900	839.69	99.5	5.136
	180	0.040	94	1088.415	96	0.900	838.18	99.4	5.147
	190	0.040	92	1094.005	96	0.900	836.67	99.0	5.139
	200	0.040	91	1099.599	96	0.900	835.91	99.1	5.143
	210	0.040	90	1105.185	96	0.900	835.15	98.9	5.135
	220	0.040	91	1110.785	96	0.900	835.91	99.4	5.148
	230	0.040	91	1116.365	97	0.900	835.91	98.7	5.121
	240	0.040	90	1121.940	96	0.900	835.15	98.7	5.125
	250	0.040	89	1127.524	96	0.900	834.39	98.7	5.134
	260	0.040	91	1133.095	96	0.900	835.91	98.9	5.122
	270	0.040	91	1138.675	96	0.900	835.91	98.9	5.130
	280						0.00	0.0	0.000
	290						0.00	0.0	0.000
	300						0.00	0.0	0.000
	310						0.00	0.0	0.000
	320						0.00	0.0	0.000
	330						0.00	0.0	0.000
	340						0.00	0.0	0.000
	350						0.00	0.0	0.000

DATE 9/16/1999

PAGE 1 OF 2

MODEL # Wood Classic

RUN # EPA 5

METER BOX # 511-M

METER V 1.0151

FILTER # (F) 938 (R) 937

PRE TEST LEAK RATE = 1000 CFM @ -15.5 IN. HG. 745 S / 7455

POST TEST LEAK RATE = 1000 CFM @ -15.0 IN. HG. 011 / 011

FILTER SIZE: 110 MM

PROBE LENGTH 24" glass

TIME
CLOCK ELAPSED

METER READING
CU. FT.

PILOT dp

TNL TEMP. (°F)

METER TEMP. (°F)

GAS METER dh

VAC IN. HG

POINT LOCATION ΔP TEMP

VELOCITY TRAVERSE

TIME	CLOCK ELAPSED	METER READING CU. FT.	PILOT dp	TNL TEMP. (°F)	METER TEMP. (°F)	GAS METER dh	VAC IN. HG	POINT LOCATION ΔP TEMP	VELOCITY TRAVERSE
1755	00	988.002	-040	92	83	90	0	N-1 0.5 -035 94	
1305	10	993.633	-040	104	84	90	0	2 1.5 -038 94	
15	20	999.270	-040	101	85	90	0	3 4.5 -036 94	
35	30	1004.828	-040	103	86	90	0	4 5.5 -033 94	
35	40	1010.390	-040	106	88	90	0	W-1 0.5 -035 94	
35	40	1010.390	-040	106	88	90	0	1.5 -040 94	
45	50	1015.962	-040	105	90	90	0	4.5 -039 94	
55	60	1021.522	-040	107	91	90	0	5.5 -038 94	
1405	70	1027.085	-040	107	92	90	0	Avg. 0.37 94.000	
15	80	1032.665	-040	108	92	90	0	Pilot Leak Check	
25	90	1038.235	-040	106	93	90	0	Pre Post	
35	100	1043.790	-040	102	94	90	0		
45	10	1049.372	-040	100	94	90	0		
55	20	1054.955	-040	99	95	90	0		
1505	30	1060.525	-040	98	96	90	0		
15	40	1066.100	-040	98	96	90	0		
25	50	1071.673	-040	96	95	90	0		
35	60	1077.240	-040	96	96	90	0		
45	70	1082.816	-040	96	95	90	0		
55	80	1088.415	-040	94	96	90	0		
1605	90	1094.005	-040	92	96	90	0		


point of Avg. delta p

$$Q_s = \sqrt{(\Delta P \times BP) \times 3167.2 \times (T.R.)}$$

137.760 CFM

BP - Static 28.52 in Hg

8h'28
130
180
240
300
360
420
480
540
600



X = 28.48

6.72
31.3
2.3

DATE 2/16/1999

PAGE 2 OF 2

MODEL # Wood Classic

RUN # EPA 4

METER BOX # 511-M

METER # 1.0151

FILTER # (F) 938 (R) 935

PRE TEST LEAK RATE = 1000 CFM @ -15.5 IN. HG, 9455/9455

POST TEST LEAK RATE = 1000 CFM @ -15.0 IN. HG, 011/011

FILTER SIZE: 110 MM
 PROBE LENGTH 24 g/l

TIME	CLOCK ELAPSED	METER READING CU.FT.	PILOT dp	TNL TEMP. (°F)	METER TEMP. (°F)	GAS METER dp	VAC IN.	VELOCITY TRAVERSE	
								POINT LOCATION ΔP	POINT LOCATION ΔP
16:15	00	1099.599	-.040	91	96	96	.90	0	0
25	10	1105.185	-.040	90	96	96	.90	0	0
35	20	1110.785	-.040	91	96	96	.90	0	0
45	30	1116.365	-.040	91	97	97	.90	0	0
55	40	1121.940	-.040	90	96	96	.90	0	0
1:05	50	1127.524	-.040	89	96	96	.90	0	0
15	60	1133.095	-.040	91	96	96	.90	0	0
25	70	1138.675	-.040	91	96	96	.90	0	0
	80	(150.673)							
	90								
	00								
	10								
	20								
	30								
	40								
	50								
	60								
	70								
	80								
	90								

POINT LOCATION ΔP

N-1 0.5" -0.35

2 1.5" -0.38

3 4.5" -0.36

4 5.5" -0.33

W-1 0.5" -0.35

2 1.5" -0.40

3 4.5" -0.39

4 5.5" -0.38

Avg. -0.3675

Pilot Leak Check

Pre Post

CP = 0.99

← W 1 2 3 4

-point of Avg. delta p

OS = $(\sqrt{\Delta P \times BP}) \times 3167.2$

137.760 CFM

BP = START 28.52 IN HG

60 28.48

120 28.47

180 28.47

240 28.47

300 28.47

360 28.47

420 28.47

480 28.47

540 28.47

600 28.47

660 28.47

720 28.47

780 28.47

840 28.47

900 28.47

960 28.47

1020 28.47

1080 28.47

1140 28.47

1200 28.47

X = 28.480

WOODSTOVE DATA SHEET #4-1: INITIAL FILTER WEIGHTS (TARE WEIGHTS)

Info Desiccator: Date 1/9/99 Time 1445 By ATM Front Half Back Half

Manufacturer: Schercher & Scheel / Size: 11cm Lot.No.: Z8961 Grade: #25 Glass

Order No: 06220

Filter #	Wt	Date	Time	By	Wt	Date	Time	By
926	7240	3/6/99	1140	TM	1739	3/5/99	1652	ATM
927	7928		1141	TM	1938			ATM
928	7485		1142	TM	1985			ATM
929	7909		1143	TM	1912			ATM
930	7448		1144	TM	1950			ATM
931	8041		1145	TM	8042			ATM
932	7917		1146	TM	9918			ATM
933	8047		1147	TM	8048			ATM
934	7981		1148	TM	9918			ATM
935	7861		1149	TM	7861			ATM
936	7827		1150	TM	7828			ATM
937	7935		1151	TM	7933			ATM
938	8086		1152	TM	8084			ATM
939	8060		1153	TM	8058			ATM
940	8151		1154	TM	8151			ATM
941	8252		1155	TM	8249			ATM
942	7982		1156	TM	7983			ATM
943	7822		1157	TM	7822			ATM
944	7938		1158	TM	7968			ATM
945	7944		1159	TM	7943			ATM
946	7852		1200	TM	7850			ATM
947	7731		1201	TM	7735			ATM
948	7936		1202	TM	7940			ATM
949	7838		1203	TM	7837			ATM
950	8040		1204	TM	8038			ATM

Checked by *Jim Minton* Date: 3/16/99 Time 2133

Filter #	Wt	Date	Time	By	Wt	Date	Time	By
926	7240	3/6/99	1140	TM	1739	3/5/99	1652	ATM
927	7928		1141	TM	1938			ATM
928	7485		1142	TM	1985			ATM
929	7909		1143	TM	1912			ATM
930	7448		1144	TM	1950			ATM
931	8041		1145	TM	8042			ATM
932	7917		1146	TM	9918			ATM
933	8047		1147	TM	8048			ATM
934	7981		1148	TM	9918			ATM
935	7861		1149	TM	7861			ATM
936	7827		1150	TM	7828			ATM
937	7935		1151	TM	7933			ATM
938	8086		1152	TM	8084			ATM
939	8060		1153	TM	8058			ATM
940	8151		1154	TM	8151			ATM
941	8252		1155	TM	8249			ATM
942	7982		1156	TM	7983			ATM
943	7822		1157	TM	7822			ATM
944	7938		1158	TM	7968			ATM
945	7944		1159	TM	7943			ATM
946	7852		1200	TM	7850			ATM
947	7731		1201	TM	7735			ATM
948	7936		1202	TM	7940			ATM
949	7838		1203	TM	7837			ATM
950	8040		1204	TM	8038			ATM

BALANCE ROOM ENVIRONMENTAL CONDITIONS

WB	DB	%RH	Date	Time	By
64	29	43	3/6/99	1135	ATM
16	81	45	3/15/99	1622	ATM
65	82	39	3/16/99	2025	ATM

QA REWEIGH

Filter #	WT	Date	Time	By
929	7912	3/16/99	2136	Jim
941	8248	3/16/99	2134	Jim
949	7837	3/16/99	2133	Jim

Post Test Weighing Session Scott Chade
 1st 2nd 3rd
 0.0000 0.0000 0.0001
 1.0000 1.0000 0.9999

INITIAL BEAKER WEIGHTS (TARE WEIGHTS)

Into Desiccator: Date: 8/20/99 Time: 1500 By: A. J. MURPHY

Beaker #	Wt	First	Second	Third
1	65.4841	8/27	8/30/99	
2	66.1509	8/27		
3	67.8583			
4	67.5870			
5	67.4720			
6	67.5444			
7	66.0219			
8	66.0219			
9	66.0219			
10	66.0906			
11	65.7072			
13	57.8946			

Beaker #	Wt	Date	Time	By	Second	Third
1	65.4841	8/27	8/30/99			
2	66.1509	8/27				
3	67.8583					
4	67.5870					
5	67.4720					
6	67.5444					
7	66.0219					
8	66.0219					
9	66.0219					
10	66.0906					
11	65.7072					
13	57.8946					

Beaker #	Wt	Date	Time	By
13	65.7022	9/13		
11	65.7021	9/11		
10	65.7022	9/13		

Beaker #	Wt	Date	Time	By	Second	Third
1	73.3159	8/27	8/31/99			
2	71.0002	8/27				
3	70.7376	8/27	8/30/99			
4	71.8322	9/13				
5	71.8322	9/13				
6	70.7376	8/27				
7	71.8322	9/13				
8	71.8322	9/13				
9	71.0002	8/27				
10	70.7376	8/27				
11	70.7376	8/27				
12	70.7376	8/27				
13	70.7376	8/27				
14	70.7376	8/27				
15	70.7376	8/27				
16	70.7376	8/27				
17	70.7376	8/27				
18	70.7376	8/27				
19	70.7376	8/27				
20	70.7376	8/27				
21	70.7376	8/27				
22	70.7376	8/27				
23	70.7376	8/27				
24	70.7376	8/27				
25	70.7376	8/27				
26	70.7376	8/27				
27	70.7376	8/27				
28	70.7376	8/27				
29	70.7376	8/27				
30	70.7376	8/27				
31	70.7376	8/27				
32	70.7376	8/27				
33	70.7376	8/27				
34	70.7376	8/27				
35	70.7376	8/27				
36	70.7376	8/27				
37	70.7376	8/27				
38	70.7376	8/27				
39	70.7376	8/27				
40	70.7376	8/27				
41	70.7376	8/27				
42	70.7376	8/27				
43	70.7376	8/27				
44	70.7376	8/27				
45	70.7376	8/27				
46	70.7376	8/27				
47	70.7376	8/27				
48	70.7376	8/27				
49	70.7376	8/27				
50	70.7376	8/27				
51	70.7376	8/27				
52	70.7376	8/27				
53	70.7376	8/27				
54	70.7376	8/27				
55	70.7376	8/27				
56	70.7376	8/27				
57	70.7376	8/27				
58	70.7376	8/27				
59	70.7376	8/27				
60	70.7376	8/27				
61	70.7376	8/27				
62	70.7376	8/27				
63	70.7376	8/27				
64	70.7376	8/27				
65	70.7376	8/27				
66	70.7376	8/27				
67	70.7376	8/27				
68	70.7376	8/27				
69	70.7376	8/27				
70	70.7376	8/27				
71	70.7376	8/27				
72	70.7376	8/27				
73	70.7376	8/27				
74	70.7376	8/27				
75	70.7376	8/27				
76	70.7376	8/27				
77	70.7376	8/27				
78	70.7376	8/27				
79	70.7376	8/27				
80	70.7376	8/27				
81	70.7376	8/27				
82	70.7376	8/27				
83	70.7376	8/27				
84	70.7376	8/27				
85	70.7376	8/27				
86	70.7376	8/27				
87	70.7376	8/27				
88	70.7376	8/27				
89	70.7376	8/27				
90	70.7376	8/27				
91	70.7376	8/27				
92	70.7376	8/27				
93	70.7376	8/27				
94	70.7376	8/27				
95	70.7376	8/27				
96	70.7376	8/27				
97	70.7376	8/27				
98	70.7376	8/27				
99	70.7376	8/27				
100	70.7376	8/27				

Checked By: A. J. MURPHY
Date: 9/11/99
Time: 1714

Balance Room Environmental Conditions

WB	DB	ZRH	Date	Time	By
68	83	46	8/27/99	2052	ATM
67	81	43	8/30/99	1154	ATM
63	76	48	8/31/99	1310	ATM
70	84	47	9/8/99	1705	ATM
69	84	46	9/11/99	1202	ATM
74	77	49	9/13/99	1926	ATM

WOODSTOVE DATA SHEET #4-21
INITIAL BEAKER WEIGHTS (TARE WEIGHTS)

Into Dessicator: Date: 6/1/99
By: A.T. Myrum

Time: 1400
By: B KAN
Date: 7/18/99

Beaker #	Wt	Date	Time	By	Second	Wt	Date	Time	By	Third	Wt	Date	Time	By
1	66.4847	7/1/99	1636	ATM	65.4847	1612	7/18/99	1612	ATM					
2	66.1504		1638	ATM	66.5506				ATM					
3	67.8572		1640	ATM	67.8567				ATM					
4	67.5897		1642	ATM	67.5880				ATM					
6	67.9268		1644	ATM	67.9266				ATM					
7	65.5436		1648	ATM	65.5437				ATM					
8	66.0212		1650	ATM	66.0211				ATM					
9	66.5299		1652	ATM	66.5295				ATM					
10	66.0889		1654	ATM	66.0888				ATM					
11	65.7015		1656	ATM	65.7013				ATM					
12	56.2656		1658	ATM	56.0653				ATM					
13	57.8948		1700	ATM	57.8944				ATM					

Checked By: A.T. Myrum
Date: 7/18/99
Time: 1800

Beaker #	Wt	Date	Time	By
65	49	7/17/99	1825	ATM
63	45	7/18/99	1604	ATM

LABOR ROOM ENVIRONMENTAL CONDITIONS

WOODSTOVE DATA SHEET #4-3: CONSTANT FINAL WEIGHTS

FINAL BEAKER WEIGHTS

Beaker #	Into Desicc	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By
20	✓	9/18/99	1210 AM	AMM	73.325	9/19/99	1358 PM	M	73.3220	9/24	1200	AMM	73.3220	9/27/99	2005	J

WST5-Form9, Pg 1, Rev 4/90
 Unit: Kunita Wood Ch 120/C

Run # EPA 5
 Date: 9/16/99

FINAL FILTER WEIGHTS

Filter #	Into Desicc	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By
938		9/16	1256 AM	AMM	.8391	9/17	2053 PM	M	.8385	9/19	1248 AM	AMM	.8390	9/19	1307 PM	M
937		9/16	1238 AM	AMM	.7951	9/18	1246 AM	AMM	.7955	9/19	1309 PM	M	.7952	9/23	2044 PM	J

QA REWEIGH: FINAL WEIGHTS

Date	Beaker #	Final Wt	By
Date	Filter #	Final Wt	By

SCALE ROOM ENVIRONMENTAL CONDITIONS

Seasion	Date	Time	By	WB	DB	%RH
1	9/17	2045 AM	AMM	66	79	49
2	9/18	1212 AM	AMM	65	78	48
3	9/19	1245 AM	AMM	62	75	47
4	9/23	2028 AM	AMM	65	79	47
5	9/24	1145 AM	AMM	64	72	49

SCALE ROOM ENVIRONMENTAL CONDITIONS

6	7	8	9
Comments			

WOODSTOVE DATA SHEET #4-3: CONSTANT FINAL WEIGHTS

Blank
7/18/99

WST5-Form 9, 81, Rev 4/90
Unit # KUMM Wood Cleaner
Run #
Date: 7/1 1999

PINAL BEAKER WEIGHTS

Beaker #	Intro Desaltic	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By
1	✓	7/6/99	1435	ATM	65.4852	8/4/99	1915	ATM	65.4846	8/8/99	1942	OBM	65.4849	8/9	1642	ATM

PINAL FILTER WEIGHTS

Filter #	Intro Desaltic	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By

QA REMEIGH, FINAL WEIGHTS

Date	Beaker #	Final Wt	By

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighting	1999	Date	Time	By	WB	DB	%RH
1	8/4	8/4	1705	ATM	69	83	49
2	8/8	8/8	1700	ATM	64	78	46
3	8/9	8/9	1615	ATM	69	84	46
4							
5							

SCALE ROOM ENVIRONMENTAL CONDITIONS

6	7	8	9	Comments

Dates From 1/9/99
Through 7/17/99

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale Mettler
Model AE100
SN K04827

Level	Recall- brated	100g Weight	10g Weight	1.0g Weight	100mg Weight	20mg Weight	Date	Time	Tech	Wet Bulb	Dry Bulb	% RH
L	Yes	99.9999	10.0001	1.0002	100.003	0.2003	1/9/99	1243	ATM	58	70	48
L	No	100.0002	10.0000	1.0000	100.000	0.2000	1/14/99	1113	ATM	62	75	47
L	Yes	99.9998	10.0002	1.0000	099.999	0.2001	1/23/99	1100	ATM	63	72	48
L	Yes	99.9999	10.0000	1.0000	100.000	0.2001	1/24/99	1318	ATM	57	74	45
L	Yes	99.9999	10.0002	1.0000	100.000	0.2000	2/1/99	0910	ATM	55	69	39
L	Yes	99.9999	10.0001	1.0001	100.002	0.2001	2/2/99	0934	ATM	60	73	46
L	Yes	99.9999	10.0001	1.0001	100.001	0.2000	2/2/99	1555	ATM	63	76	48
L	Yes	99.9999	10.0001	1.0001	100.001	0.2001	2/3/99	1335	ATM	62	76	48
L	Yes	99.9998	10.0000	1.0000	100.000	0.2000	2/10/99	1600	ATM	63	76	45
L	Yes	99.9998	10.0000	1.0000	100.000	0.2000	2/19/99	0246	ATM	64	78	46
L	No	99.9999	10.0000	1.0001	100.000	0.2000	2/21/99	1312	ATM	65	80	44
L	No	99.9999	10.0000	1.0001	100.000	0.2000	3/5/99	1435	ATM	64	80	44
L	Yes	99.9999	10.0000	1.0000	100.001	0.2000	3/6/99	1135	ATM	64	79	43
L	Yes	99.9999	10.0000	1.0000	100.000	0.2000	3/13/99	1526	ATM	65	80	44
L	Yes	99.9999	10.0000	1.0001	100.000	0.2000	3/14/99	1355	ATM	63	78	43
L	Yes	99.9999	10.0001	1.0001	100.001	0.2000	3/15/99	1622	ATM	66	81	45
L	No	100.0001	10.0000	1.0000	100.000	0.2000	3/16/99	0525	ATM	65	82	39
L	Yes	99.9997	10.0000	1.0001	100.000	0.2000	3/17/99	1615	ATM	62	82	42
L	Yes	99.9999	10.0000	1.0001	100.001	0.2000	3/18/99	2140	ATM	68	84	43
L	Yes	99.9999	10.0000	1.0001	100.000	0.2000	3/20/99	1300	ATM	64	84	32
L	Yes	99.9999	10.0000	1.0001	100.000	0.2000	3/21/99	2215	ATM	61	74	47
L	Yes	99.9999	10.0000	1.0000	100.000	0.2000	3/22/99	0102	ATM	65	85	33
L	Yes	99.9997	10.0000	1.0001	100.000	0.2000	3/23/99	1115	ATM	69	84	46
L	Yes	99.9997	10.0000	1.0001	100.000	0.2001	3/24/99	1120	ATM	77	89	43
L	Yes	99.9999	10.0000	1.0002	100.001	0.2001	3/29/99	2038	ATM	59	72	45
L	No	99.9999	10.0000	1.0002	100.002	0.2002	3/30/99	0610	ATM	66	80	47
L	No	99.9999	10.0000	1.0000	100.000	0.2001	3/31/99	1200	ATM	64	80	41
L	No	99.9999	10.0000	1.0000	100.000	0.2001	4/5/99	1330	ATM	64	80	41
L	Yes	99.9999	10.0001	1.0001	100.001	0.2001	4/6/99	1030	ATM	61	75	44
QC Services	Audit	4/6/99	-	WT	Scale	Change	4/6/99	1330	ATM	65	85	33
L	No	100.0003	10.0001	1.0001	100.001	0.2001	4/7/99	1424	ATM	65	85	33
L	Yes	99.9998	10.0001	1.0001	100.001	0.2000	4/8/99	1346	ATM	67	80	50
L	No	99.9999	10.0000	1.0001	100.001	0.2001	4/16/99	1330	ATM	66	82	48
L	Yes	99.9999	10.0000	1.0000	100.000	0.2000	4/17/99	1635	ATM	68	84	43
L	Yes	99.9999	10.0000	1.0000	100.000	0.2000	6/19/99	1050	ATM	49	72	45
L	No	99.9999	10.0000	1.0000	100.000	0.2000	7/17/99	1625	ATM	65	83	49

Dates From 7/18/99
Through 9/16/99

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale Mettler
Model AE100
SN K04827

Level	Recall- brated	100g Weight	10g Weight	1.0g Weight	100mg Weight	20mg Weight	Date	Time	Tech	Wet Bulb	Dry Bulb	% RH
V	No	99.9996	10.0000	1.0001	.1000	.0201	7/18/99	16:04	ATM	63	77	49
V	Yes	99.9994	10.0000	1.0001	.1000	.0201	7/19/99	18:35	ATM	64	77	49
V	Yes	99.9996	10.0000	1.0002	.1000	.0202	7/20/99	18:54	ATM	64	85	80
V	Yes	99.9994	10.0001	1.0001	.1000	.0201	7/21/99	21:06	ATM	64	84	50
V	Yes	99.9998	10.0000	1.0000	.1000	.0200	7/22/99	21:45	ATM	64	80	47
V	Yes	99.9998	10.0000	1.0000	.1000	.0200	7/23/99	07:45	ATM	62	76	45
V	No	99.9998	10.0000	1.0000	.1000	.0200	7/24/99	13:49	ATM	66	80	47
V	Yes	99.9998	10.0001	1.0000	.1000	.0201	8/3/99	21:17	ATM	70	84	49
V	Yes	99.9998	10.0001	1.0000	.1000	.0201	8/4/99	17:05	ATM	69	83	49
V	No	99.9998	10.0001	1.0001	.1000	.0200	8/5/99	21:06	ATM	65	78	49
V	Yes	99.9998	10.0000	1.0000	.1000	.0200	8/6/99	15:36	ATM	68	81	50
V	No	99.9999	10.0000	1.0000	.1000	.0200	8/7/99	15:15	ATM	66	80	47
V	Yes	99.9994	10.0001	1.0000	.1000	.0201	8/8/99	13:00	ATM	64	73	46
V	Yes	99.9994	10.0000	1.0001	.1000	.0200	8/9/99	13:25	ATM	69	84	48
V	No	99.9994	10.0001	1.0001	.1000	.0200	8/9/99	16:15	ATM	69	84	46
V	Yes	99.9994	10.0000	1.0000	.1000	.0200	8/10/99	13:27	ATM	70	84	49
V	Yes	99.9998	10.0000	1.0000	.1000	.0200	8/11/99	10:43	ATM	67	81	48
V	Yes	99.9994	10.0000	1.0000	.1000	.0201	8/11/99	20:35	ATM	64	78	46
V	Yes	99.9994	10.0000	1.0001	.1000	.0201	8/13/99	12:30	ATM	64	80	47
V	Yes	99.9994	10.0001	1.0002	.1000	.0201	8/14/99	19:29	ATM	63	76	48
V	Yes	99.9998	10.0000	1.0001	.1000	.0201	8/16/99	11:35	ATM	64	77	48
V	Yes	99.9998	10.0001	1.0001	.1000	.0201	8/17/99	13:50	ATM	68	83	46
V	Yes	99.9998	10.0000	1.0001	.1000	.0200	8/18/99	16:50	ATM	70	84	49
V	No	99.9999	10.0001	1.0000	.1000	.0201	8/22/99	20:52	ATM	68	83	46
V	No	99.9999	10.0001	1.0002	.1000	.0202	8/30/99	11:54	ATM	67	81	48
V	No	99.9998	10.0000	1.0000	.1000	.0200	8/30/99	13:10	ATM	63	76	48
V	Yes	99.9998	10.0000	1.0000	.1000	.0200	8/31/99	18:44	ATM	65	79	44
V	Yes	99.9998	10.0000	1.0000	.1000	.0200	9/2/99	10:32	ATM	60	74	43
V	Yes	99.9998	10.0000	1.0002	.1000	.0200	9/8/99	17:05	ATM	70	84	47
V	Yes	99.9996	10.0001	1.0002	.1000	.0201	9/11/99	12:03	ATM	69	84	46
V	Yes	99.9996	10.0000	1.0001	.1000	.0201	9/12/99	20:58	ATM	70	84	49
V	Yes	99.9996	10.0001	1.0000	.1000	.0200	9/13/99	19:36	ATM	64	73	49
V	Yes	99.9996	10.0001	1.0002	.1000	.0201	9/14/99	13:35	ATM	81	84	49
V	Yes	99.9996	10.0001	1.0000	.1000	.0200	9/14/99	8:15	ATM	81	84	49
V	Yes	99.9996	10.0001	1.0000	.1000	.0200	9/15/99	08:15	ATM	84	88	49
V	Yes	99.9996	10.0001	1.0000	.1000	.0201	9/16/99	08:45	ATM	84	84	46

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale Mettler
Model AE100
SN K04827

Dates From 9/17/99

Through _____

Level	Recall- brated	100g Weight	10g Weight	1.0g Weight	100mg Weight	20mg Weight	Date	Time	Tech	Wet Bulb	Dry Bulb	% RH
V	Yes	99.9998	10.0000	1.0001	100.1	0.2007	9/12/99	2045	ATM	66	79	49
V	Yes	99.9998	10.0000	1.0000	100.1	0.2006	9/18/99	1213	ATM	65	78	48
V	No	99.9998	10.0000	1.0000	100.1	0.2007	9/19/99	1245	ATM	65	78	49
V	Yes	99.9998	10.0000	1.0001	100.1	0.2007	9/23/99	2028	ATM	64	77	47
V	Yes	99.9997	10.0000	1.0000	100.0	0.2001	9/23/99	1145	ATM	64	77	49
V	Yes	99.9999	10.0001	1.0001	100.1	0.2006	9/23/99	2000	ATM	64	77	48
V	No	99.9997	10.0000	1.0000	100.0	0.2000	9/28/99	1340	ATM	68	70	48

Unit: Kuma Wood Classic
 Run: EPA 5
 Date: 9/16/1999
 Technicians: ATTN RLS
 WST20, Form 5

Woodstove Particulate
 Catch Processing Sheet
 Woodstove Data Sheet #5
 EPA M5G-1

Filters

Filter: (E) 938 Beaker # 20 Final Wt. 73.3220 g ✓
 Final Wt. .8384 g ✓ Ml 35 Tare Wt. 73.3160 g ✓
 Tare Wt. .8084 g ✓ Desc. Acetone Net Wt. .0060 g ✓
 Net Wt. .0300 g ✓

Filter: (R) 937 Beaker # _____ Final Wt. _____ g
 Final Wt. .7952 g ✓ Ml _____ Tare Wt. _____ g
 Tare Wt. .7933 g ✓ Desc. _____ Net Wt. _____ g
 Net Wt. .0019 g ✓

Acetone Blank Calculation: Blank done 7/13/99
 Blank Beaker # 1 Final Wt. 65.4847
 Ml 50 Tare Wt. 65.4847
 Desc Acetone Net Wt. .0000
.0000 g : 50 ml = .0000 g/ml

Particulate Catch Calculation

Filter: .0300 g ✓
 Filter: .0019 g ✓
 Beakers: .0060 - (35)(.0000) = .0060 g ✓
 Total Catch Ml of Acetone
 Blank Value/Ml of Acetone
 Total Catch = .0379 g ✓

Unit Kuma Wood Classic
 Run # EPA 5
 Date 9/16/1999
 Technician ATM M.S. T.P.
 WST6-Forml, Rev 8/96

MISCELLANEOUS TEST DATA
 WOODSTOVE DATA SHEET #8

Useable Firebox Dimensions: See QC Section Useable Volume: 2.228 ft³

Dilution Tunnel Draft (If applicable): Start 00.0 Stop 00.0

Test Chamber Air Velocity: Start: 00.0 Stop: 00.0 Avg: 00.0

Wet Bulb/ Start: WB: 62 °F DB: 74 °F 1.5 % Amb Moisture 50 %RH

Dry Bulb Stop: WB: 65 °F DB: 76 °F 1.7 % Amb Moisture 55 %RH

$\bar{X} = 1.60$ % Ambient Moisture $\bar{X} = 52.5$ % Relative Humidity (RH)

Empty Stove Wt: 419.3 lbs.

Stove Wt with Stack (Inc. Oil Seal) Wet: 510.8 lbs. Dry: 509.1 lbs.

Empty Stove Wt with Stack and Ash Ash: — lbs. Total: — lbs.

Kindling Wt. Paper: 0.3 lbs. Wood: 4.0 lbs.

Pre Burn Fuel Wt. 14.3 + 14.2 + 14.2 Total: 42.7 lbs. ✓

Total Kindling and Pre Burn Fuel Wt 47.0 lbs. ✓

Coal Bed Wt-lbs: Range (512.7-512.1) 3.6-3.0 lbs. Actual: 3.2 lbs.

Allowable Amount of Charcoal that can be removed:
 Coal Bed Wt. Range $\frac{3.6}{\text{Upper Wt.}} + \frac{3.0}{\text{Lower Wt.}} \times 12 \times .25 = \underline{.8}$ lbs. ✓

Test Fuel Wt-lbs: Ideal 15.6 lbs. Range: 13.1-14.1 lbs. Actual: 14.6 lbs. ✓

Test Fuel Size (pcs.) (.75 x 1.5 x 5" Flanges) 16 Pcs.

2 x 4's x 15/8 " 3 Pcs 6.2 lbs. 42.5 % ✓

4 x 4's x 15/8 " 2 Pcs 8.4 lbs. 57.5 % ✓

Est. Dry Burn Rate (Kg/Hr.) $\frac{14.6 - (14.6 \times .17556)}{2.2046} \times \frac{60}{970} = \underline{1.2133}$ ✓
 Est. Dry Burn Rate (Kg/Hr)

Est EPA Heat Output (H_{OE}) (19,140) x $\frac{63}{100} \times 1.2133 = \underline{14,630}$ ✓
 (Avg BTU's/Hr) Est Heat Output (H_{OE}) BTU's/Hr

Comments:

Stove Operating Data
Woodstove Test Data Sheet #9
Cold Start

Unit: Kump Wood Classic
Run: EPA 5
Date: 9/16/99
Technician(s): ATM RLS JRP
Data Sheet #9 - Rev 1/98-Pg.1

Fire Started: 0750 P.O.S.T

Warm up and Preburn: Primary Air: Wide open from ignition until the start of preburn when the primary air control(s) was (were) adjusted to the run setting of 7/16" open. At the run setting until the start of the test.

Secondary Air: No Controls, Naturally drafted.

Secondary Burn/Cat Bypass: N/A

Charcoal Bed Preparation: Broke up, raked and leveled the coal bed prior to the addition of each warm up/pre burn fuel charge. Starting 1130 before the start of the test, broke up, raked and leveled the coal bed. In stove for 35 seconds.

Test: Door wide open during loading 1 min 01 sec, then closed.

Primary Air: Wide open from the start of the test (0:00) until 4:55. Adjusted to the run setting of 7/16" open between 4:55 and 5:00. At the run setting of 7/16" open at 5:00 into the run.

Secondary Air:

No Controls, Naturally drafted,

Secondary Burn/Cat Bypass: N/A

Fan: OFF during the entire test. Fan Confirmation Test.

Test Run Anomalies: None.

WOODSTOVE OPERATING DATA
 WOODSTOVE DATA SHEET #9A-1

Wood Data: Kindling: A mix of the below grades

	Size	Mill	Grade	Species
Pre Burn	2X4	CANYON Lumber	# 2 & Better	D. Fir SFC GRN
Test Fuel	2X4	CANYON Lumber	# 2 & Better	D. Fir SFC GRN
	4X4	R.I.B. CONST.	# 1	D. Fir SFC GRN

All grades WCLB Rules unless otherwise noted.

Warm up Information:

- 1st Warm up/Pre Burn Fuel charge (14.3 lbs) added at 0818 .
- 2nd Warm up/Pre Burn Fuel charge (14.2 lbs) added at 0927 .
- 3rd Warm up/Pre Burn Fuel charge (14.2 lbs) added at 1030 .
- 4th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____ .
- 5th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____ .
- 6th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____ .
- 7th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____ .
- 8th Warm up/Pre Burn Fuel charge (_____ lbs) added at _____ .

The coals were scooped out of the stove immediately prior to adding the 3rd pre burn/warm up fuel charge. The stove lost 1.7 lbs. 3.0 lbs. of coals were put back in the stove after the scoop.

All pre burn/warm up fuel pieces were ~~16~~ 16 inches long. All preburn pieces/fuel charges were "ricked" in the stove. The pieces in the bottom layer in each rick contained 2 pcs that were 16 inches long and were loaded flat and perpendicular to the door. The pieces in the second layer in each rick were loaded on their side (edge) approximately parallel to the door and contained 4 pcs 16 inches long. The third layer (and fourth layer if present) was loaded flat, perpendicular to the door and contained 2 pcs 16 inches long. The majority of the pieces in each rick were in the second layer which had an approximate 0.5-1.0" space between pieces. (The loading directions indicate the direction of the longest dimension on each piece relative to the loading door opening.) Each pre burn/warm up fuel charge normally weighs within the weight range allowed for the actual test fuel charge


WOODSTOVE OPERATING DATA
WOODSTOVE DATA SHEET #9A-2

Unit Kamin Wood Classic
Run # EPA 5
Date 9/16/1999
Technician ATM RLS J.P.
Page 2 of 4
WS7-Form2-A, Rev 6/90


Warm up Information (cont.):

Each warm up/preburn fuel charge was ricked in exactly (as much as possible) the same manner and the weight of each rick was usually within the allowable weight range for the test fuel charge. The physical arrangement and alignment of each rick was designed to accomplish three (3) things: (1) The bottom layer was nestled firmly into the coal bed and was as close to being level with the bottom of the stove as possible, thus providing a stable loading platform for the rest of the rick, keeping it in a ricked state (as opposed to a col-lapsed or fallen down state) until the rick reached the charcoal stage and sags or collapses of its own accord. (2) It enhances the flow of primary air through the ricked preburn fuel charge, for the primary air would flow through the spaces between the pieces in the first layer and then up through the spaces between the pieces in the second, third and, if present, fourth layers. (3) It maximized, as much as possible, the surface to volume ratio of each preburn fuel charge, thereby allowing the fire immediate access to as much wood surface as possible and, thereby, insuring uniform charcoalization. All three of these enhance combustion and so get the stove as hot as possible during the warm up period, thereby maximizing the amount of heat (BTU's) stored in the stove. The actual preburn was not started until the stove surface temperatures had maximized and stabilized, thus indicating that the amount of heat stored in the stove had peaked. For this stove, the thermal storage was monitored using the 100

_____ surface temperature(s) and the peak value(s) obtained were 950 of.



Front View



Top View

The arrows indicate the direction of the air flow through the rick.

The primary air was adjusted to the run setting of 7/16" open 5.5 lbs above the upper charcoal bed weight.

WOODSTOVE OPERATING DATA
WOODSTOVE DATA SHEET #9A-3

Unit KUMA Wood Classic
Run # EPA 5
Date 9/16/99
Technician AT Myer
Page 3 of 4
WST5-Form2-Rev11/89


Additional Comments:

Test Start Sequence: ① opened primary air control wide open ② opened door ③ loaded test fuel ④ cleared coals away from the LPAO ⑤ Photograph ⑥ closed door.

Total Elapsed Time: 1:01

Test Fuel Charge Loading Information:

Test Fuel Charge and Loading Sequence Diagram



Front of stove view
4 X 4's: 3 & 5
2 X 4's: 1, 2 & 4
Loading Sequence: 1, 2, 3, 4 & then 5 last,
Driest Pcs in Load 2 & 4, 3

Loaded the test fuel charge on an essentially level, medium sized, Average/cool coal bed (in appearance, color and temperature for a medium low burn rate. The coal bed was not as bright in color orange, more dull.

Ignition 0:33 Load 1101. VC to baffle 1:05

1:35 VC curling down onto tops of 3 & 5

Flames on left side of 6 stack in front.

2:19 Flames / 2nds forward past 1st tube, CO @ 11.4%

2:45 Front tube igniting - flickering on/off.

3:00 " " fairly well ignited

3:19 Gas Balance

5:00 14.0% CO₂ / 1.30% CO

(*)

WOODSTOVE OPERATING DATA
WOODSTOVE DATA SHEET #9A-4

Additional Comments:

- 5:00 (Cont.) All Flames ↓, Maintained a hot pocket with a VC to baffle. Also Secondaries / flames above 3 & 5, Secondaries seem unstable, Till N 5:45. Were pulsing a little, slowly Ok after 5:45. Flames on top of 5 in back.
- 6:15 almost out of balance. VC ↑ and curling onto tops of 3 & 5.
- 6:42 Out of balance 9.0 / .91 gases still ↓
- 7:34 Back in 8.3 / .81
- 8:00 Barely in, Stable fire. No flames forward past the front tube.
- 9:00 Gases improving
- 10:00 in - barely
- 11:52 Out 8.5 / .87 VC ↓ The LPAO and air wash air flows are not as vigorous.
- 14:30 Back in.
- 16:00 VC ↑ out again
- 18:07 still Out 9.8 / 1.03
- 18:30 flames starting to come forward on L. side
- 19:50 Back in.
- 21:47 1st flash off front tube
- 22:30 gases improving 11.7 / .62

FUEL MOISTURE
WOODSTOVE TEST DATA SHEET #10

Unit: Kuma Wood Clinic
Run: EPA 5
Date: 9/16/1979
Technician: ATM D.S. J.P.
WST1-Form7-Rev11/89

Room Temperature: 70 °F

Correction Factor: 0

NOTE: Record readings to the nearest 0.5% moisture
Uncor Values are corrected for temperature: Yes No
Time Test Fuel Moisture Readings taken at: 1020
Calibration Checks: X Y 12.5 12.5 22.0 22.5

Pc #	Dimen	Use	Top		Bottom		Side		Piece Avg Corrected
			Uncor	Cor	Uncor	Cor	Uncor	Cor	
1	2x4x8'	K	12.0	12.8	12.0	12.8	12.5	13.3	12.967
2									
3									
4	2x4x8'	P	18.0	19.2	18.0	19.2	18.0	19.2	19.200
5	"		22.0	23.7	22.0	23.7	22.0	23.7	23.700
6	"		21.0	22.6	21.5	23.1	21.0	22.6	22.767
7	"	∨	20.0	21.4	20.0	21.4	19.5	20.9	21.233
8									86.900
9									
10	2x4-15 1/8"	T	18.0	19.2	18.0	19.2	18.0	19.2	19.200
11	"		19.0	20.3	19.0	20.3	19.0	20.3	20.300
12	"	∨	22.0	23.7	22.0	23.7	22.0	23.7	23.700
13									
14	4x4-15 1/8"	T	19.0	20.3	18.0	19.2	18.0	19.2	19.567
15	"	∨	22.0	23.7	22.0	23.7	22.0	23.7	23.700
16									106.467
17									
18									
19	5x15x75	SPACERS	20.0	21.4	20.0	21.4	20.0	21.4	21.400
20									OUT-SPACERS

	Kindling	Pretest Fuel	Test Load
% Moisture - Dry Basis:	12.967%	21.725%	21.293%
% Moisture - Wet Basis:	11.479%	17.848%	17.555%

To obtain Wet from Dry: $\frac{100 \times \% \text{ Dry Rdg.}}{100 + \% \text{ Dry Rdg.}} = \% \text{ Moisture, Wet Basis}$

Acceptable Ranges: 16-20% wet; 19-25% dry
(17.5 - 22.5 on Meter [Uncor reading] at 70°F)

Key for Use: K= Kindling P= Pretest Fuel T= Test Fuel

WOOD DENSITY DETERMINATION
WOODSTOVE TEST DATA SHEET #11

Unit: Kuma Wood Classic
Run#: EPA 5
Date: 9/16/1999
Technician: ATM RLS J.P.
WST2-form11-Rev 6/90

Wood Piece: Nominal Dimensions: 3 1/2" X 3 1/2" X 1 1/2" in
Depth (D): IN 1.521 cm 3.863 ✓
Width (W): IN 3.555 cm 9.030 ✓
Length (L): 3.508 cm in
3.505 cm in
3.503 cm in
3.498 cm in
Length \bar{X} = IN 3.504 ✓ cm 8.900 ✓
Volume: 310.458 cm³ ✓
(D X W X L)

MOISTURE: Room Temperature: 70 °F Correction Factor: 0
Uncorrected Meter Readings Corrected for temperature: Yes No

NOTE: Record moisture meter readings to the nearest 0.5%

	Uncor	Cor	%
Top:	<u>22.0</u>	<u>23.7</u>	<u>✓</u>
Bottom:	<u>22.0</u>	<u>23.7</u>	<u>✓</u>
Side:	<u>22.0</u>	<u>23.7</u>	<u>✓</u>
\bar{X} :		<u>23.700</u>	<u>✓</u>

Avg % Moisture (Dry) 23.700 %
Avg % Moisture (Wet) 19.159 %
Scale: Leveled In Out
Zeroed: In Out

Wet Weight: 193.1 g Dry Weight: 162.4 g

% Moisture Dried Basis: 15.899 %
[1 - (Dry Wt ÷ Wet Wt)] X 100

	Date	Time	Temp	OF
Into Dryer	<u>9/16/99</u>	<u>1020</u>	<u>214</u>	<u>OF</u>
Out of Dryer	<u>9/22/99</u>	<u>1549</u>	<u>214</u>	<u>OF</u>

(Minimum Time in Dryer: 24 hrs.) Minimum Dryer Temp 100°C (212°F)

Density = 162.4 g ÷ 310.458 cm³ = .5231 g/cm³
(dry wt) (volume)

Pellet Fuel Moisture Content Determination

Tare Beaker Wt. _____ g
Wet Wt: _____ g - _____ g = _____ g
Gross Wet Wt. Tare Beaker Wt. Net Wet Wt.
Dry Wt: _____ g - _____ g = _____ g
Gross Dry Wt. Tare Beaker Wt. Net Dry Wt.

% Moisture Dried Basis: _____ %
[1 - (Net Dry Wt ÷ Net Wet Wt.)] X 100

END Wt: 612.3 lbs.

Minute Time	Scale Wt	lbs left	Burn Rate	CO ₂		O ₂		T/C(1) T/C(2)		T/C(3)		SO ₂ v.	PPM	Static Press.	Comments
				v.	%CO ₂	v.	%O ₂	Wet Bulb	Dry Bulb	% H ₂ O	Calc W/B				
0	526.9	14.6	0	284	6.31	52.1	13.02	80	119	2.1	105			7039	Flow
5	526.0	13.7	.9	464	11.48	30.4	7.60	88	134	3.0	129			7075	SO ₂ 1.5
10	525.4	13.1	.6	331	8.20	46.9	11.72	110	152	7.3	129			7057	SO ₂ 1.5
15	524.8	12.5	.6	347	8.60	45.0	11.24	116	147	9.2	131			7056	SO ₂ 1.5
20	524.1	11.8	.7	389	9.63	40.8	10.19	120	148	10.5	134			7057	SO ₂ 1.5
25	523.4	11.1	.7	461	11.41	34.6	8.65	123	150	12.0	135			7060	
30	522.7	10.4	.7	499	12.35	31.7	7.92	124	153	12.0	138			7062	
35	522.0	9.7	.7	544	13.46	27.2	6.80	124	154	12.5	141			7063	
40	521.3	9.0	.7	589	13.33	27.9	6.97	125	156	12.0	140			7063	
45	520.7	8.4	.6	484	11.98	33.2	8.30	123	154	12.0	140			7062	
50	520.0	7.7	.7	499	12.35	31.5	7.87	122	152	11.5	140			7062	
55	519.5	7.2	.5	573	12.69	30.9	7.72	121	153	10.5	137			7061	
60	518.9	6.6	.6	578	12.81	30.4	7.60	121	153	10.5	137			7062	Flow
65	518.2	5.9	.7	542	13.41	28.1	7.02	121	153	10.5	138			7062	SO ₂ 1.5
70	517.6	5.3	.6	529	13.09	28.9	7.22	120	153	10.5	138			7062	SO ₂ 1.5
75	517.1	4.8	.5	579	12.84	29.7	7.42	118	152	9.5	135			7062	SO ₂ 1.5
80	516.6	4.3	.5	578	12.81	29.2	7.30	118	153	9.5	135			7062	SO ₂ 1.5
85	516.1	3.8	.5	467	11.56	33.8	8.45	115	150	8.8	133			7060	
90	515.7	3.4	.4	472	10.94	36.3	9.07	113	146	8.5	133			7057	
95	515.4	3.1	.3	410	10.15	39.3	9.82	110	142	7.5	129			7055	
100	515.1	2.8	.3	332	8.23	46.1	11.52	105	138	6.4	124			7053	
105	514.9	2.6	.2	306	7.59	48.3	12.07	101	133	5.5	121			7049	
110	514.7	2.4	.2	292	7.24	49.2	12.29	99	130	5.3	119			7047	
115	514.4	2.3	.1	293	6.77	50.6	12.14	96	127	4.6	115			7045	
														1676	
														4439	

BURN TEST AND FLUE GAS DATA
 WOODSTOVE DATA SHEET #12
 WST2-Form 14 Rev 1/88

END WT.: 512.3 lbs.

Unit: KUMA WOOD CLASSIC Date: 9/16/99
 RUN: EPA 5 Technician(s): ATM, PLS, J.P.
 Page: 3 of 3

Minute	Scale Wt	lbs left	Burn Rate	CO ₂		O ₂		CO		Ba1		Wet Bulb	Dry Bulb	% H ₂ O	Calc W/B	Stack	SO ₂ PPM	Static Press.	Comments
				v.	%CO ₂	v.	%O ₂	v.	%CO	v.	%								
120	514.5	2.2	.1	254	6.31	57.7	12.92	22.5	1.12	5.6	93	124	4.1	114	288		7044	Flow	
125	514.4	2.1	.1	252	6.26	52.1	13.02	21.8	1.10	5.7	91	122	3.9	112	281		7042	SO₂ 1.5	
130	514.3	2.0	.1	252	6.26	52.4	13.09	20.6	1.02	6.1	89	121	3.5	111	275		7041	SO₂ 1.5	
135	514.2	1.9	.1	252	6.26	52.4	13.09	21.3	1.07	5.8	88	120	3.4	110	270		7040	SO₂ 1.5	
140	514.1	1.8	.1	247	6.13	53.0	13.24	21.7	1.09	5.6	87	119	3.2	110	267		7040	SO₂ 1.5	
145	514.0	1.7	.1	245	6.08	53.3	13.31	22.8	1.14	5.3	87	118	3.2	110	264		7040		
150	513.9	1.6	.1	214	5.32	55.8	13.94	27.9	1.40	3.8	86	118	3.1	109	261		7039		
155	513.8	1.5	.1	213	5.30	55.9	13.96	27.5	1.39	3.8	86	118	3.1	109	257		7038		
160	513.8	1.5	0	211	5.25	56.0	13.99	27.9	1.40	3.7	85	117	3.0	108	254		7037		
165	513.7	1.4	.1	200	4.98	57.3	14.21	27.5	1.39	3.6	85	116	3.0	107	250		7036		
170	513.6	1.3	.1	193	4.80	58.0	14.49	28.6	1.43	3.4	85	116	3.0	107	247		7036		
175	513.5	1.2	.1	181	4.57	59.0	14.74	28.9	1.43	3.2	85	115	3.0	106	242		7036		
180	513.5	1.2	0	183	4.56	59.2	14.79								<u>3156</u>		<u>1449</u>	Flow	
185	513.4	1.1	.1	188	4.68	58.7	14.66	28.5	1.41	3.2	84	113	2.9	105	239		7036	SO₂ 1.5	
190	513.3	1.0	.1	193	4.80	58.2	14.54	27.6	1.39	3.4	84	112	2.9	104	236		7035	SO₂ 1.5	
195	513.3	1.0	0	194	4.83	58.1	14.57	27.1	1.36	3.5	83	112	2.8	103	234		7035	SO₂ 1.5	
200	513.2	.9	.1	199	4.95	57.8	14.44	26.7	1.33	3.6	83	111	2.8	103	232		7034	SO₂ 1.5	
205	513.1	.8	.1	198	4.93	57.9	14.46	25.7	1.29	3.8	83	111	2.8	103	230		7034		
210	513.1	.8	0	203	5.05	57.5	14.36	27.1	1.35	3.6	83	111	2.8	103	228		7034		
215	513.0	.7	.1	206	5.12	57.2	14.29	27.2	1.36	3.7	82	111	2.7	103	226		7033		
220	512.9	.6	.1	206	5.12	57.4	14.34	26.4	1.32	3.9	83	111	2.8	103	225		7032		
225	512.9	.6	0	201	5.00	58.0	14.49	25.1	1.22	4.0	83	112	2.8	102	223		7032		
230	512.8	.5	.1	200	4.98	58.1	14.51	26.7	1.33	3.8	82	112	2.7	102	222		7032		
235	512.8	.5	0	202	5.02	58.0	14.49	26.0	1.30	3.8	82	111	2.7	102	221		7032		
240	512.8	.5	0	202	5.02	58.0	14.49	24.7	1.23	4.1	83	110	2.9	102	220		7032		
															<u>2736</u>		<u>1401</u>		

TEMPERATURES
RECORD SHEET #14
WST2-Form14 Rev7/96

Unit: KUNNING WOOD C Date: 9/16/19
Run: EPAS Technician(s):
Page: 1 of 3 ATM / Remr'gng DIS

T/C#	Minute	Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn	Room Temp	Tunnel	C. Gas Box	Impinger Out	5G-1 Filter	5G-1 Condenser	Hot Box
0	1255	362	488	349	472	439	848	910	76	92	249	39	78	48	840
5	1300	374	477	346	465	440	731	1471	75	113	248	39	80	36	1049
10	05	477	482	335	462	440	689	1368	74	104	250	39	83	36	820
15	10	478	476	326	457	439	701	1375	74	100	250	39	85	36	1034
20	15	496	473	319	444	437	729	1429	74	101	250	39	85	36	960
25	20	534	475	314	442	434	758	1427	74	102	250	39	85	36	992
30	25	571	481	311	446	431	770	1507	75	103	250	39	86	36	994
35	30	608	490	308	453	427	795	1520	75	104	250	39	86	36	1044
40	35	631	500	308	462	424	832	1533	74	106	250	39	87	36	1081
45	40	610	511	312	472	420	852	1434	75	105	250	39	88	36	1124
50	45	595	519	316	481	417	905	1368	76	105	250	39	88	36	1117
55	50	594	526	320	487	415	939	1330	76	106	250	39	88	36	1110
60	55	600	533	323	495	414	988	1331	76	107	250	39	88	36	1106
65	1400	617	542	328	507	413	1006	1348	75	107	250	39	88	37	1116
70	05	624	550	332	509	412	996	1340	76	107	250	39	88	37	1136
75	10	623	555	337	516	411	993	1176	77	107	249	39	88	37	1171
80	15	644	558	342	523	411	1005	1192	77	108	249	39	88	37	1210
85	20	630	561	348	531	412	995	1210	77	107	250	39	88	37	1205
90	25	612	563	355	535	413	980	1184	76	106	250	39	88	37	1228
95	30	592	563	360	536	415	975	1258	76	105	250	39	88	37	1274
100	35	542	561	364	535	416	964	1147	76	102	249	38	88	37	1196
105	40	502	558	370	529	418	942	1112	77	101	250	38	88	37	1147
110	45	475	552	374	520	419	928	1093	77	100	250	37	88	37	1127
116	50	449	545	375	512	420	907	990	78	100	250	37	88	37	1131
120	55	410	526	378	508	423	892	1438	78	100	250	37	88	37	1131

13340 14551 8072 11780 19137 21228 31053 1816

TEMPERATURES
RECORD SHEET #14
WST2-Form14 Rev7/96

Unit: KUMA WOOD CLASSIC Date: 9/16/99
 Run: EPA5 Technician(s): ATH, RUS, JR
 Page: 2 of 3

T/C#	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Minute/Time	Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn	Room Temp	Tunnel	C. Gas Box	Impinger Out	5G-1 Filter	5G-1 Condenser	Com. Glass	Hot Box
120	434	537	373	506	422	892	967	76	99	250	37	88	37	1096	249
125	418	528	369	500	424	884	958	77	99	250	37	88	37	1060	249
130	407	520	365	494	426	869	952	77	98	250	37	88	37	1056	249
135	398	512	363	490	427	857	930	77	98	250	37	88	37	1039	249
140	390	505	361	486	429	845	905	77	98	250	37	88	37	1030	249
145	382	498	360	482	430	836	892	78	97	249	38	89	37	923	249
150	375	491	357	478	431	829	871	77	96	249	38	89	37	892	249
155	370	483	352	474	431	820	857	78	97	250	38	89	37	875	249
160	364	477	348	465	431	808	837	77	96	250	38	89	37	871	250
165	356	470	344	459	430	798	816	77	96	250	38	89	38	835	250
170	351	464	341	452	429	785	801	77	96	250	38	89	38	820	250
175	344	458	338	445	426	770	782	77	95	250	38	89	37	808	250
180	337	451	335	438	423	756	769	77	94	250	38	88	37	807	250
185	331	444	333	433	420	747	762	77	93	250	38	88	38	814	250
190	326	439	331	428	417	742	758	77	92	249	38	87	38	811	250
195	322	433	330	424	414	740	747	77	92	250	38	87	38	839	250
200	318	429	329	421	412	742	744	77	91	250	39	87	38	841	257
205	317	425	329	418	409	743	742	77	89	250	39	86	38	857	250
210	312	422	330	416	406	747	739	77	90	250	39	86	38	860	249
215	314	419	330	414	404	739	736	77	91	250	39	86	38	868	249
220	312	416	330	404	402	736	727	78	91	250	39	86	38	890	250
225	309	414	331	412	400	718	717	78	90	250	39	86	38	870	249
230	308	410	331	411	398	713	713	78	91	250	39	86	38	857	249
235	306	407	331	410	397	713	708	76	91	250	39	86	38	865	249
240	3817	5109	3970	5029	4902	8831	8862	996	996	250	39	86	38	865	249

8406 14,052 8240 10757 19,038 18,824 19,430 1857

T/C#	Minute	Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn Catalyst	Room Temp	Tunnel	C. Gas Box	Impinger Out	5G-1 Filter	5G-1 Condenser	Gen. det.	Hot Box
240	16:55	303	404	331	408	395	714	705	75	90	250	39	85	38	875	250
245	17:00	301	402	331	406	394	716	703	75	89	250	40	85	38	878	249
250	05	299	400	332	404	392	715	701	76	89	250	40	84	38	890	249
255	10	298	399	332	403	391	713	699	77	90	250	40	84	38	902	249
260	15	298	398	333	403	389	702	691	77	91	250	40	84	38	875	249
265	20	296	397	332	402	388	699	688	77	91	250	40	85	38	868	249
270	25	295	395	331	400	387	697	683	77	91	250	40	85	38	867	250
275	30	290	395	332	400	386	696	4870	534							
280	35															
285	40	293	396	331	405	393	698	65353	490	55	250	40	85	38	875	250
290	45	293	396	331	405	393	698	65353	490	55	250	40	85	38	875	250
295	50	423	480	339	461	414	818	1006	76							
300	55	432	480	339	461	414	818	1006	76							
305	00															
310	05															
315	10															
320	15															
325	20															
330	25															
335	30															
340	35															
345	40															
350	45															
355	50															

AVG. STONE TEMP. CHANGE
 START: 490.4
 STOP: 366.6
 ΔT: -58.8

REAR 17 JUL 18

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-1

Site: Myren Consulting, Woodinville, WA Date: 9/16/99 Analyte: CO₂

Source: Kuma Wood Classic Run #: EPA 5

Zero Cyl #: 719 430 Conc. 00.0 % CO₂ Cyl Press: 1850 psi

Certified by: Oxarc Date: 4/1/99

Span Cyl #: 350-794 Conc. 12.5 % CO₂ Cyl Press: 1310 psi

Certified by: Oxarc Date: 3/26/99

Analyzer: Make: Horiba Model: PIR-2000 SN: 607024

Range: 0 - 25.0% CO₂ Analyzer Output: 0 - 1.0 v.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter: _____

EPA Span Value = 25.0% CO₂

EPA Control Limits = + 2.5% of 25.0% CO₂ = + 0.625% CO₂

Pre Run Audit: By: RLS Time: 1120 Temp: 71 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	.000	00.0	00.0	.000	.0446	.0446	+0.18
Span	50.0	.500	12.5	49.4	.490	12.1246	-.3754	-3.00

Comments:

Post Run Audit: By: RLS Time: 1735 Temp: 76 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	.000	00.0	00.0	.000	.0446	.0446	+0.18
Span	50.0	.500	12.5	49.5	.490	12.1246	-.3754	-3.00

Comments:

+ Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Exp \% (ppm)}} \times 100$

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-2

Site: Myren Consulting, Woodinville, WA Date: 9/16/99 Analyte: O₂

Source: Kuma Wood Classic Run #: EPA 5

Zero Cyl #: 719 430 Conc. 00.0 % O₂ Cyl Press: 1850 psi

Certified by: Oxarc Date: 4/1/99

Span Cyl #: 250-794 Conc. 12.5 % O₂ Cyl Press: 1310 psi

Certified by: Oxarc Date: 3/26/99

Analyzer: Make: Taylor Model: OA 137 SN: 137/4772

Range: 0 - 25.0% O₂ Analyzer Output: 0 - 100 mv.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter:

EPA Span Value = 25.0% O₂

EPA Control Limits = + 2.5% of 25.0% O₂ = + 0.625% O₂

Pre Run Audit: By: RLS Time: 1120 Temp: 71 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ%
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	00.0	00.0	00.1	00.0	00.050	+0.0050	+0.02
Span	12.5	50.0	12.5	12.5	49.4	12.3409	-0.1591	-1.27

Comments:

Post Run Audit: By: RLS Time: 1735 Temp.: 76 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ%
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	00.0	00.0	00.1	00.0	00.050	+0.0050	+0.02
Span	12.5	50.0	12.5	12.5	49.4	12.3409	-0.1591	-1.27

Comments:

+ Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Exp \% (ppm)}} \times 100$

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-3

Site: Myren Consulting, Woodinville, WA Date: 9/16/99 Analyte: CO

Source: Kuma Wood Classic Run #: EPA 5

Zero Cyl #: 719 430 Conc. 00.0 % CO Cyl Press: 1850 psi

Certified by: Oxarc Date: 4/1/99

Span Cyl #: 250-794 Conc. 2.5 % CO Cyl Press: 1310 psi

Certified by: Oxarc Date: 3/26/99

Analyzer: Make: Infra Red Model: 702 D SN: 113

Range: 0 - 10.0% CO Analyzer Output: 0 - 100 mv.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter: _____

EPA Span Value = 5.0% CO

EPA Control Limits = +2.5% of 5.0% CO = + 0.125% CO

Pre Run Audit: By: RLS Time: 1120 Temp: 71 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	00.0	00.0	0.00	00.0	-0.0093	-0.0093	-0.19
Span	2.50	50.0	2.50	2.50	50.0	2.4914	-0.0086	-0.34

Comments:

Post Run Audit: By: RLS Time: 1735 Temp.: 76 °F

Audit Results

Point #	Expected Response			Actual Response			+ Conc. Difference	Δ %
	Meter	DVM	%	Meter	DVM	%		
Zero	00.0	00.0	00.0	0.00	00.1	-0.0043	-0.0043	-0.09
Span	2.50	50.0	2.50	2.45	48.9	2.4364	-0.0636	-2.54

Comments:

+ Conc. Difference = Act % - Exp (Std) %

Zero % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Full Scale Value}} \times 100$

Span % Difference = $\frac{\text{Act \% (ppm)} - \text{Exp \% (ppm)}}{\text{Exp \% (ppm)}} \times 100$

Unit: Kuma Wood Chocio
 Run: EPA 5
 Date: 9/16/199
 Technicians: ATM / RLS, J.P.
 WST6-Form3-Rev11/89

QUALITY CHECKS
 WOODSTOVE DATA SHEET #16

Ambient = Tr: _____ °F T/C#30: _____ °F
 Thermocouple Check (at ambient): T/C#1: 65 °F; T/C#2: 65 °F;
 T/C #3: 66 °F; T/C #4: 66 °F; T/C #5: 67 °F;
 T/C #6: 67 °F; T/C #7: 67 °F; T/C #8: 67 °F;
 T/C #9: 67 °F; T/C #10: 67 °F; T/C #11: 67 °F;
 T/C #12: 66 °F; T/C #13: 66 °F; T/C #14: 66 °F;
 T/C #15: 66 °F; T/C #16: 66 °F; T/C #17: 67 °F;
 T/C #18: 66 °F; T/C #19: _____ °F; T/C #20: _____ °F;
 T/C #21: _____ °F; T/C #22: _____ °F; T/C #23: _____ °F;
 T/C #24: _____ °F; T/C #25: _____ °F; T/C #26: _____ °F;

Comments: _____

Thermocouple Readout: Pretest Zero/Span Check and Calibration:
 Zero (0°F) : 001 °F Adj Post Test Check Zero (0°F): 001 °F % Difference +0.05%
 Span (2000°F): 1999 °F Adj Span (2000°F): 2000 °F 0

(Allowable % Difference = 1.5%. Use formulas on Woodstove Data Sheet #15 to calculate % Difference)

Thermocouple Readout Pretest Linearity Check

0°F = 000 °F; 200°F = 200 °F; 400°F = 399 °F;
 600°F = 599 °F; 800°F = 800 °F; 1000°F = 1000 °F;
 1200°F = 1200 °F; 1400°F = 1400 °F; 1600°F = 1599 °F
 1800°F = 1800 °F; 2000°F = 2000 °F

Combustion Gas (CO₂, O₂, CO) Train Leak Check: Pre Post
 Draft (Static) Gauge Zero Check: Pre Post

Scale Check Pre (Wt, #'s): 570.8 - 575.8 5.0 lbs. OK (RLS)
 Post (Wt, #'s): 572.3 - 577.3 5.0 lbs. OK (RLS)

Stack cleaned prior to the run: Yes _____ No
 Tunnel cleaned prior to the run: Yes _____ No

DILUTION TUNNEL CALCULATIONS

3/31/96

File Name: KumaEPA3

Stove Manufacturer: Kuma

Model Number: Wood Classic

Lab Name: MYREN

Test Date: 9/14/99

Run Number: EPA 3

Meter Box Y Factor: 1.0151

Barometric pressure (in): 28.6067

Gas meter temp (ave): 92

delta H(ave): 0.900

Gas meter initial reading: 732.504

Gas meter final reading: 877.782

Front catch (acetone) mg: 6.1

first filter catch (mg): 9.8

second filter catch (mg): 0.2

tunnel flow (ave cfm): 147.784

Emission Rate(g/hr): 1.073

Emission Rate(M5H) : 1.930

vs/VmTs: 0.0115

vs ave: 873.272

Tunnel average temp (°f): 101.926

Test time(min): 260

Fuel Load(lb. wet): 14.6

Wood moisture(%wet): 17.582

Burn rate(dry kg/hr): 1.260

Samp vol(scf): 134.935

front filter number: 934

back filter number: 933

acetone beaker number: 30

PRELIMINARY RESULTS

FINAL RESULTS

AUDITED

DATA SUMMARY

MODEL: Wood Classic

RUN: EPA 3

DATE: 9/14/99

DBR: 1.260

GPH UNADJ: 1.073

ADJ: 1.929961393

MYREN CONSULTING CERTIFICATION TEST DATA

Run Time (min)	PITOT DELTAP (- INCH H2O)	TNL TEMP (°F)	GAS METER RDG (ft3)	GAS METER TEMP (°F)	GAS METER DELTA H (in.H2O)	TUNNEL VELOCIT (ft/min)	PROP RATE (%)	dDGM vol std (ft3)
0	0.043	101	732.504	81	0.900	872.58		
10	0.043	118	738.071	82	0.900	885.70	104.6	5.274
20	0.043	118	743.655	84	0.900	885.70	103.0	5.270
30	0.043	122	749.216	86	0.900	888.76	102.9	5.229
40	0.043	118	754.771	88	0.900	885.70	101.4	5.205
50	0.043	113	760.347	89	0.900	881.86	101.0	5.215
60	0.043	111	765.919	90	0.900	880.32	100.9	5.201
70	0.043	107	771.507	91	0.900	877.23	100.4	5.207
80	0.043	105	777.113	91	0.900	875.68	100.7	5.224
90	0.043	103	782.703	92	0.900	874.13	100.1	5.199
100	0.043	101	788.289	93	0.900	872.58	99.7	5.186
110	0.043	99	793.869	93	0.900	871.02	99.4	5.181
120	0.043	98	799.465	94	0.900	870.24	99.7	5.196
130	0.043	98	805.050	94	0.900	870.24	99.4	5.176
140	0.043	97	810.645	94	0.900	869.46	99.4	5.185
150	0.043	97	816.238	94	0.900	869.46	99.4	5.183
160	0.043	96	821.835	95	0.900	868.68	99.1	5.178
170	0.043	96	827.425	95	0.900	868.68	99.1	5.171
180	0.043	96	833.024	96	0.900	868.68	99.1	5.170
190	0.043	95	838.615	96	0.900	867.90	98.8	5.163
200	0.043	95	844.220	96	0.900	867.90	99.1	5.176
210	0.043	95	849.900	96	0.900	867.90	100.4	5.245
220	0.043	95	855.390	97	0.900	867.90	96.9	5.061
230	0.043	95	860.950	97	0.900	867.90	98.1	5.125
240	0.043	95	866.580	97	0.900	867.90	99.4	5.190
250	0.043	94	872.175	97	0.900	867.12	98.6	5.157
260	0.043	94	877.782	97	0.900	867.12	98.9	5.168
270						0.00	0.0	0.000
280						0.00	0.0	0.000
290						0.00	0.0	0.000
300						0.00	0.0	0.000
310						0.00	0.0	0.000
320						0.00	0.0	0.000
330						0.00	0.0	0.000
340						0.00	0.0	0.000
350						0.00	0.0	0.000

KumaEPA3

DATE 1/14/1999 PAGE 1 OF 2

MODEL # Wood Classic RUN # EPA 3

METER BOX # 511-M

METER Y 1.0151

FILTER # (F) 934 (R) 933

PRE TEST LEAK RATE = .000 CFM @ -16.0 IN. HG, 1745/1745

FILTER SIZE: 110 mm

POST TEST LEAK RATE = .000 CFM @ -15.75 IN. HG, .018/.018

PROBE LENGTH 24" glass

Mag

TIME		METER READING CU. FT.	PITOT dp	INL TEMP. (°F)	METER TEMP. (°F)	GAS METER dh	VAC IN. Hg	VELOCITY TRAVERSE			
CLOCK	ELAPSED							POINT	LOCATION	ΔP	TEMP
1215	00	732.504	-043	101	81	.90	0	N-1	0.5"	-032	105
25	10	738.071	-043	118	82	.90	0	2	1.5"	-037	106
35	20	743.655	-043	118	84	.90	0	3	4.5"	-039	106
45	30	749.216	-043	122	86	.90	0	4	5.5"	-038	105
55	40	754.771	-043	118	88	.90	0	W-1	0.5"	-036	106
1305	50	760.347	-043	113	89	.90	0	2	1.5"	-042	106
15	60	765.919	-043	111	90	.90	0	3	4.5"	-041	106
25	70	771.507	-043	107	91	.90	0	4	5.5"	-040	106
35	80	777.113	-043	105	91	.90	0	Avg.	-038	105.750	
45	90	782.703	-043	103	92	.90	0	Pilot Leak Check			
55	00	788.289	-043	101	93	.90	0	Pre	<input checked="" type="checkbox"/>	Post	<input checked="" type="checkbox"/>
1405	10	793.869	-043	99	93	.90	0	Cp =	0.99	N	
15	20	799.465	-043	98	94	.90	0			1	
25	30	805.050	-043	98	94	.90	0			2	
35	40	810.645	-043	97	94	.90	0			3	
45	50	816.238	-043	97	94	.90	0			4	
55	60	821.835	-043	96	95	.90	0				
1505	70	827.425	-043	96	95	.90	0				
15	80	833.024	-043	96	96	.90	0				
25	90	838.615	-043	95	96	.90	0				

Pilot Leak Check
Pre Post

Cp = 0.99
N
1
2
3
4
→ W 1 2 3 4 (3/4)

*-point of Avg. delta p

$$Q_s = \left(\frac{\sqrt{(\Delta P \times BP)}}{T(^{\circ}R)} \right) \times 3167.2 = 138.961 \text{ cfm}$$

BP = START 28.66 in Hg
60 28.64
120 28.61
180 28.59
240 28.58
300 28.56 ✓
X = 28.6067

10.5
1.1 2.3

DATE 9/14/99

PAGE 2 OF 2

MODEL # WOOD CLASSIC RUN # EPA 3

METER BOX # 571 M

METER Y 1.0157

FILTER # (F)934 (R)933

PRE TEST LEAK RATE = .000 CFM @ -16.0 IN. HG .1745/.1745

FILTER SIZE: 119 MM

POST TEST LEAK RATE = .000 CFM @ -15.75 IN. HG .018/.018

PROBE LENGTH 246 mm

TIME		METER READING CU. FT.	PITOT dp	TNL TEMP. (°F)	METER TEMP. (°F)	GAS METER dh	VAC IN. Hg	VELOCITY TRAVERSE			
CLOCK	ELAPSED							POINT	LOCATION	ΔP	TEMP
1535	00	844.220	-.043	95	96	.90	0	N-1	0.5"	-.032	105
45	10	849.900	-.043	95	96	.90	0	2	1.5"	-.037	106
55	20	855.390	-.043	95	97	.90	0	3	4.5"	-.039	106
1605	30	860.950	-.043	95	97	.90	0	4	5.5"	-.038	105
15	40	866.580	-.043	95	97	.90	0	W-1	0.5"	-.036	106
25	50	872.175	-.043	94	97	.90	0	2	1.5"	-.042	106
35	60	877.782	-.043	94	97	.90	0	3	4.5"	-.041	106
	70	(145.278)						4	5.5"	-.040	106
	80							Avg. <u>-.038</u> <u>105.75°</u>			
	90							Pilot Leak Check Pre <input checked="" type="checkbox"/> Post <input checked="" type="checkbox"/>			
	00							Cp = <u>0.99</u>			
	10							N 1 2 3 4 → W 1 2 <u>3*</u>			
	20							*-point of Avg. delta p			
	30							Qs = $\frac{\sqrt{(\Delta P \times BP)}}{T(^{\circ}R)} \times 3167.2 =$			
	40							<u>138.961</u> cfm			
	50							BP = <u>571 M</u> <u>29.66</u> in Hg			
	60							60 28.64			
	70							120 28.61			
	80							130 28.59			
	90							240 28.53			
								260 28.56			

$\bar{X} = 28.6267$

WOODSTOVE DATA SHEET #4-1: INITIAL FILTER WEIGHTS (TARE WEIGHTS)

Into Dessicator: Date 1/9/99 Time 1445 By ATM Front Half Back Half

Manufacturer: Schleicher & Schuell Size: 11 cm Lot.No.: Z8951 Grade: #25 G/ASS
Order No: 06220

Filter #	First Wt	Date	Time	By	Second Wt	Date	Time	By	Third Wt	Date	Time	By
926	.7740	3/6/99	11:40	T.M.	.7739	3/15/99	1652	ATM				
927	.7938		11:41	T.M.	.7938		1651	ATM				
928	.7985		11:42	T.M.	.7985		1650	ATM				
929	.7909		11:43	T.M.	.7912		1649	ATM				
930	.7948		11:44	T.M.	.7950		1648	ATM				
931	.8041		11:45	T.M.	.8042		1647	ATM				
932	.7917		11:46	T.M.	.7918		1646	ATM				
933	.8047		11:47	T.M.	.8048		1645	ATM				
* 934	.7981		11:48	T.M.	.7918		1644	ATM	.7917	3/16/99	2130	Jm
935	.7861		11:49	T.M.	.7861		1643	ATM				
936	.7827		11:50	T.M.	.7828		1643	ATM				
937	.7935		11:51	T.M.	.7933		1642	ATM				
938	.8086		11:52	T.M.	.8084		1641	ATM				
939	.8060		11:53	T.M.	.8058		1640	ATM				
940	.8151		11:54	T.M.	.8151		1639	ATM				
941	.8252		11:55	T.M.	.8249		1638	ATM				
942	.7982		11:56	T.M.	.7983		1637	ATM				
943	.7822		11:57	T.M.	.7822		1636	ATM				
* 944	.7938		11:58	T.M.	.7968		1635	ATM	.7968	3/16/99	2131	Jm
945	.7944		11:59	T.M.	.7943		1635	ATM				
946	.7852		12:00	T.M.	.7850		1634	ATM				
947	.7731		12:01	T.M.	.7735		1633	ATM				
948	.7938		12:02	T.M.	.7940		1632	ATM				
949	.7838		12:03	T.M.	.7837		1631	ATM				
950	.8040		12:04	T.M.	.8038		1630	ATM				

Checked by Jm Date: 3/16/99 Time 2133

QA REWEIGH

Filter #	WT	Date	Time	By
929	.7912	3/16/99	2136	Jm
941	.8248	3/16/99	2134	Jm
949	.7837	3/16/99	2133	Jm

BALANCE ROOM ENVIRONMENTAL CONDITIONS

WB	DB	%RH	Date	Time	By
64	79	43	3/16/99	1135	ATM
66	81	45	3/15/99	1622	ATM
65	82	39	3/16/99	2025	ATM

Post Test Weighing Session Scale Check
 1st 2nd 3rd QC
 0.0000 0.0000 0.0000 Δ.0001
 1.0000 1.0000 1.0000 0.9999

WOODSTOVE DATA SHEET #4-2:
INITIAL BEAKER WEIGHTS (TARE WEIGHTS)

Into Dessicator: Date: 8/20/99 Time: 1500 By: A. Timmyan

Glass
↓

Beaker #	First Wt	Date	Time	By	Second Wt	Date	Time	By	Third Wt	Date	Time	By
1	65.4841	8/27	2059	Jm	65.4845	8/30/99	1211	ATM				
2	66.1509	8/27	2118	Jm	66.1514		1204	ATM				
3	67.8582		2116	Jm	67.8579		1207	ATM				
4	67.5890		2108	Jm	67.5891		1210	ATM				
6	67.4270		2119	Jm	67.4274		1213	ATM				
7	65.5444		2105	Jm	65.5446		1220	ATM				
8	66.0219		2221	Jm	66.0218		1205	ATM				
9	66.9297		2120	Jm	66.9296		1215	ATM				
10	66.0906		2114	Jm	66.0902		1209	ATM				
11	65.7072		2112	Jm	65.7020		1217	ATM	65.7028	9/8/99	1717	Jm
13	57.8946	✓	2110	Jm	57.8948	✓	1218	ATM				
									65.7021	9/11	1232	ATM
									65.7022	9/13	1934	Jm
20	73.3159	8/27	2125	Jm	73.3160	8/31/99	1320	ATM				
21	71.0002	8/27	2126	Jm	71.0003	✓	1325	ATM				
22	71.8322	9/11/99	1240	ATM	71.8322	9/13	1719	Jm				
23	70.7376	8/27	2131	Jm	70.7382	8/30/99	1259	ATM	70.7376	9/8	1715	Jm
24	73.2173	8/27	2130	Jm	73.2182		1301	ATM	73.2176	9/8	1713	Jm
25					72.6505	✓	1257	ATM	72.6504	9/8	1716	Jm
26	71.7865	8/27	2132	Jm	71.7868	8/31/99	1322	ATM				
27	72.3294	9/11/99	1235	ATM	72.3294	9/8	1718	Jm				
28	70.5955	8/27	2127	Jm	70.5956	8/31/99	1324	ATM				
29	71.5183	8/27	2133	Jm	71.5185	✓	1318	ATM				
30	70.7845	8/27	2128	Jm	70.7855	8/30/99	1302	ATM	70.7857	9/8	1714	Jm
31	69.6658	8/27	2129	Jm	69.6655	8/31/99	1327	ATM				
23	70.7375	9/11	1233	ATM								
24	73.2175	9/11	1242	ATM								

SS

cont. 23
cont. 24

Checked By: A. Timmyan Date: 9/11 & 13/99 Time: ATM

QA REWEIGH

Beaker #	WT	Date	Time	By

BALANCE ROOM ENVIRONMENTAL CONDITIONS

WB	DB	IRH	Date	Time	By
68	33	46	8/27/99	2052	ATM
67	31	43	8/30/99	1154	ATM
63	76	48	8/31/99	1310	ATM
70	84	47	9/8/99	1705	ATM
69	84	46	9/11/99	1202	ATM
64	77	49	9/13/99	1926	ATM

WOODSTOVE DATA SHEET #4-2:
INITIAL BEAKER WEIGHTS (TARE WEIGHTS)

Into Dessicator: Date: 6/1/99 Time: 1400 By: A.T. Myer

Beaker #	First Wt	Date	Time	By	Second Wt	Date	Time	By	Third Wt	Date	Time	By
1	65.4847	7/17/99	1636	OBM	65.4847	7/18/99	1612	ATM	← BLANK			
2	66.1804		1638	OBM	66.1506	↓	1614	ATM	7/13/99			
3	67.8572		1640	OBM	67.8567	↓	1616	ATM				
4	67.5887		1642	OBM	67.5880	↓	1618	ATM				
6	67.4268		1644	OBM	67.4266	↓	1620	ATM				
7	65.5436		1648	OBM	65.5437	↓	1622	ATM				
8	66.0212		1650	OBM	66.0211	↓	1623	ATM				
9	66.6294		1652	OBM	66.6295	↓	1625	ATM				
10	66.0889		1654	OBM	66.0888	↓	1627	ATM				
11	65.7015		1656	OBM	65.7013	↓	1628	ATM				
12	56.0655		1658	OBM	56.0653	↓	1632	ATM				
13	57.8948		1700	OBM	57.8944	↓	1630	ATM				

11111111111111111111

Checked By: A.T. Myer Date: 7/18/99 Time: 1800

QA REVIEW

BALANCE ROOM ENVIRONMENTAL CONDITIONS

Beaker #	WT	Date	Time	By

WB	DB	ZRH	Date	Time	By
65	78	49	7/17/99	1825	ATM
63	77	45	7/18/99	1604	ATM

WOODSTOVE DATA SHEET #4-3: CONSTANT FINAL WEIGHTS

WST5-Form9, Pg1, Rev4/90
 Unit KUNNING WOOD C. 11/20/16
 Run # EPA 3
 Date: 9/14/19

FINAL BEAKER WEIGHTS

Beaker #	Into Dessic	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By
30	L	9/16	1748	ATM	70.7912	9/16	1304	ATM	70.7912	9/19	1150	TM				

FINAL FILTER WEIGHTS

Filter #	Into Dessic	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By
934	.8022	9/14	1650	ATM	.8016	9/15	0831	ATM	.8017	9/17	2053	TM	.8015	9/18	1243	ATM
935	.8259	9/14	1655	ATM	.8049	9/15	0831	ATM	.8050	9/18	1312	TM	.8050	9/23/15	2030	Su

QA REWEIGH: FINAL WEIGHTS

Date	Beaker #	Final Wt	By
Date	Filter #	Final WT	By

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighing Session	1999		WB	DB	ZRH
	Date	Time			
1	9/15	0820	66	82	42
2	9/17	2015	66	79	49
3	9/18	1217	65	78	48
4	9/19	1245	62	75	47
5	9/23	0028	65	79	47

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighing Session	1999		WB	DB	ZRH
	Date	Time			
6					
7					
8					
9					
Comments					

WOODSTOVE DATA SHEET #4-3: CONSTANT FINAL WEIGHTS

Blank
7/18/99

WST5-Form 9, Rev 4/99
Unit: KUMMA Wood Chamber
Run # _____
Date: 7/18/99

FINAL BEAKER WEIGHTS

Beaker #	Into Dessic	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By
1	✓	7/11/99	1425	ATM	65.4852	8/4/99	1715	ATM	65.4846	8/8/99	1742	0811	65.4847	8/9	1642	ATM

FINAL FILTER WEIGHTS

Filter #	Into Dessic	Date	Time	By	First	Date	Time	By	Second	Date	Time	By	Third	Date	Time	By

QA REWEIGH: FINAL WEIGHTS

Date	Beaker #	Final Wt	By
Date	Filter #	Final WT	By

SCALE ROOM ENVIRONMENTAL CONDITIONS

Weighing Session	Date	Time	By	WB	DB	%RH
1	8/4	1705	ATM	69	83	49
2	8/8	1700	ATM	64	78	46
3	8/9	1615	ATM	69	84	46
4						
5						

SCALE ROOM ENVIRONMENTAL CONDITIONS

6						
7						
8						
9						
Comments						

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Dates From 1/9/99
Through 7/17/99

Scale Mettler
Model AE100
SN K04827

Level	Recall- brated	100g Weight	10g Weight	1.0g Weight	100mg Weight	20mg Weight	Date	Time	Tech	Wet Bulb	Dry Bulb	% RH
✓	Yes	99,9999	10,0001	1,0002	1003	0203	1/9/99	1243	ATM	58	70	48
✓	No	100,0002	10,0000	1,0000	1000	0200	1/14/99	1113	ATM	62	75	47
✓	Yes	99,9999	10,0002	1,0000	0999	0201	1/23/99	1100	ATM	63	72	48
✓	Yes	99,9999	10,0000	1,0000	1000	0201	1/24/99	1318	ATM	59	74	45
✓	Yes	99,9999	10,0002	1,0000	1000	0200	2/1/99	0910	ATM	55	69	39
✓	Yes	99,9999	10,0001	1,0001	1002	0201	2/2/99	0939	ATM	60	73	46
✓	Yes	99,9999	10,0001	1,0001	1001	0200	2/3/99	1555	ATM	63	76	48
✓	Yes	99,9999	10,0000	1,0001	1001	0201	2/7/99	1235	ATM	62	76	45
✓	Yes	99,9999	10,0000	1,0000	1000	0200	2/10/99	1600	ATM	63	78	45
✓	Yes	99,9999	10,0000	1,0001	1000	0200	2/19/99	0246	ATM	64	80	44
✓	No	99,9999	10,0000	1,0000	1000	0200	2/21/99	1312	ATM	65	80	44
✓	No	99,9999	10,0000	1,0000	1000	0200	3/5/99	1435	ATM	64	79	41
✓	Yes	99,9999	10,0000	1,0000	1000	0200	3/6/99	1135	ATM	64	79	43
✓	Yes	99,9999	10,0000	1,0000	1000	0200	3/13/99	1526	ATM	65	80	44
✓	Yes	99,9999	10,0000	1,0000	1000	0200	3/14/99	1355	ATM	63	78	43
✓	Yes	99,9999	10,0001	1,0001	1001	0200	3/15/99	1622	ATM	66	81	45
✓	No	100,0001	10,0000	1,0000	1000	0200	3/16/99	2025	ATM	65	82	39
✓	Yes	99,9999	10,0000	1,0000	1001	0200	3/12/99	1615	ATM	62	79	42
✓	Yes	99,9999	10,0000	1,0000	1000	0200	3/18/99	2140	ATM	66	84	43
✓	Yes	99,9999	10,0000	1,0000	1000	0200	3/20/99	1300	ATM	64	84	32
✓	Yes	99,9999	10,0000	1,0000	1001	0201	3/21/99	2215	ATM	61	74	47
✓	Yes	99,9999	10,0000	1,0000	1001	0200	3/22/99	2122	ATM	65	83	33
✓	Yes	99,9999	10,0000	1,0001	1000	0200	3/23/99	1115	ATM	69	84	46
✓	Yes	99,9999	10,0000	1,0002	1001	0201	3/24/99	1120	ATM	37	79	43
✓	Yes	99,9999	10,0000	1,0002	1001	0201	3/29/99	2038	ATM	59	72	45
✓	No	99,9999	10,0002	1,0002	1001	0202	3/30/99	0610	ATM	66	83	47
✓	No	99,9999	10,0000	1,0000	1001	0201	3/21/99	1200	Sur	64	80	41
✓	No	99,9999	10,0000	1,0000	1001	0201	4/5/99	1930	ATM	64	80	41
✓	Yes	99,9999	10,0001	1,0001	1001	0201	4/6/99	1030	ATM	61	75	44
QC	Self- check	100,0003	10,0001	1,0001	1001	0201	4/6/99	1330	ATM	65	85	33
✓	Yes	99,9999	10,0001	1,0001	1001	0200	4/7/99	1424	ATM	63	80	30
✓	No	99,9999	10,0000	1,0001	1001	0201	4/8/99	1346	ATM	67	80	30
✓	Yes	99,9999	10,0000	1,0000	1000	0200	4/16/99	1230	ATM	66	82	32
✓	Yes	99,9999	10,0000	1,0000	1000	0200	4/17/99	1625	ATM	68	84	43
✓	No	99,9999	10,0000	1,0000	1000	0198	6/19/99	1050	ATM	49	72	45
✓	No	99,9999	10,0001	1,0002	1001	0202	7/17/99	1825	ATM	65	83	49

Dates From 7/18/99
Through 9/16/99

WOODSTOVE DATA SHEET #4-4
SCALE QA SHEET

Scale Mettler
Model AE100
SN K04827

Level	Recall- brated	100g Weight	10g Weight	1.0g Weight	100mg Weight	20mg Weight	Date	Time	Tech	Wet Bulb	Dry Bulb	% RH
V	No	99.9996	10.0000	1.0001	1.0000	.0201	7/18/99	16:04	ATM	63	77	49
V	Yes	99.9997	10.0000	1.0001	1.0001	.0201	7/19/99	18:35	ATM	64	77	49
V	Yes	99.9998	10.0000	1.0002	1.0003	.0202	7/20/99	18:54	ATM	64	85	80
V	Yes	99.9999	10.0001	1.0001	1.0001	.0201	7/21/99	15:06	ATM	69	84	50
V	Yes	99.9999	10.0000	1.0000	1.0000	.0200	7/22/99	21:45	ATM	64	80	47
V	Yes	99.9998	10.0000	1.0000	1.0000	.0200	7/23/99	02:45	ATM	62	76	45
V	Yes	99.9998	10.0000	1.0000	1.0000	.0200	7/24/99	13:49	ATM	66	80	47
V	Yes	99.9998	10.0001	1.0002	1.0002	.0201	8/1/99	21:19	ATM	70	84	47
V	No	99.9998	10.0001	1.0001	1.0001	.0200	8/5/99	17:05	ATM	69	83	49
V	Yes	99.9998	10.0000	1.0000	1.0000	.0200	8/6/99	21:06	ATM	65	78	49
V	Yes	99.9998	10.0000	1.0000	1.0000	.0200	8/7/99	15:36	ATM	68	81	50
V	No	99.9999	10.0000	1.0001	1.0000	.0200	8/7/99	15:15	ATM	66	80	47
V	Yes	99.9999	10.0000	1.0001	1.0001	.0201	8/8/99	13:00	ATM	64	73	46
V	Yes	99.9999	10.0000	1.0001	1.0001	.0200	8/9/99	12:25	ATM	68	82	48
V	Yes	99.9999	10.0000	1.0001	1.0001	.0200	8/9/99	16:15	ATM	69	84	46
V	No	99.9999	10.0000	1.0001	1.0001	.0200	8/9/99	13:29	ATM	69	84	46
V	Yes	99.9999	10.0000	1.0000	1.0000	.0200	8/10/99	10:43	ATM	67	81	48
V	Yes	99.9999	10.0000	1.0000	1.0001	.0200	8/11/99	10:43	ATM	64	78	46
V	Yes	99.9999	10.0000	1.0001	1.0001	.0201	8/11/99	20:35	ATM	64	78	46
V	Yes	99.9999	10.0000	1.0001	1.0001	.0201	8/13/99	12:30	ATM	64	80	47
V	Yes	99.9999	10.0001	1.0002	1.0002	.0201	8/14/99	19:29	ATM	63	76	48
V	Yes	99.9998	10.0000	1.0001	1.0001	.0201	8/16/99	11:35	ATM	64	77	48
V	Yes	99.9998	10.0000	1.0001	1.0001	.0201	8/17/99	13:50	ATM	68	83	46
V	Yes	99.9999	10.0000	1.0001	1.0001	.0200	8/17/99	16:50	ATM	70	84	49
V	No	99.9999	10.0001	1.0000	1.0000	.0201	8/22/99	20:52	ATM	68	83	46
V	No	99.9999	10.0001	1.0002	1.0002	.0202	8/30/99	11:54	ATM	67	81	48
V	No	99.9998	9.9999	1.0000	1.0000	.0200	8/31/99	13:10	ATM	63	76	48
V	Yes	99.9999	10.0000	1.0000	1.0000	.0200	9/1/99	18:04	ATM	65	79	44
V	Yes	99.9998	10.0000	1.0000	1.0000	.0200	9/2/99	10:32	ATM	60	74	43
V	Yes	99.9998	10.0000	1.0002	1.0002	.0200	9/8/99	17:05	ATM	70	84	47
V	Yes	99.9996	10.0001	1.0002	1.0002	.0201	9/11/99	12:02	ATM	69	84	46
V	Yes	99.9996	10.0000	1.0001	1.0001	.0201	9/12/99	20:58	ATM	70	84	49
V	Yes	99.9996	10.0001	1.0002	1.0002	.0201	9/13/99	19:36	ATM	64	77	49
V	Yes	99.9996	10.0001	1.0002	1.0002	.0201	9/14/99	18:35	ATM	61	73	49
V	Yes	99.9996	10.0001	1.0002	1.0002	.0201	9/14/99	08:15	ATM	61	73	49
V	Yes	99.9996	10.0001	1.0002	1.0002	.0201	9/15/99	08:20	ATM	64	76	49
V	Yes	99.9996	10.0001	1.0001	1.0001	.0201	9/16/99	08:45	ATM	64	76	46
V	No	99.9996	10.0000	1.0000	1.0000	.0200	9/16/99	16:53	ATM	70	84	46



Dates From

9/17/99

WOODSTOVE DATA SHEET #4-4

SCALE QA SHEET

Scale Mettler

Model AE100

SN K04827

Through _____

Level	Recallibrated	100g Weight	10g Weight	1.0g Weight	100mg Weight	20mg Weight	Date	Time	Tech	Wet Bulb	Dry Bulb	% RH
✓	Yes	99.9999	10.0000	1.0000	.1000	.0200	9/17/99	0945	ATTM	66	79	48
✓	Yes No.	99.9999	10.0000	1.0000	.1000	.0200	9/18/99	1219	ATTM	65	78	48
✓	Yes	99.9998	10.0000	1.0000	.1000	.0200	9/21/99	0928	ATTM	65	79	47
✓	Yes	99.9997	10.0000	1.0000	.1000	.0200	9/21/99	1145	ATTM	64	77	47

Unit: Kumar Hood Clinic
 Run: EPH 3
 Date: 9/14/1999
 Technicians: ATM RLS
 MST20, Form 5

Woodstove Particulate
 Catch Processing Sheet
 Woodstove Data Sheet #5
 RPA M5G-1

Filter #	Final Wt.	Tare Wt.	Net Wt.	Beaker #	MI	Desc.
(F) 934	8015	7917	0098	30	35	Acetone
(F) 933	8050	8048	0002			

Filter #	Final Wt.	Tare Wt.	Net Wt.	Beaker #	MI	Desc.
70 7912	70.7851	70.7912	0061			

Acetone Blank Calculation: Blank done 7/18/99

Blank Beaker #	Final Wt.	Tare Wt.	Net Wt.
1	65.4847	65.4847	0.0000

8 : 50 ml = 10000 g/ml

Particulate Catch Calculation

Filter:	Final Wt.	Tare Wt.	Net Wt.
Filter:	0098	0002	0096
Beakers:	0061	(35)(0000)	0061
Total Catch MI of Acetone			
Blank Value/MI of Acetone			
Total Catch = 0161			

Unit Kumon Wood Classic
 Run # EPA 3
 Date 2/14/1999
 Technician ATM
 MST6-Form1, Rev8/96
 MISCELLANEOUS TEST DATA
 WOODSTOVE DATA SHEET #8

Useable Firebox Dimensions: See QC Section Useable Volume: 2.228 ft³

Dilution Tunnel Draft (If applicable): Start 00.0 Stop 00.0

Test Chamber Air Velocity: Start: 00.0 Stop: 00.0 Avg: 00.0

Wet Bulb/Start: WB: 64 °F DB: 76 °F 1.6 % Amb Moisture 51 %RH

Dry Bulb Stop: WB: 70 °F DB: 82 °F 2.0 % Amb Moisture 54 %RH

Empty Stove Wt: 419.3 lbs.

Stove Wt with Stack (Inc. Oil Seal) Wet: 570.8 lbs. Dry: 529.1 lbs.

Stove Wt with Stack and Ash: — lbs. Total: — lbs.

Kindling Wt. Paper: 0.3 lbs. Wood: 4.0 lbs.

Pre Burn Fuel Wt. 14.7 + 14.7 + 14.7

Total Kindling and Pre Burn Fuel Wt. 43.6 lbs.

Coal Bed Wt-lbs: Range (572.7 - 579.1) 3.6 - 3.0 lbs. Actual: 3.4 lbs.

Allowable Amount of Charcoal that can be removed: 1.8 lbs.

Coal Bed Wt. Range $\frac{3.6}{3.0} + \frac{3.0}{12} \times .25 = 1.8$ lbs.

Test Fuel Wt-lbs: Ideal 15.6 lbs. Range: 17.1 - 14.1 lbs. Actual: 14.6 lbs.

Test Fuel Size (pcs.) (.75 x 1.5 x 5" Flanges) 16 pcs.

2 x 4' x 16 1/16" 3 pcs 6.1 lbs. 44.8 %

4 x 4' x 16 1/16" 7 pcs 8.5 lbs. 58.2 %

Est. Dry Burn Rate (Kg/Hr.) 17.1 - (14.6 x 17.582 x 60 = 1,259.6

Est. Dry Burn Rate (Kg/Hr.) 1,259.6

Est EPA Heat Output (HOR) (19,140) x 63 $\frac{100}{100} \times 1,259.6 = 15,188$

Est Heat Output (HOR) BTU's/Hr

Comments:

Stove Operating Data

Woodstove Test Data Sheet #9

Cold Start

Fire Started: 0805 P.D.S.T.

Unit: RunA WJ000 Classic
Run: EPA 3
Date: 9/14/99
Technician(s): ATM, PLS
Data Sheet #9 - Rev 1/98-Pg.2

Warm up and Preburn: Primary Air: Wide open from ignition until the start of preburn when the primary air control(s) was (were) adjusted to the run setting of 5/8" open. At the run setting until the start of the test.

Secondary Air: No controls, Naturally drafted.

Secondary Burn/Cat Bypass: N/A

Charcoal Bed Preparation: Broke up, raked and leveled the coal bed prior to the addition of each warm up/pre burn fuel charge. Starting 1:30 before the start of the test, raked up, leveled the coal bed. In stove for 35 seconds.

Test: Door wide open during loading _____ min _____ sec, then closed.

Primary Air: Wide open during the start of the test until 4:55. Adjusted to the run setting of 5/8" open between 4:55 and 5:00. At the run setting of 5/8" open at 5:00 into the run.

Secondary Air: No controls, Naturally drafted.

Secondary Burn/Cat Bypass: N/A

Fan: ON/OFF during the warm up, ON/OFF High during the preburn, ON/OFF at the start of the test, ON/OFF for the first 30 minutes of the test, ON/OFF High at 30 minutes into the test, ON/OFF for the rest of the test.

Test Run Anomalies:

Non. Egg turn failed out much more than expected. This was supposed to be a medium high.

WOODSTOVE OPERATING DATA
 WOODSTOVE DATA SHEET #9A-1

Wood Data: Kindling: A mix of the below grades

Size	Mill	Grade	Species
Pre Burn	2X4	CANYON LUMBER	D.F.A SFC GEN
Test Fuel	2X4	CANYON LUMBER	D.F.R SFC GEN
		# 2 & Better	
		# 1	D.F.R SFC GEN

All grades WCLB Rules unless otherwise noted.

Warm up Information:



1st Warm up/Pre Burn Fuel charge	(142 lbs) added at	0825
2nd Warm up/Pre Burn Fuel charge	(142 lbs) added at	0925
3rd Warm up/Pre Burn Fuel charge	(142 lbs) added at	1023
4th Warm up/Pre Burn Fuel charge	() lbs) added at	
5th Warm up/Pre Burn Fuel charge	() lbs) added at	
6th Warm up/Pre Burn Fuel charge	() lbs) added at	
7th Warm up/Pre Burn Fuel charge	() lbs) added at	
8th Warm up/Pre Burn Fuel charge	() lbs) added at	

The coals were scooped out of the stove immediately prior to adding the ^{3 lbs} pre burn/warm up fuel charge. The stove lost 1.7 lbs. 3.0 lbs. of coals were put back in the stove after the scoop.

All pre burn/warm up fuel pieces were "ricked" in the stove. The pieces in the bottom layer in each rick contained 2 pcs that were 16 inches long and were loaded flat and perpendicular to the door. The pieces in the second layer in each rick were loaded on their side (edge) approximately parallel to the door and contained 4 pcs 16 inches long. The third layer (and fourth layer if present) was loaded flat, perpendicular to the door and contained 2 pcs 16 inches long. The majority of the pieces in each rick were in the second layer which had an approximate 0.5-1.0" space between pieces. (The loading directions indicate the direction of the longest dimension on each piece relative to the loading door opening.) Each pre burn/warm up fuel charge normally weighs within the weight range allowed for the actual test fuel charge.

Warm up Information (cont.):

Each warm up/preburn fuel charge was ricked in exactly (as much as possible) the same manner and the weight of each rick was usually within the allowable weight range for the test fuel charge. The physical arrangement and alignment of each rick was designed to accomplish three (3) things: (1) The bottom layer was nestled firmly into the coal bed and was as close to being level with the bottom of the stove as possible, thus providing a stable loading platform for the rest of the rick, keeping it in a ricked state (as opposed to a collapsed or fallen down state) until the rick reached the charcoal stage and sags or collapses of its own accord. (2) It enhances the flow of primary air through the ricked preburn fuel charge, for the primary air would flow through the spaces between the pieces in the first layer and then up through the spaces between the pieces in the second, third and, if present, fourth layers. (3) It maximized, as much as possible, the surface to volume ratio of each preburn fuel charge, thereby allowing the fire immediate access to as much wood surface as possible and, thereby, insuring uniform charcoalization. All three of these enhance combustion and so get the stove as hot as possible during the warm up period, thereby maximizing the amount of heat (BTU's) stored in the stove. The actual preburn was not started until the stove surface temperatures had maximized and stabilized, thus indicating that the amount of heat stored in the stove had peaked. For this stove, the thermal storage was monitored using the 100 surface temperature(s) and the peak value(s) of 950 obtained were _____ of _____.



The arrows indicate the direction of the air flow through the rick.

The primary air was adjusted to the run setting of 5/8" open 60 lbs above the upper charcoal bed weight.

Additional Comments:


③ Opened Primary Air Control Wide Open ③ Opened door
 ④ Loaded Test Fuel into Stove ⑤ Cleaned controls cavity
 from top part of the LPD ⑥ Photograph ⑦ closed door

Test Start Sequence:

① Turned Fan Off
 Air Control Wide Open ③ Opened door

Test Fuel Charge Loading Information:

Test Fuel Charge and Loading Sequence Diagram



FRONT
 of stove view

4 X 4's: 3 & 5

2 X 4's: 1, 2 & 4

Loading Sequence: 1, 2, 3, 4, 5

Driest Pcs in Load 2 & 4, 3

Loaded the test fuel charge on an essentially level, Medium to large sized, average to hot coal bed (in appearance, color and temperature for a Medium high burn rate.

Ignition: NO130 Load 01HS

110 VC to baffle

2114 Flames / seconds past front tube

2152 Gas Balance

3155 Engulfed,

8100 Flames ↓, Maintained VC to baffle w/ 2nds / flames
 above 3 & 5, Front Tube Flickering on/off, stayed
 in balance.

8:10 CO ↓, Never lost balance. Very good start.

Room Temperature: 69 °F
 Correction Factor: 0

NOTE: Record readings to the nearest 0.5% moisture

Uncor values are corrected for temperature: Yes No

Time Test Fuel Moisture Readings taken at: 10:30

Calibration Checks: X Y Z 12.5 12.5 22.0 22.5

#	Dimen	Use	Top			Bottom			Side			Piece Avg
			Uncor	Cor	Use	Uncor	Cor	Use	Uncor	Cor	Use	
1	24x8'	K	12.0	12.0	12.0	12.0	12.0	12.5	13.3			
2												
3												
4	24x8'	P	21.5	23.1	21.5	23.1	21.5	23.1	23.1	23.1	23.1	23.1
5	"	↑	20.5	22.0	21.0	22.6	21.0	22.6	23.1	23.1	23.1	23.1
6	"	↑	21.5	23.1	21.5	23.1	21.5	23.1	23.1	23.1	23.1	23.1
7	"	↑	21.0	22.6	21.5	23.1	21.0	22.6	23.1	23.1	23.1	23.1
8												
9												
10	24x16 1/2"	T	18.0	19.7	18.0	19.7	18.0	19.7	19.7	19.7	19.7	19.7
11	"	↑	21.5	23.1	21.5	23.1	21.0	22.6	23.1	23.1	23.1	23.1
12	"	↑	19.5	20.9	19.5	20.9	19.0	20.3	20.3	20.3	20.3	20.3
13												
14	44x16 1/2"	T	19.0	20.3	19.0	20.3	18.5	19.8	19.8	19.8	19.8	19.8
15	"	↑	22.0	23.7	22.0	23.7	22.0	23.7	23.7	23.7	23.7	23.7
16												
17												
18												
19	51x15x15 spaces		22.0	23.0	22.0	23.0	21.4	22.0	21.4	21.4	21.4	21.4
20												

Kindling	Pretest Fuel	Test Load
12.96%	22.84%	21.33%
11.47%	18.59%	17.58%

% Moisture - Dry Basis:
 % Moisture - Wet Basis:

To obtain Wet from Dry: $100 \times \% \text{ Dry Rdg.} = \% \text{ Moisture, Wet Basis}$
 $100 + \% \text{ Dry Rdg.}$

Acceptable Ranges: 16-20% wet; 19-25% dry
 (17.5 - 22.5 on Meter [Uncor reading] at 70°F)

Key for Use: K = Kindling P = Pretest Fuel T = Test Fuel

WOOD DENSITY DETERMINATION
WOODSTOVE TEST DATA SHEET #11

Unit: Kuma Wood Classic
Run#: EPA 3
Date: 9/14/1999
Technician: ATM
MST2-form11-Rev 6/90

Wood Piece: Nominal Dimensions:

3 1/2" x 3 1/2" x 1 1/2"
Depth (D): 3.914 cm
Width (W): 8.954 cm

Length (L):

3.488 in
3.492 in
3.492 in
3.492 in
3.498 in

Volume: $(D \times W \times L)$

310.928 cm³

MOISTURE: Room Temperature: 69 °F of Correction Factor: 0

Uncorrected Meter Readings Corrected for temperature: Yes No

NOTE: Record moisture meter readings to the nearest 0.5%

Uncor	Cor
21.0	22.6
21.0	22.6
20.5	22.6
22.400	22.400

Top: 21.0 %
Bottom: 21.0 %
Side: 20.5 %
X: 22.400 %

Wet Weight: 171.0 g Dry Weight: 143.8 g

% Moisture Dried Basis: 15.906 %

Date: 9/14/99
Time: 0955
Temp: 31.4
Into Dryer: 9/14/99
Out of Dryer: 9/22/99
Minimum Time in Dryer: 24 hrs. Minimum Dryer Temp 100°C (212°F)

Density = 143.8 g / 310.928 cm³ = 0.4625 g/cm³

Pellet Fuel Moisture Content Determination

Tare Beaker Wt. _____ g
Wet Wt: _____ g - Gross Wet Wt. Tare Beaker Wt. Net Wet Wt. _____ g
Dry Wt: _____ g - Gross Dry Wt. Tare Beaker Wt. Net Dry Wt. _____ g
% Moisture Dried Basis: [1 - (Net Dry Wt. / Net Wet Wt.)] X 100

END Wt: 512.5 lbs.

Unit: Gamma Wood Classic Date: 9/14/19
 Run: EPA 3 Technician(s): ATL
 Page: 1 of 3 PLS

Minute	Scale Wt	lbs left	Burn Rate	CO ₂		O ₂		Tel	CO		T/C(1)/T/C(2)		T/C(3)		SO ₂		Static Press.	Comments		
				v.	%CO ₂	v.	%O ₂		v.	%CO	Bal	Wet Bulb	Dry Bulb	% H ₂ O	Calc W/B	Stack			v.	PPM
0	512.5	512.5	0	30.2	7.61	44.8	11.94													
5	526.0	13.5	1.1	55.3	13.68	22.7	5.62	545	10.7	0.55	24.9	10.8	16.2							Flow
10	545.2	19.2	1.8	43.2	10.69	37.0	9.24		9.8	0.49	21.8	14.1	18.3							
15	524.4	11.9	1.8	53.3	13.18	28.3	7.07		6.5	0.34	38.8	13.9	18.2							
20	523.5	11.0	1.9	59.2	14.15	25.7	6.42		5.0	0.25	56.6	13.2	19.2							
25	522.6	10.1	1.9	59.5	14.71	23.5	5.87		4.3	0.23	64.0	13.3	19.8							
30	521.7	9.2	1.9	64.1	15.85	18.4	4.60		10.2	0.52	36.5	13.4	20.5							
35	520.8	8.3	1.9	64.2	16.60	17.6	4.40		17.9	0.91	17.6	13.3	20.2							
40	519.9	7.4	1.9	63.2	15.63	18.7	4.67		13.2	0.66	23.7	13.1	19.5							
45	519.1	6.6	1.8	62.2	15.38	19.6	4.90		7.9	0.40	38.4	13.8	18.9							
50	518.3	5.8	1.8	58.9	14.57	23.4	5.85		7.2	0.37	34.4	12.6	18.4							
55	517.8	5.3	1.5	56.9	14.67	25.4	6.35		4.4	0.22	44.0	12.5	18.2							
60	517.2	4.7	1.6	52.3	12.94	29.1	7.22		3.7	0.19	68.1	12.2	17.4							
65	516.7	4.2	1.5	44.9	11.11	36.1	9.02		7.7	0.39	28.5	11.8	16.7							
70	516.3	3.8	1.4	44.2	10.20	38.6	9.64		4.6	0.25	40.8	11.4	16.1							
75	516.0	3.5	1.3	40.4	10.00	39.5	9.82		6.8	0.36	27.8	11.2	15.7							
80	515.7	3.2	1.3	39.2	9.71	40.9	10.22		7.5	0.39	24.9	10.9	15.3							
85	515.4	2.9	1.3	38.2	9.46	41.8	10.44		7.1	0.37	25.6	10.7	15.0							
90	515.1	2.6	1.3	35.4	8.77	44.8	11.19		8.9	0.45	19.5	10.4	14.8							
95	514.9	2.4	1.2	33.3	8.25	46.3	11.57		9.2	0.49	16.8	10.1	14.6							
100	514.8	2.3	1.1	36.1	7.47	49.2	12.29		11.7	0.59	12.7	9.8	14.1							
105	514.7	2.2	1.1	37.0	6.70	51.4	12.84	945	17.8	0.90	3.4	9.5	13.2							
110	514.6	2.1	1.1	35.2	6.38	52.4	13.07		19.2	0.92	6.6	9.2	13.5							
115	514.5	2.0	1.1	24.2	6.13	53.5	13.36		22.3	1.13	5.4	9.1	13.3							

7903

1.485

(42193)

(1.648)

(4.84)

(1.53)

BURN RATE AND FLUE GAS DATA
 WOOD-JVE DATA SHEET #12
 WST2-Form 14 Rev 1/88
 EMO Wt: 572.5 lbs,

Site: KUMA WOOD Classic
 Run: EPA 3
 Page: 3 of 3
 Date: 9/14/99
 Technician(s): ATY, etc.

Minute Time	Scale Wt	Lbs Left	Burn Rate	CO ₂		O ₂		CO		T/C(1)/T/C(2)		T/C(3)		SO ₂		Static Press.	Comments		
				V.	%CO ₂	V.	%O ₂	V.	%CO	Wet Bulb	Dry Bulb	% H ₂ O	Calc W/B	Stack	V.			PPM	
120	415	514.4	1.9	1.1	6.08	53.6	13.39			23.8	1.20	5.1	90	132		481		-7043	Flow
125	30	514.3	1.8	1.1	6.16	53.7	13.41			21.6	1.08	5.7	89	130		475		-7041	SO ₂ 1.5
130	25	514.2	1.9	1.1	5.96	54.5	13.61			22.3	1.11	5.4	89	130		470		-7040	SO ₂ 1.5
135	30	514.1	1.6	1.1	6.83	54.6	13.64			22.7	1.16	5.0	88	128		465		-7039	SO ₂ 1.5
140	35	514.0	1.5	1.1	6.76	55.0	13.74			23.5	1.19	4.8	88	128		460		-7039	SO ₂ 1.5
145	40	513.9	1.4	1.1	6.32	55.1	13.76			24.0	1.20	4.8	88	127		457		-7038	
150	45	513.9	1.4	1.1	5.72	56.9	14.21			24.0	1.20	4.4	88	126		452		-7038	
155	50	513.8	1.3	1.1	5.02	57.7	14.41			26.4	1.33	3.8	87	124		448		-7037	
160	55	513.7	1.2	1.1	4.93	58.2	14.54			27.6	1.40	3.5	87	123		445		-7036	
165	50	513.6	1.1	1.1	4.43	59.8	14.94			32.8	1.64	2.7	87	123		442		-7036	
170	05	513.6	1.1	1.1	4.61	58.9	14.91			30.5	1.53	3.0	87	122		439		-7035	
175	10	513.5	1.0	1.1	4.63	58.8	14.69			31.4	1.58	2.9	87	122		435		-7035	
180	15	513.4	0.9	1.1	4.61	59.4	14.84			28.1	1.41	3.3	87	121		432		-7035	SO ₂ 1.5
185	20	513.4	0.9	1.1	4.58	59.6	14.89			28.3	1.41	3.2	87	121		429		-7034	SO ₂ 1.5
190	25	513.3	0.8	1.1	4.58	59.9	14.96			27.1	1.36	3.4	86	120		427		-7033	SO ₂ 1.5
195	30	513.2	0.7	1.1	4.56	59.7	14.91			28.6	1.42	3.2	88	120		425		-7033	SO ₂ 1.5
200	35	513.2	0.7	1.1	4.53	59.6	14.89			29.5	1.47	3.1	87	120		423		-7033	
205	40	513.1	0.6	1.1	4.56	59.9	14.96			27.6	1.40	3.3	88	120		422		-7031	
210	45	513.1	0.6	1.1	4.41	60.4	15.09			28.6	1.43	3.1	89	120		420		-7031	
215	50	513.0	0.5	1.1	4.43	60.3	15.06			28.4	1.43	3.1	89	120		417		-7030	
220	55	512.9	0.4	1.1	4.51	60.1	15.01			28.0	1.41	3.2	90	120		416		-7030	
225	60	512.9	0.4	1.1	4.09	61.7	15.41			28.8	1.45	2.8	90	119		413		-7030	
230	05	512.8	0.3	1.1	4.19	61.4	15.34			26.9	1.35	3.1	90	118		411		-7030	
235	10	512.8	0.3	1.1	3.96	62.1	15.51			30.0	1.50	2.6	90	119		409		-7030	
																444		-7039	

5912

1834

FWO WT. 512.5 lbs

Unit: Kiln (1000) Cassio Date: 9/14/99
 In: EDA 3 Technician(s): A.T.M.
 age: 3 or 3

Minute Time	Scale Wt	lbs left	Burn Rate	CO ₂		O ₂		CO		T/C(1)/T/C(2)		T/C(3)		SO ₂		Static Press.	Comments	
				v.	%CO ₂	v.	%O ₂	v.	%CO	Wet Bulb	Dry Bulb	% H ₂ O	Calc W/B	Stack	v.			PPM
240	512.7	.2	.1	16.2	40.4	61.7	15.41	29.4	1.48	2.7	90	119	208			0.30	Flow	
245	512.7	.2	0	15.9	3.96	62.3	15.56	27.8	1.39	2.9	90	117	206			0.30	SO ₂ 1.5	
250	512.6	.1	.1	15.3	3.82	62.6	15.64	27.5	1.48	2.6	90	117	204			0.29	SO ₂ 1.5	
255	512.6	.1	0	15.8	3.94	62.3	15.56	28.2	1.42	2.8	90	116	202			0.28	SO ₂ 1.5	
260	512.5	0	.1	16.7	4.16	62.0	15.49	28.5	1.18	3.5	90	117	201			0.28	CO 1.5	
265																		
270																		
275																		
280																		
285																		
290																		
295																		
300																		
305																		
310																		
315																		
320																		
325																		
330																		
335																		
340																		
345																		
350																		
355																		

FLOW

SO₂ 1.5

CO₂ 1.5

O₂ 1.5

CO 1.5

1031V

14636V

216V

1415

21466

1049

PRE BURN DATA
 RECORD SHEET #13
 Test Start wt. Range WST2-Form16

PREP. PRESSURE 1199
 98.66

Unit: Kumho Wood Classic
 Run: EPA 3
 Page: 1 of 1
 Date: 9/14/19
 Technician(s): ATM RLS

Hot Box On

Minute	Scale Weight	Burn Rate	Stack	Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn Catalytic	Room Temp	Static	Comments
0	578.2	0	669	931	592	415	610	499	876	1660	75	-1510	Primary Air Set at 5.78" ORCA
5	577.8	.9	548	881	615	395	623	495	879	1449	76	-1080	Secondary Air Set at N/A
10	576.8	1.0	530	860	625	399	624	490	916	1447	76	-1078	Fan: ON HIGH
15	575.9	.9	516	852	634	398	622	485	1082	1475	75	-1076	TUNNEL ON AT: 1047
20	575.2	.7	493	808	642	395	620	477	1103	1448	75	-1073	Buckets, TALL
25	574.7	.5	470	764	644	389	618	470	1055	1482	74	-1069	AMPLIFIERS SPANNED
30	574.3	.4	441	673	647	386	620	463	1028	1472	75	-1062	Pumps turned on at: 1115
35	574.1	.2	405	623	650	391	618	459	1021	1556	75	-1063	MAKE COALS
40	573.9	.2	380	608	643	392	611	454	1018	1260	74	-1058	
45	573.7	.2	354	550	634	386	602	449	999	1158	76	-1053	Check WB/DB: 86/100 52443
50	573.5	.2	332	502	625	381	588	443	972	1126	75	-1051	
55	573.4	.1	329	485	618	377	578	440	956	1093	75	-1050	
60	573.2	.2	323	468	606	371	562	432	947	1096	76	-1049	Probe IN Tunnel L
65	573.1	.1	312	456	595	364	552	435	933	1021	76	-1048	
70	573.0	.1	311	446	588	362	549	435	928	1047	76	-1047	
75	572.9	.1	306	438	579	356	542	435	906	1045	76	-1046	
80	572.7	.2	301	429	571	352	534	435	893	1036	77	-1045	
85	572.6	.1	298	421	563	347	528	435	895	1008	78	-1045	
90	572.5	.1	294	412	555	342	523	435	890	992	77	-1045	

453.4

TEMPERATURES
RECORD SHEET #14
MST2-Form14 Rev7/96

Unit: KUMA Wood Classic Date: 9/17/18
 Run: EP43 Technician(s):
 Page: 1 of 3 ATM Rem JNE DJS

T/C#	Minute	Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn	Room Temp	Tunnel	C. Gas Box	Impinger Out	5G-1 Filter	5G-1 Condenser	Hot Box	
0	15	412	555	342	523	435	890	992	72	101	248	38	80	48	932	248
5	20	453	538	353	511	435	854	1305	72	125	248	38	82	36	1234	248
10	25	612	530	342	499	435	835	1250	78	118	249	39	85	36	984	249
15	30	603	524	335	486	432	836	1276	78	117	250	39	86	36	1119	250
20	35	702	524	333	482	429	840	1344	79	118	250	39	87	36	1163	249
25	40	735	530	331	483	423	861	1222	79	119	250	38	88	36	1209	249
30	45	766	541	332	489	418	886	1324	78	122	250	39	88	36	1225	249
35	50	715	514	312	506	413	910	1532	79	123	250	39	88	36	1208	249
40	55	764	580	304	519	402	930	1650	79	118	250	39	88	36	1252	248
45	55	755	592	295	532	402	953	1615	79	115	250	39	88	36	1216	248
50	05	739	602	294	542	398	970	1563	78	113	250	39	88	36	1320	248
55	10	715	611	298	550	392	980	1436	79	113	249	39	88	36	1323	248
60	15	688	619	303	556	395	998	1321	80	111	249	39	88	36	1315	250
65	20	644	623	308	560	395	991	1329	80	109	249	39	88	36	1312	250
70	25	600	622	309	562	393	969	1214	81	107	249	39	88	36	1258	250
75	30	581	619	310	563	394	948	1182	80	106	249	40	89	36	1235	250
80	35	565	614	311	562	395	938	1176	80	105	249	39	89	36	1216	250
85	40	544	608	313	558	392	966	1296	81	104	249	39	89	36	1216	250
90	45	615	602	314	551	399	989	1128	81	103	249	39	89	36	1199	249
95	50	486	606	312	542	401	994	1095	81	102	249	39	89	36	1261	249
100	55	414	603	320	535	402	983	1080	81	101	249	39	89	36	1176	249
105	00	441	596	318	526	402	966	1022	81	100	249	39	89	36	1065	249
110	05	424	585	313	516	403	942	988	82	99	249	39	88	37	1045	249
115	10	410	576	308	502	403	922	955	82	99	250	40	88	37	1053	249

14468 13969 7630 19660 9803 29356 30531 P10

TEMPERATURES
RECORD SHEET #14
WST2-Form14 Rev7/96

Unit: Ruppel Wood Classic Date: 9/14/99
 Run: EPA 3 Technician(s): HTM, L...
 Page: 2 of 3

T/C#	Minute/Time	Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn Catalyst	Room Temp	Tunnel	C. Gas Box	Impinger Out	5G-1 Filter	5G-1 Condenser	Gen- 172 nd day	HOT BOX
120	1415	396	525	304	498	404	901	929	82	98	250	40	88	37	1036	248
125	20	384	556	300	490	403	885	915	83	98	250	40	88	37	1026	250
130	25	377	546	295	482	403	864	899	82	98	250	40	88	37	1004	250
135	30	371	537	292	474	403	850	886	83	97	250	40	88	37	977	250
140	35	364	527	290	467	404	841	874	83	97	250	40	88	37	967	250
145	40	359	519	287	460	403	831	870	83	97	250	40	88	37	1028	250
150	45	357	511	282	454	402	802	861	83	97	250	40	88	37	947	250
155	50	346	502	274	449	401	780	847	83	96	250	40	88	37	925	249
160	55	342	493	268	443	400	761	835	83	96	250	40	88	37	912	249
165	50	335	483	262	438	398	742	806	83	96	250	40	88	37	832	249
170	05	330	473	257	431	396	729	801	83	96	249	38	88	37	826	249
175	10	326	464	252	426	394	717	786	84	96	249	37	88	37	819	249
180	15	322	454	248	420	392	709	778	84	96	249	37	88	37	812	249
185	20	317	447	245	416	390	706	770	82	96	249	37	88	37	812	250
190	25	312	440	242	411	388	704	768	82	95	249	37	88	37	814	250
195	30	310	434	241	406	387	702	756	83	96	249	38	88	37	839	250
200	35	306	428	239	402	385	704	746	84	95	249	38	88	37	846	250
205	40	303	423	238	397	383	682	738	84	95	249	38	88	37	797	250
210	45	301	419	239	393	382	674	731	84	95	249	38	88	37	788	250
215	50	297	415	239	389	379	665	724	84	95	249	38	88	37	781	249
220	55	295	411	238	385	377	660	719	84	95	249	39	88	37	787	249
225	00	291	406	236	381	375	645	702	84	95	249	39	88	37	759	249
230	05	288	401	234	376	374	637	697	84	95	250	39	88	37	769	249
235	10	286	396	232	373	372	629	688	85	95	250	39	88	37	763	233

7909 11,050 6334 10,361 9395 17,830 19,106 1999

TEMPERATURES
RECORD SHEET #14
MST2-Form14 Rev7/96

Site: KUWA 0000 CLASSIC Date: 9/14/99
 : EPA 3 Technician(s): ATJ
 Page: 3 of 3 15

T/G#	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Minute Time	Stove Top	Left Side	Back	Right Side	Bottom	Firebox	2nd Burn Catalytic	Room Temp	Tunnel	C. Gas Box	Impinger Out	5G-1 Filter	5G-1 Condenser	Gen- dat	HOT BOX
240	382	392	380	368	370	620	682	84	95	250	39	88	37	722	248
245	380	382	228	364	369	611	678	83	95	250	39	88	37	712	249
250	378	383	226	360	368	604	669	84	94	250	39	88	37	740	249
255	375	378	225	356	366	604	663	84	94	250	39	88	37	760	250
260	372	315	225	352	364	605	662	83	94	250	39	88	37	799	250
265	382	1915	184	180	1832	3044	3359	418							
270	45														
275	376	3734	4988	2421	2135	4322	5306	4322	531					4534	
280	418	512	383	466	397	815	1000	82						327	
285														1358	
290															
295															
300															
305															
310															
315															
320															
325															
330															
335															
340															
345															
350															
355															

PEARL

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-1

MST6-Form8 Rev 5/96

Site: Myren Consulting, Woodinville, WA Date: 9/17/99 Analyte: CO₂
Source: Kuma Wood Classic Run #: EPA 3

Zero cyl #: 719 430 Certified by: Oxarc Date: 4/1/99
Conc. 00.0 % CO₂ - Cyl Press: 1850 psi

Span cyl #: 250 - 794 Certified by: Oxarc Date: 3/26/99
Conc. 125 % CO₂ - Cyl Press: 1310 psi

Analyzer: Make: Horiba Model: PIR-2000 SN: 607024
Range: 0 - 25.0% CO₂ Analyzer Output: 0 - 1.0 v.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter:
EPA Span Value = 25.0% CO₂
EPA Control Limits = + 2.5% of 25.0% CO₂ = + 0.625% CO₂

Pre Run Audit: By: PLS Time: 1110 Temp: 75 °F

Point #	Expected Response		Actual Response		+ Conc. Difference %
	Meter	DVM	Meter	DVM	
Span	50.0	50.0	49.6	49.6	-1.82
Zero	00.0	.000	00.0	.000	+0.446

Audit Results

Post Run Audit: By: PLS Time: 1650 Temp: 80 °F

Point #	Expected Response		Actual Response		+ Conc. Difference %
	Meter	DVM	Meter	DVM	
Span	50.0	50.0	49.5	49.5	-0.3261
Zero	00.0	.000	00.0	.000	+0.446

Audit Results

Comments:

Point #	Expected Response		Actual Response		+ Conc. Difference %
	Meter	DVM	Meter	DVM	
Span	50.0	50.0	49.5	49.5	-0.3261
Zero	00.0	.000	00.0	.000	+0.446

Comments:

+ Conc. Difference = Act % - Exp (Std) %
Zero % Difference = Act % (ppm) - Exp % (ppm) X 100
Full Scale Value
Span % Difference = Act % (ppm) - Exp % (ppm) X 100
Exp % (ppm)

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-2

Site: Myren Consulting, Woodinville, WA Date: 9/14/99 Analyte:
Source: Kuma Wood Classic Run #: EPH 3

Zero CYL #: 719 430 Certified by: Oxarc Date: 4/1/99
CYL Press: 1850 psi
Span CYL #: 250-794 Certified by: Oxarc Date: 3/26/99
CYL Press: 1310 psi

Analyzer: Make: Taylor Model: OA 137. SN: 137/4772
Range: 0 - 25.0% O₂ Analyzer Output: 0 - 100 mv.
Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter:

EPA Span Value = 25.0% O₂
EPA Control Limits = + 2.5% of 25.0% O₂ = + 0.625% O₂

Pre Run Audit: By: PLS Time: 1110 Temp: 75 of

Audit Results

Point #	Expected Response		Actual Response		+ Conc. Difference	Δ%
	Meter	DVM	Meter	DVM		
Zero	00.0	00.0	00.0	00.0	+0.050	+0.02
Span	12.5	50.0	12.5	49.7	-0.842	-0.67

Comments:

Post Run Audit: By: PLS Time: 1650 Temp: 80 of

Audit Results

Point #	Expected Response		Actual Response		+ Conc. Difference	Δ%
	Meter	DVM	Meter	DVM		
Zero	00.0	00.0	00.0	00.0	+0.050	+0.02
Span	12.5	50.0	12.5	49.5	-0.841	-0.67

Comments:

+ Conc. Difference = Act % - Exp (Std) %
Zero % Difference = Act % (ppm) - Exp % (ppm) X 100
Full Scale Value
Span % Difference = Act % (ppm) - Exp % (ppm) X 100
Exp % (ppm)

PRE AND POST TEST ZERO/SPAN CHECK
WOODSTOVE DATA SHEET #15-3

Site: Myren Consulting, Woodinville, WA Date: 9/14/99 Analyte: CO

Source: Kumar Wood Classic Run #: EPA 3

Zero cyl #: 719 430 conc. 00.0 % CO Cyl Press: 1850 psi Date: 4/1/99

Certified by: OXARC

Span cyl #: 250-794 conc. 2.5 % CO Cyl Press: 1310 psi Date: 3/26/99

Certified by: OXARC

Analyzer: Make: Infra Red Model: 702 D SN: 113

Range: 0 - 10.0% CO Analyzer Output: 0 - 100 mv.

Flow: 1.5 SCFH Measured by: Rotameter: X Flowmeter:

EPA Span Value = 5.0% CO
EPA Control Limits = +2.5% of 5.0% CO = + 0.125% CO

Pre Run Audit: By: PLS Time: 1110 Temp: 75 of

Audit Results

Point #	Expected Response		Actual Response		+ Conc. Difference	Δ %
	Meter	DVM	Meter	DVM		
Zero	00.0	00.0	00.0	00.0	-0.093	-0.19
Span	2.50	50.0	2.50	49.9	2.4864	-0.54

Comments:

Post Run Audit: By: PLS Time: 1650 Temp: 80 of

Audit Results

Point #	Expected Response		Actual Response		+ Conc. Difference	Δ %
	Meter	DVM	Meter	DVM		
Zero	00.0	00.0	00.0	00.1	-0.043	-0.09
Span	2.50	50.0	2.41	48.0	2.3914	-4.34

Comments:

+ Conc. Difference = Act % - Exp (Std) %
 Zero % Difference = Act % (ppm) - Exp % (ppm) X 100
 Full Scale Value
 Span % Difference = Act % (ppm) - Exp % (ppm) X 100

Unit: Kuma Wood Classic
 Run: BPH 3
 Date: 4/14/99
 Technicians: ATM / BLS
 MST6-Form3-Rev11/89

QUALITY CHECKS
 WOODSTOVE DATA SHEET #16

Ambient = Tr: _____ OF T/C#30: _____ OF

Thermocouple Check (at ambient): T/C#1: 65 OF; T/C#2: 65 OF;

T/C #3:	<u>67</u>	OF;	T/C #4:	<u>67</u>	OF;
T/C #6:	<u>67</u>	OF;	T/C #7:	<u>67</u>	OF;
T/C #9:	<u>67</u>	OF;	T/C #10:	<u>67</u>	OF;
T/C #12:	<u>67</u>	OF;	T/C #13:	<u>67</u>	OF;
T/C #15:	<u>67</u>	OF;	T/C #16:	<u>67</u>	OF;
T/C #18:	<u>67</u>	OF;	T/C #19:	_____	OF;
T/C #21:	_____	OF;	T/C #22:	_____	OF;
T/C #24:	_____	OF;	T/C #25:	_____	OF;
T/C #26:	_____	OF;	T/C #27:	_____	OF;

Comments: _____

Thermocouple Readout: Pretest Zero/Span Check and Calibration:

Zero (0°F) : 001 OF to: 000 OF Post Test Check % Difference +0.05%

Span (2000°F): 1999 OF to: 2000 OF Span _____

(Allowable % Difference = 1.5%. Use formulas on Woodstove Data Sheet #15 to calculate % Difference)

Thermocouple Readout Pretest Linearity Check

0°F = <u>000</u>	OF; 200°F = <u>200</u>	OF; 400°F = <u>399</u>	OF;
600°F = <u>600</u>	OF; 800°F = <u>800</u>	OF; 1000°F = <u>1001</u>	OF;
1200°F = <u>1200</u>	OF; 1400°F = <u>1400</u>	OF; 1600°F = <u>1599</u>	OF;
1800°F = <u>1800</u>	OF; 2000°F = <u>2000</u>	OF;	

Combustion Gas (CO₂, O₂, CO) Train Leak Check: Pre Post

Draft (Static) Gauge Zero Check: Pre Post

Scale Check Pre (Wt, #'s): 570.8-575.8 - 5.0 lbs, OK (PLS)

Post (Wt, #'s): 572.2-577.2 - 5.0 lbs, OK (PLS)

Stack cleaned prior to the run: Yes No

Tunnel cleaned prior to the run: Yes No

SCALE CALIBRATION RECORD

Customer: MIDREN CONSULTING INC Date: 9/29/99

Work Order Number: 2-1001 PO Number:

Equipment Mfg.	Serial Number	Specifications	Weight used	Initial Readings	Final Readings
1. <u>PANTHER</u>	<u>4466459</u>	<u>1K X.1 LB</u>	ϕ	ϕ	
	<u>Pass...Fail</u>		<u>1$\phi\phi$.ϕ</u>	<u>1$\phi\phi$.ϕ</u>	
Notes:			<u>2$\phi\phi$.ϕ</u>	<u>2$\phi\phi$.ϕ</u>	
			<u>4$\phi\phi$.ϕ</u>	<u>4$\phi\phi$.ϕ</u>	
			<u>5$\phi\phi$.ϕ</u>	<u>5$\phi\phi$.ϕ</u>	
			ϕ	ϕ	

Equipment Mfg.	Serial Number	Specifications	Weight used	Initial Readings	Final Readings
2. <u>D1-1ϕ</u>	<u>301165</u>	<u>1K X.1 LB</u>	ϕ	ϕ	ϕ
	<u>Pass...Fail</u>		<u>1$\phi\phi$.ϕ</u>	<u>1$\phi\phi$.ϕ</u>	<u>1$\phi\phi$.ϕ</u>
Notes:			<u>2$\phi\phi$.ϕ</u>	<u>2$\phi\phi$.ϕ</u>	<u>2$\phi\phi$.ϕ</u>
			<u>4$\phi\phi$.ϕ</u>	<u>399.8</u>	<u>4$\phi\phi$.ϕ</u>
			<u>5$\phi\phi$.ϕ</u>	<u>499.6</u>	<u>5$\phi\phi$.ϕ</u>
			ϕ	ϕ	ϕ

Equipment Mfg.	Serial Number	Specifications	Weight used	Initial Readings	Final Readings
3.					
	<u>Pass...Fail</u>				
Notes:					

Equipment Mfg.	Serial Number	Specifications	Weight used	Initial Readings	Final Readings
4.					
	<u>Pass...Fail</u>				
Notes:					

Additional Comments:

Last Checked: 3/4/99 Next Check Due: 3/4/00
 Weights Certified: 1 Technician: [Signature]

SCALE CALIBRATION RECORD

Customer: MYREN CONSULTING, INC. Date: 4 MAR 99

Work Order Number: _____ PO Number: _____

Equipment Mfg.	Serial Number	Specifications	Weight used	Initial Readings	Final Readings
1. <u>PANTHER</u>	<u>444459-4X4</u>	<u>1000x.1 lb</u>	<u>φ</u>	<u>φ</u>	
	<u>Pass</u> .Fail		<u>1φφ.φ</u>	<u>1φφ.φ</u>	
Notes:			<u>2φφ.φ</u>	<u>2φφ.φ</u>	
			<u>3φφ.φ</u>	<u>3φφ.φ</u>	
			<u>5φφ.φ</u>	<u>5φφ.φ</u>	
			<u>φ</u>	<u>φ</u>	

Equipment Mfg.	Serial Number	Specifications	Weight used	Initial Readings	Final Readings
2.					
	Pass...Fail				
Notes:					

Equipment Mfg.	Serial Number	Specifications	Weight used	Initial Readings	Final Readings
3.					
	Pass...Fail				
Notes:					

Equipment Mfg.	Serial Number	Specifications	Weight used	Initial Readings	Final Readings
4.					
	Pass...Fail				
Notes:					

Additional Comments: _____

Last Checked: 9/98 Next Check Due: 9/99
 Weights Certified: _____ Technician: [Signature]

QUALITY CONTROL SERVICES

LABORATORY AND METROLOGY EQUIPMENT: SALES AND SERVICE

Date: 04/13/1999

Customer: Myren Consulting
512 Williams Lake Road
Colville, WA 99114
Attn: Ben Myren

CERTIFICATE OF CALIBRATION

THE INSTRUMENTS LISTED BELOW HAVE BEEN SERVICED AND CALIBRATED BY QUALITY CONTROL SERVICES ON THE DATE INDICATED. SERVICE CONSISTS OF ACCURACY TESTS, ADJUSTING TO MANUFACTURER OR CUSTOMER SPECIFICATIONS AND COMPLETE CALIBRATION WITH STANDARDS TRACEABLE TO THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY (N.I.S.T.).

Item:	Make:	Model:	Serial Number:	Location:	Contact:	Cal. Date:	Cal. Due:
Balance	Mettler	AE100	K04827	Lab	Ben Myren	04/06/1999	09/1999

STANDARDS USED FOR THIS CALIBRATION:

Item:	Make:	Model:	Serial Number:	NIST ID:	Cal. Date:	Cal. Due:
Weight Set	Rice Lake	IMG-20KG	A45	822/251337	07/07/1998	07/1999

Technician: D.Deleasa

Signature

D. Deleasa

QUALITY CONTROL SERVICES

LABORATORY AND METROLOGY EQUIPMENT: SALES AND SERVICE

DATE: December 04, 1997

CUSTOMER: Myren Consulting
512 Williams Lake Rd.
Colville, WA 99114
Attn: Ben Myren

WEIGHT TRACEABILITY CERTIFICATE

THE BALANCES/SCALES LISTED BELOW HAVE BEEN SERVICED AND CALIBRATED BY QUALITY CONTROL SERVICES.

THIS DOCUMENT CERTIFIES THAT THE TEST WEIGHTS USED ARE TRACEABLE TO THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY (N.I.S.T.) UNDER TEST # 822/251337.

QCS Weight Set

I.D. Number	Calibration Date	Next Calibration Due
A45	07-02-97	07-98
8543	07-02-97	07-98
5735	07-02-97	07-98
7809	07-02-97	07-98
G782	07-02-97	07-98

DATE OF SERVICE	TYPE	MANUFACTURER	SERIAL NUMBER	TECHNICIAN
12-01-97	AE163	Mettler	K04827	G. Cahill

AUTHORIZED REPRESENTATIVE: G. Cahill

DENSITY STANDARD USED FOR TROEMNER PRECISION WEIGHTS

Troemner Inc. adjusts all new weights and all weights received for recalibration on the basis of apparent mass versus material of density 8.0g/cm^3 at 20°C . This action is in accordance with the recommendations of the American Society for Testing and Materials specification ANSI/ASTM E 617 and the International Organization of Legal Metrology (OIML) International Recommendation No. 20.

Previously, all weights had usually been adjusted on the basis of apparent mass versus "brass," a hypothetical material of defined density 8.4g/cm^3 at 0°C and 8.3909g/cm^3 at 20°C . This practice originated in the early 1800's and was adopted in all of the English speaking countries as well as a number of other countries. Now most mass standards and test weights are made from stainless steel (density ranges from 7.77g/cm^3 to 8.0g/cm^3). A number of countries have adopted the recommendations of OIML and the foremost balance manufacturers are adjusting the built-in weights in their balances on the basis of apparent mass versus 8.0g/cm^3 . In order to smooth the transition in this country, the Reports of Calibration of the National Bureau of Standards are reporting the corrections to calibrated mass standards on both bases.

In terms of normal weighing procedures the change is very small. For a given weight, the mass value assigned on the basis of apparent mass versus density 8.0g/cm^3 material will be 7 parts per million higher than the value assigned on the basis of apparent mass versus "density 8.4g/cm^3 " material. In many cases the allowed weight adjustment tolerances are so

large that this change is immaterial although closely adjusted weights often have a smaller tolerance than the correction change. For example at the 1 kilogram level the change is 7 mg. For comparison the ANSI/ASTM E 617 Class 6 tolerance for 1 kilogram is 100 mg while the Class 1 tolerance is 2.5 mg. A detailed discussion of mass and mass values is given in Reference 3.

Precision Weights manufactured by Troemner Inc. to ASTM Class 1, 1.1, 2, 3, 4, 5, and 6 tolerances and the equivalent OIML and NBS tolerances are of the following materials:

Designation	Base Material	Density	Weight Range
Stainless Steel	18-8	7.84g/cm^3 at 20°C	1 g & larger
Stainless Steel	18-8	8.0g/cm^3 at 20°C	50 mg to 500 mg
Aluminum	1100	2.7g/cm^3 at 20°C	30 mg & smaller

References:

- ANSI/ASTM E 617
Available from: Troemner Inc. 6925 Greenway Ave., Phila. Pa. 19142
215-724-0800 or American Society for Testing and Materials, 1916 Race Street, Phila., Pa. 19103
- OIML INTERNATIONAL RECOMMENDATION No. 20
Available from: Organisation Internationale De Metrologie Legale
11 Rue Trudot - 75009 Paris, France
- NBS MONOGRAPH 139, MASS AND MASS VALUES
Available from: Superintendent of Documents, U.S. Government
Printing Office
Washington, D.C. 20540
Order by SD Catalog No. C13,44:1331 Stock Number 0503-01178



TROEMNER INC.

Manufacturers of Precision Weights...
Mass Standards • Balances • Laboratory Apparatus
6925 Greenway Avenue - Philadelphia, Pa. 19142
215/724-0800

Wts. used for Scale QC Checks, P. 4-4.

WOODSTOVE DATA SHEET #33

Thermocouple Calibration Record

TC #	Location	Ice Water Bath (°F)	Boiling Water (°F)	TC #	Location	Ice Water Bath (°F)	Boiling Water (°F)
1	Wet Bulb	32.5	209.7	21			
2	Dry Bulb	32.4	209.8	22			
3	Stack	32.6	209.6	23			
4	Stove Top	32.4	209.8	24			
5	Left Side	32.5	209.7	25			
6	Back	32.5	210.1	26			
7	Right Side	32.6	210.3	27			
8	Bottom	32.5	209.9	28			
9	Firebox	32.6	209.9	29	Oven		
	2nd Burn			30	N/A-Calibrator		
10	Catalytic	32.6	209.7	31			
11	Room	32.3	209.8	32			
12	Furnace T.N.L. Temp	32.5	210.0	33			
13	Sample Box C. Gas Hor Box	32.5	209.7	34			
14	Impinger Out C. Gas	32.4	209.9	35	Rear Top		
15	Gas Box Filter #1	32.3	209.7	36	Rear L Side		
16	Gas Out Filter #1 Cond	32.4	209.9	37	Rear R Side		
17	Gas Out Filter #2	32.3	209.9	38	Rear Firebox		
18	Extra Filter #2 Cond	32.4	209.8	39	Rear 2nd/cat		
19	Extra			40			
20	Extra						

Thermocouples checked against

Reference Thermometer #: ERTCO CAT 1005-3FC CAT 517 SN 1697Ice Water Bath 32.3 °FBoiling Water 210.0 °FRoom Temp 72 °FB.P. 28.495 "HgDate: 7/17/99 Technician: A. J. Myren

Range 0-1999 °F

Date: 7/17/99

Thermocouple No.: Extech Model 4020 KF

Ambient Temperature: 72 °F

Barometric Pressure: 28.495 "Hg

Calibrator: A.V. Myren

Reference: Mercury-in-glass: ERTCO SN 1697

Other: Altec

Reference point No. ^a	Source ^b (specify)	Reference thermometer temperature, °F	Thermocouple potentiometer temperature, °F	Difference, % ^c
1	Altec	0	2	+2.43
2		100	102	+0.36
3		200	202	+0.30
4		300	299	-0.13
5		400	399	-0.12
6		500	500	0
7		600	600	0
8		700	698	-0.17
9		800	800	0
10		900	899	-0.07
11		1000	1002	0.14
12		1100	1101	0.06
13		1200	1201	0.06
14		1400	1401	0.05
15		1600	1600	0
16		1800	1799	-0.04
17	✓	1900	1899	-0.04

^a Every 300C (500F) for each reference point

^b Type of Calibration system used

^c
$$\frac{(\text{Ref. temp. } ^\circ\text{C} + 273) - (\text{Test therm. temp. } ^\circ\text{C} + 273)}{\text{Ref. Temp. } ^\circ\text{C} + 273} \times 100 < 1.5\%$$

Date: 7/17/99
 Ambient Temperature: 72 °F
 Calibrator: A.T. Myren

Range 0 - /SN 900167
 Thermocouple No.: JENCO Model 768 - F-02
 Barometric Pressure: 28.495 "Hg
 Reference: Mercury-in-glass: ERTCO SN 1697
 Other: Altec

Amb ERTCO 72 72 0/Medic Box 511M

Reference point No. ^a	Source ^b (specify)	Reference thermometer temperature, °F	Thermocouple potentiometer temperature, °F	Difference, % ^c
1	Altec	0	0	0
2		100	99	-0.10
3		200	201	+0.15
4		300	299	-0.13
5		400	398	-0.23
6		500	497	-0.31
7		600	597	-0.29
8		700	697	-0.26
9		800	800	0
10		900	901	+0.07
11		1000	1006	+0.41
12		1100	1108	+0.51
13		1200	1211	+0.66
14		1400	1420	+1.03
15		1600	1616	+0.78
16		1800	1811	+0.59
17	↓	2000	1999	-0.04

^a Every 300°C (500°F) for each reference point

^b Type of Calibration system used

^c
$$\frac{(\text{Ref. temp. } ^\circ\text{C} + 273) - (\text{Test therm. temp. } ^\circ\text{C} + 273)}{\text{Ref. Temp. } ^\circ\text{C} + 273} \times 100 \leq 1.5\%$$

Meter Box 45G-P

Omega Model 115KF

Date: 7/17/99

Thermocouple No.: SN 84487KF Range 0-2000°

Ambient Temperature: 72 °F

Barometric Pressure: 28.495 "Hg

Calibrator: A.T. Myren

Reference: Mercury-in-glass: ERTCO SN 1697

Other: Altec

Ambient ERTCO 72 72 0

Reference point No. ^a	Source ^b (specify)	Reference thermometer temperature, °F	Thermocouple potentiometer temperature, °F	Difference, ^c %
1	Altec	0	0	0
2		100	99	-.18
3		200	201	+ .15
4		300	301	+ .13
5		400	400	0
6		500	500	0
7		600	601	+0.09
8		700	700	0
9		800	800	0
10		900	901	+0.07
11		1000	1001	+ .07
12		1100	1100	0
13		1200	1201	+ .06
14		1400	1400	0
15		1600	1601	+0.05
16		1800	1801	+0.04
17	V	2000	1999	-0.04

^a Every 30°C (50°F) for each reference point

^b Type of Calibration system used

^c
$$\frac{(\text{Ref. temp: } ^\circ\text{C} + 273) - (\text{Test therm. temp. } ^\circ\text{C} + 273)}{\text{Ref. Temp. } ^\circ\text{C} + 273} \times 100 < 1.5\%$$

ALTEK

CERTIFICATE OF CALIBRATION

This is to Certify that your Altek Unit has been calibrated using standards whose accuracies are traceable to the National Institute of Standards and Technology (formerly NBS) within the limits of the NIST Calibration Services. Actual records pertaining to these standards are on file and are available for examination.

Certified by: Altek Industries Corp.
Recommend Recalibration: Annually

In service date 4/11/96

Model K2100F Serial No. Serial # 177533

T. Kuech

Calibration Technician

31 AUG 95

Factory Calibration Date

ALTEK INDUSTRIES CORP

210 Commerce Drive, Rochester, NY 14623 U.S.A.

(716) 334-3720 FAX: (716) 334-6673

800-32-ALTEK

800-322-5835

Anywhere in USA

R E P O R T O F C A L I B R A T I O N
LIQUID-IN-GLASS-THERMOMETER

CALIBRATED BY EVER READY THERMOMETER CO.

MARKED: ERTCO CAT 1005-3FC S/N-1697
RANGE: -1 TO +101 DEGREES C IN 0.1 DEGREE GRADUATIONS.

THERMOMETER READING	CORRECTION (ITS-90)**
0.00 C	0.00 C
10.00	0.00
20.00	0.00
30.00	0.00
37.00	0.00
40.00	0.00
50.00	0.00
56.00	0.00
60.00	0.02
70.00	0.00
80.00	0.00
90.00	0.00
100.00	0.00

** ALL TEMPERATURES IN THIS REPORT ARE BASED ON THE INTERNATIONAL TEMPERATURE SCALE OF 1990 (ITS-90) PUBLISHED IN THE METROLOGIA 27, NO. 1, 3/10/90.

THIS THERMOMETER WAS CALIBRATED AGAINST A STANDARD CALIBRATED AT THE NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY (NIST) FORMERLY THE NATIONAL BUREAU OF STANDARDS (NBS) IN ACCORDANCE WITH ASTM METHOD E 77, AND NBS MONOGRAPH 174.

FOR A DISCUSSION OF ACCURACIES ATTAINABLE WITH SUCH THERMOMETERS SEE NBS MONOGRAPH 250-23.

IF NO SIGN IS GIVEN ON THE CORRECTION, THE TRUE TEMPERATURE IS HIGHER THAN THE INDICATED TEMPERATURE; IF THE SIGN GIVEN IS NEGATIVE, THE TRUE TEMPERATURE IS LOWER THAN THE INDICATED TEMPERATURE. TO USE THE CORRECTIONS PROPERLY, REFERENCE SHOULD BE MADE TO THE NOTES GIVEN BELOW.

CONTINUED

TEST NUMBER: 152439
DATE: 07/16/96
STANDARD SERIAL NO. 128239
NIST IDENTIFICATION NO. 88024

R E P O R T O F C A L I B R A T I O N

LIQUID-IN-GLASS-THERMOMETER

THE THERMOMETER WAS TESTED IN A LARGE, CLOSED-TOP, ELECTRICALLY HEATED, LIQUID BATH, BEING "IMMERSED" 76MM. THE TEMPERATURE OF THE ROOM WAS ABOUT 25 DEGREES C (77 DEGREES F). IF THE THERMOMETER IS USED UNDER CONDITIONS WHICH WOULD CAUSE THE AVERAGE TEMPERATURE OF THE EMERGENT LIQUID COLUMN TO DIFFER MARKEDLY FROM THAT PREVAILING IN THE TEST, APPRECIABLE DIFFERENCES IN THE INDICATIONS OF THE THERMOMETER WOULD RESULT.

THE TABULATED CORRECTIONS APPLY PROVIDED THE ICE-POINT READING, TAKEN AFTER EXPOSURE FOR NOT LESS THAN 3 DAYS TO A TEMPERATURE OF ABOUT 20 DEGREES C (70 DEGREES F) IS 0.00 DEGREES C. IF THE ICE-POINT READING IS FOUND TO BE HIGHER (OR LOWER) THAN STATED, ALL OTHER READINGS WILL BE HIGHER (OR LOWER) TO THE SAME EXTENT. IF THE THERMOMETER IS USED AT A GIVEN TEMPERATURE SHORTLY AFTER BEING HEATED TO A HIGHER TEMPERATURE. AN ERROR OF 0.01 DEGREES OR LESS, FOR EACH 10 DEGREE DIFFERENCE BETWEEN THE TWO TEMPERATURES, MAY BE INTRODUCED. THE TABULATED CORRECTIONS APPLY IF THE THERMOMETER IS USED IN THE UPRIGHT POSITION; IF USED IN A HORIZONTAL POSITION, THE INDICATIONS MAY BE A FEW HUNDREDTHS OF A DEGREE HIGHER.

TEST NUMBER: 152439
DATE: 07/16/96
STANDARD SERIAL NO. 128239
NIST IDENTIFICATION NO. 88024



Charles Tang-Nian
QUALITY CONTROL MANAGER

Thermometer Calibrations

MFR	ERTCO	ERTCO	VWR	Fisher	Taylor	Taylor	Premium	Weston
CAT#	1005-3FC 517		0016-015USA	ASTM-59F	1330NA	1330NA		
SN	1697	K85-163-	—	A04544	WB	DB	A1	
Range	-1 to 101°C	0-260°C	-30-50°C	0-180°F	20-120°F	20-120°F	0-220°F	-40-160°F
Graduations:	0.1°C	1.0°C	1.0°C	1°F	1°F	1°F	1°F	2°F
Type	Tube	Tube	Tube	Tube	Tube	Tube	Dial	Dial
Temp Pt.	22.1	22	22	72	72	71.5	71	71
	27.1	27	27	81	81	80.5	80	80
	7.1	7.0	7.0	45	46	46	45	45
	0.1	0.5	0.5	32	32	32	33	31
	98.5	98	—	—	—	—	210	—

$$^{\circ}\text{F} = (^{\circ}\text{C} \times 9/5) + 32$$

$$^{\circ}\text{C} = (^{\circ}\text{F} - 32) \times 5/9$$

Drying
Oven

A.T. Myren

7/17/99

Note: Taylor 1330 NA WB & DB = Thermometers in the sling psychrometer.

DRY GAS METER CALIBRATION DATA

Date

7/17/11

Calibration Meter #

300392

Console Leak Check

Back

Y = 1.01437

Meter Box #

511M

Barometric Pressure, Bp = 29.495

Pitot Leak Check

N/A

Calibrated by

A.T. Dwyer

Dry Gas Meter #

511M

Electrical Check

OK

Orifice (dH) in. H2O	Gas Volume			Temperature				Time (O), min.
		Cal. Meter (Vc), cu.ft.	Dry Gas Meter (Vm), cu.ft.	Cal. Meter (Tc), F	Dry Gas Meter			
					Inlet (Tmi), F	Outlet (Tmo), F		
1.50	init.	571.842	504.600	init.	79	83.35	84.92	12:58.09
1.50	final	577.152	509.900	final	81	83	84	
1.50	total	5.310	5.300	avg.	81(54)	84.33	84.33	
1.75	init.	577.855	510.600	init.	83.84	87.89	84.95	10:01
1.75	final	582.843	515.601	final	85	89	85	
1.75	total	4.988	5.001	avg.	84(54)	86.33	84.63	
1.00	init.	583.538	516.300	init.	86.37	89.39	88.35	9:08.62
1.00	final	588.915	521.704	final	87	90	87	
1.00	total	5.377	5.404	avg.	86.7		87.83	
1.25	init.	589.605	522.400	init.	88.88	89.90	87.37	8:02.57
1.25	final	594.976	527.704	final	89	90	87	
1.25	total	5.371	5.304	avg.	88.3		87.3	
1.50	init.	595.857	528.700	init.	89.39	90.91	87.88	7:11.22
1.50	final	601.032	533.905	final	89	91	88	
1.50	total	5.175	5.305	avg.	89		87.88	

$$Y = \frac{Y Vc Pb(Tm + 460)}{Vd(Pb + dH/13.6) (Tc + 460)}$$

$$dH = \frac{0.0317 dH}{Pb(Tmo + 460)} [(Tc + 460) \theta/Vc]^2$$

$$Y = \frac{(Y_w)(V_w)(P_b)(T_d)}{(V_d)(P_b + \frac{AH}{13.6})(T_w)}$$

$$Y = \frac{(1.01437)(5.310)(28.495)(544.33)}{(5.300)(28.495 + \frac{.50}{13.6})(541)} = \frac{82,536,447}{81,307,179} = 1.0217$$

$$Y = \frac{(1.01437)(4.989)(28.495)(546.33)}{(5.001)(28.495 + \frac{.75}{13.6})(544)} = \frac{78,806,383}{77,671,931} = 1.0146$$

$$Y = \frac{(1.01437)(5.377)(28.495)(547.83)}{(5.404)(28.495 + \frac{1.00}{13.6})(546.7)} = \frac{85,135,352}{84,401,950} = 1.0093$$

$$Y = \frac{(1.01437)(5.371)(28.495)(543.3)}{(5.304)(28.495 + \frac{1.25}{13.6})(548.3)} = \frac{85,133,299}{83,135,977} = 1.0244$$

$$Y = \frac{(1.01437)(5.175)(28.495)(549.17)}{(5.205)(28.495 + \frac{1.50}{13.6})(549)} = \frac{82,135,696}{81,740,915} = 1.0054$$

Y	Variation	Allowed ±0.02
1.0217	+0.0066 ✓	
1.0146	-0.0005 ✓	
1.0093	-0.0058 ✓	
1.0244	+0.0093 ✓	
1.0054	-0.0097 ✓	
$\bar{Y} = 1.01508$		
$= 1.0151$		

511 m
 7M7199
 A. Thompson

$$\Delta H @ = \frac{(.0317)(\Delta H)}{(P_b)(T_{mo})} \cdot \left[\frac{(T_w)(\theta)}{(Y_w)(V_w)} \right]^2$$

$$\Delta H @ = \frac{(.0317)(0.5)}{(29.495)(543.67)} \cdot \left[\frac{(541)(10.97)}{(1.01437)(5.510)} \right]^2 = 1.7346 \quad \checkmark$$

$$\Delta H @ = \frac{(.0317)(0.55)}{(29.495)(544.67)} \cdot \left[\frac{(544)(10.02)}{(1.01437)(4.998)} \right]^2 = 1.7761 \quad \checkmark$$

$$\Delta H @ = \frac{(.0317)(1.00)}{(29.495)(546.33)} \cdot \left[\frac{(546.2)(9.16)}{(1.01437)(5.377)} \right]^2 = 1.7148 \quad \checkmark$$

$$\Delta H @ = \frac{(.0317)(1.25)}{(29.495)(547)} \cdot \left[\frac{(548.3)(8.04)}{(1.01437)(5.371)} \right]^2 = 1.6628 \quad \checkmark$$

$$\Delta H @ = \frac{(.0317)(1.50)}{(29.495)(547.67)} \cdot \left[\frac{(549)(7.137)}{(1.01437)(5.175)} \right]^2 = 1.7197 \quad \checkmark$$

$\Delta H @$	Variation (Allowed ± 0.2)
1.7346	+ 0.0130 ✓
1.7761	+ 0.0545 ✓
1.7148	- 0.0068 ✓
1.6628	- 0.0538 ✓
1.7197	- 0.0019 ✓

$$\bar{x} = 1.7216 \quad \checkmark$$

METER BOX CALIBRATION AUDIT

Test Data										
Run #	1	2	3	4	5	6	7	8	9	10
Avg. ΔH	<u>900</u>	<u>900</u>	<u>900</u>	<u>900</u>	<u>900</u>	<u>900</u>	<u>900</u>	<u>900</u>		
Max Vac	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>		

Avg. Test Series ΔH : 900 in H₂O. Test Series Max Vac: 0 in Hg

Audit Dry Gas Meter: 300392 Correction (Y) Factor: 1.01487
 Test Dry Gas Meter: 511 M Correction (Y) Factor: 1.0151

Audit Data

	Audit #1	Audit #2	Audit #3
BP:	<u>28.70</u>	<u>28.705</u>	<u>28.705 " Hg</u>
Vac:	<u>0</u>	<u>0</u>	<u>0</u>
Audit Meter:			
Final Vol	<u>735.183</u>	<u>741.040</u>	<u>747.539</u>
Initial Vol	<u>730.045</u>	<u>735.958</u>	<u>742.400</u>
Vol (V _w , ft ³)	<u>5.138</u> ✓	<u>5.082</u> ✓	<u>5.139</u> ✓
Audit Meter:			
Temp (°F)(T _w)			
Initial	<u>66</u>	<u>67</u>	<u>68</u>
Mid	<u>67</u>	<u>68</u>	<u>69</u>
Final	<u>67</u> ✓	<u>68</u> ✓	<u>69</u> ✓
Avg (°F/°A)	<u>(66.7) 526.7</u>	<u>(67.7) 527.7</u>	<u>(68.7) 528.7</u>
ΔH (in H ₂ O)			
Initial	<u>900</u>	<u>900</u>	<u>900</u>
Mid	<u>900</u>	<u>900</u>	<u>900</u>
Final	<u>900</u>	<u>900</u>	<u>900</u>
Avg	<u>0.900</u> ✓	<u>900</u> ✓	<u>900</u> ✓
Dry Gas Meter:			
Final Vol	<u>254.500</u>	<u>260.084</u>	<u>265.526</u>
Initial Vol	<u>249.100</u>	<u>254.800</u>	<u>260.300</u> ✓
Vol (V _d , ft ³)	<u>5.400</u> ✓	<u>5.284</u> ✓	<u>5.226</u> ✓
Dry Gas Meter			
Temp (°F): Inlet			
Initial	<u>64</u>	<u>70</u>	<u>74</u>
Mid	<u>68</u>	<u>73</u>	<u>77</u>
Final	<u>71</u> ✓	<u>75</u> ✓	<u>77</u> ✓
Avg (°F/°A)	<u>(67.7) 527.7</u>	<u>(72.7) 532.7</u>	<u>(76) 536</u> ✓
Dry Gas Meter			
Temp (°F): Outlet			
Initial	<u>63</u>	<u>66</u>	<u>67</u>
Mid	<u>64</u>	<u>67</u>	<u>69</u>
Final	<u>66</u> ✓	<u>67</u> ✓	<u>70</u> ✓
Avg (°F/°A)	<u>(64.3) 524.3</u>	<u>(66.7) 526.7</u>	<u>(68.7) 528.7</u>
Avg Dry Gas	<u>(66) 526.0</u>	<u>(69.7) 529.7</u>	<u>(72.4) 532.4</u>
Meter Temp (T _m -°F/°A)	<u>10:48:13</u>	<u>10:00:137</u>	<u>10:00:168</u>
Time (minutes)			

$$Y = \frac{(V_w)(MCF)(BP)(T_m)}{(V_d)(BP + \frac{\Delta H}{13.6})(T_w)}$$

$$Y \text{ Factor } \% \text{ Difference} = \frac{\text{Act} - \text{Exp}}{\text{Exp}} \times 100$$

NOTE: MCF = Meter Correction (Y) Factor for Dry Gas Meter used as a Transfer Standard

Run 1

$$Y = \frac{(5.138)(1.01487)(28.70)(526)}{(5.400)(28.70 + \frac{.900}{13.6})(526.7)} = \frac{78,717.656}{81,816.184} = 0.9621$$

$$\Delta\% = \frac{(0.9643 - 1.01142)}{1.01142} \times 100 = -4.88\%$$

Run 2

$$Y = \frac{(5.082)(1.01487)(28.705)(529.7)}{(5.284)(28.705 + \frac{.900}{13.6})(527.7)} = \frac{78,421.040}{80,224.593} = 0.9775$$

$$\Delta\% = \frac{(0.9775 - 1.01142)}{1.01142} \times 100 = -3.35\%$$

Run 3

$$Y = \frac{(5.139)(1.01487)(28.705)(532.4)}{(5.226)(28.705 + \frac{.900}{13.6})(528.7)} = \frac{79,704.828}{79,494.364} = 1.0026$$

$$\Delta\% = \frac{(1.0026 - 1.01487)}{1.01142} \times 100 = -0.87\%$$

NOTE: The Y Factor % Difference must be < ±5.0% to be acceptable

Determination of Interpolated Y Factor for Average Certification Test Series Delta H from Dry Gas Meter Calibration Data:

$\bar{X} = 3.033\%$

$\frac{0.75}{(A)}$ inch H₂O Delta H = $\frac{1.0146}{(C)}$ Calculated Calibration Y Factor (from Calibrations)

$\frac{1.00}{(B)}$ inch H₂O Delta H = $\frac{1.0093}{(D)}$ Calculated Calibration Y Factor (from Calibrations)

$$\frac{1.00}{(B)} - \frac{.75}{(A)} = \frac{.25}{(E)} \times 100 = \frac{25}{(E)}$$

$$\frac{1.0093}{(D)} - \frac{1.0146}{(C)} = \frac{-.0053}{(E)} \div \frac{.25}{(E)} = \frac{.000212}{(F)}$$

$$\frac{.900}{\text{Avg Delta H}} - \frac{.75}{(A)} = \frac{0.150}{(G)} \times 100 = \frac{15}{(G)}$$

$$\left[\frac{-.000212}{(F)} \times \frac{15}{(G)} \right] + \frac{1.0146}{(C)} = \frac{1.01142}{\text{Interpolated Y Factor For Avg. Test Series Delta H}}$$

Volume Metering System Leak Check: 003 CFM @ -145 inch H₂O in one minute

REFERENCE METER CALIBRATION
TWO POINT VERIFICATION CHECK
ENGLISH REFERENCE METER UNITS

DSM Serial # 300992
 Date 7/19/99

Barometric Pressure 29.86
 Meter V₀ 1.00000
 K (deg R/inches Hg) 17.64

Filename: F:\DATA\FILE\CALIBR\MAT\CAL_MERU.ARE\MDSM_Z02R\TEMP\PLAT
 Reviewed: 1/5/98

Time (min)	Pressure (In. H ₂ O)		Dry Gas Meter (DSM)		Temperature		Met Test Meter (MTM)		DSM Coefficient		Flow Rate (CFM)		PREVIOUS DATA	
	Initial	Final	Initial	Final	Initial (deg F)	Final (deg F)	Initial (cubic feet)	Final (cubic feet)	Yds	Yds	Rate (CFM)	Rate (CFM)	Coef	Coef
20.00	-5.200	655.882	675.745	19.943	81.0	80.0	609.930	699.525	0.993	0.993	0.930	0.930	1.004	1.004
15.00	-2.000	649.460	655.882	6.342	80.0	81.0	673.570	679.930	1.005	1.005	0.411	0.411	0.977485	0.977485

CHANGE MUST BE +/- 1.5%, ELSE PERFORM 15PT CAL

I certify that the above Dry Gas Meter was calibrated in accordance with E.P.A. Method 5, Paragraph 7.1; CFR 40 Part 60, using the Precision Wet Test Meter # 11A66, which in turn was calibrated using the American Bell Prover # 3785, certificate # F107, which is traceable to the National Bureau of Standards (N.I.S.T.).

Signature [Signature] Date 7-19-99

REFERENCE METER CALIBRATION
 TWO POINT VERIFICATION CHECK
 ENGLISH REFERENCE METER UNITS
 DGM Serial # 300392
 Date 7/26/98

Barometric Pressure 29.71
 Meter Yw 1.00000
 K (deg R/inches Hg) 17.64

Filename: F:\DATAFILE\CALIBRAT\CAL_MENU.DSK\DGM_2VER\300392-
 Revised: 1/5/98

Time (min)	Pressure (in. H2O)	Dry Gas Meter (DGM)		Temperature		Wet Test Meter (WTM)		PREVIOUS DATA	
		Initial	Final	Initial (deg F)	Final (deg F)	Volume (cubic feet)	Volume (cubic feet)	DGM Coefficient Yds	DGM Coefficient Yds
10.00	-5.000	417.848	427.852	10.004	80.0	588.070	588.070	1.004	1.009
20.00	-1.800	427.852	436.302	8.450	81.0	596.510	8.440	1.006	1.013

Flow Rate (CFM) 0.962
 %CHANGE 0.4509415 %
 0.410 1.013
 %CHANGE 0.6838462 %

%CHANGE MUST BE +/- 1.5%, ELSE PERFORM 15PT CAL

I certify that the above Dry Gas Meter was calibrated in accordance with E.P.A. Method 5, paragraph 7.1; CFR 40 Part 60, using the Precision Wet Test Meter # 11AE6, which in turn was calibrated using the American Bell Prover # 3785, certificate # F107, which is traceable to the National Bureau of Standards (N.I.S.T.).

Signature  Date 7-26-98

REFERENCE METER CALIBRATION
ENGLISH REFERENCE METER UNITS

Barometric Pressure 29.55
Meter Ym 1.00000
K (deg R / inches Hg) 17.64

DGM Serial # 300392
Date 4/17/97

Filename: F:\DATAFILE\CALIBRAT\CAL_MENU.DSK\DGM_REF.
Revised: 06/08/95

Time (min)	Dry Gas Meter (DGM)			Temperature			Wet Test Meter (WTM)			Coefficient Variation Yds-(Avg.Yds)	Flow Rate (CFM)
	Pressure (in. H2O)	Meter Readings Initial	Meter Readings Final	Initial (deg F)	Final (deg F)	Volume (cubic feet)	Volume (cubic feet)	Temp (deg F)	Volume (cubic feet)		
43.50	-6.800	975.414	1027.032	74.0	75.0	51.618	50.978	70.0	1.013	0.000	1.153
5.00	-6.800	27.032	33.092	75.0	76.0	6.060	5.970	70.0	1.013	0.000	1.174
5.50	-6.800	33.092	39.759	76.0	76.0	6.667	6.561	70.0	1.012	0.000	1.173
Max Yds - Min Yds = 0.000757781 Must be no greater than 0.030											
Average Yds = 1.012668100 Must be no greater than 0.95 to 1.05											
21.00	-4.600	39.759	59.519	76.0	76.0	19.760	19.529	70.0	1.011	0.001	0.915
8.00	-4.600	59.519	67.033	76.0	76.0	7.514	7.401	70.0	1.008	-0.002	0.910
6.50	-4.600	67.033	73.137	76.0	77.0	6.104	6.021	70.0	1.010	0.000	0.911
Max Yds - Min Yds = 0.003425424 Must be no greater than 0.030											
Average Yds = 1.009592597 Must be no greater than 0.95 to 1.05											
35.00	-3.000	73.137	99.630	77.0	76.0	26.493	26.218	70.0	1.009	-0.003	0.737
11.50	-3.000	99.630	108.357	70.0	72.0	8.727	8.821	74.0	1.013	0.000	0.749
17.50	-3.000	108.357	121.465	72.0	72.0	13.108	13.259	74.0	1.015	0.003	0.740
Max Yds - Min Yds = 0.006019406 Must be no greater than 0.030											
Average Yds = 1.012417828 Must be no greater than 0.95 to 1.05											
11.50	-2.000	121.465	127.641	72.0	73.0	6.176	6.314	74.0	1.025	-0.002	0.536
28.00	-2.000	127.641	142.554	73.0	75.0	14.913	15.258	74.0	1.028	0.002	0.532
10.00	-2.000	142.554	147.894	75.0	76.0	5.340	5.434	74.0	1.026	-0.001	0.530
Max Yds - Min Yds = 0.003679685 Must be no greater than 0.030											
Average Yds = 1.026129451 Must be no greater than 0.95 to 1.05											
27.50	-1.400	147.894	159.237	76.0	77.0	11.343	11.430	74.0	1.016	0.002	0.406
22.50	-1.400	159.237	167.914	77.0	79.0	8.677	8.694	74.0	1.013	-0.001	0.377
16.00	-1.400	167.914	174.098	79.0	80.0	6.184	6.171	74.0	1.012	-0.002	0.376
Max Yds - Min Yds = 0.004226433 Must be no greater than 0.030											
Average Yds = 1.013540053 Must be no greater than 0.95 to 1.05											
Overall Average Yds = 1.014869606											

I certify that the above Dry Gas Meter was calibrated in accordance with E.P.A. Method 5, paragraph 7.1; CFR 40 Part 60, using the Precision Wet Test Meter # 11AE6, which in turn was calibrated using the American Bell Prover # 3785, certificate # F107, which is traceable to the National Bureau of Standards (N.I.S.T.).

Signature  Date 4-17-97

VANEOMETER CALIBRATION

Myren Consulting uses a Dwyer Model #480 Vaneometer to measure test chamber air velocity. The manufacturer's specifications for accuracy are $\pm 5.0\%$ to 100 FPM and $\pm 10\%$ from 100 FPM to top of scale. Myren Consulting insures that the instrument is level and clean prior to taking each reading. According to EPA personnel (Westlin, RTP) no further calibration of the instrument is necessary.

DRAFT GAUGE CALIBRATION

Myren Consulting uses a Dwyer Model 115-AV 0 - 0.25" inclined water manometer (readability resolution ± 0.001 " of water) to measure the static pressure in the stack. Once leveled and zeroed as per the manufacturer's written operating instructions, the Dwyer 0 - 0.25" manometer is a primary standard and needs no additional calibration.

The manometer is leveled and zeroed at the start of each test run, checked as necessary during the run to verify that the settings have not changed and again at the end of each test run. The results of each check are recorded on Woodstove Data Sheet #16 in each individual test run.

BAROMETER CALIBRATION

Myren Consulting uses a Weems and Plath aneroid barometer to measure barometric pressure (BP) in the Woodinville, WA lab. The barometer is calibrated daily by obtaining the barometric pressure (station pressure) from the National Weather Service (NWS) adjusting that pressure for altitude and then calibrating the lab barometer as necessary to that pressure.

MOISTURE METER CALIBRATION

The Delmhorst Model RC-1E, SN 1509 Moisture Meter is calibrated each time the meter is turned on using the two (2) calibration settings (Zero and Span). The potentiometers for each calibration point (X = Zero, Y = Span) are adjusted until the meter is correctly calibrated. Then the operation of the meter is checked in the normal operating range used during testing (11 - 25%) with a Delmhorst Model MCS-1 Moisture Content Standard at 12.5% and 22%.

Myren Consulting has a second moisture meter - Delmhorst Model RDX-1 SN 1359 - to use as a backup and as means of checking the readings on the Model RC-1E.

The readings obtained from the moisture meter are corrected as per the manufacturer's written instructions. See the following page for the correction table used to correct the readings.

10.0 - 10.6

24.0 - 26.0

10.5 - 11.2

24.5 - 26.6

11.0 - 11.7

25.0 - 27.2

11.5 - 12.3

12.0 - 12.8

12.5 - 13.3

13.0 - 13.9

13.5 - 14.4

14.0 - 14.9

14.5 - 15.4

15.0 - 15.9

15.5 - 16.5

16.0 - 17.0

16.5 - 17.5

17.0 - 18.1

17.5 - 18.6

LEGAL ↑

18.0 - 19.2

RANGE

18.5 - 19.8

19.0 - 20.3

19.5 - 20.9

20.0 - 21.4

20.5 - 22.0

21.0 - 22.6

21.5 - 23.1

22.0 - 23.7

22.5 - 24.3

↓ 23.0 - 24.9

23.5 - 25.4

26-ED ELECTRODE

OPERATING INSTRUCTIONS

The 26-E and 18-E Electrodes, fitted with insulated pins and used with any Delmhorst Moisture Detectors for Wood, are available in detecting moisture gradient in lumber or in testing dry stock that is wet on the surface.

These Electrodes, as long as they have good insulation on their shanks, measure moisture content at the tip of the pins only, that is in a layer about 3/16" thick.

Shell and core, moisture content is easily measured by driving the pins to the proper depths.

When using the Electrode, place the pins on the wood so that the current will flow parallel to the grain and drive the pins into the wood by means of the sliding hammer. Note the pins' penetration, and read the meter.

The Moisture Meter is calibrated for use with a 4-pin Electrode. When using a 2-pin Electrode, a small correction should be applied, as noted below, where line "A" shows meter readings, and line "B" the correct readings for the 2-pin Electrode.

A=	7	8	10	12	14	16	18	20	22
B=	7.3	8.4	10.6	12.8	14.9	17.0	19.2	21.4	23.7

When the insulation on the contact pins wears off, the above correction should be disregarded, and the electrode should not be used on lumber which may have a wet surface. Always use the L-319 insulating washer especially if surface moisture on the wood is expected. If washers are not available, do not allow the retainers to touch the surface of the wood.

DELMHORST
INSTRUMENT CO.

WOODSTOVE DATA SHEET #26-A
 CEM GAS TRAIN RESPONSE TIME
 PRE CERTIFICATION TEST SERIES CHECK

Date	7/17/99	7/17/99	7/17/99	7/17/99	7/17/99	7/17/99	7/17/99	7/17/99	7/17/99
Technicians	ATM	ATM	ATM	ATM	ATM	ATM	ATM	ATM	ATM
Elapsed Time	CO2 Conc.(V)	CO2 Conc.(V)	CO2 Conc.(V)	CO Conc.(V)	CO Conc.(V)	CO Conc.(V)	O2 Conc.(V)	O2 Conc.(V)	O2 Conc.(V)
0 Seconds	.309	.306	.98	.99	1.03	1.03	51.3	51.5	51.8
15	.308	.305	.98	.99	1.03	1.03	51.2	51.5	51.7
30	.047	.043	.09	.10	.11	.11	81.2	81.5	81.4
45	.021	.019	.08	.08	.08	.08	82.5	82.9	82.7
60	.011	.010	.06	.07	.06	.06	83.8	84.0	83.9
75	.008	.008	.05	.06	.04	.04	84.3	84.6	84.5
90	.006	.007	.04	.05	.04	.04	84.4	84.7	84.6
105	.004	.005	.03	.05	.03	.03	84.5	84.6	84.7
120	.002	.004	.03	.04	.03	.03	84.6	84.6	84.7
135	.002	.003	.02	.03	.02	.02	84.7	84.7	84.7
150	.001	.002	.01	.02	.01	.01	84.7	84.7	84.8
165	.001	.001	.01	.01	.01	.01	84.7	84.7	84.7
180	.001	.001	.00	.01	.01	.01	84.7	84.8	84.8
Initial Response Time (Seconds)	N 15	N 15 ⁺	N 15-20	N 15-20	N 15-20	N 15-20	N 20	N 20	N 20
95% Response Time (Seconds)	>45<60	>45<60	>75<90	>75<90	>60<75	>60<75	>45<60	>45<60	>45<60
Analyzer Flow Rate	1.5SCFH	1.5SCFH	1.5SCFH	1.5SCFH	1.5SCFH	1.5SCFH	1500cc/min	1500cc/min	1500cc/min

Comments

95% = .015 .015 .015 .049 .050 .050 .050 .82.84 .83.04 .83.06
 Clean Train & Filters

Pre kuma Wood Classic

QA WS 1/85

CO₂ ANALYZER
MULTIPOINT CALIBRATION REPORT FORM

Site: Colville, WA 99114 Date: 9/11/99
Analyzer: Make: HORIBA Model: PIR2000 SN: 607204
Calibration by: A.T. Myren
Cal Gas Flow: 1.5 SCFH Measured by: Rotameter: Mass Flowmeter:
BP: 28.73" Hg Instrument ID: Weems
Temp: 80° F Instrument ID: Tenco
Analyzer last calibrated: 7/30/99 By: A.T. Myren

Cylinders:

1. # 719430 Concentration: 0.00 % CO₂ Cyl. Press.: 1860 psi.
Certified by: Oxarc Date: 4/1/99
2. # 250-794 Concentration: 12.5 % CO₂ Cyl. Press.: 1330 psi.
Certified by: Oxarc Date: 3/26/99
3. # 250-1175 Concentration: 21.0 % CO₂ Cyl. Press.: 1380 psi.
Certified by: Oxarc Date: 8/22/97
4. # 250-1060 Concentration: 6.0 % CO₂ Cyl. Press.: 1350 psi.
Certified by: Oxarc Date: 8/22/97

Analyzer: Calibrated Range. 0-25.0 % Output: 0-1.0 v.
Flow: 1.5 SCFH Measured by: Rotameter: Mass Flowmeter:

Calibration Results

Point #	Cyl. #	% CO ₂	Expected		Actual		Adj.		% Dif.	Potentiometer	
			Meter	DVM	Meter	DVM	Meter	DVM		Unadj.	Adj.
1	1	00.0	00.0	.000	.000	.000	.000	—	—	6.56	6.65
2	2	12.5	50.0	.500	50.8	.513	49.75	.500	—	2.67	2.38
3	3	21.0	84.0	.840	85.0	.853	—	—	+0.35	—	—
4	4	6.0	24.0	.240	24.0	.242	—	—	+0.18	—	—
5	1	00.0	00.0	.000	00.0	.000	—	—	0	—	—

21.074
6.011

Comments: .500 = 12.3711272

Linear Regression Results:


$$Y = MX + B$$

$$\text{Slope (M)} = \frac{24,650.6613}{}$$

$$\text{Y Intercept (B)} = \frac{0.04555}{}$$

$$\text{Correlation Coefficient (r)} = \frac{0.9979504}{}$$

Analyzer
Output
(volts)



Comments

InterMountain Ambient

P.O. Box 5106 Missoula, MT 59806 [406] 543-6174

Pre Kurra Wood Classic

QA WS 1/85

O₂ ANALYZER MULTIPOINT CALIBRATION REPORT FORM

Site: Colville, WA 99114 Date: 9/11/99

Analyzer: Make: Taylor Model: OA 137 SN: 137/4772

Calibration by: A.T. Myrum

Cal Gas Flow: 1500 cc/min Measured by: Rotameter: Mass Flowmeter:
BP: 29.78" Hg Instrument ID: WELMS
Temp: 80°F Instrument ID: JENCO

Analyzer last calibrated: 7/30/99 By: A.T. Myrum

Cylinders:

1. # 719430 Concentration: 0.00 % O₂ Cyl. Press.: 1860 psi.
Certified by: Oxarc Date: 4/1/99

2. # 250-794 Concentration: 12.5 % O₂ Cyl. Press.: 1330 psi.
Certified by: Oxarc Date: 3/26/99

3. # 250-1135 Concentration: 21.0 % O₂ Cyl. Press.: 1380 psi.
Certified by: Oxarc Date: 8/22/97

4. # 250-1060 Concentration: 6.0 % O₂ Cyl. Press.: 1350 psi.
Certified by: Oxarc Date: 8/22/97

Analyzer: Calibrated Range: 0-25.0 % Output: 0-100 mv.

Flow: 1500 cc/min Measured by: Rotameter: Mass Flowmeter:

Calibration Results

Point #	Cyl. #	% O ₂	Expected		Actual		Adj.		% Dif.	Potentiometer	
			Meter	DVM	Meter	DVM	Meter	DVM		Unadi.	Adj.
1	1	00.0	00.0	00.0	00.0	00.0	—	—	—	—	—
2	2	12.5	12.5	50.0	12.8	50.8	12.75	50.0	—	—	—
3	3	21.0	21.0	84.0	21.0	84.1	—	—	+0.03	—	—
4	4	6.0	6.0	24.0	6.0	24.0	—	—	-0.03	—	—
5	1	00.0	00.0	00.0	00.0	00.0	—	—	—	—	—

21.006
5.998

Comments:

50.0 = 12.4907584

Linear Regression Results:

$Y = MX + B$


Slope (M) = $\frac{0.477113}{1}$

Y Intercept (B) = 0.005044

Correlation Coefficient (r) = 0.999417

Analyzer
Output
(mvolts)

$\times 10^2$



Comments

Prekuma Wood Classic

QA WS 1/85

CO ANALYZER MULTIPOINT CALIBRATION REPORT FORM

Site: Colville, WA Date: 9/10/99
Analyzer: Make: Infra Red Model: 702 D SN: 113
Calibration by: A.T. Myren
Cal Gas Flow: 1.5 SCFH Measured by: Rotameter: Mass Flowmeter:
BF: 29.7% Hg Instrument ID: Weems
Temp: 80°F Instrument ID: Jenco
Analyzer last calibrated: 7/30/99 By: A.T. Myren

Cylinders:

1. # 719430 Concentration: 00.0 % CO Cyl. Press.: 1860 psi.
Certified by: Oxarc Date: 4/1/99
2. # 250-794 Concentration: 2.50 % CO Cyl. Press.: 1330 psi.
Certified by: Oxarc Date: 3/26/99
3. # 250-1175 Concentration: 4.03 % CO Cyl. Press.: 1380 psi.
Certified by: Oxarc Date: 2/22/97
4. # 250-1060 Concentration: 1.26 % CO Cyl. Press.: 1350 psi.
Certified by: Oxarc Date: 8/22/97

Analyzer: Calibrated Range: 0-5.0 % Output: 0-100 mv.
Flow: 1.5 SCFH Measured by: Rotameter: Mass Flowmeter:

Calibration Results

Point #	Cyl. #	% CO	Expected		Actual		Adi.		% Dif.	Potentiometer	
			Meter	DVM	Meter	DVM	Meter	DVM		Unadi.	Adi.
1	1	00.0	0.00	00.0	0.00	00.0	—	—	—	—	—
2	2	2.50	2.50	50.0	2.56	51.5	2.50	49.9	—	—	—
3	3	4.03	4.03	90.6	4.03	90.8	—	—			
4	4	1.26	1.26	25.2	1.30	25.8	—	—			
5	1	00.0	0.00	00.0	0.00	00.0	—	—			

Comments: 50.0 = 2.4914065

Linear Regression Results:

$$Y = MX + B$$


$$\text{Slope (M)} = \frac{19.9942464}{}$$

$$\text{Y Intercept (B)} = \frac{0.1862051}{}$$

$$\text{Correlation Coefficient (r)} = 0.9974597$$

Analyzer
Output
m(volts)

X10²



Comments

WELDING PRODUCTS
INDUSTRIAL SUPPLIES
INDUSTRIAL GASES
MEDICAL GASES



SPECIALTY GASES
BEVERAGE SYSTEMS
SAFETY PRODUCTS
FIRE EQUIPMENT

WWW.OXARC.COM

MAIN OFFICE

SPOKANE, WA 99220
4003 E. BROADWAY
P.O. BOX 2605
(509) 535-7794
FAX (509) 535-0368

BOISE, ID 83709
7615 W. LEMHI ST.
(208) 376-0377
FAX (208) 376-1133

COEUR D'ALENE, ID 83814
3530 RAMSEY RD.
(208) 785-3311
FAX (208) 667-5974

COLVILLE, WA 99114
328 W. 1ST.
(509) 684-3778
FAX (509) 684-6742

ELLENSBURG, WA 98926
704 N. WENAS
(509) 925-1518
FAX (509) 925-1136

HERMISTON, OR 97338
HERMISTON-
McNARY HIWAY
(503) 567-7377
FAX (503) 567-2265

KENNEWICK, WA 99336
800 W. COLUMBIA DR.
(509) 582-4202
FAX (509) 586-9859

LEWISTON, ID 83501
2513 3RD. AVE., NORTH
(208) 743-6571
FAX (208) 746-8374

MOSES LAKE, WA 98837
1401 WHEELER ROAD
(509) 785-9247
FAX (509) 786-9958

OKANOGAN, WA 98840
2256 ELMWAY
(509) 826-3205
FAX (509) 826-3905

PASCO, WA 99302
716 SOUTH OREGON
(509) 547-2494
FAX (509) 547-3103

TWIN FALLS, ID 83303
729 COMMERCIAL AVE.
(208) 734-9711
FAX (208) 734-7923

WENATCHEE, WA 98801
OHME GARDENS RD.
(509) 662-8417
FAX (509) 662-1229

YAKIMA, WA 98903
1004 EAST MEAD
(509) 249-0827
FAX (509) 452-8704

Primary Standard Certificate of Analysis

Method of Analysis: Micro GC / Gravimetric

Customer: Myren Consulting Reference # PM7234-4
P.O.# Cylinder # 250-1060

Results of Investigation

<u>Component</u>	<u>Requested</u>	<u>Concentration</u>
Air	N/A	N/A
Argon	N/A	N/A
Carbon Dioxide	6.00%	6.00%
Carbon Monoxide	1.25%	1.26%
Helium	N/A	N/A
Hydrogen	N/A	N/A
Methane	N/A	N/A
Nitrogen	Balance	Balance
Oxygen	6.00%	6.00%

Hazard Class UN 1956
DOT Shipping Name Compressed Gas NOS
Shipping Volume (scf approximate) 160 scf @ ntp
Cylinder Pressure 1500 psig
CGA Valve Connection 350

Oxarc Primary Standard mixtures are prepared with gravimetric techniques using weights traceable to NIST. Mixture blended to +/- 1% relative to minor component and certified to +/- 1% analytical accuracy.

Authorized Signature Travis Auger **Date** 8/25/97
Travis Auger

Comments:

WELDING PRODUCTS
INDUSTRIAL SUPPLIES
INDUSTRIAL GASES
MEDICAL GASES



SPECIALTY GASES
BEVERAGE SYSTEMS
SAFETY PRODUCTS
FIRE EQUIPMENT

WWW.OXARC.COM

MAIN OFFICE

SPOKANE, WA 99220
4003 E. BROADWAY
P.O. BOX 2605
(509) 535-7794
FAX (509) 535-0368

BOISE, ID 83709
7615 W. LEMHI ST.
(208) 378-0377
FAX (208) 378-1133

COEUR D'ALENE, ID 83814
3530 RAMSEY RD.
(208) 765-3311
FAX (208) 667-5974

COLVILLE, WA 99114
328 W. 1ST.
(509) 684-3778
FAX (509) 684-6742

ELLENSBURG, WA 99926
704 N. WENAS
(509) 925-1518
FAX (509) 925-1136

HERMISTON, OR 97838
HERMISTON-
McNARY HIWAY
(503) 567-7377
FAX (503) 567-2285

KENNEWICK, WA 99336
800 W. COLUMBIA DR.
(509) 582-4202
FAX (509) 586-9859

LEWISTON, ID 83501
2513 3RD. AVE., NORTH
(208) 743-6571
FAX (208) 746-8374

MOSES LAKE, WA 98837
1401 WHEELER ROAD
(509) 765-9247
FAX (509) 766-9958

OKANOGAN, WA 98840
2256 ELMWAY
(509) 826-3205
FAX (509) 826-3905

PASCO, WA 99302
716 SOUTH OREGON
(509) 547-2494
FAX (509) 547-3103

TWIN FALLS, ID 83303
729 COMMERCIAL AVE.
(208) 734-9711
FAX (208) 734-7923

WENATCHEE, WA 98801
OHME GARDENS RD.
(509) 662-8417
FAX (509) 662-1229

YAKIMA, WA 98903
1004 EAST MEAD
(509) 248-0827
FAX (509) 452-8704

Primary Standard Certificate of Analysis

Method of Analysis Micro GC / Gravimetric

Customer: Myren Consulting Reference # PM7234-2

P.O.# Cylinder # 250-1175

Results of Investigation

<u>Component</u>	<u>Requested</u>	<u>Concentration</u>
Air	N/A	N/A
Argon	N/A	N/A
Carbon Dioxide	21.0%	21.0%
Carbon Monoxide	4.00%	4.03%
Helium	N/A	N/A
Hydrogen	N/A	N/A
Methane	N/A	N/A
Nitrogen	Balance	Balance
Oxygen	21.0%	21.0%

Hazard Class UN 1956
DOT Shipping Name Compressed Gas NOS
Shipping Volume (scf approximate) 160 scf @ ntp
Cylinder Pressure 1500 psig
CGA Valve Connection 350

Oxarc Primary Standard mixtures are prepared with gravimetric techniques using weights traceable to NIST. Mixture blended to +/- 1% relative to minor component and certified to +/- 1% analytical accuracy.

Authorized Signature  **Date** 8/25/97
Travis Auger

Comments:



Welding Products • Industrial Supplies
 Industrial Gases • Medical Gases
 Specialty Gases • Beverage Systems
 Safety Products • Fire Equipment

Primary Standard Certificate of Analysis

Cylinder filled in Pasco WA

Method of Analysis Micro GC / Gravimetric

Customer: Myren Consulting Reference # PA90844

P.O.# Cylinder # 250-794

Results of Investigation

<u>Component</u>	<u>Requested</u>	<u>Concentration</u>
Air	N/A	N/A
Argon	N/A	N/A
Carbon Dioxide	12.5 %	12.5 %
Carbon Monoxide	2.50 %	2.50 %
Helium	N/A	N/A
Hydrogen	N/A	N/A
Methane	N/A	N/A
Nitrogen	Balance	Balance
Oxygen	12.5 %	12.5 %

Hazard Class UN 1956
DOT Shipping Name Compressed Gas NOS
Shipping Volume (scf approximate) 180 scf @ ntp
Cylinder Pressure 1600 psig
CGA Valve Connection 350

Oxarc Primary Standard mixtures are prepared with gravimetric techniques using weights traceable to NIST. Mixture blended to +/- 2% relative to minor component and certified to +/- 1% analytical accuracy.

Authorized Signature  **Date** 3/20/99
Travis Auger

Comments:

- Main Office
 Spokane, WA 99202
 4003 E. Broadway
 P.O. Box 2825
 PH. (509) 535-7794
 FAX (509) 535-0368
- Boise, ID 83709
 7515 W. Lamar St.
 PH. (208) 375-0377
 FAX (208) 375-1133
- Coeur d'Alene, ID 83814
 3530 Ramsey Rd.
 PH. (208) 765-3311
 FAX (208) 667-5974
- Colville, WA 99114
 328 W. 1st
 PH. (509) 684-3775
 FAX (509) 684-6742
- Ellensburg, WA 99926
 704 N. Wenas
 PH. (509) 925-1518
 FAX (509) 925-1136
- Hermiston, OR 97638
 Hermiston-McNary Highway
 PH. (503) 567-7377
 FAX (503) 567-2265
- Lawiston, ID 83501
 2513 3rd Ave., North
 PH. (208) 743-6571
 FAX (208) 746-8374
- Moses Lake, WA 98837
 1401 Wheeler Road
 PH. (509) 765-9247
 FAX (509) 766-9958
- Okanogan, WA 98840
 2256 Elmway
 PH. (509) 826-3205
 FAX (509) 826-3905
- Pasco, WA 99302
 716 South Oregon
 PH. (509) 547-2494
 FAX (509) 547-3103
- Twin Falls, ID 83303
 729 Commercial Ave.
 PH. (208) 734-9711
 FAX (208) 734-7923
- Wenatchee, WA 98901
 291 Ohme Gardens Rd.
 PH. (509) 662-3417
 FAX (509) 662-1229
- Wenatchee, WA 98903
 1004 E. 1st Street
 PH. (509) 662-3227
 FAX (509) 662-3704

MALLINCKRODT

CERTIFICATE OF ANALYSIS

A Division of Mallinckrodt Baker, Inc.
222 Red School Lane • Phillipsburg, NJ 08865
Telephone: (908) 859-2151 • Fax: (908) 859-9318

ITEM: ACETONE AR (ACS)
CODE: 2440
LOT : KTDC

TESTS	LIMITS	RESULTS
TITRATABLE ACID	0.0003 meq/g Max.	0.0002 meq/g
ALDEHYDE	0.002% Max.	0.002%
TITRATABLE BASE	0.0006 meq/g Max.	0.0004 meq/g
ISOPROPYL ALCOHOL	0.05% Max.	0.005%
METHANOL	0.05% Max.	0.005%
RESIDUE AFTER EVAPORATION	0.001% Max.	0.0002%
SOLUBILITY IN WATER	To Pass Test	Passes Test
SUBSTANCES REDUCING PERMANGANATE	To Pass Test	Passes Test
WATER	0.5% Max.	0.3%
COLOR	APHA 10 Max.	APHA 5
ASSAY	99.5% Min.	99.9%

It is hereby certified that the above is a true copy of the actual analysis of the lot indicated.


Mark Featherston

Mark Featherston
Manager, QA/QC
Mallinckrodt Baker, Inc
03/07/96 wwr

2 Bottles. Same lot #
Acetone Purchased 7/10/96
1st blank done 8/8/96
2nd blank done 9/10/97
3rd blank done 8/10/97
4th blank done 3/13/97
5th blank done 3/10/93
6th blank done 3/15/99
7th blank done 7/18/99

Stove QC

The Kuma Wood Classic noncatalytic wood stove is a large mid sized stove. It has a useable firebox volume of 2.3 cubic feet. Its most distinguishing feature is the fact that it is a step top design. It has a rear secondary air preheat chamber and uses four SS tubes to deliver the secondary air to the combustion chamber. The unit also has a LPAO that takes its air directly from the air in the pedestal, rather than from the primary air duct behind the door.




Top View

Kuma Wood Classic

Top View Not to Scale

A.T. Myren



SIDE VIEW

Kuma Wood Classic
Side View - Not to Scale
Art by Myren

USEABLE FIREBOX VOLUME Calculations:

$$18 \times 17.75 \times 10.625 = 3394.688 \quad \checkmark$$

$$16.5 \times 2.75 \times 10.625 = \underline{482.109} \quad \checkmark$$

$$3876.797 \quad \checkmark$$

Less:

PRIMARY Air Duct behind door
 $2.75 \times 1.5 \times 16.5 = 22.688$

LPAO

$$\frac{1.5 \times 1.5}{2} \times 3.5 = 3.938$$

$$1.5 \times 1 \times .5 = \underline{0.75}$$

$$27.376$$

$$3876.797 - 27.376 = 3849.421 \text{ in}^3 \div 1728 \text{ in}^3/\text{ft}^3 = \underline{2.228 \text{ ft}^3}$$


FUEL LOAD CALCULATIONS:

$$2.228 \text{ ft}^3 \times 7 \text{ lbs}/\text{ft}^3 = 15.594 \text{ lbs. IDEAL FUEL LOAD WT.}$$


$$15.594 \pm (.10 \times 15.594) = 17.153 - 14.034 \text{ lbs}$$

$$= \underline{17.1 - 14.1 \text{ lbs Fuel Load Weight Range}}$$


Primary Air Inlet Dimensions:




Shaded area = amount the PAC was open for the low burn. Run 1



TITLE:	DR. NO.	DR. BY
KUMA WOOD CLASSIC	1	M.F.
VIEW:	DATE	SCALE
SIDE; CROSS-SECT. A-A.	9/14/99	1/4" = 1"



TITLE: KUMA WOOD CLASSIC	DR. NO. 2	DR. BY: M.F.
VIEW: FRONT	DATE: 9/14/99	SCALE: 1/4" = 1"



TITLE: KUMA WOOD CLASSIC	DR. NO. 3	DR. BY: M.F.
VIEW: TOP CROSS-SECT. "B-B"	DATE: 9/14/99	SCALE: 1/4" = 1"


5

----- = 1/8" x 6" primary air openings





----- = 1/4" x 1/2" P.A.C. Slider

Scale: 1/2" = 1", Top View


1/2" x 1/2" 7 iron tracks




3/8" = 3/8" open from fully closed position = low burn setting



x 2 = open area at low burn setting - .375 x .375 = .1406 sq. in




TITLE: KUMA WOOD CLASSIC	DR. NO. 4	DR. BY: M.F.
VIEW: PRIMARY AIR CONTROL DETAIL	DATE: 9/14/99	SCALE: AS NOTE



1/2" Dia
LPAO inlet
hole through
firebox bottom.

TITLE: KUMA WOOD CLASSIC	DR. NO. 5	DR. BY: M.F.
VIEWS: L.P.A.O. DETAIL	DATE: 9/14/99	SCALE: 1"=1"




Tube #	No. of Holes	Hole Spacing	Hole Dia.
1	37	1/2" ϕ	5/32"
2	59	3/8" ϕ 5/16"	1/8"
3	37	1/2" ϕ	1/8"
4	19	1" ϕ	1/8"

TITLE: KUMA WOOD CLASSIC	DR. NO. 6	DR. BY: M.F.
VIEW: BAFFLE DETAIL PERSPECTIVE	DATE: 9/14/99	SCALE: 3/16" = 1"


All Refractory is
Low-Duty Firebrick
Mfg. by: Mutual
Materials Co., Inc.,
Bellevue, Wa.

Composition:
81% Fireclay
19% Silicated
Alumina




Top View of
Baffle Fire
brick Layout
(10 pcs)

(21)



Firebox
Back
(5 pcs)

Firebox
Left
side
(4 pcs)





Firebox
Right
side
(4 pcs)

Firebox Bottom (8 pcs)

DIMENSIONS	L	W	THICK.
No. 1 - 26	9"	4 1/2"	1 1/4"
No. 27-28 *	9"	4 1/2"	1 1/4"
No. 29-31	9"	2 1/4"	1 1/4"

* No 27, 28 have
a 3/4" x 1" Notch to
accommodate the L.P.A.O.
tower.

TITLE: KUMA WOOD CLASSIC	DR. NO. 7	DR. BY: M.F.
VIEW: FIREBRICK DETAIL	DATE: 9/14/99	SCALE: 1/8" = 1"



NOTE:
Glass retainer is
a one-piece, full
perimeter ring to
secure glass. It
is 10 ga. steel x
1" in width - 7
Fasteners.

cutaway side view
(not to scale).

TITLE: KUMA WOOD CLASSIC	DRAW. NO. 8	DR BY. S.C.
VIEW: DOOR DETAIL	DATE: 9-14-99	SCALE: 1/4" = 1"

	DESCRIPTION	DIMENSIONS	QTY.	MATERIAL, MFG., MODEL, ETC.
1	Firebox Assembly	23 ¹ / ₈ " x 21" x 20 ³ / ₈ "	1	A-36 Steel 3/16" plate
2	Firebox Top	25" x 26"	1	A-36 Steel 1/4" Plate
	Flue Collar	2" H x 6" I.D.	1	Mild Steel 3/16" Thick
	Primary Draft Channel	2" x 2 1/2"	1	Mild Steel 10 ga.
5	Primary Air Control	3/8" x 16"	1	3/8" Dia. C.R. Steel
6	Primary Air Wash	3 5/8" x 16 1/4"	1	Mild Steel 10 ga
7	Secondary Draft Box	3" x 4 3/8" x 1"	1	Mild Steel 12 ga.
8	Secondary Draft Channel	12 3/4" x 20 1/2"	1	Mild Steel 10 ga.
9	Secondary Draft Manifolds	1" x 3" x 19"	2	Mild Steel 12 ga.
10	Secondary Draft Tubes	7/8" dia. x 18"	4	Stainless Steel .049 Wall
11	Convection Shell	24 3/4" x 23 1/2" x 21 3/8"	1	Mild Steel 14 ga.
12	Heat Shield	21" x 20 3/8"	1	Mild Steel 16 ga.
13	Pedestal	14" x 19"	1	Mild Steel 10 ga.
14	Pedestal Base	22" x 28"	1	Mild Steel 10 ga
15	Door	1 1/4" x 13" x 16"	1	Cast Iron
16	Glass Retainer	11 5/8" x 14"	1	Mild Steel 10 ga x 1" wide
17	Door Handle	1/2" x 7"	1	1/2" H.R. Round
18	Door Pins	3/8" x 2"	2	Steel, Rd Hd. Rivet
19	Glass	10" x 12 3/8"	1	5mm Neo-Ceramic
20	Door Gasket	5 1/8" x 54"	1	Woven Fiberglass rope product; 96.5 fibrous glass, 3.5% surface sizing.
21	Glass Gasket	1/8" x 3/4" x 45"	1	Mfg. by Heatsak, Inc. Redmond, Wa
21	Firebrick	4 1/2" x 9"	28	81% Fireclay, 19% Silica Alumina
		2 1/4" x 9"	3	Mfg. by Mutual Materials Co. Inc Bellevue, Wa.
22	Baffle Wool Blanket	19" x 20"	1	1/2" Thickness, Ceramic Wool Fiber Blanket 4 lb. density 1 ft., Mfg. by Western Industrial Ceramics.
23	Blower Motor (not shown)	4" x 4 1/2" x 14"	1	Model A-125 Mfg. by Fasco Industri 115V, 3200 RPM, 125 cfm.
24	Blower Speed Control	2 1/2" x 3 1/2" x 1 1/2"	1	Wells Tech. Prod. ILS-3-8T 3 Amps
25	Baffle Brick Support (F)	2" x 1 1/2" x 20 1/2"	1	Stainless Steel F.B.
26	Baffle Brick Support (R)	2" x 1 1/4" x 20 1/2"	1	Stainless Steel F.B.
27	L.P.A.O. Tower	1" x 2" x 3 1/2"	1	Mild Steel

TITLE:	DR. NO.	DR. BY:
KUMA WOOD CLASSIC	9	M.F.
VIEW:	DATE:	SCALE:
SPECIFICATION LIST	9/14/99	—

OPERATING INSTRUCTIONS

FOR THE

KUMA WOOD CLASSIC

DURING

EPA CERTIFICATION TESTING

PRIMARY AIR CONTROL (PAC):

Slide rod in to reduce the amount of air entering the stove. To set the control, measure the gap between the end of the spring closest to the stove and the side heat shield. At the "Stop" the gap should be $\frac{3}{4}$ " and the PAC should be open $\frac{3}{8}$ ".

	Gap	PAC Open
Low: Set control at the stop	0.75"	0.375"
Medium Low: Set control at	0.75- 1.125"	0.375- 0.75"
Medium High: Set control at	0.875- 1.50"	0.5- 0.75"
High:	Wide Open	Wide Open
Fan Confirmation Test:	0.75-0.875"	0.375-0.5"

DOOR:

Normally close the door as soon as the test fuel has been loaded in the stove. If the fire is slow to start, crack the door open until the fuel ignites, then close the door.

FAN:

Operate the fan as follows:

Low, Medium Low and Medium High: Turn fan on high at 30 minutes.

High: Turn fan on as soon as the fuel is loaded (~1 minute).

Lower Primary Air Orifice (LPAO):

Clear the coals away from in front of the LPAO on all runs.

Mark Freeman

9/7/99

*Revised
9/2/99
M.F.*



Kuma Stove and Iron Works
Rathdrum, ID. 83858

MODEL:
WOOD CLASSIC

***INSTALLATION AND OPERATING
INSTRUCTIONS***

SAVE THESE INSTRUCTIONS

This manual describes the installation and operation of the KUMA model *Wood Classic* wood heater. Under specific test conditions, this heater has been shown to meet the U.S. Environmental Protection Agency's emission limits for residential wood heaters.

Please read the following safety precautions and the entire installation and operating instructions.

SAFETY PRECAUTIONS

1. If this stove is not properly installed, a house fire can occur. For your protection, follow the installation instructions provided. We recommend contacting local building or fire officials regarding restrictions and installation inspection requirements in your area.
2. **DO NOT CONNECT THIS UNIT TO A CHIMNEY FLUE SERVING ANOTHER APPLIANCE.**
3. Do not use gasoline, gasoline-type lantern fuel, kerosene, charcoal lighter fluid, or similar liquids to start or "freshen up" a fire in this heater. Keep all such liquids well away from the heater while it is in use.
4. Do not burn garbage.
5. Do not overfire. The stove is in an overfire position if any part of the stove glows. If this should happen, immediately close air damper.
6. **WARNING: DO NOT INSTALL IN A SLEEPING ROOM.**
7. Caution: The structural integrity of a mobile home floor, wall, and ceiling/roof must be maintained.
8. Do not use single-wall pipe for exterior chimney or mobile home applications.
9. When installing into an existing metal or masonry chimney, examine the chimney system carefully. If you have any questions, seek professional advice. **DO NOT CONNECT THIS UNIT TO A CHIMNEY FLUE SERVING ANOTHER APPLIANCE.**
10. Note all minimum clearances to combustibles. Installation must comply with minimum clearances as listed in this manual.
11. **INSTALL AND USE IN ACCORDANCE WITH THE MANUFACTURER'S INSTALLATION AND OPERATING INSTRUCTIONS ONLY.**
12. Safety Notice: If this heater is not properly installed, a house fire may result. For your safety, follow the installation directions.
13. Do not operate stove with firing door in an open position.
14. This room heater must be connected to a minimum 6" diameter listed chimney that complies with U.L. 103, HT-Type factory built chimney, or a code approved masonry chimney with a U.L. 1777 listed flue liner.
15. When connecting single-wall stove or double-wall listed chimney connector from the stove flue collar to the listed factory built chimney or masonry chimney, make sure all interconnecting joints of the flue pipe and the connection at the flue collar are secured with three (3) sheet metal screws.
16. When connecting this stove to a masonry chimney, make sure you observe all applicable clearances to combustible ceilings, walls, or other combustibles. A masonry chimney must be a 6" diameter minimum and constructed with a liner according to NFPA 211 code. If you are passing a chimney through a combustible wall to an outside chimney, use a U.L. 103, HT-Type approved insulated chimney section with a wall thimble, maintaining chimney to manufacturer's listed minimum clearance to combustibles. When attempting to connect this stove into a masonry chimney use these steps:
 - a. Chip out hole through masonry into liner at least 6" in diameter.
 - b. Install stainless steel single-wall liner all the way into the masonry liner (see figure 2A).
 - c. Seal or mortar stainless liner in with a refractory high-test type cement.
 - d. Connect stove pipe into masonry hole.
 - e. When passing through a combustible wall into masonry chimney, cut hole in wall large enough for the wall thimble, and use a U.L. 103, HT-Type insulated chimney section that directly connects into masonry liner described above (refer to figure 2A).

CODES AND APPROVALS:

The Kuma model Wood Classic stove is tested to U.L. 1482 safety standard and is listed by Omni Test Laboratories, Inc. This unit is also approved for alcove installations. Maximum alcove depth: 48". Minimum clearance from stove top to ceiling: 52".

MOBILE HOME INSTALLATION INSTRUCTIONS

Model: Kuma Wood Classic

CAUTION: THE STRUCTURAL INTEGRITY OF A MOBILE HOME FLOOR, WALL, AND CEILING/ROOF MUST BE MAINTAINED.

CAUTION: DO NOT INSTALL IN A SLEEPING ROOM.

Before you start, ensure that there are no major obstructions (i.e. floor joists, ceiling joists, electrical wires, heat ducts, plumbing, etc.).

Clearance: backwall= 6", corners= 4", sidewall= 14" (using HT-Type listed chimney and double-wall connector). See figures 5 and 6. Consult your local building official and build your hearth pad to local building requirements.

Typical hearth pad (see example: typical hearth pad on page 3)- 18" to front of unit, 6" to sides.

Material required for installation: 5 or 6" outside air duct with screen, roof mate to seal roof flashing, assorted nails and screws, 8-gauge ground wire, 3/8 lag bolts to fasten stove to the floor (length will depend upon hearth thickness)

Tools required: saber saw, screwdrivers, measuring tape, pencil, plumb line, electric drill and assorted bits, tin shears, knife, pliers, hammer.

1. After locating possible obstructions (joists, pipes, etc.) and taking into account the necessary combustible clearances (fig.2), position the stove in the intended installation position. Use a plumb line to locate the position of the ceiling hole for the chimney. Size the chimney hole to the recommended manufacturer's clearances for your chimney. Mark the hole.
2. Mark a pencil outline around the base of the stove. Move the stove out of the way.
3. Mark with a pencil the holes to be drilled to fasten the stove to the floor, then mark with a pencil a 6" for the fresh air intake. This hole may be positioned anywhere under the stove.
4. If ceiling and floor are clear of all obstructions, cut out the holes (NOTE: Do not cut ceiling trusses).
5. In case of attic space use a plumb line to locate the hole in the roof. Cut out the opening, keeping in mind the chimney manufacturer's recommended clearances.
6. Install the outside air duct to the floor using screws or nails. Ensure that your air duct has a screen or mesh to keep out rodents, etc. Air ducts must be 5 or 6".
7. Install a hearth pad 18" in front of the unit, 6" to the back, 6" to the sides according to local building codes or manufacturer's specs (see applicable figures—corner or straight wall).
8. Position the stove on the hearth and lag bolt the stove to the floor. Ensure that your lag bolts fasten securely to the floor of the mobile home.
9. Ground your stove to the mobile home frame with a minimum 8-gauge wire. See figure 2B wiring diagram.
10. For a list of typical chimney pipe parts, see figure 2.
11. Check all chimney pipe for damage. Do not use any damaged pipe. Installation procedures may vary from manufacturer to manufacturer of listed chimney. Install the chimney up through the hole in the ceiling and roof, observing pipe manufacturer's minimum clearance to combustibles.
12. In cases where there is attic space, install a protective joist shield tube or box. Consult local building officials or chimney manufacturer.
13. Install the roof flashing, sealing water tight. Install the storm collar and seal water tight. Install chimney cap. NOTE: Refer to chimney manufacturer's specs. Chimney height, see figure 7. Minimum for mobile home is 9 1/2' above stove.
14. Install double-wall stove pipe connector from the stove to the chimney pipe, making sure to secure all joints of pipe together as well as the pipe to the stove flue collar with three sheet metal screws at each joint.
15. Call for final inspection.
16. INSTALL AND USE IN ACCORDANCE WITH THE MANUFACTURER'S INSTALLATION AND OPERATING INSTRUCTIONS ONLY.

YOUR STOVE IS NOW READY FOR USE. REFER TO OPERATING INSTRUCTIONS.

RESIDENTIAL INSTALLATION INSTRUCTIONS

Model: Kuma Wood Classic

CAUTION— Always read instructions before beginning the installation.

Check all listed factory built chimneys for concealed damage.


Exercise caution to ensure that all necessary parts are installed correctly.

BEFORE YOU START ensure that there are no major obstructions (i.e. floor joists, ceiling joists, electrical wires, heat ducts, plumbing, etc.).


Clearance— See figures 3 through 6. Consult your local building official and build your hearth pad to local building requirements.

Use minimum 6" diameter black or "blue" steel chimney connector, 24 gauge minimum.

EXAMPLE: Typical hearth pad



NOTE: For residential installation, in which outside air intake is not desired, remove cover-plate at rear of pedestal base before installing stove as shown below. In this application, a hole through the floor is not required.



INSTALLATION

1. After locating possible obstructions (joists, pipes, etc.) and taking into account the necessary combustible clearances (fig. 2), position the stove in the intended installation position. Use a plumb line to locate the position of the ceiling hole for the chimney. Size the chimney hole to the recommended manufacturer's clearances for your chimney. Mark the hole.
2. If the ceiling is clear of all obstructions, cut out the hole (**NOTE:** Do not cut the ceiling trusses).
3. In case of attic space use a plumb line to locate the hole in the roof. Cut out the opening, keeping in mind the chimney manufacturer's recommended clearances.
4. If outside air is desired, locate and cut a 5 or 6" diameter hole through the floor anywhere under the pedestal stove base. If air through the wall is preferred, a dryer-type vent pipe should be installed from the wall to the 3 1/2" diameter hole at the pedestal base back. A mesh-type screen should be installed to keep out rodents, etc.
5. Install a hearth pad according to local building codes or manufacturer's specs (see above figure).
6. Position the stove on the hearth.
7. Check all chimney pipe for damage. Do not use any damaged pipe. Installation procedures may vary from manufacturer to manufacturer of listed chimney. Install the rest of the chimney up through the hole in the ceiling and roof.
8. In cases when there is an attic space, install a protective joint shield tube or box. Consult local building officials or chimney manufacturer.
9. Install the roof flashing, sealing water tight. Install the storm collar and seal water tight. Install chimney cap. **NOTE:** Refer to chimney manufacturer's specs. Chimney height, see figure 7.
10. Install the stove pipe connector from the stove top to the chimney pipe, making sure to secure all joints of pipe together as well as the pipe to the stove fire collar with three sheet metal screws at each joint.
11. Call for final inspection.
12. Read completely the operating and burning instructions.

Your stove is ready to burn.

WOOD BURNING OPERATING INSTRUCTIONS

Model: Kuma Wood Classic

RECOMMENDATIONS ON BUILDING AND MAINTAINING A FIRE:

1. Open air control by pulling draft handle all the way out.
2. Start with tinder and small kindling. When starting a fire, stack wood in a "crisscross" arrangement so as to allow the fuel plenty of air. Place smaller chunks of wood, on up to larger ones until desired fire size and heat level is achieved. Once the desired heat level in house is reached, pushing the air control handle back in decreases the air to the firebox, and thus reduced heat produced. Use the following table as a general guideline for desired burn rates:

Low-burn-	Draft handle pushed all the way in.
Med-low-	Draft handle pulled out approximately 1/8".
Medium-	Draft handle pulled out approximately 1/4".
Med-high-	Draft handle pulled out approximately 1/2".
High burn-	Draft handle pulled all the way out.

CAUTION: When building the first couple of fires, be careful to build the fire small and increase heat slowly over a 4-5 hour period. The paint on the stove "cures" with heat and needs to be done slowly. As the paint "cures" it gives off a smell of paint, and even sometimes a visible "smoky" haze into the room. Make sure the area is well ventilated during the curing operation. The smell will disappear after a few hours of operation.

OPTIONAL BLOWER OPERATING INSTRUCTIONS: Install blower unit in back of stove as per instructions, and plug into nearest 115V grounded circuit. Turn the variable speed knob to 'click' onto high speed. As the knob is turned clock-wise, the blower speed decreases to your desired speed. The blower speed should match the desired burn rate on your stove: i.e. low-burn rate...low blower speed; high-burn rate... high blower speed and so forth.

DO NOT OPERATE THIS STOVE WITH THE DOOR OPEN. It may be necessary, however, to crack the door during the first 5 or 10 minutes during the start-up stage. Contact your dealer if you have any questions or problems building or maintaining a fire.

CAUTION: DO NOT USE CHEMICALS OR FLUIDS TO START OR FRESHEN UP A FIRE. DO NOT BURN GARBAGE OR FLAMMABLE FLUIDS SUCH AS GASOLINE, NAPHTHA, OR ENGINE OIL.

1. The unit is designed to burn wood only. Build the fire directly on the firebrick. Do not use grates. Your stove will burn better with about one inch of ash in the bottom. Your stove is a very efficient "airtight" heater and if you use high quality wood, there will be very little ash residue.
2. Use only the best grade of dry wood available. It takes a full year to properly dry your split wood, so plan ahead. Burning wet or green wood greatly increases the chance of creosote build-up and produces less heat. Store your fuel in a dry location and be sure to maintain clearances from the wood supply to your stove.
3. Small hot fires produce less creosote than long, low smoldering fires. When you start your stove, open the draft fully, and once or twice each day repeat this high burn cycle to reduce any creosote build-up. Just after starting the fire, some smoke may occur until the chimney warms up to produce some draft. During normal operation, adjust the draft to the position required. If properly set, it will assure longest burn times and the most even heat cycle.
4. Make routine inspections of your flue system at least once every two months to ensure clean, safe operation.
5. Ensure an adequate supply of outside combustion air is available. Failure to provide adequate combustion air is dangerous. Fifteen (15) square inches is recommended.

WOOD BURNING OPERATING INSTRUCTIONS (continued)

CREOSOTE FORMATION AND NEED FOR REMOVAL:

6. When wood is burned slowly, it produces tar and other organic vapors which combine with expelled moisture to form creosote. The creosote vapors condense in the relatively cool chimney flue of a slow burning fire. As a result, creosote residue accumulates on the flue lining. When ignited, this creosote makes an extremely hot fire. If creosote has accumulated, it should be removed to reduce the risk of a chimney fire.

DISPOSAL OF ASHES:

7. Ashes should be placed in a metal container with a tight-fitting lid. The closed container of ashes should be placed on a non-combustible floor on the ground, well away from all combustible materials, pending final disposal. If the ashes are disposed of by burial in soil or other wise locally dispersed, they should be retained in the closed container until all cinders have thoroughly cooled.

8. Maintain door seals, etc., to ensure airtight fit. Operate only with the fire door closed. Open door only to fuel fire.

9. Resist the temptation to refuel too soon. Let the fire burn down to just glowing coals before you open the door. This will be the most efficient operation and there will be less smoking. Do not overfire.

10. Contact your local or provincial fire authority for information on how to handle a chimney fire.

11. For further information on using your heater safely, obtain a copy of the National Fire Protection Association publication: "Using Coal and Wood Stoves Safely." NFPA No. HS-8-1974. The address of NFPA is: 470 Atlantic Ave., Boston, MA. 02210.

GLASS DOOR

1. Never clean hot glass.

2. Clean with an approved cleaner. Never use an abrasive.

3. Excessive mechanical stress will crack or break the glass. Should breakage occur see your dealer or carefully remove retainer screws to release glass. Dispose of broken glass in a safe place. Replace the glass only with 5mm neoceram available from your dealer. Always replace the gasket with a glass replacement. Check glass after heater has been fired to ensure a tight seal. Tighten retainer just enough to provide the airtight seal. Uneven pressure from over-tightened screws will break the ceramic (glass). See figure 1.

4. Never build the fire up against the glass.

5. When closing the door, do not allow logs to protrude against the glass.


A WORD ABOUT DRAFT:

The principle of draft is that warm air rises. Your chimney provides draft which sucks the smoke up the chimney. The stove does not "push" out the smoke. Your Wood Classic stove has been designed and approved for use under normal conditions. Unacceptable smoking usually indicates poor draft in your chimney system. **CHECK THAT YOU HAVE PROVIDED FOR ADEQUATE OUTSIDE AIR FOR COMBUSTION, IF APPLICABLE.**

PROBABLE CAUSES FOR SMOKING ARE:

1. Insufficient chimney height above nearby obstructions.
2. Clogged or obstructed chimney system.
3. Downdrafts caused by nearby trees, hills, buildings, etc.

Figure 1



Typical Mobile Home Installation

Figure 2






Figure 2B




Ground wire to Mobile Home Frame. #8GA Wire & Approved Terminal.

Figure 2A




Use only 6" diameter Listed chimney system parts that have been tested and found to be compliant with all applicable U.L. standards. Clearances to combustibles must be maintained as per manufacturers instructions on chimney pipe, and stove pipe connectors. Use only double-wall connector in mobile home applications.

Figure 3




**MINIMUM CLEARANCES TO COMBUSTIBLES— STRAIGHT WALL
CLASS C SINGLE-WALL CHIMNEY CONNECTOR**

Figure 4




**MINIMUM CLEARANCES TO COMBUSTIBLES - CORNER
CLASS C SINGLE-WALL CHIMNEY CONNECTOR**

Figure 5



**MINIMUM CLEARANCES TO COMBUSTIBLE- STRAIGHT WALL
HT-TYPE LISTED CHIMNEYS USING APPROVED DOUBLE-WALL CONNECTOR**

Figure 6




**MINIMUM CLEARANCES TO COMBUSTIBLES- CORNER
HT-TYPE LISTED CHIMNEYS USING APPROVED DOUBLE-WALL CONNECTOR**

HEIGHT REQUIREMENTS

A chimney must be the required height above the roof or other obstruction for safety and for proper draft operation. The requirement is that the chimney must be at least 3' higher than the highest point where it passes through the roof and at least 2' higher than the highest part of the roof or structure that is within 10' of the chimney, measured horizontally (figure 7).

Figure 7



WARRANTY

Five year limited warranty

Your KUMA model Wood Classic is warranted against defects in materials or workmanship for 5 years from the date of purchase. Electrical components are warranted for 1 year from the date of purchase. Warranty does not cover gold, brass, or nickel items, glass, or normal maintenance items such as paint or gasket. This warranty does not apply or cover in cases of abuse, mishandling, unauthorized repair, or alterations.

STOVE STORAGE

The Kuma Wood Classic Noncatalytic Woodstove

tested by Myren Consulting, Inc. is being held in custody by

Kuma Stove and Iron Works and
is being stored at:

Kuma Stove and Iron Works

Contact person(s):

450 Old Highway 95

Mark Freeman

Rathdrum, ID 83858

Phone:

(208) 762-8002

A. Temporary storage at Myren Consulting until certification is granted:

A single strap of steel banding is placed around the stove so that the banding crosses the door horizontally, making it impossible to open the door on the unit. If it is necessary to break the banding to check an internal dimension or component, the banding is immediately replaced after the work on the unit is completed. The unit is identified with its name written on a stove storage label that is taped to the window of the unit. (See next page for an example copy of a stove storage label.)

B. Permanent storage after certification has been granted:

The following measures have been taken to permanently seal the unit and prevent tampering. Several lengths of steel banding are placed around the stove in a manner that prevents the door from being opened. At least two of these lengths cross at 90° angles. At each 90° crossing point on the top of the stove and perhaps elsewhere, a Myren Consulting address label is placed over the crossing point. The lab manager then initials the label and it is then taped in place with 2" clear packing tape. The stove is then loaded onto a pallet and strapped to the pallet with several lengths of steel banding. A box - either cardboard, chipboard or plywood - is placed over the stove and attached to the pallet.

C. The sealed unit is identified as follows:

The name of the unit is written on a Myren Consulting address label which is affixed to the outside of the box. The top and sides of the box also have several stove storage labels affixed to it which clearly identify the unit as a test stove being stored pursuant to 40 CFR Part 60. These labels have the name of the stove clearly written on them. (A sample stove storage label follows on the next page.)

D. The unit was returned to the manufacturer via: Truck

W A R N I N G

SEALED EPA TEST STOVE

DO NOT OPEN OR TAMPER WITH THE SEALS AND PACKAGING ON THIS STOVE.

TO DO SO WILL VOID THE CERTIFICATION ON THIS STOVE.

Kuma Wood Classic

W A R N I N G

SEALED EPA TEST STOVE

DO NOT OPEN OR TAMPER WITH THE SEALS AND PACKAGING ON THIS STOVE.

TO DO SO WILL VOID THE CERTIFICATION ON THIS STOVE.

Kuma Wood Classic

